***		REGIN	ΔΤΟ	INFOR		L DISTRIBUTION	STF	MORIDS	;) ·	
	ACCESSIO FACIL:5 AUTH.N UHRIG,R RDCIP. EISENHU	N NBR:8202020 0-389 'St. Luc AME AU .E. Flo NAME RE T,D.G. Div	389 ie Pl THOR rida cIPIE isior	DOC.I ant, U AFFILIA Power 1 NT AFF of Li	DATE: nit 2, ATION & Ligh ILIATI censir	82/01/28 NOTA Florida Power at Co. ON 9 50 50 CTA	RIZED & Li	: NO ght Co		DOCKET # 05000389
	SUBJECT	: Responds to third intak telcon.	NRC e pir	820118 beline.(l(tr∍r 9uesti	equesting addl	info ised	ne pro per 82(pose 121	d
	DISTRIB TLTLE:	UTION⊇CODE: ⟨C Environ, Repo	001S nt An	COPIE	S IRECE ts & F	IVED:LTR EN Related Cornesp	CL/ onden	SIZE:		,
	NOTES:									
	ACTION:	RECIPIENT ID CODE/NAM LIC BR #3 BC NERSES,V.	E 18 ∘04	COPIE LTTR 1 1	B ENCL 1 1	RECIPIENT ID CODE/NAM LIC BR #3 LA	E 19	COPIE LTTTR E 1	S Incl 1	
	'INTERNAL:	ELD NRR/DE/AEAB NRR/DE/HGEB NRR/DSI/ETSB REG FILE	•08	1 1 1 1	0 1 1 1 1	IE NRR/DE/EEB NRR/DE/SAB NRR/DSI/RAB	15 06 07 09	^2 1 1 1	2 · 1 1 1	
	EXTERNAL:	ACRS NRC PDR NTIS	02 20∙	*3 1 1	13 1 1	LPDR NSIC	03 -05	1 1	1 1	

.

4

,

....

t

.



•

na 1920 yr - 1 Yn Yn Y

۰ ۰ ۰

۲ ۲ ۰ ۰

•



January 28, 1982 L-82-33

Office of Nuclear Reactor Regulation Attention: Mr. Darrell G. Eisenhut, Director Division of Licensing U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: St. Lucie Unit 2 Docket No. 50-389 Environmental Report Requests for Additional Information

RECEIVED FEB 1 1982 ⊵ DS REALER RESULTANT COMPANY COUNCIL RUNGEMENT ER TIDC

Attached are Florida Power & Light Company (FPL) responses to NRC staff requests for additional information which have been formally submitted on the St. Lucie Unit 2 docket via your letter of January 18, 1982. These responses will be incorporated into the St. Lucie Unit 2 Environmental Report in a future amendment.

Please note that the question numbers have been revised per a telephone conversation with Mr. V. Nerses on January 21, 1982.

Very truly yours,

ver Z Robert E. Uhrig

Vice President Advanced Systems and Technology

REU/RAK/ah

Attachments

cc: J.P. O'Reilly, Director, Region II (w/o attachments) Harold F. Reis, Esquire (w/o attachments)

202020389

.

.

.

.

RESPONSE TO NRC REQUEST FOR ADDITIONAL INFORMATION ON THE PROPOSED THIRD INTAKE PIPELINE FOR THE ST. LUCIE PLANT UNIT 2

Question 291.11: The discussion of the difficulties experienced maintaining flows introduces uncertainty as to what the actual cooling water flow will be with two units in service. With the new intake in service what will the flow be through each unit? Will this be maintained by throttling back pumps? Apparently higher flows could be employed. At what reduced flow and corresponding elevated temperature rise will intake pipeline cleaning procedures be initiated?

Response: The actual cooling water flow rate requirements will remain constant for St. Lucie 1 and 2 assuming a design condenser ∆ T of 24° F. Intake canal water level will be drawn down slowly to offset the increased pipe resistance in the ocean intake lines as a result of marine fouling. When the canal level has been drawn down to the lowest allowable limit ocean intake pipe cleaning must be initiated to preclude a reduction in flow and a corresponding reduction in unit output.



Question 291.12: Discuss recirculation of discharged water to the new intake pipeline.

Response: The separation distance between the existing twin intake pipelines and the plant discharge diffusers is approximately 2300 feet. The addition of the third pipeline (located north of the existing pipelines) will reduce the separation distance by 100 feet which is only 4.35 percent of the original separation distance. The following discussion relates to recirculation of discharged water to the new intake pipeline as well as the existing pipelines.

- There would be no recirculation for either individual or two unit operation under both stagnant and northward current conditions.
- (2) Under a southward current condition, there would be some possibility of recirculating discharge water to all three intake pipelines up to 30 percent of the time on an annual basis.
- (3) For the worst case conditions the plant intake water temperature rise due to recirculation would be 0.2°F and 1.2°F for one unit and two unit operation respectively. This is based on the assumption that the new intake pipeline will carry 1150 CFS and each of the two existing pipelines will carry 575 CFS. The addition of a new intake pipeline will not increase nor decrease

flow volume used for plant operation. Therefore recirculation potential for three intake pipelines is expected to be similar to that for two intake pipelines.

(4) The temperature rises due to recirculation are relatively small as compared to the daily ambient temperature fluctuations of the ocean water, which can range from 2° to 5° F.

Based on the above discussions it appears that the addition of a third intake pipeline will not significantly reduce the separation distance between the intake and discharge pipelines nor will it increase the flow volume used for plant operation. Therefore, it is concluded that the recirculation potential for three intake pipelines will not be significantly higher than, if not the same as, that for two intake pipelines. Question 291.13: Page 10 of the Circulating Water System Modification document provides some flow velocities in the pipelines. Indicate if these velocities are based on no pipe fouling or with fouling. Explain why the maximum flow velocity would be reduced to 2/3's of the twin pipeline flow velocity when the existing pipelines are 12' in diameter and the new pipeline is to be 16' in diameter.

Response:

The maximum calculated flow velocity of 10.18 fps through the two existing 12' dia intake pipelines corresponds to the initial design requirement: supply a total flow of Q=2300 cfs for two unit operation.

The maximum flow velocity of 6.8 fps through the proposed 16' dia third intake pipeline was developed for a calculated flow distribution of Q=1360 cfs through the 16' pipe and Q=470 cfs through each of the 12' pipes. This flow distribution results from the following assumed friction factors: f=0.02 in the 'proposed pipe and f=0.07'in the existing pipes. (the increased friction factor is a result of marine growth built up in the pipes since the last pipe cleaning performed in 1980).

.

Ċ

Question 291.14: Provide estimates of flow velocities at the entrance of each velocity cap, each vertical pipe section of the velocity cap, each intake pipeline, and the intake canal under one and two unit operation and clean and fouled conditions.

Response:

The flow distribution through the three pipes varies with the change in the friction factors as a result of marine fouling.

For the scheduled start of two unit operation in June 1983 the friction factors are assumed to be f=0.07 for the 12 foot pipes which were last cleaned in 1980 and f=0.02 for the new 16 foot line (note: f=0.015 for a clean pipe, however, it takes less than 2 months for the friction factor to increase to f=0.02).

It is estimated that the pipes will be able to operate on a 7 to 8 year cleaning cycle with the flow velocities noted in Table 1. Please note that the velocities in Table 1 are for two units operation. Velocities for one operation are 1/2 the values shown.







	Friction "f"	Factor	Velocity Cap Flow Velocity (FPS)		Vert. Pipe Sect. Flow Velocity (FPS)		Pipe Flow Velocity (FPS)		Canal Flow Velocity (EPS)
Year	12'	16'	12'	16'	12'	16'	12'	16'	
1983	0.07 _. .	0.02	0.368	1.00	1.18	6.77	4.16	6.77 _.	1.0 <u>+</u>
1986	0.115	0.07	0.401	0.941	1.28	6.34	4.54	6.34	1.0 <u>+</u>
1988	0.145	0.10	0.411	0.927	1.31	6.24	4.62	6.24	1:0 <u>+</u> `
1990	0.175	0.13	0.414	0.918	1.32	6.18	4.67	6.18	1.0 <u>+</u>
· _							-		
•			c						
	-			-					
•									
3					-i anti-		t		
	• •			•	÷.				•

t.

.



Question 291.15: Describe the procedures for removing a pipeline from service . and cleaning it.

Response:

I. For 16' diameter intake line:

- A. Remove line from service by closing the 16' line sluice gate.
- B. Place stop-logs into headwall
- C. Insert cleaning machine into intake structure
- D. Open sluice gate
- E. Cleaning machine is hydraulically forced through the ocean pipeline to effect cleaning.
- F. Cleaning machine is removed, sluice gate closed, stop logs removed.
- G. Line is placed into service by opening the sluice gate.

II. For 12' diameter intake line:

- A. During a period of zero flow through either 12' diameter line, the cleaning machine is inserted into the pipeline and a cover plate is then installed on the headwall.
- B. Cleaning machine is hydraulically forced through the ocean pipeline to effect cleaning.
- C. During a subsequent zero flow condition, the cover plate and cleaning machine are removed and the line restored to service.



Question 291.16: Indicate whether cleaning of any of the ocean intake pipelines will be attempted during two unit operation or whether cleaning be limited to outages.

Response: Normally, pipe cleaning will be scheduled during a unit outage. However, cleaning of 16' intake pipe during two unit operation may be performed if warranted.



• •

, , i P .

Ŧ

. •

٠

• .

a e

* 1

4

-

•

.

¥



Question 291.17: Indicate whether all three pipelines will be used at all times or whether any pipeline will be blocked off during periods of one unit operation or kept on standby for any reason.

Response: Except for periods of cleaning, all three intakes pipelines will be in service during one unit operation.



Question 291.18: Verify that construction is still planned for February through December 1982.

Indicate if applicable the period of time construction activities will occur on a three shift per day basis.

Response: Mobilization has commenced and construction activity is presently scheduled for three shifts per day from February through December 1982. Question 291.19: On page 13 of the Circulating Water System Modification document a discussion of decreased turtle nesting due to initial intake and discharge construction is presented. Provide the magnitude of the decrease in turtle nesting due to recent construction of the second discharge structure.

Response: As a test for 1981 construction effects (i.e. the second discharge pipeline), the number of nests occurring at the Plant Site (Area 4; Figure H-1, Applied Biology, Inc., 1980) were compared to the expected number predicted by a linear regression model. These counts were within 14 percent of the estimate each year except 1975 and 1981, when the counts dropped to 50 and 65 percent, respectively, of the estimate (Applied Biology, Inc., 1982). The apparent cause of these discrepencies was the construction of intake pipelines (1975) and discharge pipelines (1975 and 1981) in the beach and nearshore environment. Construction activity and lights on the construction pier at night, as well as localized beach erosion south of the structures, reduced nesting activity in this area. Nesting is expected to return to normal levels as was observed during years following nearshore construction in 1975.

References:

Applied Biology, Inc. 1980. Florida Power & Light Company, St. Lucie Plant, annual non-radiological environmental monitoring report 1979, AB-244. Applied Biology, Inc., Atlanta, Ga.

Applied Biology, Inc. 1982. Florida Power & Light Company, St. Lucie Plant, annual non-radiological environmental monitoring report 1981, AB-379. Applied Biology, Inc., Atlanta, Ga.



Question 291.20: Is there any intention of using chemical procedures or chemical coatings to control fouling in the new intake? If so, give adequate detail for impact assessment.

Response: FPL has no intention of using chemicals to control fouling of the ocean intake pipelines.

Question 291.21: Indicate the status of other Federal and State permit actions related to the new intake. Where actions are complete, provide copies of the permits or approvals along with copies of any conditions or qualifications. Provide copies of all environmental impact appraisals and other environmental review documents prepared in conjunction with the other permitting actions. Specifically, provide copies of the comments of the USFWS and the NMFS submitted to the Corps of Engineers on their permit.

Response:FPL submitted a Dredge and Fill permit application to the
Corps of Engineers on November 24, 1981. The Corps
Permit #81D-1679 was signed by FPL on December 31, 1981,
with stipulations for modification to the special conditions.
The Corps has agreed that mangroves do not have to be
transplanted but instead FPL will plant seedlings. Because
the area to be used for mitigation will be used during
construction as a lay-down area, the Corps has agreed that
mangroves will be planted within one year of issuance of
the Dredge and Fill Permit. The Corps expects to sign the
permit momentarily. No official comments were received
from National Marine Fisheries Service or the U.S. Fish and
Wildlife Service. The Corps that they had no comments.

FPL applied for a modification to the St. Lucie NPDES Permit #FL0002208 on December 3, 1981 to include the third intake pipe.

FPL petitioned the Florida Department of Environmental Regulation to amend the St. Lucie 2 Certification #PA-24-02 on November 30, 1981 to include the construction of the third intake pipe. At this time, the amendment is expected to be approved on January 26, 1982.

FPL applied for an easement with the Florida Department of Natural Resources for the third intake pipe on November 30, 1981. The easement #3177-56, will be granted on January 13, 1982. v

, . ۰ ۰ ۰

· ·

, ,

· · · ·

.

.

. ·

۲. Be

• • • • • · · ·

*

•

November 30, 1981

Dr. Elton J. Gissendanner Executive Director Florida Department of Natural Resources 3900 Commonwealth Blvd. Tallahassee, FL 32303

RE: APPLICATION FOR EASEMENT ST. LUCIE POWER PLANT - ST. LUCIE COUNTY THIRD INTAKE PIPELINE

Dear Dr. Gissendanner:

Enclosed please find an Easement Application for a subaqueous cooling water pipeline extending approximately 1195 feet offshore from Hutchinson Island into the Atlantic Ocean. The foregoing application and attachments are being submitted on behalf of Florida Power and Light in reference to its St. Lucie Power Plant. These materials are being submitted in an effort to obtain an Easement across sovereignty lands of the State of Florida for public utility purposes, pursuant to chapter 16Q-17.09 F.A.C. (Sovereignty Submerged Lands).

We request that you review the enclosures describing the Florida Power and Light Company's proposed easement, and that you place this application before the Board of Trustees of the Internal Improvement Trust Fund at the earliest possible date. We have provided the pertinent information regarding our proposal on the aforementioned application and attachments for your convenience.

Respectfully submitted this 30th day of November 1981.

Sincerely. Discionit

W. J. Barrow, Jr./ Manager Environmental Permitting and Programs

WJBjr/pc

Attachments: Easement Application

- Map of Survey Project No. 225 Permit Appraisal - Biological Report Circulating Water System Modification
- cc: Victoria Tschinkel W/O Attachments Hamilton Oven - W/O Attachments



November 30, 1981

Dr. Elton J. Gissendanner Executive Director Florida Department of Natural Resources 3900 Commonwealth Blvd. Tallahassee, FL 32303

RE: APPLICATION FOR EASEMENT ST. LUCIE POWER PLANT - ST. LUCIE COUNTY SUBAQUEOUS INTAKE PIPELINES

Dear Dr. Gissendanner:

Enclosed please find an Easement Application for two existing and one proposed intake pipeline extending approximately 1195 feet offshore from Hutchinson Island into the Atlantic Ocean. The two existing intake lines were permitted by the Board of Trustees (TIIF) on March 22, 1972 (Permit No. 253.123(2) (b)-1101). The foregoing application attachments are being submitted on behalf of Florida Power and Light Co. in reference to its St. Lucie Power Plant. These materials are being submitted in an effort to obtain an easement across sovereignty lands of the State of Florida for public utility purposes, pursuant to Chapter 16Q-17.09 F.A.C. (Sovereignty Submerged Lands).

We request that you review the enclosures describing the Florida Power and Light Company's proposed easement, and that you place this application before the Board of Trustees of the Internal Improvement Trust Fund at the earliest possible date. We have provided the pertinent information regarding our proposal on the aforementioned application and attachments for your convenience.

Respectfully submitted this 30th day of November, 1981.

Sincerely Heilb W. J. Barrow,

Manager ,0 Environmental Permitting & Programs

WJBjr/os

Attachments: Easement Application Map of Survey - Project No. 225 Permit Appraisal - Biological Report Circulating Water System Modification

cc: Victoria Tschinkel - w/o attachments Hamilton Oven - w/o attachments EASEMENT APPLICATION

•

Easement No.		Date
Please type or print information requested	. Fill in the blanks I is not applicable,	for all applicable information. If so indicate by placing N/A in the blank.
APPLICANT INFORMATIO	4:	
NameFlo	orida Power & Light Co	Dmpany
AddressP.	O. Box 529100	
Mia	ami, FL	Zip Code 33152
	Celephone Number: (305) 552-3564
Name of Agent W. J.	Barrow, Jr.	
Manage Address of Agent 22	er, Environmental Perm 50 Palm Beach Lakes Bl	nitting & Programs
. Wes	t Palm Beach, FL	Zip Code 33409
1	elephone Number:(305) 684-8500
Proposed easement wil	1 be used for:	• •
Public Utility (Private Utility (Other () Expla	XX) Pub) Pri in: <u>Electric Generat</u> Ocean Intake Pipe	olic Road Right-of-Way () ivate Road Right-of-Way () ing Faclity (Power Plant) eline for plant cooling water.
LOCATION:		
Section 16	Township 36.5	South Range 41 East
County St. Lu	cie' Cit	y <u> </u>
Water body affected b	y activity:Atl	lantic Ocean
Project is in an aqua If "yes", give preser	tic preserve? Yes vo number:N/A	() NO (X)
List names and addres of the project site. Kra North Boundary:	antz, Christ. & Mary I Geo. & Mary Ann	and owners of property on each side
	200 Ocean Tr. Ap Jupiter, FL 334	bt. 1210 . 158 .
South Boundary: Sar P. Stu	nd Dollar Villas Dev. O. Drawer 2315 Mart, FL 33494	Со.

Describe the proposed activities in detail.

An ocean intake pipeline and channel extension to convey cooling water from the Atlantic Ocean into the intake canal is proposed. The 1515 foot pipeline has an inside diameter of 16 feet and extends 1195 feet offshore and is to be buried beneath the dunes and ocean bottom. The pipe terminates with a velocity cap of precast reinforced concrete, supported on tremie concrete placed within a sheetpiling enclosure below the ocean bottom. Dredged materials include sands, silts and clay. Backfill material will be dredged sands.

The channel extension projects about 100 feet into the east slope of the existing intake canal.

* See supplemental sheet 1



-

-

•

,

· •

List all approvals or certification required for this activity:

Issuing Agency	Type of Approval	'Identification Number	Date of Application	Date of Approval
US NRC	Construction	Permit Docket 50)-389 -	May. 2, 1977
State of Florida	Site Suitabil Certificate	ity PA-74-02	-	June 10, 1975
U. S. COE	Dredge & Fill Permit	815-1679	11/23/81	Pending

i

REMARKS: Any comment that you feel should be made in regards to this application.

See Supplemental Sheet 2.

1

ALL LISTS OF REQUIRED INFORMATION SHOULD BE ATTACHED TO THIS APPLICATION WHEN

THE APPLICATION IS SUBMITTED.

Manager

• • • • • • •

Environmental Permitting & Programs

Date: December 30, 1981 Signature of Applicant: _________W. J. Barrow, Jr.



.

ŕ

1

. .

,

.

ĩ

.

£...



PPOJECT No 222



November 25, 1981

Ms. Victoria Tschinkel, Secretary Florida Department of Environmental Regulation 2600 Blair Stone Road Tallahassee, FL 32301

RE: St. Lucie Power Plant Unit No. 2 Modification of Conditions of Certification No. PA-74-02

Dear Secretary Tschinkel:

We are submitting this letter to request that the Florida Department of Environmental Regulation modify the conditions of the above-referenced certification for the St. Lucie Power Plant Unit No. 2 pursuant to § 403.516(1), Florida Statutes, and § 10 of the General Conditions of Certification. As grounds for this requested modification, Florida Power & Light Company relies upon the material and information contained in the enclosed Joint Application Department of the Army/Florida Department of Environmental Regulation for Activities in Waters of the State of Florida and attachments. We have provided the pertinent information regarding our proposal on the aforementioned application and attachments for convenience, since these same forms are being hand-delivered this date to the Department of Army/Corps of Engineers, Jacksonville District. A copy of the cover letter sent to the Corps has also been attached.

We request that you review the enclosures describing Florida Power and Light's proposed modification, and that you amend and modify the conditions of certification accordingly.

Respectfully submitted this 30th day of November 1981.

Sincerely,

W. J. Barrow, Jr., Manager Environmental Permitting and Programs

WJBjr/pc

Enclosures: 1)

- 1) Joint Application (2 pages)
- 2) Joint Application Supplement Sheet #1 (1 page)
- 3) Joint Application Supplement Sheet #2 (2 pages)
- 4) Joint Application Drawings (6 pages)
- 5) Cover letter to Corps of Engineers (1 page)
- 6) Circulating Water System Modification (18 pages)

cc: Hamilton S. Oven

Copies of the foregoing letter and enclosures have been furnished to all of the individuals and entities listed on the attached service list.



November 30, 1981

TO WHOM IT MAY CONCERN:

Attached for your information is an application to the Department of Environmental Regulation for Modification of Conditions of Certification No. PA-74-02 at Florida Power & Light Company's St. Lucie Power Plant Unit No. 2. This notification is for the construction of a 16' third intake pipe which is explained in detail by the attached documents.

Respectfully submitted this 30th day of November, 1981.

Sincercly,

W. J. Barrow, Jr

Manager Environmental Permitting & Programs

· WJBjr/os

attachments



SERVICE SCHEDULE

Mr. Hamilton S. Oven Administrator of Power Plant Siting State of Florida Department of Environmental Regulation 2600 Blair Stone Road Tallahassee, Florida 32301

John C. Bottcher, Esq. Deputy General Counsel State of Florida Department of Environmental Regulation Office of General Counsel 2600 Blair Stone Road Tallahassee, Florida 32301

Arthur Canaday, Esq. General Counsel Florida Public Service Commission Room 207, Fletcher Building Tallahassee, Florida 32301

Ms. Joan M. Heggen, Secretary
Department of Veteran and. Community Affairs
2571 Executive Center Circle East
Tallahassee, Florida 32301

C. Laurence Keesey, Esq. Department of Veteran and Community Affairs 2571 Executive Center Circle East Tallahassee, Florida 32301

Mr. James Dean Associate Planner Power Plant Siting Program Bureau of Veteran and Community Affairs 2571 Executive Center Circle East Tallahassee, Florida 32301

Conservation Alliance of St. Lucie County c/o Mrs. Margorie Silver Alder 304 St. Andrews Lane Fort Pierce, Florida 33450 Martin County Conservation Alliance c/o Martin Harold Hodder, Esq. 1131 Northeast 86th Street Miami, Florida 33138

League of Women Voters of St. Lucie County c/o Mrs. Judith James Route 3, Box 423 Fort Pierce, Florida 33450

Mr. Estes Whitfield Senior Governmental Analyst Office of Planning and Budgeting Office of the Governor The Capitol Tallahassee, Florida 32301

Citizens United Against Radioactive Environment c/o Harold H. Alder 304 St. Andrews Lane Fort Pierce, Florida 33450

Steve Walker, Esq. South Florida Water Management District Post Office Box V West Palm Beach, Florida 33402

Sam Shannon, Esq.
Treasure Coast Regional Planning
Council
Post Office Box 396
Stuart, Florida 33495

The Honorable Bob Graham Governor The Capitol Tallahassee, Florida 32304

The Honorable George Firestone Secretary of State The Capitol ^{*} Tallahassee, Florida 32301

The Honorable Jim Smith Attorney General The Capitol Tallahassee, Florida 32304





The Honorable Gerald Lewis Comptroller The Capitol Tallahassee, Florida 32301

The Honorable Bill Gunter Treasurer The Capitol Tallahassee, Florida 32304

The Honorable Ralph D. Turlington Commissioner of Education The Capitol Tallahassee, Florida 32301

The Honorable Doyle E. Conner Commissioner of Agriculture The Capitol Tallahassee, Florida 32301

,



November 24, 1981

Mr. John Adams, Chief Regulatory Section U. S. Department of the Army Corps of Engineers P. O. Box 4970 Jacksonville, FL 32201

RE: APPLICATION FOR DREDGE AND FILL ST. LUCIE POWER PLANT-ST. LUCIE COUNTY THIRD INTAKE PIPELINE

'Dear Mr. Adams:

Enclosed please find a Joint Application Department of the Army/Florida Department of Environmental Regulation for Activities in Waters of the State of Florida and attachments. The foregoing application and attachments are being submitted on behalf of Florida Power and Light in reference to its St. Lucie Power Plant Unit No. 2. These materials are being submitted in an effort to obtain a Department of Army Permit to perform works in or affecting navigable waters of the United States and to discharge dredged or fill material into waters of the United States. The foregoing activities are being conducted in accordance with the provisions of the Florida Electrical Power Plant Siting Act, 403.501 et seq., Florida Statutes, and therefore a modification of the power plant's certification is required for this proposed activity but said modification procedures obviate the need for a separate Florida Department of Environmental Regulation dredge and fill permit. We are also, this date, submitting a request to the Secretary of the Florida Department of Environmental Regulation for modification of the power plant certification, consistent with the enclosed.

Thank you for your assistance and cooperation in this matter.

Very truly yours, all

W. J. Barrow, Jr. Manager Environmental Permitting & Programs

cc: Victoria Tschinkel, - This COPY FOR - CA Secretary of Florida Dept. of Environmental Regulation

WJBjr/os

enclosures

JOINT APPLICATION DEPARTMENT OF THE ARMY/FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION FOR ACTIVITIES IN WATERS OF THE STATE OF FLORIDA

1.0

		12	Data			3 For official use only
1	Application number (10 be assigned)	4.	24	Now.	1981	-
			<u></u>			
		1				
4.	Name, address and zip code of applicant				•	• •
	W. J. Barrow, Jr., Manager	rnor	ame			3
	Florida Power: & Light Company	LOGI	umo			
	P_{10} , Box 529100					
	Miami, FL 33152					
	Telephone Number			•		
	Alama address ain onde and title of applicant's	autho	rized a	óant for cer	mit applicati	ion coordination
ο.	Mrs., Elsa A. Bishop			Sour to: bei		
	Associate Environmental Coordi	nato	or			
	Environmental Permitting and P	rogr	ams			
	Florida Power & Light Company					
	P. O. Box 529100				_	
	Miami, FL 33152					
	Telephone Number <u>305–684–8500</u>					
6.	Describe the proposed activity, its purpose and	d inte	nded u	se, including	a descriptio	n of the type of structures, if any,
	to be erected on fills, or pipe or float-supporte	d plat	torms,	and the typ	e, compositi	on and quantity of materials to be
	Anocean intake pipeline and c	z. hann	el.e	xtension	to con	vev_cooling_water_from
th	e Atlantic Ocean into the intak	e ca	inā1	is propo	isëd. The	he 1515 ft long pipelin
đu	nes and ocean bottom. The pipe	ter	mīņa	tes into	a velo	city cap, a precast
re a	sheetpiling enclosure below the	ppor oce	rced ean b	on trempottom.	Dredged	soils will be sands.
si.	lts and clay. Backfill will be	dre	edged	sands.		
in	The channel extension projects g intake canal. Dredged/Ex	abo (cavati	out l	00 ft in	nto the e	east slope of the exist Filled/Deposited
	Volume of Material: *CY			CY	·····	CYCY
*Se	Supplement OHW. or M.H.W.	с. О.Н	andwar .W. or N	d of A.H.W.	Waterward O.H.W. or M	d of Landward of I.H.W. O.H.W. or M.H.W.
Sh	et 1					
7.	Proposed use		marcia	ואו ס	ther [] (Ex	olain in remarks)
8.	Name and address including zip code of adjoini	ing pro	operty	owners who	se property i	iso actoins the waterway.
No	rth Boundary: Barnett Winston,	720) G11	more 54.	, Jackso	onville, Florida 32204
So	ith Boundary: John R Mayer & E	liza	beth	M Johns	ston	٠.
	P O Box 617, Jen	sen	Beac	h Floric	ia	
						4
						• *
9.	Location where proposed activity exists or will	occui	r			ı .
	Street address N/A	רכ נו	0211	-		h .
	Longitude <u>N 00014</u> Latitude	w 21	21		known)	172 V.
	Sec. 10 Twp.	1 30	, 3	F	Rge, <u>K 4</u>	VE Diance
	FIOTIDA SE LU	<u>cre</u>			ty or Town	Near City or Town
10	Name of waterway at location of the activity	Δ+	-lant		n	
SAJ	FURM 983					•
61 1	ut //					1
	•		••	-	• • •	1 101 1 1 100 10 10 10 10 10 10 10 10 10

•	
	11. Date activity is proposed to commence Feb. 1982
	Date activity is expected to be completed Feb. 1983
. ÷	12 Is any portion of the activity for which authorization is sought now complete? Yes [] No []
	If answer is "Yes" give reasons in the remarks section. Month and year the activity was completed
	. Indicate the existing work on the drawings.
	13. List all approvals or certifications required by other Federal interstate, state or local agencies for any structures, con
•	struction, discharges, deposits or other activities described in this application, including whether the project is a Diversion of Regional impact.
	Issuing Agency Type of Approval Identification No. Date of Application Date of Approv
	US NRC Construction Permit Docket 50-389 - May 2, 1977
	State of Florida Site Suitability $P_{4-74-02}$ = June 10 19
1	Certificate
	Fla DNR Easerment No
	· · · · · · · · · · · · · · · · · · ·
L	
	14. Has any agency denied approval for the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any activity directly related to the activity described herein or for any act
	Yes [] No [] (If "Yes" explain in remarks)
\vdash	15. Remarks (see Instruction Pamphlet for additional information required for certain activities)
	See supplemental sheets entitled "Item 15 Remarks"
I	
	•
	· · ·
L	,
	16. Application is hereby made for a permit or permits to authorize the activities described herein. I agree to provide an additional information/data that may be necessary to provide reasonable assurance or evidence to show that the proposed project will comply with the applicable State Water Quality Standards or other environmental protection star dards both during construction and after the project is completed. I also agree to provide entry to the project site for inspectors from the environmental protection agencies for the purpose of making preliminary analyses of the site an monitoring permitted works, if permit is granted. I certify that I am familiar with the information contained in the application, and that to the best of my knowledge and belief such information is true, complete, and accurate. I fur ther certify that I possess the authority to undertake the proposed activities.
	November 24, 1981
الله الله الله الله الله الله الله الله	W. J. Barrow, Jr., Manager, Environmental Permitting and Programs W. J. Barrow, Jr., Manager, Environmental Permitting and Programs 18 U.S.C. Section 1001 provides that: Whoever, in any manner within the jurisdiction of any department or agency of the United States knowingly and willfully falsifies, conceals, or covers up by any trick, scheme, or device a material fact or makes any false, fictitious or fraudulent statements or representations or makes or uses any false writing of document knowing same to contain any false, fictitious or fraudulent statement or entry, shall be fined not more than \$10,000 or imprisoned not more than five years, or both.
	The application must be signed by the person who desires to undertake the proposed activity; however, the application may be signed by a duly authorized agent if accompanied by a statement by that person designating the agent and agreeing to furnish upon request, supplemental information in support of the application.
	FEE: Attach Checks/Money Orders on front Payable to Department of Environmental Regulation \$200 Standard form projects
	S20 Short forms and Chapter 403 projects only
•	· · · ·
	· · · · ·
	• • • • • • • • • • • • • • • • • • • •
	,

FLORIDA POWER & LIGHT COMPANY ST LUCIE PLANT

JOINT APPLICATION

DEPARTMENT OF THE ARMY/FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION FOR

ACTIVITIES IN WATERS OF THE STATE OF FLORIDA

ITEM 6 - Volume of Material

The table below has been prepared to delineate the volumes of dredge and fill material estimated for this proejct. The project has been divided into two parts: pipeline construction and channel extension.

VOLUME OF MATERIAL

ITEM	DREDGEI	D/EXCAVATED	FILLED/DEPOSITED		
	Waterward of MHW	Landward of MHW	Waterward of MHW	Landward of MHW	
Pipeline Construction	37,700 cy	11,800 cy	25,100 cy	8,400 cy	
Channel Extension		31,400 cy		3,900 cy	

cy - cubic yard

SUPPLEMENTAL SHEET 1

•

•

л

.
FLORIDA POWER & LIGHT COMPANY ST LUCIE PLANT

CCC X VI

JOINT APPLICATION

DEPARTMENT OF THE ARMY/FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION FOR

ACTIVITIES IN WATERS OF THE STATE OF FLORIDA

ITEM 15 - Remarks:

The proposed pipeline and channel extension is part of the plant cooling water system. This system consists of subaqueous ocean intake and discharge pipelines extending into the ocean, canals on land connecting the ocean pipelines to the plant, and equipment and conduits in the plant area. Major portions of this system were constructed with the first unit (St. Lucie 1) and have been in operation for about 5 years. The proposed intake pipeline is for both units (St. Lucie 1 & 2). Construction of St. Lucie 2 is authorized by a Construction Permit dated May 2, 1977 issued by the Nuclear Regulatory Commission (NRC). Alternatives to the pipeline, such as cooling towers and cooling ponds were evaluated in the Environmental Report submitted to and reviewed by the NRC in the Final Environmental Statement, Docket 50-389 dated May 1974. The State of Florida Site Suitability Certificate was issued on June 10, 1975. The plan of development for the site is found in the Environmental Report.

The site for the St. Lucie Nuclear Power Plant consists of approximately 1132 acres on Hutchinson Island in St. Lucie County about half way between the cities of Fort Pierce and Stuart on the East Coast of Florida. The St. Lucie plant is sited near the center of a long, narrow island. To the east is the Atlantic Ocean. To the west, the island is separated from the mainland by the Indian River.

The site itself is generally flat. Much of it consists of swamp and, outside the mosquito control areas, the land is covered with a dense vegetation characteristic of Florida coastal mangrove swamps. At the ocean shore the land rises slightly in a dune or ridge to approximately 15 feet above mean low water. Of the 1132 acres owned by Florida Power and Light Company, approximately 380 acres is occupied or modified by the plant (Units 1 & 2) and the plant facilities.

The effects of the construction of the pipeline and the water conveyed from the Atlantic Ocean into the plant were evaluated in the same documents outlined above. These documents state that the waters of the state will not be degraded by the proposed activity. Specific provisions designed to minimize the potentially adverse environmental impact caused by construction are: a) construction of a temporary beach dune when cutting through the natural dunes, b) use of sheet piling and/or silt screens around excavation work to limit turbidity to less than 50 Jackson Units, and c) the disposal of spoils in approved onshore disposal areas.

Construction methods to be used for this project are anticipated to be as follows:

Material will be dredged from the Atlantic Ocean from within a sheetpile trench by a crane.

The pipe trench will be excavated from in situ soils. Material removed from within the sheetpile will be used to backfill other portions of the pipeline; or will be stockpiled temporarily on the ocean adjacent to the trench, or will be disposed of in approved onshore spoil areas. The ground profile along the pipeline will be restored to its original contour after construction. Construction equipment and materials will be brought to and removed from the site via truck transport or via barge. Barges may be off loaded at an existing barge slip located at the site on an appendage of the Indian River, or they may be moved directly to the construction site (the Atlantic Ocean).

The channel extension on land, behind the dune line, will involve clearing less than 1/2 acre of mangrove swamp. The concrete headwall structure will require dewatering and excavation within a cofferdam. After completing the structure, the onland portion of the pipeline will be constructed followed by the canal and dike construction modification.

Water from the dewatering operation will be discharged into the intake canal.

Dredged material disposed of onland will be contained by dikes or other means as necessary such that any runoff will not contaminate the waters of the State. ' Dredge water will be decanted and released to either the intake or discharge canal. Rainfall runoff will not affect any part of this construction except where there are bare soil slopes during construction. Such slopes include the canal dike extension and spoil piles. Runoff from such slopes will not adversely affect the waters of the State.

The pipeline will be constructed with concrete pipe.

The proposed intake pipeline is sixteen feet inside diameter, four feet larger than the existing two twelve foot inside diameter pipelines previously installed in the ocean at this site. This increase in size is due to the effects of marine fouling experienced with the operation of the twelve foot diameter pipes. The marine fouling effects experienced are a heavy build-up of marine organism on the pipe wall. This build-up results in an increase in pipe friction and pressure drop, decrease in canal water level and a reduction in the flow of water through the system. To limit these adverse effects, the pipelines have been periodically "cleaned," a not inexpensive operation.

The sixteen foot diameter pipeline will greatly reduce the effects of marine growth. This reduction is due to the fact that pressure drop through the pipeline is proportional to the square of the flow velocity. For the twelve foot diameter pipeline, with a design flow velocity of 10 feet per second (fps), the pressure drop was proportional to 100. For the sixteen foot diameter pipeline, with a maximum design flow velocity of approximately 6.8 fps, the pressure drop is proportional to 46. Therefore, the sixteen foot pipe results in a 54% reduction in pressure drop. This reduction is important as it will reduce the frequency of pipe cleanings necessary.



A

---- .



f · ·

•



•



ومورد ومرار بعد المار من مورد ومن محالمة ومعالمة ومن مرامه معالمة وموار محمد المارية ومحاله معالمة معا معالمة ومعا



1

,____

•



FLORIDA POWER AND LIGHT COMPANY

23

ST LUCIE PLANT - UNITS 1 & 2

CIRCULATING WATER SYSTEM MODIFICATION

November, 1981

CONTENTS

٠,	Section	· · ·	Page
	1.0	NEED FOR CIRCULATING WATER SYSTEM MODIFICATION	• 1
	2.0	EXISTING CIRCULATING WATER SYSTEM	4
	3.0	ECOLOGY	5
	3.1	Terrestrial	5
	3.2	Aquatic	6
	4.0	THIRD INTAKE PIPELINE	10
	5.0	CONSTRUCTION EFFECTS	12
	5.1	Ecological Effects	12
•	5.1.1	Terrestrial .	12
	5.1.2	Aquatic .	13

. (

ſ

<u>,</u> ц

CONTENTS (Cont'd)

•

:

۰,

•	Section	·	Page
·	6.0	OPERATION EFFECTS	16
	6.1	Ecological Effects	16
	6.1.1	Entrainment	16
	6.1.2	Impingement	17
	6.2	Other Effects	18
	6.2.1	Aesthetics	18
	6.2.2	Noise	18

÷.,

. =

Full flow operation of the Circulating Water System (CWS) for St Lucie Unit 1 was attempted in January of 1976. At that time, the ocean portion of the system consisted of two 12 foot diameter intake pipelines and one 12 foot discharge pipeline. Separate intake and discharge canals on land conveyed the ocean cooling water to and from the plant. During initial operation, very high water levels occurred in the discharge canal, causing some flow over an emergency spillway. Because of this, the system was shutdown. Subsequent testing of CW pumps performance in early February indicated that they were pumping about 15 percent above the design flow. However, throttling the pumps with the discharge valves to the design flow still resulted in higher than expected water level in the discharge canal and hydraulic headlosses in excess of those expected in both intake and discharge pipelines. These conditions were determined to be the result of higher than expected ocean tides, and the formation of marine growth on the pipe wall, as described below.

A diver's inspection of the pipelines revealed the formation of marine growth on the pipe wall (several inches thick on the intake pipelines, about one inch thick on the discharge pipeline) along the entire length of these pipelines. Tests performed to determine the hydraulic characteristics of each pipeline indicated that the hydraulic headlosses in the ocean pipelines were high, and that the pipeline friction factor (Darcy-Wiesbach 'f') was determined to be 0.030 for the intake pipeline and 0.024 for the discharge pipeline, as compared with a clean pipe

1

1.0

friction factor of 0.015 or less. These higher friction factors were caused by marine growth on the pipe wall and added approximately three ft and two ft of hydraulic headloss to the intake and discharge pipelines, respectively, representing 50 percent and 30 percent increase in total headlosses for these pipelines.

To demonstrate that the marine growth seriously affected the hydraulic friction factor, the discharge pipeline was cleaned in September of 1976 to restore the friction factor to 0.016. A reduction of about two feet of headloss was realized. Additionally, periodic monitoring of the hydraulic performance of the ocean pipelines was initiated to determine changes in the friction factor. The results of this monitoring are shown in Figure 1.0-1.

From the monitoring program, it was concluded that marine growth on the pipe wall would require treatment either by periodic cleaning of the pipelines, or by some type of control or by physical modification of the system.

Since the two intake pipelines were designed to supply water for St Lucie Units 1 and 2, no operating problem was experienced for St Lucie Unit 1 on the intake side. However, when St Lucie Unit 2 becomes operational in 1983 the combined effects of headlosses, as indicated in tests simulating two unit' operation, will adversely affect plant operations in that excessive headlosses through the intake pipelines could reduce the intake canal water level such that minimum pump submergence requirements could



not be met. Similarly, excessive headlosses in the ocean discharge pipeline would result in high water levels in the discharge canal and possible spillway overflow to the mangroves north of the canal. Finally, the combined headloss increases would reduce the volume of cooling water pumped through the plant such that plant temperature rise would exceed the original 24 F maximum and plant efficiency would be reduced.

572

In 1978, the discharge canal dikes and the overflow spillway were raised to accommodate higher water levels in the discharge canal. Additionally, a periodic pipe cleaning routine was intitated for the 12 foot diameter ocean discharge pipeline. Finally, the St Lucie Unit 2 ocean discharge pipeline, which has been constructed, was increased in diameter to allow for marine growth accumulations. These actions alleviated the problem on the discharge side. For the intake side, a third intake pipeline is proposed. This new pipeline will be constructed north of the existing twin intake pipelines. Environmental impacts associated with the construction and operation of the third intake pipeline are addressed herein.



EXISTING CIRCULATING WATER SYSTEM

2

2.0

The circulating water system for St Lucie Plant has been described in detail in Section 3.4 of the St Lucie Unit 2 Environmental Report - Operating License.

ECOLOGY

3.0

3.1 · TERRESTRIAL

Terrestrial vegetation and wildlife in the Plant site area has been described in detail in Section 2.2-1 of the St Lucie Unit 2 Environmental Report - Operating Licensing. The following description relates to the area where the proposed third intake pipeline is located.

Beach and dume vegetation near the existing intake pipelines are characterized by dense stands of saw palmetto (<u>Serenoa repens</u>) or sea grape (<u>Coccoloba uvifera</u>) and sandy open areas with sea oats (<u>Uniola</u> <u>paniculata</u>), battis (<u>Battis maritima</u>) and other species. Plant species observed in this area along two sampling transects are noted in Tables 3-1 and 3-2 along with estimates of cover/abundance. Important species are sea oats, which stabilize the foredune against wind and storm erosion, and other species which are of tropical affinity and consequently of interest to botanists and naturalists. The latter include sea grape, Spanish bayonet (<u>Yucca aloifolia</u>), <u>Myrsine guianensis</u>, lantana (<u>Lantana involucrata</u>)⁽¹⁾ and neckless pod (<u>Sophora</u> <u>tomentosa</u>)⁽²⁾

Land immediately north of the existing intake canal comprises of mangrove swamp, and an area used for storage of heavy equipment during construction. The swamp is dominated by red mangrove (<u>Rhizophora</u> <u>mangle</u>). It includes scattered individuals of white mangrove = (<u>Laguncularia racemosa</u>) black mangrove (<u>Avicennia genminans</u>) and

572

buttonwood (<u>Conocarpus erectus</u>). Hydrologically, this swamp is isolated from marine and estuarine communities by State Route AIA, the intake and discharge canals, and a service road parallel to the beach.

3.2 AQUATIC

Atlantic Ocean marine communities offshore Hutchinson Island which would be exposed to construction and operation of the circulating water system are described in Section 2.2.2 of the St Lucie Unit 2 Environmental Report - Operating License.

CHAPTER 3: REFERENCES

- Long, R W and O Lakela, 1976. A Flora of Tropical Florida, Banyan Books, Miami, Florida.
- Small, J K, 1933. Manual of the Southeastern Flora, Hafner Publishing Company, New York.

TABLE 3-1

COVER/ABUNDANCE ESTIMATES FOR DUNE FLORA: AREA OF INTAKE PIPELINES

SPECIES	STATIONS:	1	2	3	4	5	_6	7	8	9	10	0_11	12	: 13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	<u>28</u> ;	<u>29 3</u>	0
																								•			-				
Jniola paniculata (sea oats)		7	5	7	7	7	5	3																							
Coccoloba uvifera (sea grape)	-		•			1	3	3		3	2	2 3	5	4	1		1	2		4					2						
Helianthus debilis var debilis (sunflow	er)						3	5	4		2	2	5	4	6	4	4	4	7	5	3		•								
enchrus incertus (burgrass)								•				6	3	5	3			5	3	4	3	4	1								
Croton punctatus									1																						
ucca aloifolia (Spanish bayonet)	•						•.			5	5	5								:											
Sattis maritima (bnattis)											. 2	2	5	5	2	2	2														
litex trifolia										•											4	7	3	5	3	-					
Cassuarina sp (Australian pine)																									1	7					
Bare Sand	*	3	5	3	3	3	5	s	7	6	6	j 4	5	3	3	7	6	5	3	3	6	4	7	7	7	3	•7	7	7	7	7

.

4

Note: Stations located contiguously along transect perpendicular to coastline. Stations 1-5 occur on east side of foredume; transect terminated on west side of foredume at FP&L ferceline (road). Each station is one meter (3.3 feet) square. Observations recorded January 30, 1979. Voucher specimens identified at University of Miami. Nomenclature follows Long and Lakela(1). Cover abundance scale(3): 1 = solitary, cover less than 6 percent; 2 = few, cover less than 6 percent; 3 = numerous, cover less than 6 percent; 4 = 6-25 percent cover; 5 = 26-50 percent cover; 6 = 51-75 percent cover; 7 = 76-100 percent cover.

.

•	•							•																		•	•				
SPECIES STAT	IONS:	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28 2	29 :	30
•																				•				•							
Uniola paniculata (sea oats)		6	7																												
Croton punctatus		2	3													-															
Helianthus debilis var debilis (seaflover)			1		•																								3	7	4
Cenchrus incertus (burgrass)			1																						•						
Coccoloba uvifers (sea grape)				7	7	7																•						5	5		
Yucca aloifolia (Spanish bayonet)				-		2														•											
Serenoa repens (saw palmetto)							7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	5	7	4	6				
Myrsine guisnensis																				1	5	3	1	7	7	6					
Sophora tomentosa (neckless pod)			4	1						•																1	1				4
Lantana involucrata (lantana)		r			_																					7	5	-			
Panicus rhizomatus				1	-								•								•										
1	•																						•					•			
Bare Sand		4	3	2	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	5	4	5

1

TABLE 3-2 COVER/ABUNDANCE ESTIMATES FOR DUNE FLORA: AREA IMPEDIATELY NORTH OF INTAKE PIPELINES

Note: See note for Table 3-1. Stations 1-3 occur on east side of foredune.

t

1.

4.0 THIRD INTAKE PIPELINE

The addition of a third intake pipeline (TIP) would reduce the hydraulic losses in the ocean intake pipelines because headlosses are a function of the velocity of flow squared (V^2). For example, by adding a third 16 foot diameter pipeline, the maximum flow velocity would be reduced to two-thirds of the twin pipeline flow velocity (from approximately 10 fps, to approximately 6.8 fps); the headlosses would correspondingly be reduced by 54 percent.

577

During the several years that the intake pipeline headlosses were monitored, and before the pipelines were cleaned, marine fouling continued to grow and the pipe wall friction factor increased. An upper limit for growth and friction factor were not established. Accordingly, it has been assumed that periodic pipe cleaning will be necessary even with a TIP in service; however, the frequency of such cleanings can be greatly reduced Cleaning of the TIP can be scheduled to coincide with refueling outage of one unit, without interrupting operation of the other unit. Therefore, by adding a TIP, operational reliability and flexibility of the Plant CWS systems would be greatly improved.

Construction of the 16 foot diameter pipeline would be within a sheetpiled trench and would be similar in all respects to the construction methods used for both the twin intake pipeline construction in 1973/74 and the Unit 2 discharge pipeline construction in 1980/81. Construction methodology for the latter is described in Section 4.1 of the St Lucie Unit 2 Environmental Report - Operating License.

As shown in Figures 4.1-1 through 4.1-4, the pipeline would begin at an offshore velocity cap structure located approximately 1200 feet from the Mean Low Water line. The velocity cap structure would be of similar size and design to the existing structures. The pipeline would be buried for its entire length, both offshore and onshore. The pipeline would enter the east end of the intake canal at a new headwall structure. The headwall structure would be of similar design to the one built for St Lucie Unit 2 discharge structure. A short sheetpile channel would be constructed from the headwall to the existing canal.



412 412

.:



fi



្រ នូវ



5,2

٩,

CONSTRUCTION EFFECTS

5.1 ECOLOGICAL EFFECTS

•

5.0

Construction of the TIP will probably begin in February 1982 and will be completed by December 1982, before the operation of St Lucie Unit 2.

Ecological effects are temporary and impacts are primarily restricted to marine systems.

5.1.1 Terrestrial

Construction of the TIP will follow the same practices for constructing the discharge pipelines which were addressed in Sections 4.1.3.2 and 4.1.3.3 of the St Lucie Unit 2 Environmental Report - Operating License. Terrestrial impacts include (i) excavation of a strip of dune vegetation and sand less than 100 feet wide, and (ii) preemption of less than one half an acre of mangrove swamp immediately west of the storage area and north of the intake canal for an access road and canal widening (see Figure 4.1-1).

The dune area affected is characterized by dense stands of saw palmetto and more open areas providing habitat for plant species noted in Tables 3-1 and 3-2. Dune flora is important for its role in soil stabilization, and for the assemblage of relatively uncommon plants of tropical affinity. After contours have been restored to pre-construction

conditions, the disturbed areas will be replanted with native dune-stabilizing species. No longterm effects on dune flora diversity or abundance are anticipated. Removal of less than one half an acre of the mangrove swamp represents about one percent of the mangrove between the

intake and discharge canals.

5.1.2 Aquatic

Construction of a TIP during any part of the marine turtle nesting season (1 May to 1 September) will probably cause local, short-term impacts on marine turtles. In 1975, pipeline construction at the St. Lucie site apparently reduced the suitability for nesting of the beach near the Plant. Analysis of nesting data showed that nesting density near the Plant decreased to about 50 percent of the expected number of nests.^(1, 2) However, turtles that failed to nest in the Plant vicinity probably nested elsewhere on the island as evidenced by the higher than expected nest densities in areas to the north and south of the plant. The effects of construction should be limited to the nesting season during which construction occurs. After construction ended in 1975, nest numbers were near expected values.

Additional impacts associated with construction of the TIP may include the crushing and excavation of nests by construction equipment on the beach and nest losses resulting from beach erosion. A nest surveillance and relocation program will be instituted on those areas of beach potentially affected by construction activity, as described in Section 4.1.3.2 of the St Lucie Unit 2 Environmental Report - Operating License.

÷.,,

The pipeline sheetpiled trench will disrupt the littoral flow of sand that normally stabilizes beaches and, with time, could result in some changes in beach profiles near the construction site. During storms, the process is accelerated and nests in the affected area could be lost to erosion, flooding or additional accumulations of sand.

In the marine environment, impacts due to construction of a TIP would be identical in nature to those discussed in Section 4.1.3.3 of the St Lucie Unit 2 Environmental Report - Operating License. The sheetpile trench excavated for the TIP would be 364 m (1200 ft) long and 7.6 m (25 ft) wide. The total surface area disturbed would be 2782 m² (0.7 acre), raising the total amount of disruption from 55640 m² (14 acres for the St Lucie Unit 2 discharge pipeline alone) to 58420 m² (14.7 acres). Thus, the temporary loss in numbers and/or biomass of benthic organisms would be five percent greater than that presented in St Lucie Unit 2 Environmental Report - Operating License. Past history at the St Lucie site indicate that substrate stabilization and recolonization should occur rapidly following pipeline construction.

CHAPTER 5: REFERENCES

- Applied Biology Incorporated ABI. 1978. Ecological monitoring at the Florida Power & Light Co. St. Lucie Plant, annual report 1977.
 2 vol. AB-101. Prepared for Florida Power & Light Co., Miami, Fla.
- 2. Applied Biology Incorporated. 1980. Non-radiological environmental monitoring report 1979. vol. AB-244. Prepared for Florida Power & Light Co., Miami, Fla.

OPERATION EFFECTS

6.0

6.1 ECOLOGICAL EFFECTS

Operational impacts of the TIP include entrainment and impingement, as described below.

....

6.1.1 Entrainment

Section 5.1.3.1.1 of the St Lucie Unit 2 Environmental Report - Operating License described impact of entraining planktonic organisms into the circulating water system. Use of three intake pipelines, rather than two, to convey the required 2320 cfs cooling water will not increase plankton entrainment. The types and concentration of planktonic organisms will also be similar among intake pipelines due to the fact that the TIP would withdraw water from the same source volume as that presently used.

Three intake pipelines, will have intake velocities lower than the 1.0 fps evaluated for the existing twin pipelines (Section 3.4.2.1 of the St Lucie Unit 2 Environmental Report - Operating License). Thus, to the extent that entrainment is a species-specific function of intake velocity (ie, ability to resist or avoid intake currents), actual losses of organisms for two unit operation may be less than that estimated in Section 5.1.3.1.1 of the St Lucie Unit 2 Environmental Report - Operating License. An entrainment rate of 3.6 percent of the near-field community was presented as a worst case for two unit operation in the St Lucie Unit 2 Environmental Report-Operating License.

.

6.1.2 Impingement

Impingement effects of two unit operation at St Lucie were discussed in detail in Section 5.1.3.1.2 of the St Lucie Unit 2 Environmental Report-Operating License. Conservative impingement rates for fish and shellfish were estimated to be 150,000 and 60,000 individuals/yr, respectively. These estimates assumed a linear increase in impingement with respect to capacity or velocity, and year-round operation of both units. The actual rate is likely to be lower, particularly for important species such as Spanish mackerel and bluefish which appear capable of avoiding entrainment into the pipelines. Impingement rates for two pipeline operation with average intake velocities of 1.0 fps should exceed those for three pipeline operation.

1.13

Intake operation will affect mostly subadult turtles because they may frequent nearshore waters more than adults. Adult turtles are found inshore only during the nesting season. Studies of turtle populations in Mosquito Lagoon, at the north end of the Indian River, showed that subadults were selectively inhabiting these inshore waters.

It is not known if turtles are attracted to the plant intake area or if they encounter the intakes by chance. However, turtles do seem attracted to underwater objects that appear to provide cover. Behavioral studies of immature loggerhead and green turtles showed that turtles seek out covered areas in which to rest. The existing two velocity caps and exposed portions of the intake probably appear to turtles as suitable resting and foraging spots in an area otherwise devoid of bottom

profile. Turtles may enter the intake pipes in response to the visual cue of the dark area under the velocity caps, or accidentally, while searching for food or swimming in the area when the water is turbid.

112

The addition of a third intake structure may increase the entrapment rate of marine turtles. The percentage of turtles coming in contact with the plant intake that actually enter the pipelines is not known, but a TIP will increase the probability of a turtle encountering a structure.

6.2 OTHER EFFECTS

6.2.1 Aesthetics

Since the TIP is buried under the ocean and the beach dunes, operation of the TIP will offer no visual impacts.

6.2.2 Noise Effects

Operation of the TIP as well as the existing twin intake pipelines would not produce any noise.

Question 291.22:

On an aerial photo such as provided on site visit (scale 1"=200', taken 12/12/80) show the exact location for the third intake pipeline including detail for the on-land portion. Also show the details of the mitigation area to be provided as compensation for the destruction of mangrove swamp.

On the same photo, if appropriate, or on other photo identify boundaries of areas to be used for the disposition of dredge spoils resulting from the construction of the third intake pipeline, headwall, and widening of the intake canal.

Response:

See attached marked-up aerial photo.




Question 291.23: Provide the following information:

- A. The month the mangrove swamp mitigation action is to take place.
- B. The kind of equipment used to perform the mitigation action (e.g., backhoe, dragline).

C. The names of the specific native species to be planted.

Response:

A. The mangrove swamp mitigation will be completed by February 1, 1983.

B. Equipment to be used will be a backhoe to bring the lay down area elevation down to wetland elevation. Mangrove seedlings will be planted by either using a mechanical auger or by hand.

C. Mangroves (<u>Rhizophora mangle</u>) will be planted per the Crops permit special conditions.



Question 291.24: Conduct a survey of the mangrove swamp to determine whether any leather ferns are in area to be destroyed.

Response:

A survey of the construction area has been conducted and no leather ferns were found.

Question 291.25: Provide a narrative of any present or future efforts that have been or will be taken to prevent marine turtle entrainment at the offshore intake structure.

Response:

Efforts to understand and reduce turtle entrapment at St. Lucie Plant date to May 1976, when Unit 1 began operation. Monitoring of entrapped sea turtles began in 1976 (intermittent plant operation) when 33 loggerheads were handled. Monitoring of entrapped sea turtles continued in 1977 and 84 turtles (mostly loggerheads) were handled. After the 1977 entrapment data were reviewed for the annual non-radiological reports, the Environmental Department realized that turtle entrapment would be a continuing phenomenon and began a series of evaluations on potential methods to reduce it.

On April 5, 1978, a recommendation was made to the Power Plant Engineering Department that they investigate the feasibility of covering the underwater intake opening with a network of bars. Based on carapace width of 140 turtles (four species: green, n=4; hawksbill n=1; leatherback n=3; loggerhead n=132), maximum dimensions recommended were: square opening of 31.5 cm (12.5 in.) on a side or a diagnoal measurement of 44.5. These dimensions would exclude approximately 95% of the turtles. On July 24, 1978 this preliminary design was completed and reviewed by FPL. The design called for a cage-like structure with a network of bars on 30.5 cm centers to be hinged to the top of the velocity cap. The package included a description of the project, data sheets, material lists, and estimated costs. No further work was authorized on this design because of expected marine fouling and subsequent reduction of flow, costs, and because other methods to modify turtle behavior were under consideration.

An experiment to reduce turtle entrapment occurred in June, 1978, when one of the two intake pipes was plugged and Unit 1 operated off the other pipe, which had just been cleaned of fouling organisms. This action increased the horizontal approach velocity around the plane of the velocity cap to 30.5 cm/sec and doubled the water velocity in the pipeline (e.g. the design criteria when both units are in operation). The hypothesis being tested was that the lower approach velocity of 15.3 cm/sec was insufficient for turtles ' to detect and by operating at the design criteria, the turtles could sense this velocity and avoid being entrapped. Turtle catch per effort during one pipe mode of operation (June 1-24) was compared to catch data during two-pipe operation and it was concluded that there was no difference between the two modes of operation.

On June 8, 1978, Florida Power & Light Company contracted with Applied Biology Inc., of Atlanta, Georgia to conduct a 28 month laboratory investigation on methods to minimize sea turtle entrapment at the St. Lucie Plant. Area of investigation included how light and mechanical devices would modify turtle behavior. In August, 1980, a final report on this project (Applied Biology, 1980) concluded that under laboratory conditions, turtles readily sought out and utilized dark box habitats during resting periods in both night and day situations. Lights (100 watts) in the box habitats were a useful deterrent at night but were ineffective during the day when ambient solar light negated their results.

The study also concluded that a bubble screen was effective in excluding turtles from the box habitats during daylight hours. The effects were more positive during bright light conditions probably due to increased visibility as the bubbles reflected the sun light. At night the bubble screen was ineffective.

Under laboratory conditions, the combined installation of lights and a bubble screen in or around the velocity cap was felt to be promising methods to reduce turtle entrapment. Further testing of prototype designs was felt warranted, but a number of unknowns needed to be evaluated such as effects on other biotic communities and logistics of installing these devices in an ocean environment.

Based on the results of the above study, an evaluation was made on methods to determine if there was a day or night pattern of turtle entrapment. To monitor time of turtle entrapment, sonar and underwater closed-circuit television were considered for the velocity cap and an optical beam was considered for the headwall. However, because of practical and logistic problems associated with the installation of this equipment and other research work on electrical field about to begin, no further work using these monitoring methods was authorized.

On June 1, 1981, FPL contracted with Environmental and Chemical Science (ECS) of Atlanta, Georgia, to perform a study on how electrical fields (AC and DC) could modify turtle behavior. The final report (Environmental and Chemical Sciences, 1981) was issued in December, 1981, and is being evaluated by FPL at the present time. The conclusions of the study are as follows:

- Marine turtles avoided both AC and pulsed DC electric fields of sufficient intensity.
- Exposure to low voltage electric fields did not harm the turtles. Turtles did not exhibit learned behavior after repeated exposures to such fields.
- 3. For a given peak voltage, sine wave AC fields were more effective than pulsed DC in repelling turtles. While there was some variability in the response of turtles to different DC pulse rates, pulse width and waveforms, no well-defined set of parameters appear to be superior.
- 4. There was considerable variation in the responses exhibited by individual turtles to electric fields. Size was important because the larger turtles are more sensitive. Species variations may exist as

there were some indication that green turtles are more sensitive than loggerheads.

5. The field intensity experienced by the head of the turtle may be the most important electrical parameter determining behavior.

6. Under some conditions, turtles entered strong electrical fields and lost motor coordination. At the field intensity studied, the turtles recovered immediately when released from the field with no apparent damage and, again, no apparent learning.

The scope of work for the ECS contract was expanded on November 30, 1981, to allow a preliminary analysis on using sound to modify turtle behavior. This evaluation is underway at this time.

Future Efforts

Until the electrical field and sound work is further evaluated on engineering, cost, practicality and safety criteria, the direction of future work is uncertain. Undoubtedly, further laboratory testing using scale models of the intake structure would be appropriate. Depending on a number of variables, lights, bubble curtains, electrical fields, and sound devices may all have potential for modifying turtle behavior and reducing turtle entrapment at St. Lucie Plant.

References:

Applied Biology, Inc. 1980. Turtle Entrainment Deterrent Study, AB-290, Atlanta, Ga.

Environmental and Chemical Sciences, Inc. 1981. Avoidance responses by sea turtles exposed to electric fields, Atlanta, Ga.

Question 291.26:

Provide details on any refinements considered for the current procedures used to capture turtles in the intake canal.

Response:

In April 1978, it was recognized that if the turtles entrapped in the intake canal could be restricted to a small area by the headwall, then the efficiency of their removal could be improved. Based on this reasoning, a request was made to the Power Plant Engineering Department to install a 12 inch square mesh barrier net (strand diameter 3/8") the entire width of the canal at the AIA bridge. This net was installed in the summer of 1978 and is still in place.

On May 3, 1977, Applied Biology, Inc., under contract with Florida Power & Light Company, prepared formal procedures on net placement, turtle removal, tagging, data recording, and turtle release. These procedures were updated in May 1979 and June 1981 and incorporated the following steps to reduce mortalities (not limited to greens):

- The utmost care is taken in handling the animals to prevent injury and trauma.
- Sick or injured turtles are treated and occasionally held for observation prior to release. Treatment includes injections of antibiotics and vitamins by a local veterinarian if warranted.
- 3. Resuscitation techniques are used if the animal appears recently dead (a green was revived by mouth-to-mouth resuscitation in 1981).

- 4. Sport fishing in the canal has been prohibited (turtles have been found with hooks and monofilament line entangled or attached; however, this did not necessarily happen while they were in the canal).
- 5. Gill netting for fish monitoring has been deleted at a station by the headwall.
- Plant personnel have home phone numbers of Applied Biology, Inc., personnel so they can be notified of sea turtle occurrences at irregular hours.
- 7. Plant and Applied Biology personnel are checking the tangle nets more frequently.

The following are methods which will be evaluated and/or employed to further reduce mortalities (emphasis on greens or other small turtles):

- Use special nets which are lighter in weight, fish near the surface, and have finer mesh than presently used.
- Modification in size, weighting or positioning of the presently used nets.
- Discontinue use of one of the two currently used turtle nets during January through March when the majority of greens occur.
- 4. Check the nets more frequently during January through March.
- 5. Experiment with net positions and its effectiveness as a function of turtle behavior. For example, if the greens stay near the headwall the lighter nets could

fished there, while the heavier nets could be placed . farther up the canal for the loggerheads. Through practical experience as other ideas occur on on methods to reduce turtle netting mortality, they will be tested and, if effective, they will be incorporated into the procedures. Question 291.27: Provide information on what percent of the Caribbean populations of green and loggerhead sea turtles nest in the area of the power plant. Also provide an estimate of the number of nesting turtles (both green and loggerhead) on Florida's east coast. Fully document and reference your response.

Response: Data on green and loggerhead nestings on Hutchinson Island (i.e. the vicinity of the power plant) are based on six survey years - 1971, 1973, 1975, 1977, 1979, and 1981 conducted by the Florida Department of Natural Resources and Applied Biology, Inc., under contract with Florida Power & Light Company. Further details of these studies are reported in the annual non-radiological monitoring reports for St. Lucie Plant including the 1982 report, which is in draft stages.

> Green turtles over the six-year period had a range of 5 - 37 nests per year (actual count, but excluding the northern 10 percent of the island during the first five survey years) with a mean of 19 per year (Applied Biology, Inc., 1980, 1982). R. Witham of DNR reported 62 nests in 1978 (a non-survey year for FPL) (Applied Biology, Inc. 1980). Loggerhead turtles had a range of 3000 - 4800 nests per year with a mean of approximately 4000 (these figures are whole island estimates based on extrapolations from transects)(Applied Biology, Inc., 1980, 1982).

> Figure H-11 (Applied Biology, Inc. 1980) illustrates that greens predominantly nest south of the St. Lucie Power Plant (Area 4). However, in 1981 when 10 green nests were verified on Hutchinson Island, there was one nest recorded in Area 4. (Applied Biology, Inc. 1982).

Figure H-3 (Applied Biology, Inc., 1980) illustrates the nesting pattern of loggerheads in Area 4 (e.g. the Plant Site). In 1981 (Applied Biology, Inc., 1982), 65 nests were recorded in Area 4, compared to 124 nests observed in 1979 when no beach and nearshore construction occurred.

Pritchard (1978) estimates the U.S. loggerhead population consists of about 15,714 adult females. An estimated 19,895 nests are dug in Florida each year by an adult female population estimated at 14,210 individuals.

Pritchard (1978) also estimates the current population of the Florida green as no more than 50 mature females, however, other data suggests this estimate is low. For example, Huff <u>et al.</u> (1980), surveyed selected Florida beaches on the east coast (a total of 222.1 km), and listed actual green nest counts at 281(Table 2). Counts for loggerhead nests during the same survey were 9448 (Table 2). Comparison from 1979 and 1980 revealed two short-term trends: loggerhead nesting decreased in 1980 and green turtle nesting increased in 1980.

References:

Applied Biology, Inc. 1980. Florida Power & Light Company, St. Lucie Plant, annual non-radiological environmental monitoring report 1979, AB-244. Applied Biology, Inc., Atlanta, Ga.

Applied Biology, Inc. 1982. Florida Power & Light Company, St. Lucie Plant, annual non-radiological environmental monitoring report 1981, AB-379. Applied Biology, Inc., Atlanta, Ga. References (Contd)

Huff, J. Alan, P. Ross Witham Carol J. Gray, and Lou
Fallon 1980. Summary of Marine turtle activity in.
Florida in 1980. Florida Department of Natural Resources,
Marine Research Laboratory, St. Petersburg, Fl.

Pritchard, Peter C. H. (ed.) 1978. Rare and endangered biota of Florida, Vol. 3, Amphibians and Reptiles. University Presses of Florida, Gainesville, Fl.

Table 2 - 1980 Nest Survey-Atlantic Coast of Florida -

Actual Counts

Location		County	<u>Caretta caretta</u>	<u>Chelonia mydas</u>
1.	Key Biscayne	Dade	22	10
2.	Miami Beach	Dade	10	0
3.	Deerfield Beach	Broward	555	. 21
4.	Boca Raton	Palm Beach	127	2
5.	Highland Beach	Palm Beach	511	34
6.	Lantana	Palm Beach	10	0
7.	Lost Tree Village Beach	Palm Beach	189	16
8.	Juno Pier	Palm Beach	384	2
´9.	Jupiter Island	Martin	1,104	23
10.	Hutchinson Island	St. Lucie	528	14
11.	Fort Pierce Beach	St. Lucie	1	0
12.	Fort Pierce Inlet	St. Lucie	16	0
13.	Sebastian Inlet	Brevard & India	in R. 335	0
14.	Indialantic	Brevard	35	0
15.	Port Canaveral S. to Sebastian Inlet	Brevard	3,933	122
16.	Canaveral National Seashore & Kennedy Space Center	Brevard	1,261	. 33
17.	North of Brevard County Line	Volusia	392	4
18.	Fort Matanzas	St. Johns	3	° 0
19.	Little Talbot Island	Duval	32	
	TOTAL		9,448	281

