



- NOTES**
- FOR GENERAL NOTES, REFERENCE DRAWING & SYMBOLS SEE DWS. 2998-G-339.
  - 
  - FOR TRAY SUPPORT & INSTALLATION SEE DWG P56-2998-E-040.
  - 
  - FOR CONDUIT TURNING "DOWN" SEE DWG G-342. FOR CONDUIT TURNING "UP" SEE DWG G-347.
  - FOR HEAT ACTIVATING DEVICE SEE NOTE 5 DWG G-341.
  - INSTALL A 4IN CABLE RISER FROM THE STATION GROUNDING GRID TO MEZZ FLOOR LOCATED AT COLUMN 32A SIMILAR TO THAT SHOWN AT COLUMN LINE 32X THIS DWG FOR CONNECTION TO THE 4IN GROUND LOOP.
  - THE GROUND CABLE VERTICAL RISER SHOULD BE INSTALLED INSIDE THE WEB OF THE COLUMN STEEL AND SUPPORTED BY A 1/2 INCH PIPE OR CONDUIT, ONE HOLE STRAP AND A THREADED NELSON STUD & NUT.

PRO APERTURE CARD

Rev: 1 # 50-385  
 Crc: 1 # 80725034A  
 Date: 11/10/75  
 of Document  
 REGULATORY DCKET FILE

ATTACHMENT 6 REV. 1

THIS DOCUMENT IS THE PROPERTY OF EBASCO SERVICES INCORPORATED. ITS USE IS EXPRESSLY RESTRICTED BY THE TERMS OF THE CONTRACT, DATED AS OF SEPTEMBER 1, 1975 BETWEEN EBASCO SERVICES INCORPORATED AND FLORIDA POWER & LIGHT COMPANY.

**FLORIDA POWER & LIGHT COMPANY**  
 ST. LUCIE PLANT  
 1983-820 MW(e) EXTENSION - UNIT NO. 2  
 TURBINE BUILDING MEZZANINE FLOOR  
 CONDUITS, TRAYS AND GROUNDING-SH.4

EBASCO SERVICES INCORPORATED	
SCALE: 1/4"=1'-0"	APPROVER
DIV. ELEC.	DATE
DR.	2998 G 346
CHK.	

NO.	DATE	REVISION	BY	CHK.