

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8203020603. DOC. DATE: 82/02/25. NOTARIZED: NO
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe
 AUTH. NAME: BOUCHEY, G. D.
 RECIP. NAME: SCHWENCER, A.
 AUTHOR AFFILIATION: Washington Public Power Supply System
 RECIPIENT AFFILIATION: Licensing Branch 2

DOCKET # 05000397

SUBJECT: Forwards table of scenarios verifying that cable cooling sys can maintain diesel generator cable area within 115 F limit, per NRC 820222 request.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: 2 copies all matl: PM.

05000397

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL		LTTR	ENCL
ACTION:	A/D LICENSNG	1	0	LIC BR #2 BC	1	0
	LIC BR #2 LA	1	0	AULUCK, R. 01	1	1
INTERNAL:	ELD	1	0	IE	06	3
	IE/DEP/EPDB 35	1	1	IE/DEP/EPLB 36	3	3
	MPA	1	0	NRR/DE/CEB	11	1
	NRR/DE/EOB 13	3	3	NRR/DE/GB	28	2
	NRR/DE/HGEB 30	2	2	NRR/DE/MEB	18	1
	NRR/DE/MTEB 17	1	1	NRR/DE/QAB	21	1
	NRR/DE/SAB 24	1	1	NRR/DE/SEB	25	1
	NRR/DHFS/HFEB40	1	1	NRR/DHFS/LQB 32	1	1
	NRR/DHFS/OLB 34	1	1	NRR/DHFS/PTRB20	1	1
	NRR/DSI/AEB 26	1	1	NRR/DSI/ASB 27	1	1
	NRR/DSI/CPB 10	1	1	NRR/DSI/CSB 09	1	1
	NRR/DSI/ETSB 12	1	1	NRR/DSI/ICSB 16	1	1
	NRR/DSI/PSB 19	1	1	NRR/DSI/RAB 22	1	1
	NRR/DSI/RSB 23	1	1	NRR/DST/LGB 33	1	1
REG FILE	04	1				
EXTERNAL:	ACRS 41	16	16	BNL (AMDTS ONLY)	1	1
	FEMA-REP DIV 39	1	1	LPDR 03	1	1
	NRC PDR 02	1	1	NSIC 05	1	1
	NTIS	1	1			

TOTAL NUMBER OF COPIES REQUIRED: LTTR

65
 63 ENCL 60
 58

THE UNIVERSITY OF CHICAGO
DEPARTMENT OF CHEMISTRY
58 CHEMISTRY BUILDING
CHICAGO, ILLINOIS 60637

RECEIVED
DEPARTMENT OF CHEMISTRY
UNIVERSITY OF CHICAGO
CHICAGO, ILLINOIS 60637

DATE: _____


NO.	NAME	ADDRESS	PHONE	TELETYPE
1	ALAN D. JENKINS	1000 N. LAUREL AVE.	312-437-1234	
2	JOHN D. SMITH	1234 E. MAIN ST.	312-555-6789	
3	MARY K. BROWN	5678 W. RIVER ST.	312-222-3333	
4	ROBERT L. GREEN	9010 S. OAK ST.	312-777-8888	
5	SARAH J. WHITE	2345 N. MAPLE ST.	312-444-5555	
6	DAVID E. BLACK	3456 E. PINE ST.	312-666-7777	
7	JANE M. GRAY	4567 W. BIRCH ST.	312-888-9999	
8	WILLIAM H. RED	5678 N. CEDAR ST.	312-111-2222	
9	ELIZABETH C. BLUE	6789 E. SPRING ST.	312-333-4444	
10	THOMAS A. GOLD	7890 W. SUMMER ST.	312-555-6666	
11	ANNE B. SILVER	8901 N. WINTER ST.	312-777-8888	
12	CHARLES F. COPPER	9012 E. FALL ST.	312-999-0000	
13	MICHAEL G. IRON	0123 W. HILL ST.	312-222-3333	
14	SUSAN L. ZINC	1234 N. VALLEY ST.	312-444-5555	
15	JOHN P. LEAD	2345 E. CANYON ST.	312-666-7777	
16	MARIE R. TIN	3456 W. MOUNTAIN ST.	312-888-9999	
17	EDWARD S. NICKEL	4567 N. PLAIN ST.	312-111-2222	
18	HELEN T. COBALT	5678 E. VALLEY ST.	312-333-4444	
19	FRANK W. SILVER	6789 W. HILL ST.	312-555-6666	
20	JOAN Q. ZINC	7890 N. VALLEY ST.	312-777-8888	

8203020603 820225
PDR ADDCK 05000397
A PDR

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

February 25, 1982
G02-82-255
SS-L-02-PLP-82-008



Docket No. 50-397

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Schwencer:

Subject: NUCLEAR PROJECT NO. 2
WNP-2 DIESEL-GENERATOR
AREA CABLE COOLING SYSTEM

As requested during a phone conversation on February 22, 1982, between NRC staff (Messrs. R. Auluck and J. Ridgley) and Supply System personnel (Messrs. W.H. Kelso and R.M. Nelson), attached is a table of scenarios that verifies that the WNP-2 Cable Cooling Systems can maintain the Diesel-Generator Cable Area within the 115°F limit.

Very truly yours,

A handwritten signature in cursive script that reads "G. D. Bouchey".

G. D. Bouchey
Deputy Director, Safety and Security

PLP/jca
Attachment

cc: R Auluck - NRC
WS Chin - BPA
R Feil - NRC Site
J Ridgley - NRC

B001
3
1/1



Handwritten scribble or mark in the middle right area.

Handwritten scribble or mark at the bottom right corner.

9.4.8 DIESEL-GENERATOR AREA CABLE COOLING SYSTEM

Failure combinations under which the Emergency Diesel-Generators and Cable Cooling systems will operate and the 115°F limit maintained.

Reference: Figure 9.4-7

<u>Combination</u>	DEA-FN-51 Normal Exhaust (Power from Offsite or Div. 1 D.G.)	DEA-FN-52 Standby Exhaust (Power from Div. 1 D.G.)	DMA-AH-51 Air Handling Unit (Power from Div. 2 D.G.)
1. Normal Offsite Power	On	Off	Off
2. Offsite Power Loss Div. 1 D.G. On	On	On	Off
3. Offsite Power Loss Div. 2 D.G. On	Off	Off	On
4. Offsite Power Loss Div. 1 D.G. & Div. 2 D. G. On	On	On	On

A failure of the Air Handling Unit fan, as indicated by the DMA-FN-51 Annunciator will require plant operation to shut down the Div. 2 D.G. in order to maintain the 115°F temperature limit in the cable corridor.

