REGULATORY FORMATION DISTRIBUTION SYMEEM (RIDS)

ACCESSION NBR: FACIL:50-397	8205280321 DOC.DAT WPPSS Nuclear Project	E: 82/05/20 , Unit 2, Was	NOTARIZED: NO shington Public	Powe	DOCKET #
BOUCHEY, G.D.	Washington Public	Power Supply	v System		
SCHWENCER, A.	RECIPIENT AFFILI Licensing Bran	ATION ch'2			
			4)		

SUBJECT: Submits inforre fast scram hydrodynamic loads on control rod drive sys per NRC 820405 request, Requests that issue be considered confirmatory pending submittals of BWR owners group generic rept.

DISTRIBUTION CODE: BOOIS COPIES RECEIVED: LTR ____ ENCL ____ SIZE: ______

NOTES:

	RECIPIENT		COPIE	ES ,	RECIP	IENT		COPI	ES
	ID CODE/NAM	E	LTTR	ENCL	ID CODE	EZNAME		LTITR	ENCL
•	A/D LICENSNG		» 1 ·	~ Q	LIC BR	#2 :BC		1	•Ø
4	LIC BR #2 LA		1	þ	AULUCK	₹.	•01	1	- fi
INTERNAL:	ELD/HDS2	ŝ	.1.	- b	IE FILE			1	
	IE/DEP EPDS	*35	. 1	1	IE/DEP/E	EPLB	36	*3	-> \$ -
	MPA		1	- b	NRR/DE/	CEB	11	1	
	NRR/DE/EQB	13.	+3	18	NRR/DE/C	GB	28	'2	Ł
	NRR/DF/HGEB	130	2	-5	NRR/DF/N	AFB	18	Ĩ	- Fi
	NRR/DE/MTER	17	1	F	NRR/DE/	JAR .	21	1	5
	NPR/DE/SAR	12/1	1	i i		SER	25	1	۲.
	NDD / DUES / UEE	54 D//A	4				.70		1
	NKK/DRFS/ARE	D4V 7/1	1	1			52	1	1
	NRR/DHFS/ULB	34	1	լ	NKK/DHF		20	1	
	NRR/DSI/ALB	26	1.	p	NRR/USI/	ASB	21	1	4
	NRR/DSI/CPB	10	1	° tr	NRR/DSI/	CSB	09	1	- J
	NRR/DSI/ETSB	12	1	μ	NRR/DSI/	/ICSB	16	1	1
	NRR/DSI/PSB	1/9	1	k i	NRR/DSI/	RAB '	22	1	1
	NRR/DSI/RSB	'2 3	1	1.0	NRR/DST/	/LGB	33	1	1
(REGFILE	04	1 -	4	RGN5			'2 *	4
EXTERNAL:	ACRS	41	16	16	BNL (AMD)	S .ONL	.Y.)	1	h
	FEMA-REP DIV	·39	· 1	1	LPDR		03	1	1]
	NRC PDR	-02	1	L L	NSIC		05	1	. 1
	NTIS		ĩ	Ę,				-	. V

0

;5⁄8

TOTAL NUMBER OF COPIES REQUIRED: UTTR 63 ENCL

الله الذي المرتبي المرتب المرتبي المرت المرتبي المرت المرتبي المرتبي المرتيان المرتي المرتيان المرتيان المرتيان المرتيان المرتيان المرتي المرتيان المرتيان المرتيان المرتي المرتي المرتي المرتيان المرتيان المرتيان المرتيان المرتيان المرتيان المرتيان المرتي المرتيان المرتيا المرتيان المرتيان * 1 j Pa C. P. S. Star B. B.

to ADA AN ANY MORE

and a second the second contract of the second A REAL AND A REAL TRADE AND WARDED TO BE AND THE AND

and a second a se .

• • • • •

• •

2	۰.	8 (4 x 9 x 8	Huffy.	د ¥ با ¥ م	
1 a	B x 1	al de 🔨 🔨 de sub de 🗴	¥ ¥ * '* ¥	A TAKE & A P	
	8	¥ - €_aa ing r - ¥⊾ X	1	きしゃまだ みこの入り	
ł	٠	₩ ● ¹ ● ¹ ★ 1★ 14 → X , 15	1	Филь 🕨 Ти	
,	1	i a T x a f	fu 1	K. SANN ARE SHUTHER	1
	a 1	E PETEX IS NOR	*		
1	ł				
£	1		ا لا	a Partice to the state	
	,		٤ .,		
·	,	an saint an saint sai	· 8		
	, k	a the second s	· .		
	2				
*			* 1	· · · · · · · · · · · · · · · · · · ·	
۴	i A			V Constraints and the second secon	
×	1 u	en Sala e Sa			
¥	*		· *	X MARY NO	
1	7	SHE SHENG AND	1. A	a Alexandra Andrea Andrea Alexandra	
*	р М	the second s	5i	$\mathbb{R} = \{0, \dots, n\} \in \mathbb{R} \setminus \{1, \dots, N\}$	
લ	*	$f = -\frac{1}{2} \int \frac{1}{2} \int$	ξ 👔	 Example 1 (SNC) and (SNC) 	
đ		X	к 🔺		
	B	e k til er er	14 C. R.	1 · · · · · · · · · · · · · · · · · · ·	
۴	7	* * * *	8 <u>1</u>	V I Start Start	
4	1	₹ A	i x		
			1	· · · · ·	

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

May 20, 1982 GO2-82-455 SS-L-02-PLP-82-033

Docket No. 50-397

Mr. A. Schwencer, Chief Licensing Branch No. 2 Division of Licensing U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Dear Mr. Schwencer:

Subject:

NUCLEAR PROJECT NO. 2 FAST SCRAM HYDRODYNAMIC LOADS ON CONTROL ROD DRIVE SYSTEMS

Reference:

Letter. A. Schwencer (NRC) to R.L. Ferguson (SS), Same Subject, dated April 5, 1982

The referenced letter identified hydrodynamic loads in the CRD system as an open item for WNP-2. The Supply System has performed a review of the WNP-2 CRD system and provides the following information:

- The referenced letter states that the "worst case" loads occur when a design basis inlet valve opening time of 20 milliseconds is used. WNP-2 valve opening times are 60-100 milliseconds, and 40-60 milliseconds for the inlet and exhaust valves, respectively. The slower opening times will limit the magnitude of the quick opening valve transient load experienced on the WNP-2 system.
- The Supply System staff has reviewed the "quick look" results of tests conducted on the LaSalle County system to measure the subject loads. The quick look results indicate that the loads are significantly less than those analytically predicted. Since the WNP-2 design is similar to LaSalle County it is anticipated that the test results will be applicable to WNP-2.
- The BWR Owner's Group is preparing a generic response to this issue. As a participant in the BWR Owner's Group it is the Supply System's intention to work with the Owner's Group in resolving this issue.

8205280321: A

A. Schwencer Page Two May 20, 1982 G02-82-455

Considering that the BWR Owner's Group generic approach will not be ready for submittal in the near term and that an evaluation of the Supply System design indicates that the WNP-2 design does not incorporate those design aspects responsible for the "fast scram" hydrodynamic load, it is requested that this issue be considered confirmatory pending submittal of the BWR Owner's Group generic report.

Should you have any questions, please contact Mr. R. M. Nelson, Project Licensing Manager, WNP-2.

Very truly yours,

Douc

G. D. Bouchey Deputy Director, Safety and Security

PLP/jca

cc: R Auluck - NRC WS Chin - BPA R Feil - NRC Site CS Haynes - BECH H Reading - BECH . . •

· `.

. • -

. . .

•

' s