

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8207280168 DOC. DATE: 82/07/07 NOTARIZED: NO DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Power 05000397  
 AUTH. NAME AUTHOR AFFILIATION  
 BOUCHEY, G. D. Washington Public Power Supply System  
 RECIPIENT NAME RECIPIENT AFFILIATION  
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Forwards info re max average rate of strike-slip displacement on RAW & "Re-Evaluation of Seismic Velocity Measurements," per NRC request.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4717  
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	A/D LICENSNG	1 0	LIC BR #2 BC	1 0
	LIC BR #2 LA	1 0	AULUCK, R. 01	1 1
INTERNAL:	ELD/HDS2	1 0	IE FILE	1 1
	IE/DEP EPDS 35	1 1	IE/DEP/EPLB 36	3 3
	NRR/DE/CEB 11	1 1	NRR/DE/EQB 13	3 3
	NRR/DE/GB 28	2 2	NRR/DE/HGEB 30	2 2
	NRR/DE/MEB 18	1 1	NRR/DE/MTEB 17	1 1
	NRR/DE/QAB 21	1 1	NRR/DE/SAB 24	1 1
	NRR/DE/SEB 25	1 1	NRR/DHFS/HFEB40	1 1
	NRR/DHFS/LQB 32	1 1	NRR/DHFS/OLB 34	1 1
	NRR/DHFS/PTRB20	1 1	NRR/DSI/AEB 26	1 1
	NRR/DSI/ASB 27	1 1	NRR/DSI/CPB 10	1 1
	NRR/DSI/CSB 09	1 1	NRR/DSI/ETSB 12	1 1
	NRR/DSI/ICSB 16	1 1	NRR/DSI/PSB 19	1 1
	NRR/DSI/RAB 22	1 1	NRR/DSI/RSB 23	1 1
	NRR/DST/LGB 33	1 1	<del>REG FILE</del> 04	1 1
	RGNS	2 2	RM/DDAMI/MIB	1 0
EXTERNAL:	ACRS 41	16 16	BNL (AMDTS ONLY)	1 1
	DMB/DSS (AMDTS)	1 1	FEMA-REP DIV 39	1 1
	LPDR 03	1 1	NRC PDR 02	1 1
	NSIC 05	1 1	NTIS	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 64 ENCL 59

THE UNITED STATES OF AMERICA  
 DEPARTMENT OF THE ARMY  
 OFFICE OF THE ADJUTANT GENERAL  
 WASHINGTON, D. C. 20315

FORM NO. 1  
 1-64 (REV. 1-64)  
 PREVIOUS EDITIONS ARE OBSOLETE

THIS FORM IS USED FOR THE PREPARATION OF THE  
 SUMMARY OF THE ADJUTANT GENERAL'S REPORT  
 AND IS TO BE COMPLETED BY THE ADJUTANT  
 GENERAL AT THE TIME OF HIS REPORT.

DATE	TIME	LOCATION	ACTIVITY	REMARKS
1	0800	...	...	...
1	0900	...	...	...
1	1000	...	...	...
1	1100	...	...	...
1	1200	...	...	...
1	1300	...	...	...
1	1400	...	...	...
1	1500	...	...	...
1	1600	...	...	...
1	1700	...	...	...
1	1800	...	...	...
1	1900	...	...	...
1	2000	...	...	...
1	2100	...	...	...
1	2200	...	...	...
1	2300	...	...	...
1	2400	...	...	...
1	0100	...	...	...
1	0200	...	...	...
1	0300	...	...	...
1	0400	...	...	...
1	0500	...	...	...
1	0600	...	...	...
1	0700	...	...	...

## Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

July 7, 1982

G02-82-581

SS-L-02-CDT-82-082

Docket No. 50-397

Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Schwencer:

Subject: NUCLEAR PROJECT NO. 2  
RESPONSE TO INFORMAL REQUESTS FOR INFORMATION

Enclosed are sixty (60) copies of the information on Maximum Average Rate of Strike-Slip Displacement on RAW and Reevaluation of Seismic Velocity Measurements which were requested informally by the NRC.

Very truly yours,




G. D. Bouchey  
Deputy Director, Safety and Security

CDT/jca  
Enclosure

cc: R Auluck - NRC  
WS Chin - BPA  
R Feil - NRC Site

13001




## MAXIMUM AVERAGE RATE OF STRIKE-SLIP DISPLACEMENT ON RAW

The data regarding the amount and timing of strike-slip displacement on RAW do not allow estimates of the present slip rate to be made with a high degree of confidence. However, it is possible to place constraints on the average (long-term) lateral slip rate on the basis of assumptions regarding the known geologic relationships.

No individual stratigraphic or geomorphic markers have been shown to be laterally offset across RAW. The observations that suggest a lateral component of strain along RAW are: (1) horizontal strata that are present on fault surfaces within the Wallula fault zone, and (2) the northwest orientation of RAW relative to the inferred north-south orientation of the maximum compressive stress in the central Columbia Plateau. The tectonic models that propose strike-slip displacement along RAW postulate a zone of dextral shear that is at the surface along the Wallula fault zone to the southeast and that becomes either deeper (Laubscher, Appendix 2.5-O) and/or broader and more diffuse (Davis, Appendix 2.5-N) to the northwest beneath the structures of CLEW. Therefore, any assessment of the lateral slip along RAW northwest of the Wallula fault zone must be based on an assumed relationship between the surface deformation and inferred dextral strain at depth.

A major problem in assessing fault slip rates is using rates averaged over a long period of time to estimate present-day slip. The assumption that slip rates are constant over long periods of time may not be correct; detailed studies of fault slip rates show temporal variations over intervals of thousands of years (e.g., Sharp, 1980). For the Columbia Plateau, some studies suggest that the rate of deformation has been declining during the Quaternary period (Davis, Appendix 2.5-L) and geodetic data suggest deformation has either stopped or is continuing at a low




rate (Savage et al., 1981). Therefore, the present-day slip rate may be considerably less than that based on the deformation that has occurred during the past 14 m.y., which is the interval during which the Columbia River Basalts have been deformed.

In light of the uncertainties presented in the previous discussion, several estimates of the maximum average rate of strike-slip displacement along RAW are presented below. A prominent north-south gravity anomaly has been identified (Weston Geophysical, 1981) that crosses CLEW without any apparent lateral deflection at about longitude 120°W. Weston Geophysical (1981) estimates that, based on the resolution of the gravity data, the cumulative offset of the anomaly can be no more than 3 km. The anomaly is believed to be associated with a basement feature that predates the initial deposition of the Columbia River basalts (about 14 m.y. ago). The slip rate that results from a 3 km displacement during a 14 m.y. period is 0.2 mm/yr.

Constraints on the maximum cumulative offset may also be estimated by relating the pattern and amount of surface deformation to inferred dextral strain at depth. For example, Laubscher (Appendix 2.5-0) develops structural and kinematic arguments for the Columbia Plateau that limit the lateral component of strain across CLEW/RAW to less than 2 to 3 km. Assuming displacement along CLEW/RAW coincided with the initiation of Columbia River basalts about 14 m.y. ago (Davis, 2.5-N), the maximum average slip rate is 0.1-0.2 mm/yr.

Bentley (1980) and Laubscher (Appendix 2.5-0) present data on amounts of crustal shortening across the east-west trending folds of the Yakima fold belt. If it is assumed that all of the north-south shortening across the Yakima folds within CLEW occurs along the north-west striking CLEW/RAW as strike-slip faulting, then the cumulative strike-slip displacement can be estimated. At longitude 120°W, the displacement is calculated to be 3.2 km (shortening 4.5 km) based on Bentley's data, and 1.5 km





(shortening 2.1 km) based on Laubscher's data. Again, assuming a 14 m.y. time period, the resulting maximum average slip rates are 0.2 mm/yr and 0.1 mm/yr, respectively.

The following table summarizes the slip rate estimates:

Slip Rates

<u>Technique</u>	<u>Data</u>	<u>Slip Rate</u>	<u>Reference</u>
N-S Gravity Anomaly	<3 km	0.2 mm/yr	Weston Geo-physical (1981)
Kinematic Analysis	2-3 km	0.1-0.2 mm/yr	Laubscher (1981)
Horizontal Shortening	3.2 km	0.2 mm/yr	Bentley (1981)
Horizontal Shortening	1.5 km	0.1 mm/yr	Laubscher (1981)

References

Davis, G. A., 1981, Late Cenozoic tectonics of the Pacific Northwest with special reference to the Columbia Plateau: WNP-2, FSAR, Appendix 2.5N, 47 p.

Laubscher, H. P., 1981, Models of the development of Yakima deformation: WNP-2 FSAR, Appendix 2.5-O, 69 p.

Sharp, R. V., 1980, Variable rates of late Quaternary strike slip on the San Jacinto fault zone, southern California: U.S. Geological Survey Open-File Report 80-95, 37 p.

Savage, J. C., Lisowski, M., and Prescott, W. H., 1981, Geodetic strain measurements in Washington: Journal of Geophysical Research, v. 86, no. B6, p. 4929-4940.

Weston Geophysical Corporation, 1981, Compilation and interpretation of gravity in Washington, Oregon, and adjacent parts of British Columbia and Idaho: WNP-2 FSAR, Appendix 2.5-L, 28 p.

