

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8307120309 DOC. DATE: 83/06/22 NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 BOUCHEY, G.D. Washinton Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION
 SCHWENCER, A. Licensing Branch 2

SEE REP

SUBJECT: Forwards "WPPSS 2 Purge & Vent Valves Seismic & Hydrodynamic Analysis," per SER Outstanding Issue 26.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 6 SIZE: 2+300
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: *Limited Distribution*

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	NRR/DL/ADL	1 0	NRR LB2 BC	1 0
	NRR LB2 LA	1 0	AULUCK, R. 01	1 1
INTERNAL:	ELD/HDS2	1	IE FILE	1
	IE/DEPER/EPB 36	3	IE/DEPER/IRB 35	1
	IE/DEQA/QAB 21	1	NRR/DE/AEAB	1
	NRR/DE/CEB 11	1	NRR/DE/EHEB	1
	NRR/DE/eqB 13	2	NRR/DE/GB 28	2
	NRR/DE/MEB 18	1	NRR/DE/MTEB 17	1
	NRR/DE/SAB 24	1	NRR/DE/SGEB 25	1
	NRR/DHFS/HFEB40	1	NRR/DHFS/LQB 32	1
	NRR/DHFS/PSRB	1	NRR/DL/SSPB	1
	NRR/DSI/AEB 26	1	NRR/DSI/ASB	1
	NRR/DSI/CPB 10	1	NRR/DSI/CSB 09	1
	NRR/DSI/ICSB 16	1	NRR/DSI/METB 12	1
	NRR/DSI/PSB 19	1	NRR/DSI/RAB 22	1
	NRR/DSI/RSB 23	1	<u>REG FILE</u> 04	1 1
	RGNS	3	RM/DDAMI/MIB	1 0
EXTERNAL:	ACRS 41	6	BNL (AMDTS ONLY)	1 0
	DMB/DSS (AMDTS)	1	FEMA-REP DIV 39	1 0
	LPDR 03	1 1	NRC PDR 02	1 1
	NSIC 05	1 1	NTIS	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTR 53 ENCL 46



[The text in this section is extremely faint and illegible due to low contrast and scan quality. It appears to be a list or a series of entries, possibly containing names and dates, but the characters are not discernible.]

50-397

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

June 22, 1983
G02-83-550

Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Schwencer:

Subject: NUCLEAR PROJECT 2
QUALIFICATION OF WNP-2 CONTAINMENT
VENT AND PURGE VALVES

- References:
- 1) Letter, A. Schwencer (NRC) to R. L. Ferguson, (Supply System), "Request for Additional Information", dated September 16, 1982, Docket No. 50-397
 - 2) NUREG-0892, WNP-2 SER, Outstanding Issue No. 26, "Operability of Purge Valves"
 - 3) Letter, G. D. Bouchey (Supply System) to A. Schwencer (NRC), G02-83-170, "Nuclear Project No. 2, Qualification of WNP-2 Containment Vent and Purge Valves", dated February 24, 1983

Reference 3) provided partial response to the Purge and Vent valve operability concerns cited in Reference 1) and 2). This letter transmits stress analysis work to address the remaining open issues.

The enclosed reports provide the qualification stress analyses for the subject valves and their operators. Each has a positive margin of safety when the stress caused by a safe shutdown earthquake is combined with safety relief valve operation along with chugging or annulus pressurization. Acceptance criteria are from Section III of the ASME Boiler and Pressure Vessel Code or the AISC Steel Construction Manual, whichever is applicable.

These margins of safety were found only with the modifications described in the attached reports. These modifications will be performed prior to operation of WNP-2.

8307120309	830622
PDR	ADOCK 05000397
E	PDR

Boo1
1/6

LIMITED DISTRIBUTION



1-2-7
1-1-1
1-1-1

1-1-1

Mr. A. Schwencer
Page 2
June 22, 1983


With the modifications in place, these valves will remain functional through forty years of postulated hydrodynamic events, five operating basis earthquakes, and one safe shutdown earthquake.


G. D. Bouchey, Manager
Nuclear Safety and Regulatory Programs

RWH/sms

Attachments

cc: Mr. R. Auluck - NRC
Mr. W. S. Chin - BPA
Mr. A. Toth - NRC Site



Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

The attached reports are the structural analysis of the purge and vent valves and operators installed at WNP-2. The loads used in the analysis are the valve operating loads combined with the dynamic loads which would result from seismic and hydrodynamic events as determined by the piping analyses for the plant.

There are three reports attached. They separately address:

- 1) The 24-inch butterfly valves manufactured by BIF (identified as QID 361106),
- 2) The 30-inch butterfly valves manufactured by BIF (identified as QID 361104), and
- 3) The air operators manufactured by Miller Fluid Power and supplied by BIF as a part of the valve assembly (identified as QID 018001).

These reports have been prepared by Cygna Energy Services for the Supply System's Equipment Qualification Group and are in their complete form in the Equipment Qualification files. However, in the interest of conserving space in the transmittal to the U.S. NRC, pages which are duplicated in the reports have been removed from all but one of the reports. Also, documents which have previously been submitted to the U.S. NRC are not attached as stated in the report.

830.712.0309

SECRET

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

SUPPLIER TRANSMITTAL FORM

(AREA WITHIN HEAVY BORDER TO BE COMPLETED BY SUPPLIER)

TO THE ATTENTION OF: Dennis Armstrong
(COGNIZANT PURCHASE AGENT/BUYER/CONTRACT ADMIN.)
 ADDRESS: 3000 George Washington Way, Richland
 SUBJECT: Equip. Seismic/Hydrodynamic Requal.
 FROM: Cygn Energy Services
 ADDRESS: 1200 Jadwin, Suite 565, Richland, WA
 THE FOLLOWING PUBLICATIONS/DRAWINGS ARE SUBMITTED FOR:
 APPROVAL REVIEW INFORMATION DISTRIBUTION
 NO. OF PRINTS _____ OF EACH NO. OF REPRODUCIBLES _____ OF EACH
 SUBMITTED BY: Fawaz Khanachet
 TITLE: Assistant Project Manager
 SUBVENDOR: _____ CONT./P.O. NO.: _____

PAGE 1 OF 1
 TRANSMITTAL NO. 099
 NEW RE-SUBMITTAL
 DATE SUBMITTED: 6/9/83
 REQUESTED DATE OF RETURN: _____
 CONTRACT NO: C-0892
 P.O. NO: _____
 WORK ORDER NO: _____
 SPEC. NO: _____
 SPEC. SECT. NO: _____

ITEM NO.	PUBLICATION OR DRAWING NO.	REV. NO.	PUBLICATION OR DRAWING TITLE	MANUFACTURER	WPPSS ACTION
1	361106	3	Original Requal, Rpt. for QID 361106		A
2	T-644RB		Cygn Energy T-644RB		

COMMENTS: (USE ADDITIONAL SHEET, IF REQUIRED)

- TO BE REVIEWED BY -

RECEIVED BY: (PURCHASING ONLY) TRANSMITTED BY: (PURCHASING ONLY)
 NAME _____ DATE _____ NAME _____ DATE _____
 APPROVED BY: Dennis Armstrong TITLE Project Manager DATE 5/10/83

ACTION LEGEND:
 A = APPROVED FOR PUBLICATION I = INFORMATION ONLY
 AN = APPROVED AS NOTED FOR FABRICATION NA = NOT APPROVED



Final Qualification Report

PROJECT: Equipment Seismic/Hydrodynamic Requalification

JOB NO: 82044

CALC NO: OT.01.F

CLIENT: Washington Public Power Supply System

VOID NO: 361106
TO 33847

TITLE: Equipment Seismic and Hydrodynamic Requalification of
24" Cylinder Operated Butterfly Valves for:

CSP-V-3,4,5,6, and 9

CEP-V-3A, and 4A

PREPARED BY: Mark Scott 6/9/83
DATE

REVIEWED BY: Lourdes Fernandez 6/9/83
DATE

APPROVED BY: Fawaz Khanachet 6/9/83
DATE

REVISION: 3

SUPPLY SYSTEM REVIEW.

R.W. Hickman

R. W. HICKMAN

6/10/83

REVISION STATUS REPORT

REV	DATE	PRE'D BY REV'D BY	APPROVED BY	DESCRIPTION
0	8/6 th /82	R. Hsieh H. ABOLCHODT	W. Schlofer	ORIGINAL ISSUE
1	10/27/82	R. Hsieh H. ABOLCHODT	W. Schlofer	INCLUSION OF SUMMARY & REVISE CALC. TABLE OF CONTENTS
2	12/6/82	J.M. Foley B. B. B.	W. Schlofer	Revised entire calc to reflect new cylinder combined correct spring preloads and to include dynamic torque effects.
	5/12/83	D. E. Karamzadeh D. E. Karamzadeh	W. Schlofer	Revised entire calc for 2000 psi max. using actual piping loads. Addressed actual number of bolts.
3	6/9/83	M. C. C. L.C. Fernandez	W. Schlofer	REVISE EAR WELD STRESS CONCLUSION INCORPORATE COMMENTS

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

REQUALIFICATION CERTIFICATE

WNP- 2

QID# 361106

³

COMPONENT NO: CSP-V-3, CSP-V-4, CSP-V-5, CSP-V-6, CSP-V-9, CEP-V-3A & CEP-V-4A

COMPONENT DESCRIPTION: 24" Cylinder Operated Butterfly Valves

MANUFACTURER: BIF

MODEL NO: A-206765

EQUIPMENT CLASSIFICATION: ACTIVE

PASSIVE

SEISMIC QUALIFICATION REPORT REFERENCE:

Cyana Report 0t.01/F, QID 361106

"24" Cylinder-Operated Butterfly Valve"

- Required action:
- 1) Remove A-307 Ear Bolts and replace with A-325.
 - 2) Reinforce valve ear group with 1/2" shear plates to qualify air operators for required fatigue cycles.

³

THE ABOVE SEISMIC AND ~~QUALIFICATION~~ QUALIFICATION REPORTS HAVE BEEN REEVALUATED IN ACCORDANCE WITH THE CURRENT NRC SEISMIC AND ~~OPERATIONAL~~ CRITERIA:

1. IEEE STANDARDS 344 (1975)
2. USNRC REGULATORY GUIDES 1.92, 1.100
3. STANDARD REVIEW PLANS 3.9.2, 3.10, ~~3.10.1~~

THE ABOVE COMPONENT HAS BEEN FOUND ACCEPTABLE FOR PERFORMING ITS INTENDED SAFETY RELATED FUNCTION WHEN SUBJECTED TO THE PLANT SPECIFIC VIBRATORY ~~LOADS~~ LOADS.

PREPARED BY	<u>JE RAGOWSKI</u>	DATE	<u>5/2/83</u>
REVIEWED BY	<u>H.E. Seale</u>	DATE	<u>5/12/83</u>
APPROVED BY	<u>R.W. Fleckman</u>	DATE	<u>6/16/83</u>

FORM 1001 U.S.

U.S. DEPARTMENT OF JUSTICE



2.0 SQRT FORM(S) AND REFERENCES.

MEMORANDUM

TO : SAC, [illegible]

FROM : [illegible]

RE : [illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

Qualification Summary of Equipment

OID# 361106

Ref. No.

I. PLANT NAME: WNP-2 TYPE
PWR _____
 1. NSSS: GE 2. A/E: Burns & Roe BWR 5, Mark II

II. COMPONENT NAME: 24" Cyl. Oper. Butterfly Valve COMPONENT NO. CSP-V-3, 4, 5, 6, & 9
CEP-V-3A & 4A

1. SCOPE: NSSS BOP
 2. MODEL NUMBER: A-206765 QUANTITY: 7
 3. VENDOR: BIF
 4. IF THE COMPONENT IS A CABINET OR PANEL, NAME AND MODEL NO. OF THE DEVICES INCLUDED:
N/A

5. PHYSICAL DESCRIPTION: a. APPEARANCE: Butterfly Valve with 8" Cyl Operator
 b. DIMENSIONS: 24" nominal diameters
 c. WEIGHT: 847# - Valve Assy; 676# - Operator & bracket

6. LOCATION: BUILDING: Reactor
 ELEVATION: Maximum elevation: 495' (CSP-V-3A & 4A)

7. FIELD MOUNTING CONDITIONS: BOLT (NO. _____ SIZE _____)
 WELD (LENGTH _____)

8. a. SYSTEM IN WHICH LOCATED: Containment Supply Purge Systems
 b. FUNCTIONAL DESCRIPTION: Primary Containment isolation, prevention of the release of radioactive material to the environment.
 c. IS THE EQUIPMENT REQUIRED FOR: HOT STANDBY COLD SHUTDOWN
 BOTH NEITHER

9. PERTINENT REFERENCE DESIGN SPECIFICATION: WPPSS Spec. 2808-68

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT: YES NO

Qualification Summary of Equipment (Continued)

QID# 361106

Ref. No.

IV. EQUIPMENT QUALIFICATION METHOD:

TEST ANALYSIS COMBINATION OF TEST & ANALYSIS

QUALIFICATION REPORT: 24" Cylinder-Operated Butterfly Valve*

(NO., TITLE & DATE): OT.01.F, Revision 3, June, 1983

COMPANY THAT PREPARED REPORT: Cyona Energy Services

COMPANY THAT REVIEWED REPORT: Washington Public Power Supply Systems
*Plus original valve analysis

15

3,4

V. VIBRATION INPUT:

1. LOADS CONSIDERED: a. SEISMIC ONLY
 b. HYDRODYNAMIC ONLY
 c. COMBINATION OF (a) AND (b)

2. METHOD OF COMBINING RRS: ABSOLUTE SUM SRSS OTHER (SPECIFY) _____

3. REQUIRED RESPONSE SPECTRA (ATTACH THE GRAPHS): Section 5.1 of QID 361106

4. DAMPING CORRESPONDING TO RSS: OBE _____ SSE _____

5. REQUIRED ACCELERATION IN EACH DIRECTION: ZPA OTHER (SPECIFY) Section 5.5

OBE S/S = Attached F/B = _____ V = _____

SSE S/S = Attached F/B = _____ V = _____

6. WERE FATIGUE EFFECTS OR OTHER VIBRATION LOADS CONSIDERED?

YES NO

IF YES, DESCRIBE LOADS CONSIDERED AND HOW THEY WERE TREATED IN OVERALL QUALIFICATION PROGRAM:

The calculated stress ranges were compared to the
AISC allowables, as the structures analyzed were not
part of the pressure boundary.

15

NOTE: IF MORE THAN ONE REPORT, COMPLETE ITEMS IV THROUGH VII FOR EACH REPORT

Qualification Summary of Equipment (Continued)

QID# 361106

Ref. No.

VI. IF QUALIFICATION BY TEST, THEN COMPLETE*:

N/A

1. SINGLE FREQUENCY MULTI-FREQUENCY RANDOM
2. SINGLE AXIS MULTI-AXIS SINE BEAT _____

3. NO. OF QUALIFICATION TESTS: OBE _____ SSE _____ OTHER (SPECIFY) _____

4. FREQUENCY RANGE: _____

5. NATURAL FREQUENCIES IN EACH DIRECTION (SIDE/SIDE, FRONT/BACK, VERTICAL):

S/S = _____ F/B = _____ V = _____

6. METHOD OF DETERMINING NATURAL FREQUENCIES:

- LAB TEST IN SITU TEST ANALYSIS

7. TRS ENVELOPING RRS USING MULTI-FREQUENCY TEST: YES (ATTACH TRS & RRS GRAPHS) NO

8. INPUT g-LEVEL TEST: OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. LABORATORY MOUNTING:

- BOLT (NO. _____, SIZE _____) WELD (LENGTH _____) _____

10. FUNCTIONAL OPERABILITY VERIFIED: YES NO NOT APPLICABLE

11. TEST RESULTS INCLUDING MODIFICATIONS MADE:

12. OTHER TEST PERFORMED (SUCH AS AGING OR FRAGILITY TEST, INCLUDING RESULTS):

*NOTE: IF QUALIFICATION BY A COMBINATION OF TEST AND ANALYSIS, ALSO COMPLETE ITEM VII.

Qualification Summary of Equipment (Continued)

QID# 361106

Ref. No.

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. METHOD OF ANALYSIS:

- STATIC ANALYSIS EQUIVALENT STATIC ANALYSIS
 DYNAMIC ANALYSIS TIME-HISTORY RESPONSE SPECTRUM

2. NATURAL FREQUENCIES IN EACH DIRECTION (SIDE/SIDE, FRONT/BACK, VERTICAL):

s/s = 10.81 Hz F/B = 26.1 Hz v = >100

3. MODEL TYPE:

- 3D 2D 1D FINITE ELEMENT BEAM CLOSED FORM SOLUTION

4. COMPUTER CODES: _____

FREQUENCY RANGE AND NO. OF MODES CONSIDERED: _____

- HAND CALCULATIONS

5. METHOD OF COMBINING DYNAMIC RESPONSES: ABSOLUTE SUM SRSS OTHER (SPECIFY) _____

6. DAMPING: OBE _____ SSE _____ BASIS FOR THE DAMPING USED: N/A*

7. SUPPORT CONSIDERATIONS IN THE MODEL: pipe-mounted

8. CRITICAL STRUCTURAL ELEMENTS:

A. IDENTIFICATION	LOCATION	GOVERNING LOAD		TOTAL STRESS	STRESS ALLOWABLE
		OR RESPONSE COMBINATION	SEISMIC STRESS		
Valve Ears	CSP-V-3&4	pipe-axial	15743	19538	26880 (PSI)
Ear Bolts	CSP-V-3&4	pipe-normal	15777	18382	66000 (PSI)
Drive Rod	CSP-V-4	rod-normal	8543	33019	86400 (PSI)
Ear Bolts	CSP-V-6	pipe-normal	57543	58884	66000 (PSI)

B. MAX. CRITICAL DEFLECTION

<0.01"

LOCATION

Valve disk radial deflection

MAXIMUM ALLOWABLE DEFLECTION TO ASSURE FUNCTIONAL OPERABILITY

approx 1/8" radial clearance

*Final response accelerations from piping analysis were used.

Qualification Summary of Equipment (Continued)

#QID 361106

VIII. REFERENCES

1. BIF Drawings:

D-207110-H, D-207110-G, (Valve Data Sheets)

A-206767, 18", 24" & 30" Butterfly Valve - General

C-26096, "Certified Dimension for Model A-83-B Cylinder"

2. WPPSS Unit 2 Drawings:

CSP-807-81.08

Containment Purge Air Supply

CSP-809-1.2

Suppression Pool Vacuum Breaker

CEP-625-3.4

From Reactor Nozzle X-67 to SGT-Fu-1A, 1B

CEP-625-1.2

From Reactor Nozzle X-67 to SGT-Fu-1A, 1B

D.220-0310

Support and Erection Isometric-IR64
(Johnson Controls)

3. BIF Report TR-27234 and TR-27235, "Dynamic Torque Calculation of Butterfly Valve; Sizes 24 and 30 inch", dated November 10, 1982.

4. Report #TR-74-7 by McPherson Assoc., Inc., "Design & Seismic Analysis 24" Cylinder operated Butterfly Valve." (Rev. 1) 1/5/76.

5. WPPSS letter to Cygna Energy Services, GE-02-RWH-018, 12/17/82.

REFERENCES CONTINUED ON PAGE 2.6

Completed By	<i>J E RAKOWSKI</i>	Date	<i>3/24/83</i>
Reviewed By	<i>A. C. Seane</i>	Date	<i>5/12/83</i>

CONFIDENTIAL
1952
SECRET
CONFIDENTIAL

CONFIDENTIAL
SECRET

SECRET

SECRET

SECRET

SECRET

SECRET

SECRET
SECRET

SECRET
SECRET

SECRET
SECRET
SECRET



Calculation Sheet

Project	Washington Public Power Supply System	Prepared By: <i>J.F.</i>	Date	5/27/83	
Subject	Equipment Seismic/Hydrodynamic Requal.	Checked By: <i>L.C.F.</i>	Date	5/27/83	
System	CSP & CEP	Job No.	82044	File No.	OT.01.F
Analysis No	QID 361106	Rev. No.	2	Sheet No.	2.6

SECTION 4.4

REFERENCES (CONTINUED):

6. Cygna Energy Services Communications Report, R. Ricappito, BIF Valve, and J. Rakowski, CES, "BIF Valve Dimensions", 2/11/83.
7. Cygna Energy Services, Project Manual Design Criteria, DC-1, Rev. 1, November, 1982.
8. Cygna Energy Services, Equipment Qualification Walkdown Verification Forms, Revision 1, dated 1/5/83.
9. WPPSS, WNP-2, Safety Related Mechanical Equipment List Summary Sheets, dated 2/10/83.
10. "AISC Manual of Steel Construction", American Institute of Steel Construction, 8th Edition, 1980.
11. Preliminary Transfer of Final Burns & Roe Piping Loads for CSP-V-1,2,3,4,5,6 and CEP-V-3A&4A, received 4/13/83.
12. Cygna Energy Services, "Equipment Seismic and Hydrodynamic Requalification of 30" Cylinder Operated Butterfly Valves for CSP-V-1, & 2, and CEP-V-1A, & 2A," File No. OS.01.F, QID No. 361104, Revision 1, June, 1983.
13. Cygna Energy Services, "Equipment Seismic and Hydrodynamic Requalification for 8", 10" and 12" Bore Air Cylinder Operators," File No. 1P.01.F, QID No. 018001, Revision 0, May, 1983.
14. USNRC, "Standard Review Plan, NUREG-0800"
15. Cygna Energy Services, "Equipment Seismic and Hydrodynamic Requalification of 24" Cylinder Operated Butterfly Valves for CSP-V-3,4,5,6, & 9 and CEP-V-3A & 4A," File No. OT.01.F, QID No. 361106, Revision 3, June, 1983.



Calculation Sheet

Project	APPS - EQUIPMENT QUALIFICATION	Prepared By:	JACK	Date	6/29/83
Subject	22' BUTTERFLY VALVES	Checked By:	M. J. ...	Date	5/19/83
System	WATER	Job No.	52064	File No.	12015
Analysis No.	661106	Rev. No.	2	Sheet No.	2.7

M. J. ... 6/3/83
 J. J. ... 6/9/83

SUMMARY TABLE 1.1

22' VALVE REQUIRED S-LEVELS
 (EQUIPMENT QUALIFICATION)

LINE	TYPE	FN	EL. REQ.	ACCELERATIONS (G's)			EQUIPMENT CLASSIFICATION	⚠
				X	Y	Z		
CSA-V-3	Y	FIC	40'	1.73	1.73	0.96	A	
CSA-V-4	Y	FIC	470	2.16	2.17	1.2	A	
CSA-V-5	Y	FIC	512'	2.96	2.44	1.22	A	
CSA-V-6	Y	FIC	460	2.33	2.33	1.05	A	
CSA-V-9	Y	FIC	470	3.57	2.73	2.67	A	**
CEA-V-3A	Y	FIC	470	4.27	1.26	0.96	A	
CEA-V-4A	Y	FIC	470	1.34	1.34	0.69	A	

LINE	EMERGENCY			UPSET		
	X	Y	Z	X	Y	Z
CSA-V-3	2.48	2.69	0.62	1.73	1.60	0.96
CSA-V-4	2.35	2.27	1.71	1.14	1.40	1.50
CSA-V-5	2.80	2.60	2.32	0.97	1.40	1.71
CSA-V-6	11.37	2.18	2.33	2.69	2.09	1.22
CEA-V-3A	4.54	0.61	0.76	1.20	0.76	0.51
CEA-V-4A	0.66	0.23	0.73	1.03	1.29	0.21

NOTE: THESE ACCELERATIONS ARE BASED ON THE TRANSMITTAL (STRUCTURE TO ARISTRONG) OF LATEST EDITION OF THE HANDBOOK AND THE SECTION 5.5, INCORPORATING SLP MODEL NUMBER B, THE HANDBOOK. ** CSA-V-9, HOWEVER, AND PREVIOUS ACCELERATIONS ARE STILL APPLICABLE.



TABLE OF CONTENTS

QID# 361106

<u>SECTION</u>	<u>TITLE</u>	<u>NO OF PAGES</u>
1.0	Requalification Certificate	1
2.0	SQRT Forms	7
3.0	Table of Contents	-
4.0	Requalification Analysis	-
4.1	Conclusions	1
4.2	Summary of Results	4
4.3	Analysis	-
4.3.1	Introduction	2
4.3.2	Calculations	66 +Appendices
4.4	References	1
5.0	Appendices	-
5.1	Response Spectra	2
5.2	Walkdown Sheets	21
5.3	Valve Local Coordinate Systems	4
5.4	SRM Sheets	7
5.5	Final Pipe-Mounted Equipment Response G-levels	8
6.0	Drawings	9

Revision 3



TABLE OF CONTENTS
CON'T

QID# 361106

<u>SECTION</u>	<u>TITLE</u>	<u>NO OF PAGES</u>
7.0	Transmittals, Prior Calculations and Reports	-
7.1	Communication Reports & Correspondence	37
7.2	Old Requalification & SQRT Forms	8
7.3	BIF Report	98
7.4	McPherson Associates Analysis	75

NO COPY
(copy)

SECTION 4.0

REQUALIFICATION ANALYSIS

THE UNITED STATES OF AMERICA

DEPARTMENT OF JUSTICE

FEDERAL BUREAU OF INVESTIGATION

WASHINGTON, D. C. 20535

REPORT OF INVESTIGATION

IDENTIFICATION OF SUBJECTS

1. NAME

2. ALIAS

IDENTIFICATION OF SUBJECTS

IDENTIFICATION OF SUBJECTS

IDENTIFICATION OF SUBJECTS

IDENTIFICATION OF SUBJECTS

IDENTIFICATION OF SUBJECTS

IDENTIFICATION OF SUBJECTS

IDENTIFICATION OF SUBJECTS



Calculation Cover Sheet

Project	Equipment Seismic & Hydrodynamic Requalification	Job No.	82044
Client	Washington Public Power Supply System	File No.	OT.01/F
Subject	Seismic Qualification of 24" Cylinder Operated Butterfly Valves QID 361106, EPN #CSP-V-3,4,5,6 & 9, and CEP-V-3A & 4A	Calc. Set No.	1
		No. of Sheets	66

Statement of Problem

The equipment qualification was performed based on calculations using valve and operator response g-levels transmitted by the A/E, (Final piping loads dated 3/31/83).

Sources of Data


See sheets 4.3.65 and 4.3.66

Sources of Formulae & References

See sheets 4.3.65 and 4.3.66

Remarks

None

Originators	Checkers	Distribution	Revision No.
J. Rakowski	D. Searle	WPPSS-2 Project File-1	3
M. Kuntz	L. Kaner		Supersedes Calculation Set No. Revision 2
M. Scott	LC Fernandez		Approved By:  Date: 6/9/83



Calculation Sheet

Project	Prepared By:	Date
Subject	Checked By:	Date
System	Job No.	File No.
Analysis No.	Rev. No.	Sheet No.

CONTENTS

	Calculation Cover Sheet
4.1	Conclusions
4.2	Summary of Results
4.3	Analysis
4.3.1	Introduction
4.3.2	Calculations
4.4	References



Calculation Sheet

Project	Prepared By:	Date
Subject	Checked By:	Date
System	Job No.	File No.
Analysis No.	Rev. No.	Sheet No.

SECTION 4.1

CONCLUSIONS



Calculation Sheet

Project	WPPSS Equipment Seismic Hydrodynamic Regualification	Prepared By:	<i>[Signature]</i>	Date	6/9/83
Subject	BIF Valves/Miller Operators	Checked By:	<i>LC Fernandez</i>	Date	6/9/83
System	CEP & CSP	Job No.	82044	File No.	1T.01.F
Analysis No.	361106	Rev. No.	3	Sheet No.	4.1.1

CONCLUSIONS

Seven 24-inch BIF Butterfly valves with Miller Air Products cylinder operators have been analyzed for structural integrity and operability for the plant specific seismic and hydrodynamic piping loads transmitted from Burns and Roe. These piping loads are in the form of air operator response G-levels (Section 5.5, dated March 31, 1983).

The valves will be qualified after incorporating the following modifications:

- 1) Remove the existing operator bracket attachment bolts (A-307) and replace with an A-325 or A-490 bolt.
- 2) Reinforce the operator support ears with the addition of shear plates as shown on page 4.3-48 or 4.3-54 of 361106, Rev. 3 (this report).



Calculation Sheet

Project		Prepared By:	Date
Subject		Checked By:	Date
System		Job No.	File No.
Analysis No.	Rev. No.	Sheet No.	

SECTION 4.2

SUMMARY OF RESULTS



Calculation Sheet

Project	WPPSS MECHANICAL EQ	Prepared By:	<i>J. S. D. Chowdhury</i>	Date	3/20/83
Subject	24" Butterfly Valves	Checked By:	<i>A. E. Shank</i>	Date	3/30/83
System	CSP & CEP	Job No.	82044	File No.	OT.01.F
Analysis No.	361106	Rev. No.	2	Sheet No.	361106-4.2-1

SUMMARY OF RESULTS

Parametric data for the seven subject valves in this report is given in Table 1.1. Results of the requalification analyses, which include a comparison of calculated stresses to the allowables are given in Table 1.2. Allowable stresses for the various material types are given in Table 1.3.



Calculation Sheet

Project	IPSS - EQUIPMENT QUALIFICATION	Prepared By:	V.A.L.	Date	6/10/83
Subject	24" BUTTERFLY VALVE	Checked By:	M. J. [Signature]	Date	5/19/83
System	23P-2CF	Job No.	43024	File No.	P.O.I.F
Analysis No.	3611A's	Rev. No.	2	Sheet No.	3611A-4.2-2

M. J. [Signature] 6/3/83
 J.C. [Signature] 6/9/83

SUMMARY TABLE 1.1


24" VALVE REQUIRED G-LEVELS (LIMITED CONDITION)

EQUIP. ID	SIDEN	FN	EL. PEAR.	ACCELERATIONS (G'S)			EQUIPMENT CLASSIFICATION
				X	Y	Z	
23P-1-3	Y	FIC	40'	1.12	3.73	3.76	A
23P-1-4	Y	FIC	470'	2.16	3.17	4.17	A
23P-1-5	Y	FIO	475'	2.96	3.44	5.22	A
23P-1-6	Y	FIO	420'	1.37	3.33	5.05	A
23P-1-9	Y	FIO	470'	2.57	1.73	2.67	A ***
23P-1-3A	Y	FIC	475'	4.57	1.26	0.97	A
23P-1-4A	Y	FIC	475'	2.35	1.34	0.89	A

	EMERGENCY			UPSET		
	X	Y	Z	X	Y	Z
23P-1-3	2.48	2.09	3.62	1.75	1.60	0.96
23P-1-4	2.30	1.77	1.71	1.14	1.40	1.50
23P-1-5	2.30	2.69	5.32	0.97	1.40	1.71
23P-1-6	11.37	3.18	5.83	2.69	2.09	1.43
23P-1-9	4.54	0.81	0.74	1.20	0.74	0.51
23P-1-4A	2.66	0.73	0.73	1.05	0.59	0.51

NOTE: THESE ARE LIMITED CONDITION VALUES FOR TRANSMITS (CONNECTED TO AIR STRONG) OF UPSET BURST PIPE FROMS (EQUIPMENT) ONLY. FOR UPSET BURST PIPE FROMS (EQUIPMENT) ONLY.

*** 23P-1-7, LIMITED AND PROJECTS ACCORDING TO THE ABOVE STILL APPLICABLE.



Calculation Sheet

Project: WPPSS EQUIPMENT SERIAL
 Subject: 24" LIFE RESTRICTED VALVE
 System: CSP 1 CEP
 Analysis No.: 361106
 Rev. No.: 3
 Job No.: 82041
 File No.: 12.01E
 Prepared By: [Signature]
 Checked By: J.N. [Signature]
 Date: 6/9/83
 Date: 6/14/83
 Sheet No.: 361106-4.2-3

SUMMARY TABLE 1.2 FAULTED CONDITION
 (STRESS IN PSI)

MEMBER	MATERIAL TYPE	TYPE	VALVE EPN'S						MATERIAL ALLOWABLE
			CSP-V-3	CSP-V-4*	CSP-V-5	CSP-V-6	CSP-V-3A	CSP-V-4A	
TRUITION PINS	SA-276	S			4108 MAX				11840
TAPERED PINS	SA-276	S			8710 MAX				11840
DRIVE LEVER	A-395	T			10420 MAX				43200
LEVER KEYWAY	A-395	T			27381 MAX				43200
MAIN SHAFT	SA-479	S			9127 MAX				14500
DRIVE ROD	A140	T	31629	23019	40634	33433	7462	7462	26400
EAR BOLTS	A-325**	T	16845	18392	20348	58354	23525	18018	66000
		S	14670	15475	19482	17564	4533	6136	26250
SILVERITE WELD	EG0	S	---	---	10437	---	---	---	28800
VALVE EAR WELD	EG0	S	---	---	8050	---	---	---	28800

FATIGUE RESULTS - STRESS RANGE IN PSI

								ALLOWABLE STRESS RANGE
TAPER PINS	SA276	S***						90000
DRIVE ROD	A140	T	63258	66038	81268	66866		90000
TRUITION PINS	SA-276	S***			16432 MAX			90000
SILVERITE WELD	EG0				20354			22500
VALVE EAR WELD	EG0				16100			22500

* EPN-CSP-V-7 ENVELOPED BY CSP-V-4 BY WIDE MARGIN
 ** AS INSTALLED BOLTS ARE CURRENTLY A-320 - REQUIRE CHANGING TO A-325
 *** FATIGUE EVALUATED ON A TENSILE LOAD REQUIRES INTO A TENSILE STRESS RANGE
 AS FOLLOWS: $T_{MAX} - 2T_{MIN}$ SR = $2T_{MAX} - 4T_{MIN}$



Calculation Sheet

Project	WPPSS EQ	Prepared By:	<i>J. E. Robinson</i>	Date:	3/25/83
Subject	24" Butterfly Valves	Checked By:	<i>A. E. Shank</i>	Date:	3/30/83
System	CSP & CEP	Job No.	82044	File No.	OT.01/F
Analysis No.	361106	Rev. No.	2	Sheet No.	361106-4.2-4

3 *W. E. O'Neil* 6/9/83
J. C. Fernandez 6/9/83

SUMMARY TABLE 1.3 ALLOWABLE STRESSES

Since operability is required, the stresses for the faulted condition will be kept below yield*. The table below is based on AISC criteria and the yield stresses at temperature (340°F) from PG. 9 of REF. 4 for conservatism.

MATERIAL	YIELD STRESS (PSI)	LEVEL A & B		LEVEL D	
		.6 Fy	.4 Fy	1.6 x .6 Fy = 0.96 Fy	1.6 x .4 Fy = 0.64 Fy
		BENDING ALLOW.	SHEAR ALLOW.	BENDING ALLOW.	SHEAR ALLOW.
AISI - 4140 HEAT TREATED	90,000	54,000	36,000	86,400	57,600
SA-276, GR 304	18,500	11,100	7,400	17,760	11,840
ASTM A-395-60-45-15	45,000	27,000	18,000	43,200	28,800
SA-307	23,300	13,980	9,320	22,370	14,900
AISI - 1018 (MIN YIELD)	35,000	21,000	14,000	33,600	22,400
SA-193, GR 33, 304SS	31,000	18,600	12,400	29,760	19,840
SA-479, 304SS	22,650	13,590	9,060	21,744	14,500
SA-516, GR 60	28,000	16,800	11,200	26,880	17,920

**

** 1.6 FACTOR REFERENCE DESIGN CRITERIA DC-1, REF 14.
 * BRACKET BOLT ALLOWABLES TAKEN FROM AISC, STEEL ED., SEC. 1.5.2.2.

SECTION 4.3

ANALYSIS



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: <i>J. E. Reda</i>	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: <i>V. J. Smith</i>	Date 5/23/83
System CSP & CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-1

EQUIPMENT REQUALIFICATION FOR QID 36110 BIF 24" CYLINDER OPERATOR BUTTERFLY VALVES

4.3.1 Introduction

The seven valves in this file are classified according to the parametric data given in Summary Table 1.1.

Since hydrodynamic loads apply in certain cases, fatigue analyses were provided for components with the highest stress ranges.

The calculated stresses are based on valve and operator G-levels calculated from the piping analysis and received from Burns & Roe. Since these loads were initially too high to qualify all EPN's the response G-levels were subsequently recalculated with some of the conservatism removed from the piping analysis. In addition, an SRSS analysis was set up in a computer program for each valve EPN in its specific orientation in the piping system (see Section 5.4). Each computer program (Appendix A) is compiled and hence not subject to subsequent change unless recompiled (and documented).

The method calculates stress from the north, vertical, and east component of operator response g-levels. The SRSS is taken at the stress level and operating loads due to seating torque force and dead weight are later combined by an absolute sum. Valve ear bending stress components due to any one response g-level component are combined by an absolute sum.



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: J. E. Ralowski	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: C. J. ...	Date 3.30.83
System CSP & CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106 - 4.3-2

The computer analysis addresses only the more highly stressed components in the valve operator assembly. Separate analysis is given for the remaining components using a simpler approach with upper bound loads. This applies to all valve operator EPN's in QID 361106 (24" Valve/8" cylinders) and QID 361104 (30" valves/10" operators). Hand calculations which check selected portions of computer output are shown in Appendix C.

Appendix B of this section describes the air operator mass/stiffness model which was incorporated in the final piping analysis for calculation of operator response g-levels. The computer program includes an option for using the valve ear forces and moments which are directly output from the piping analysis with the valve/operator model included. This was not finally utilized, however, to qualify the subject equipment.

The equipment locations and elevations were taken from the P&ID's in section 6.0. Natural frequency calculations are given for the air operator assemblies in Section 4.3.2.1.

Preliminary analyses were performed which showed that, for operator response g-levels greater than approximately 3 g's, the air cylinder spring preload force would be exceeded and hence some disk flutter would occur when the valve is in the open position. The calculation in section 4.3.2.2 shows that the magnitude of the valve disk flutter vibration angle due to upper bound g-levels which occur in the hydrodynamic frequency range is approximately 6 degrees. This flutter was evaluated to have no detrimental effect on system safety function as noted in Reference 5.

Valve operability was addressed in the following manner. For the valves with Use Code 2, operability after the event can be assured by demonstrating that faulted condition stresses remain below elastic limits (see Summary of Results).




Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: J. S. [Signature]	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: [Signature]	Date 1-10-83
System CSP and CEP	Job No. 82044	File No. OT 01/E
Analysis No. 361106	Rev. No. 2	Sheet No. 361106 4.3-3

For valves CSP-V-3 and 4, which must operate from open to fail closed during an event, the following additional evaluations were made:

- 1) Dynamic flow torques were assessed per Ref. 3 and found to be less than the seating torque which controlled the equipment stresses. Furthermore these flow torques tend to move the valve disk toward the fail-closed position, as noted in the above report.
- 2) The details of BIF drawing 206 767, parts of which are shown in figures 1.1 and 1.2, allow the following conclusions to be made for valve operability:
 - A) Figure 1.1 shows that thrust bearings are part of the shaft bearing design. This design prevents lateral movement of the disk in the direction of the shaft to eliminate interference with the valve body when closing. Further, it is noted on Page 26 of Ref. 3 that frictional torques in the shaft bearing system are negligible.
 - B) Figures 1.1 and 1.2 show a circular valve cross section having an internal rim within which the valve seats in the closed position. The only mechanism remaining to affect valve closing which can be postulated is out-of-round distortion of the section due to DBE piping loads and dynamic loads on the valve.


These loads were accounted for in Ref. 4 in the overall valve sizing calculations, where analysis showed that the stress intensity in the 0.5 inch thick valve body remained below $1.2 S_m$, or approximately 0.8 of yield. Stress contribution from dynamic loads on the valve and operator were relatively small. Further, as shown in the figures:



Calculation Sheet

Project: *SPC-1000-101-101-01* Prepared By: *JE RACOWSKI* Date: *3/25/85*
Subject: *221-1000-101-101-01* Checked By: *Jim Wash* Date: *5.20/85*
System: *SPC AIR OGF* Job No.: *32244* File No.: *OTN1*
Analysis No.: *36106* Rev. No.: *2* Sheet No.: *361105-4343A*

FIGURE 1.1 BIF DRAWING 206767





Calculation Sheet

Project	PHSE-EDU-1011 QUA	Prepared By	JERAKOWSKI	Date	3/25/88
Subject	2nd FLOOR, JALIES	Checked By	J. J. J.	Date	3.30.88
System	CEILING	Job No.	82042	File No.	17.11.5
Analysis No.	36.11.6	Rev No.	2	Sheet No.	36.11.6-4.3-5




FIGURE 1.2 BIF DRAWING 206767, DETAIL A



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By J. E. D. [Signature]	Date 1/10/83
Subject 24" Butterfly Valves	Checked By A. E. [Signature]	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106 - 4.3 - 6

1. The valve seat forms a heavily reinforced section made up of the valve body, internal hub and external flanges (including the mating flange of the piping). Hence the stress levels in this section are much lower than in the valve body and hence no distortion of the section could occur to affect seating of the valve. Valve flange dimensions are given below. Note the relatively large internal radial clearance of 1/8 inch.
2. Stress analysis of the valve extended structures are given in this report. Air operator operability is addressed in QID 018001.

The design data used in the analyses are given in Summary Table 1.1 (pipe-orientations and elevations are taken from the appropriate P&ID's in Section 6.0). Other pertinent data is given below.

- 1) Spring preload per communication report in Section 7.0 of QID 018001 are:
$$\begin{aligned} \text{Fail Open Preload} &= 350\# \\ \text{Final} &= 1850\# \\ \text{Fail Closed Preload} &= 1500\# \\ \text{Final} &= 3000\# \end{aligned}$$
- 2) Cylinder C.G.'s shown on the following sketches represent data received from BIF in the communication report of Section 7.0 of QID 018001.
- 3) Closing torque values are taken from Ref. 3.
- 4) Valve component dimensions: (Ref. Feb. 10, 11/83 communication report - Section 7)/
Flange: width = 3.5", thickness = 1.78"
Radial Clearance Disk/Seat 1/8"






FIGURE 1.3 GEOMETRY OF THE VALVES
24" Cylinder Operated Butterfly Valves QID# 361106
Group II; Cylinder Operator Fail Close
(Valves: CSP-V-3, 4 & CEP-V-3A & 4A)
(Info. taken from Ref. (1) & (4))

Project	Supply System - EQ	Job No.	82044	Prepared By:	E.R. [Signature]	Date	3/25/83
Subject	24" Butterfly Valve	Checked By:	[Signature]	Date	3/20/83		
System	CSP & CEP	Rev. No.	1	File No.	OT.01/E		
Analysis No.	361106	Sheet No.	361106-43-7				



Calculation Sheet

Project Supply System - EQ
Subject 24" Butterfly Valve

Job No. 82044


Checked By: [Signature] File No. OT.01/F

Prepared By: [Signature] Date 3/25/82

System CSP & CEP
Analysis No. 361106

Rev. No. 1

Sheet No. 361106 - 438



SCALE: 1/10" = 1"

FIGURE 1.4 GEOMETRY OF THE VALVES
 24" Cylinder Operated Butterfly Valves QID# 361106
 Group I; Cylinder Operator Fail Open
 (Valves: CSP-V-5, 6, 9)
 (Info. taken from Ref. (1) & (4))



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By: J. E. Kolesinski	Date	1/10/83	
Subject	24" Butterfly Valves	Checked By: J. E. Smith	Date	3 30 83	
System	CSP and CEP	Job No.	82044	File No.	OT.01/F
Analysis No.	361106	Rev. No.	2	Sheet No.	361106-4.3-9

4.3.2 CALCULATIONS

4.3.2.1 NATURAL FREQUENCY CALCULATIONS

Perform natural frequency calculations for the following four operator configurations:

Group I - Fail Open

EPN's CSP-V-5 6, and 9

Case I Valve Open

Case II Valve Closed

Group II - Fail Closed

EPN's CSP-V- 3 and 4 and CEP-V-3A and 4A

Case I Valve Open

Case II Valve Closed




<h2 style="text-align: center;">Calculation Sheet</h2>		Prepared By:	Date
		Checked By:	Date
Project	Subject	Job No.	File No.
System	Analysis No.	Rev. No.	Sheet No.

Project: SUPPLY SYSTEM
 Subject: 24" BUTTERFLY VALVE
 System: CSP & CEP
 Analysis No.: 36" O.S. Rev. No.: 2
 Job No.: 32044
 File No.: OT.01/F
 Sheet No.: 361106-4.5-0

GROUP I CYLINDER OPERATOR "FAIL OPEN"

CALCULATE THE NATURAL FREQUENCY OF THE CYLINDER OPERATOR DUE TO THE BENDING STIFFNESS OF THE DRIVE ROD AND THE CYLINDER OPERATOR. THESE CALCULATIONS ASSUME THAT OPERATOR PISTON REMAINS SEATED AGAINST THE OPEN OR CLOSED POSITION STOP BY ACTION OF THE SPRING.

CASE I VALVE OPEN




$$I_1 = 0.46 \text{ in}^4$$

$$I_2 = \frac{\pi}{64} (8.45^4 - 7.97^4) = 52.2 \text{ in}^4$$

CALCULATION OF FA:

$$f_A = \frac{Pl^3}{3EI} = \frac{500 (10.96)^3}{3(29 \times 10^6)(52.2)} = 0.000145 \text{ IN}$$


WITH END B FIXED





<h2 style="text-align: center;">Calculation Sheet</h2>		Prepared By:	Date
		M. V. ...	11/9/32
Project <u>SUDOKU SYSTEM</u> Subject <u>24" BUTTERFLY VALVE</u>		Checked By:	Date
		L. ...	11/10/32
System	Job No.	File No.	
<u>CSP & CEP</u>	<u>32044</u>	<u>OT.01/F</u>	
Analysis No. <u>361106</u> Rev. No. <u>2</u>	Sheet No. <u>361106-43-11</u>		

ROTATION AT "B" DUE TO M_0 OF M/I DIAGRAM



$$M_0 = 500(10.96) = 5480 \text{ in}^{\#}$$


$$\frac{5480}{52.2} = 104.9$$

$$\frac{3630.5}{52.2} = 69.55$$

$$\frac{3630.5}{0.46} = 7892.4$$

$$W_1 = 7892.4 \left(\frac{26.5}{2} \right) = 104574.2$$

$$W_2 = \left(\frac{104.9 + 69.55}{2} \right) (13.5) = 1177.5$$



AREA 1

$$CG_{\text{AREA 1}} = \frac{1}{3}(26.5) = 8.83 \text{ IN}$$

AREA 2

RECTANGLE:

$$CG_R = \frac{1}{2}(13.5) = 6.75$$

$$A_R = (13.5)(69.6) = 939.6$$

TRIANGLE:

$$CG_T = \frac{2}{3}(13.5) = 9.0$$

$$A_T = \frac{1}{2}(13.5)(35.3) = 238.3$$

$$CG_{\text{AREA 2}} = \frac{(CG_{\text{RECT}})(A_{\text{RECT}}) + (CG_{\text{TRI}})(A_{\text{TRI}})}{(A_{\text{RECT}}) + (A_{\text{TRI}})}$$

$$= \frac{(6.75)(939.6) + (9)(238.3)}{939.6 + 238.3}$$

$$= 7.21 \text{ IN}$$

$$\therefore 13.5 - 7.21 = 6.3 \text{ IN}$$

$$R_B = 104574.2 \left(\frac{17.67}{40} \right) + 1177.5 \left(\frac{33.7}{40} \right) = 46195.7 + 99.21$$

$$= 47197.3$$

$$\theta_B = \frac{47197.3}{29 \times 10^6} = .00163 \text{ rad.}$$



<h1>Calculation Sheet</h1>		Prepared By:	Date
		Checked By:	Date
Project	Subject	Job No.	File No.
System	Analysis No.	Rev. No.	Sheet No.

Project: SUPPLY SYSTEM
 Subject: 24" BUTTERFLY VALVE
 System: CSP & CEP
 Analysis No.: EG1106 Rev. No.: I
 Job No.: 820-14 File No.: OT. 01/F
 Sheet No.: EG1106-4.3-12

DEFLECTION OF POINT A

$$\begin{aligned}
 \delta A' \text{ due to } \theta_B & \\
 &= .00163 (10.96) \\
 &= .0179
 \end{aligned}$$


$$\therefore \text{TOTAL } \delta A = .00045 + .0179 = .0181$$

$$K = \frac{500}{.0181} = 27700.8 \text{ \# / in}$$

$$f_n = \frac{1}{2\pi} \sqrt{\frac{27700.8 (386.4)^2}{399 \text{ \#}}} = 26.07 \text{ Hz.}$$

(DEAD WT. OF CYL. OPERATOR = 399 \#)

CASE II VALVE CLOSED







<h2 style="text-align: center;">Calculation Sheet</h2>		Prepared By:	Date:
		Y. K. ...	11/13
Project <u>SUPPLY SYSTEM</u> Subject <u>24" BUTTERFLY VALVE</u> System <u>CSP & CEP</u>		Checked By:	Date:
		L. ...	
Analysis No. <u>361106</u> Rev. No. <u>2</u>		Job No. <u>82044</u>	File No. <u>OT.01.F</u>
		Sheet No. <u>361106-43-13</u>	

CALCULATION OF f_n :

$$f_n = \frac{P L^3}{3EI} = \frac{500 \# (11.73^3)}{3(29 \times 10^6)(52.2)} = .000173$$



ROTATION AT "B" DUE TO M_o OF M/I DIAGRAM



$$M_o = 500(11.73) = 5865 \text{ in} \#$$


$$\frac{5865}{52.2} = 112.36$$

$$\frac{2698}{52.2} = 51.69$$

$$\frac{2698}{0.40} = 5865.22$$

$$W_1 = 5865.22 \left(\frac{11.5}{2} \right) = 33725$$

$$W_2 = \left(\frac{112.36 + 51.69}{2} \right) (13.5) = 1107.3$$



AREA 1
 $CG_{AREA1} = \frac{1}{3}(11.5) = 3.83 \text{ IN}$

AREA 2
 RECTANGLE:
 $CG_2 = \frac{1}{2}(13.5) = 6.75$
 $A_2 = (13.5)(51.7) = 697.95$
 TRIANGLE:
 $CG_1 = \frac{2}{3}(13.5) = 9.0$
 $A_1 = \frac{1}{2}(13.5)(112.4 - 51.7) = 400.73$
 $CG_{AREA2} = \frac{(CG_2)(A_2) - (CG_1)(A_1)}{A_2 - A_1}$
 $= \frac{(6.75)(697.95) - (9)(400.73)}{697.95 - 400.73}$
 $= 7.58 \text{ IN}$
 $13.5 - 7.58 = 5.92 \text{ IN}$



Calculation Sheet		Prepared By:	Date
Project <u>SUPPLY SYSTEM</u>		<u>W. D. V.</u>	<u>5-2</u>
Subject <u>24" BUTTERFLY VALVE</u>		Checked By: <u>()</u>	Date
System <u>CSP & CEP</u>		Job No. <u>82044</u>	File No. <u>OT.0. =</u>
Analysis No. <u>36106</u> Rev. No. <u>2</u>		Sheet No. <u>36106-4.3-1</u>	

$$R_B = 33725 \left(\frac{7.67}{25} \right) + 1107.3 \left(\frac{19.1}{25} \right) = 10346.8 + 845.2$$
$$= 11191.99$$

$$\theta_B = \frac{11191.99}{29 \times 10^6} = .00039 \text{ rad}$$

DEFLECTION AT POINT "A"

$$\delta_A' \text{ due to } \theta_B$$
$$= .00039 (11.73)$$
$$= .0046$$

$$\text{TOTAL } \delta_A = .000178 + .0046 = .00478$$

$$K = \frac{500 \#}{.00478} = 104603 \# / \text{IN}$$

$$f_N = \frac{1}{2\pi} \sqrt{\frac{104603(386.4)}{399}} = 50.66 \text{ Hz}$$




<h2 style="text-align: center;">Calculation Sheet</h2>		Prepared By:	Date
		Checked By:	Date
Project	SUPPLY SYSTEM	Job No.	File No.
Subject	24" BUTTERFLY VALVE	82044	OT.01/F
System	CSP & CEP	Sheet No.	
Analysis No.	361106 Rev. No. 2	361106-4.3-15	

GROUP II CYLINDER OPERATOR "FAIL CLOSE"

CALCULATE THE NATURAL FREQUENCY OF THE CYLINDER OPERATOR DUE TO THE BENDING STIFFNESS OF THE DRIVE ROD AND THE CYLINDER OPERATOR.

CASE I VALVE OPEN




$$I_1 = .46 \text{ IN}^4$$

$$I_2 = \frac{\pi}{64} (3.45^4 - 7.97^4) = 52.2 \text{ IN}^4$$

CALCULATION OF f_N :

$$\delta_A = \frac{PQ^3}{3EI} = \frac{500 \# (10.24)^3}{3(29)(10)^6 (52.2)} = .000118 \text{ IN}$$


WITH END 'B' FIXED.





<h1 style="text-align: center;">Calculation Sheet</h1>		Prepared By:	M. Kundu	Date	11/11/32
		Checked By:	L. Kumar	Date	1.1/32
Project	SUPPLY SYSTEM		Job No.	82044	
Subject	24" DIAPHRAGM VALVE		File No.	OT.01/F	
System	CSP & DEP		Sheet No.	361106 - 4.3-16	
Analysis No.	361106	Rev. No.	2		

ROTATION AT "B" DUE TO M_0 OF M/E DIAGRAM



$$M_0 = 500(10.24) = 5120 \text{ in} \cdot \#$$


$$\frac{5120}{52.2} = 98.1$$

$$\frac{3392}{52.2} = 64.98$$

$$\frac{3392}{.46} = 7373.9$$

$$W_1 = (7373.9) \left(\frac{26.5}{2} \right) = 97704.35$$

$$W_2 = \left(\frac{98.1 + 64.98}{2} \right) (13.5) = 1100.8$$



AREA 1
 $CG_{\text{AREA 1}} = \frac{1}{3}(26.5) = 8.83 \text{ in}$

AREA 2

RECTANGLE:
 $CG_R = \frac{1}{2}(13.5) = 6.75$
 $A_R = (13.5)(65) = 877.5$

TRIANGLE:
 $CG_T = \frac{2}{3}(13.5) = 9.0$
 $A_T = \frac{1}{2}(13.5)(98 - 65) = 222.75$

$$CG_{\text{AREA 2}} = \frac{(CG_R)(A_R) + (CG_T)(A_T)}{A_R + A_T}$$

$$= \frac{(6.75)(877.5) + (9)(222.75)}{877.5 + 222.75}$$

$$= 7.21 \text{ in}$$

$$R_B = 97704.35 \left(\frac{17.67}{40} \right) + 1100.8 \left(\frac{33.7}{40} \right) = 43160.2 + 927.42 = 44088.32$$

$$\theta_B = \frac{44088.32}{29 \times 10^{10}} = .00152 \text{ rad}$$



Calculation Sheet		Prepared By:	Date
Project <u>SUPPLY SYSTEM</u>		<u>-M. V. ...</u>	<u>11/32</u>
Subject <u>H BUTTERFLY VALVE</u>		Checked By: <u>C</u>	Date
System <u>OSP & CEF</u>		Job No. <u>32044</u>	File No. <u>OT.01/F</u>
Analysis No. <u>361106</u> Rev. No. <u>2</u>		Sheet No. <u>361106-4.3-17</u>	


DEFLECTION OF POINT A

$$\begin{aligned} \delta_{A'} \text{ due to } \theta_B &= .00152 (10.24) \\ &= .0156 \\ \therefore \text{TOTAL } \delta_{A'} &= .000119 + .0156 = .0157 \\ k &= \frac{500}{.0157} = 31810.7 \frac{\#}{\text{IN}} \end{aligned}$$

$$F_N = \frac{1}{2\pi} \sqrt{\frac{31810.7(399\#)}{399\#}} = 27.93 \text{ Hz}$$

(DEAD WEIGHT OF CYL. OPERATOR = 399#)

CASE II VALVE CLOSED






<h2 style="text-align: center;">Calculation Sheet</h2>		Prepared By:	Date
		Checked By:	Date
Project	Subject	Job No.	File No.
System	Analysis No.	Rev. No.	Sheet No.


Project: SUPPLY SYSTEM
 Subject: 24" BUTTERFLY VALVE
 System: CSP & CEP
 Analysis No.: 361106 Rev. No.: 2
 Job No.: 32044 File No.: 07.01/F
 Sheet No.: 361106-43-13

CALCULATION OF f_n :

$$f_{OA} = \frac{Pl^3}{3EI} = \frac{500^3 (14.46^3)}{3(29 \times 10^6)(52.2)} = .000032$$



ROTATION AT "B" DUE TO M_0 OF M/I DIAGRAM



$$M_0 = 500(14.46) = 7230$$


$$\frac{7230}{52.2} = 138.51$$

$$\frac{3325.8}{52.2} = 63.71$$

$$\frac{3325.8}{0.46} = 7230$$

$$W_1 = 7230 \left(\frac{11.5}{2} \right) = 41572.5$$

$$W_2 = \left(\frac{138.51 + 63.71}{2} \right) (13.5) = 1364.99$$



AREA 1
 $CG_{AREA 1} = \frac{1}{3}(11.5) = 3.83$ IN

AREA 2
 RECTANGLE:
 $CG_R = \frac{1}{2}(13.5) = 6.75$
 $A_R = (13.5)(63.71) = 860.09$
 TRIANGLE:
 $CG_T = \frac{2}{3}(13.5) = 9.0$
 $A_T = \frac{1}{2}(13.5)(138.51 - 63.71) = 504.9$
 $CG_{AREA 2} = \frac{(CG_R)(A_R) + (CG_T)(A_T)}{A_R + A_T}$
 $= \frac{(6.75)(860.09) + (9.0)(504.9)}{860.09 + 504.9}$
 $= 7.58$ IN
 $\therefore 13.5 - 7.58 = 5.92$



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By: <i>E. Subramanian</i>	Date	1/10/83	
Subject	24" Butterfly Valves	Checked By: <i>W. C. Seale</i>	Date	3/30/83	
System	CSP and CEP	Job No.	82044	File No.	OT.01/F
Analysis No.	361106	Rev. No.	2	Sheet No.	361106 - 4.3 - 19

$$R_B = 41572.5 \left(\frac{7.67}{25} \right) + 1364.99 \left(\frac{19.1}{25} \right) = 12754.44 + 1042.85 = 13797.29$$

$$\theta_B = \frac{13797.29}{29 \times 10^6} = .000476 \text{ rad}$$

Deflection at Point "A"

$$\begin{aligned} \delta A' \text{ due to } \theta_B &= .000476 (14.46) \\ &= .0069 \end{aligned}$$

$$\text{Total } \delta A = .0069 + .000032 = .0069$$

$$k = \frac{500\#}{.0069} = 72306.99\#/\text{IN}$$

$$f_n = \frac{1}{2\pi} \sqrt{\frac{(72307)(386.4)}{399}} = 42.12 \text{ Hz}$$

CALCULATION OF f_n PARALLEL TO THE DRIVE END
AND TRUNNION PINS :

(CONTINUED)



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By E. P. ...	Date 3/25/83
Subject 24" Butterfly Valves	Checked By H. ...	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev No. 2	Sheet No. 361106-4.3-20

CALCULATION OF f_n PARALLEL TO THE DRIVE ROD AND TRUNNION PINS:

APP. B
PG. 2/13

BRACKET STIFFNESS IS: (CANTILEVER BEAM OF EFFECTIVE I_{zz})

$$K = \frac{P}{\delta} = \frac{3EI}{l^3} = \frac{3 \times 2.9(10) \times 2.16}{(28.5)^3} \quad \begin{matrix} (2.16 \text{ IN}^4 \text{ FOR } 8" \text{ CYL}) \\ (4.22 \text{ IN}^4 \text{ FOR } 10" \text{ CYL}) \end{matrix}$$

$$= .00081 \times 10^{-7} = 8100 \text{ lb/in}$$

$$M = \frac{(\bar{w}_{AO} + \bar{w}_{BR})}{g} = \frac{(399 + 277)}{384.6} = 1.76 \frac{\text{lb} \cdot \text{sec}^2}{\text{in}}$$

$$f = \frac{1}{2\pi} \sqrt{\frac{K}{M}} = \frac{1}{6.28} \sqrt{\frac{8100}{1.76}} = \underline{10.81} \text{ Hz}$$

B) PARALLEL TO DRIVE ROD

APP. E, PG 2/13 | SAME MASS, STIFFNESS = EAR ENDING STIFFNESS
EAR STIFFNESS = $K_{yy} = 48 \times 10^6 \text{ lb/in (10")}$, $= 7.5(10) \frac{\text{lb}}{\text{in}} (8")$

$$f_n |_{10"} = \frac{10^3}{2\pi} \sqrt{\frac{48}{2.38}} = 715 \text{ Hz}$$

$$f_n |_{8"} = \frac{10^3}{2\pi} \sqrt{\frac{7.5}{1.76}} = 328 \text{ Hz}$$




Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: E. R. Rowshni	Date 3/25/83
Subject 24" Butterfly Valves	Checked By: J. E. Seank	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4-3-21

4.3.2.2 APPROXIMATE VALVE FLUTTER MAGNITUDE

USING DIMENSIONS FROM FIGURE 1.3 :



CONSERVATIVELY ASSUME THAT THE MAX ACCELERATION COMPONENT OUTPUT FROM THE PIPING ANALYSIS FOR CSP-V-5 (OPEN / FAIL-OPEN) PRODUCES DISPLACEMENTS OF THE AIR OPERATOR RELATIVE TO THE PIPE IN THE FORM OF

$$d_{\max} = \frac{A}{\omega_n^2} \quad \text{WHERE } A = 9.35 g^2 \times 386.4 \text{ "/s}^2 \text{ (TABLE 1.1)}$$

FROM THE SPECTRA IN SECTION 5.1, FOR HYDRODYNAMIC LOADS:

$$\omega_n |_{\min} = 2\pi (15 \text{ Hz}) \text{ (R/S)}$$

$$\theta_1 = \tan^{-1} \frac{d}{11.0} = \tan^{-1} \left(\frac{19.35 \times 386.4}{11.0 (94.2)^2} \right) = \left(\frac{.41}{11} \right) = \tan^{-1} (.04)$$

$$\theta_1 = 2.13^\circ$$

$$\therefore \theta_2 \sim 3 * \theta_1 \sim 6^\circ \quad (\text{SMALL})$$



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification		Prepared By E. Polonski	Date 1/10/83
Subject 24" Butterfly Valves		Checked By A. Shank	Date 3/30/83
System CSP and CEP		Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-22	

4.3.2.3 STRESS ANALYSIS

The procedures for the analysis of the subject valves are outlined below:

1. Recalculate the valve appurtenance stresses addressed in Ref. 4 using response g-levels from the final piping analysis. Incorporate the current seating torque given in Ref. 3. Compare stresses to the appropriate percentage(s) of yield strength as indicated in Summary Table 1.3.
2. Perform a fatigue analysis on significantly stressed components. Determine allowable alternating stress ranges from AISC 8th Edition, Appendix B, noting commentary.

The fatigue analysis is to be performed only for those EPN's subject to hydrodynamic loads. The number of respective load cycles is given below.

LOAD COMBINATIONS & STRESS CYCLES

The following table lists the load combinations and the number of expected stress cycles for each combination. (From the design criteria)

<u>Combination</u>	<u>Cycles</u>
1. SRV Alone	13500-200=13300 cycles
2. OBE+SRV	50
3. SRV+AP+CHUG	140
4. SSE+SRV+AP+CHUG	10

Note: Load combination #4 with 150 cycles can be used to conservatively bound combinations 3 and 4.



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: <i>R. [Signature]</i>	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: <i>[Signature]</i>	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-23

STRESS ANALYSIS OF VALVE AND AIR OPERATOR COMPONENTS NOT COVERED IN QID .018001

1) TRUNNION PINS

TRUNNION PINS WERE ANALYZED AND THE SHEAR STRESS WAS FOUND TO BE PRIMARILY DEPENDENT ON OVERTURNING IN THE 3-AXIS DIRECTION. WHEN ANALYZED WITH AN ACCELERATION IN THIS DIRECTION OF 13.9 g's, THE SHEAR STRESS WAS ONLY 35 PERCENT OF THE ALLOWABLE. THEREFORE THE PINS ARE SUFFICIENT FOR ALL EPN'S.

THIS CALCULATION FOLLOWS:
(CEP-V-3A)

$$L_{ROD} = 25 \text{ (CLOSED)} \quad L_{CG} = 14.46 \text{ "}$$

	8"	10"
L _{CG}	14.46	21.50
X	12.75	13.38
A _{TP}	2.41 IN	2.41 IN

$$M_1 = \bar{W}_{AO} g_3 L_{CG} = (399 \times 13.9 \times 14.46) = 80,139 \text{ IN} \#$$

$$F_{23} = \frac{M_1}{X} = \frac{80139}{12.75} = 6285 \#$$

$$F_{11} = \frac{(L_{ROD} + L_{CG})}{L_{ROD}} \frac{\bar{W}_{AO} g_1}{Z} = \frac{39.46}{25 \times 2} (399 \times 1.04) = 327 \#$$

$$F_{22} = \frac{\bar{W}_{AO} g_2}{Z} = \frac{399(1.66)}{2} = 332 \#$$

$$F_{ST2} = \frac{1201 \#}{2} = 601 \# \quad \left. \begin{array}{l} \\ \\ \end{array} \right\} \text{FIXED}$$

$$F_{WEIGHT(2)} = \frac{399}{2} = 200 \#$$

$$F_{ST2} = \frac{\text{SEAT TRGNE} \times \cos 11.32^\circ}{11.75 \text{ "}}$$

FOR 8" = $\frac{13808 \text{ "}}{11.75} \times .86 = 1150$

FOR 10" = $\frac{22,174 \text{ "}}{11.75} \times .86 = 1647$

SEE EPIRIT'S CALCULATION SHEET

CONSERVATIVE COMBINATION

$$\gamma = \frac{1}{.75(2.41)} \left\{ \left[(F_{23} + F_{22})^2 + F_{11}^2 \right]^{\frac{1}{2}} + F_{FIXED} \right\} = 4108 \text{ PSI} < 11,840 \text{ PSI (3K)}$$



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: <i>J. E. [unclear]</i>	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: <i>A. [unclear]</i>	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-24

CLEVIS

4, 32

THE TOTAL LOAD ON THE CLEVIS IS THE VECTOR SUM OF $F_C \rightarrow$ AND $F_{ST} \downarrow$.

$$F_{CLEVIS} = \left[F_C^2 + F_{STZ}^2 \right]^{\frac{1}{2}}$$

ASSUME UPPER LIMIT OF $g_1 = 15g$ 'S JUST FOR THIS MEMBER, $F_{STZ} = 1847 \#$, $W_{A0} = 539 \# (10")$, $L_{CG} = 21.5"$

4, 33

$$F_{CLEVIS} = \left[1847^2 + 6953^2 \right]^{\frac{1}{2}} = 7194 \#$$

$$\sigma_{CLEVIS} = 7194 \# / 2.44" = 2949 \text{ PSI} < 28,800 \text{ (OK)}$$

CLEVIS PIN


$$\tau = 7194 \# / 3.53 \text{ IN}^2 * \frac{4}{3} = 2717 \text{ PSI} < 11,840 \text{ (OK)}$$

4, 32

\therefore CLEVIS & PIN ARE GOOD FOR ALL 8" & 10" A/O EPN'S.

DRIVE LEVER

IMPOSE THE SEATING TORQUE LOAD AND DYNAMIC REACTION FORCE ON THE DRIVE LEVER IN THEIR RESPECTIVE DIRECTIONS:



REF. Pg 35

LOAD F_C WILL INCREASE THE AXIAL FORCE IN THE DRIVE LEVER, HOWEVER, THE MAXIMUM TORQUE ON THE LEVER IS THE SEATING TORQUE. THE AIR OPERATOR TRUNNIONS AND INTERNAL SPRING HOLD THE VALVE STABLE IN THE CLOSED POSITION.



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By J. J. [Signature]	Date 1/10/83
Subject 24" Butterfly Valves	Checked By D. [Signature]	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-25

MAX NORMAL FORCE ON DRIVE LEVER:

$$F_{ST} \cos \theta + F_C \sin \theta = 2529 \text{ LB (ENVELOPE)}$$

$$1847 \times .99 + 6953 \times .10 =$$

MAX AXIAL FORCE ON DRIVE LEVER:

$$F_{ST} \sin \theta + F_C \cos \theta = 7068 \text{ LB (ENVELOPE)}$$

$$1847 \times .10 + 6953 \times .99 =$$

REF 4, Pg. 34

MINIMUM DRIVE LEVER AREA = 1.875 in²
CONSIDERING FAILURE MODES.

AXIAL STRESS:

MAX BENDING MOMENT = 13,808 IN-LB (CONSERVATIVE FOR
USE ON MIN. AREA OUT NEAR CLEVIS PIN)

$$\sigma_{AXIAL} = \frac{Mc}{I} + \frac{F_{AX}}{A}$$

REF 4, Pg. 35

$$\sigma_{AXIAL} = 13,808 \times \frac{1.44}{2.99} + \frac{7068}{1.875} = 10,420 \text{ PSI}$$

$$10,420 < 43,200 \text{ PSI OK}$$

SHEAR STRESS:

$$\tau = \frac{2524}{1.875} = 1346 \text{ PSI} < 28,800 \text{ PSI OK}$$

DRIVE LEVER
SUFFICIENT
ON BOTH
8" & 10"
A/O'S.



Calculation Sheet

Project: WPPSS Mechanical Equipment Qualification
Subject: 24" Butterfly Valves
System: CSP and CEP
Analysis No.: 361106
Rev. No.: 2
Prepared By: E. P. S. [Signature] Date: 1/10/83
Checked By: [Signature] Date: 3/30/83
Job No.: 82044 File No.: OT.01/F
Sheet No.: 361106 - 4.3 - 26

KEY WAY BEARING STRESS - DUE TO SEATING TORQUE

REF 4, PG 36

$$A_B = 0.448 \text{ IN}^2$$

$$M = 13,800 \text{ IN-LB}$$

$$\frac{D_{MIN}}{2} = 1.125 \text{ IN}$$

$$F_{BRG} = \frac{M \times 2}{D_{MIN}} = 12,267 \text{ LB}$$

$$\sigma_{BRG} = \frac{F_{BRG}}{A_B} = 27,381 \text{ PSI}$$

27,381 < 43,200 PSI	OK	MARGIN = 58%
---------------------	----	--------------

REF 4, PG 37

$$\text{SHEAR AREA OF KEY} = 1.33 \text{ IN}^2$$

THEREFORE - BEARING STRESS CONTROLS.

MAIN SHAFT:

PRELIMINARY ANALYSIS SHOWS THIS IS NOT A HIGHLY STRESSED COMPONENT, \therefore ANALYZE FOR ENVELOPE LOADS.

$$\begin{aligned} \text{STRESS} = & \text{STRESS DUE TO SEATING TORQUE} + \\ & \text{STRESS DUE TO SHEAR OF } F_{ST2} + \\ & \text{STRESS DUE TO BENDING OF } F_{ST2}. \end{aligned}$$



Calculation Sheet

Project: WPPSS Mechanical Equipment Qualification
 Subject: 24" Butterfly Valves
 System: CSP and CEP
 Analysis No.: 361106
 Rev. No.: 2
 Prepared By: [Signature] Date: 1/10/83
 Checked By: [Signature] Date: 3/30/83
 Job No.: 82044 File No.: OT.01/F
 Sheet No.: 361106-4.3-27

	8"	10"
r	1.1248"	1.25"
$J = 2I$	2.514 in ⁴	3.83 in ⁴
l_5	6.005"	6.32"
l_6	10.31"	11.18"
I_s	1.257	1.916
T_s	13808 in ⁴	22174 in ⁴

REF 4, PG 49

$$\textcircled{1} \tau_T = \frac{T r}{J} = \frac{22174 (1.25)}{3.83} = 7237 \text{ PSI}$$

$$\textcircled{2} \tau_{AVE} = \frac{F_{COMB.}}{A} \quad \text{FROM FIG. ON PAGE 0, § PS. P}$$

$$F_{COMB.} = [2524^2 + 7068^2]^{\frac{1}{2}} = 7505 \text{ LB}$$

$$\tau_{AVE} = \frac{7505}{3.97} = 1890 \text{ PSI}$$

$$\textcircled{3} M = \frac{1847 (6.32)(11.18)}{16.315 = (l_6 + l_5)} = 7999 \text{ IN-LB}$$

$$\sigma = \frac{M c}{I} = \frac{7999 (1.1248)}{1.257} = 7158 \text{ PSI}$$

CONSERVATIVELY ADDING SHEAR STRESSES

$\tau = 7237 + 1890 = 9127 \text{ PSI} < 14,500 \text{ OK}$
$\sigma = 7158 \text{ PSI} < 21744 \text{ OK}$

RESULT GOOD FOR BOTH 24" & 30" VALVES



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By E. R. Robinson	Date 1/10/83
Subject 24" Butterfly Valves	Checked By D. E. Clark	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/E
Analysis No. 361106	Rev. No. 2	Sheet No. 361106 - 4.3-28

Disc

The stresses in the disc were shown on page 51 of Ref. 4 to be due almost entirely to the pressure load. Since the stress found in Ref. 4 of 3871 PSI will not change significantly for the new accelerations, the disc is acceptable.

Taper Pins

The stress in these pins is due only to the seating torque. The stress in Ref. 4, page 53, is 10,753 PSI and is therefore acceptable. For the new, lower seating torque, the stress becomes 8710 PSI.

Analysis for: Drive Rod, cylinder bushing pressure, valve ears and valve ear bolts.

Method I: Use element forces and moments output from the piping analysis (Summary Table 1.1) and the absolute sum of stresses. The conservatism of SRSS summing of the component stresses cannot be assured because the independence of the six element forces (/moments) cannot be determined without analysis of modal participation.



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By E. Rudowski	Date 1/10/83
Subject 24" Butterfly Valves	Checked By W. Shank	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106 - 4.3-29

Method II: Use the north, east and vertical operator accelerations output from the piping analysis. Absolute sum for stresses with each component then SRSS over results for N,E and V.

Note 1: Analysis of the distribution of stress on 4 valve ears to predict the maximum tensile stress cannot confirm a maximum value lower than the absolute sum of the elemental tensile stresses due to the six forces (from one acceleration direction, N,E or V). Therefore the absolute sum will be used at this level.

Note 2: Add stress due to the vector sum of deadweight plus seating torque force after above SRSS combinations are performed. (ABS)


Note 3: 10" A/O parameters are shown for use in QID 361104.

Analysis of Seating Torque Forces

1) Seating Torque loads control the stress in the valve lever arm, keyway, shaft and taper pins. These stresses were less than allowables for the valves of seating torque given in Ref. 3, for all valves.

2) For valve EPN's which are Fail-Open with Use-Code 2, no seating torque forces are applied during the faulted and upset conditions (CSP-V-5,6).

3) For the Fail-Closed valves, the forces at the trunnion pins are shown below, along the cylinder axis, for +2-axis g-loading:





Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By E. D. [Signature]	Date 1/10/83
Subject 24" Butterfly Valves	Checked By A. E. [Signature]	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. .361106	Rev. No. 2	Sheet No. 361106-4.3-30

As the bracket deflects in +2, under dynamic loads, the seating torque force is relieved. The extent of relief depends on the relative stiffness of the bracket and valve ears relative to the valve seat. Since the steel brackets and ears are very stiff in this direction, little relief can be expected. Hence seating torque forces will be added as an ABS sum to the valve ears. However, seating torque force will oppose operator weight when the brackets hangs downward from horizontal pipes.

Operator Drive Rod

Drive rod dynamic stress is due only to g_1 because g_3 and g_2 forces are taken out by trunnion pins. Add seating torque stresses.

$$F_c = \frac{L_{CG} \bar{W} g_1}{L_{ROD}}$$


TWO POINTS ARE CRITICAL, PT A AT THE BUSHING AND PT B AT THE REDUCED THREAD DIAMETER

$$M_A = F_c (L_{ROD} - 13.5")$$

$$\sigma_A = \frac{M_A C_A}{I_A}$$

$$M_B = 7.125 F_c$$

$$\sigma_B = \frac{M_B C_B}{I_B}$$



	8"	10"
IA	.4604 IN ⁴	
CA	.875 IN	same -
IB	.1383 IN	same
CB	.6478 IN	same
AB	1.405 IN	
AA	2.41 IN	2.41 IN



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: <u>E. D. [unclear]</u>	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: <u>A. E. [unclear]</u>	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT. 01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-31

FINALLY:

$$\left. \begin{aligned} (A)_{OPERATING} &= \frac{F_{STZ}}{A_A} + \frac{MAC}{I_A} \Bigg) DW \\ (B)_{OPERATING} &= \frac{F_{STZ}}{A_B} + \frac{MBC}{I_B} \Bigg) DW \end{aligned} \right\} \text{ADD AS ABS SUM AFTER SRSS OF DYNAMIC COMPONENTS}$$

SEISMIC / DYNAMIC FORCES ON VALVE EARS


A SAP-TYPE MASS / STIFFNESS MODEL WAS PREPARED FOR THE PIPING MODEL TO CALCULATE A/O RESPONSE G-LEVELS (SEE ATTACHMENT). THE VALVE-EAR SYSTEM BENDING AND TORSIONAL FLEXIBILITY WAS INCLUDED IN THE MODEL AND SRSS FORCES AND MOMENTS WILL ALSO BE OUTPUT FOR CONVERSION INTO VALVE EAR STRESSES. THE EQUATIONS ARE:

Tension due to M_1 & T_3 :
(SEE LOCAL COORD. DEF'N - NEXT PG)

$$2Pd_1 = M_1$$

$$\sigma_{M_1} = \frac{P}{A} = \frac{M_1}{2d_1 A}$$

	8"	10"
l_2	2.5"	3"
l_1	1.5	1.75
d_1	7.5"	9.5"
d_2	10.0"	10.5"




① $\sigma_{T_3} = \frac{P}{4A} = \frac{T_3}{4l_1 l_2}$
(Tension due to T_3)
+ WHEN $T_3 = +$

② $\sigma_{T_3 \text{ tension due to } M_1} = \frac{M_1}{2d_2 l_1 l_2}$

TOP IN TENSION (+) WHEN M_1 IS +

SAP-MODEL:
(SEE ATTCHMNT)
(APPENDIX B)






Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By <i>E. Polanski</i>	Date 1/10/83
Subject 24" Butterfly Valves	Checked By <i>A. E. Seale</i>	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-32 0

COORDINATE SYSTEM (LOCAL)






Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By E. Robinson	Date 1/10/83
Subject 24" Butterfly Valves	Checked By W. E. Sore	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-33

FORCES DUE TO TORQUE



F_R & F_C CONSTRAIN EAR DEFLECTION TO BE TANGENT TO CIRCLE.

F_C IS DETERMINED FROM TORQUE DUE TO $\frac{d_1}{d_2} * W_{A/B}$ ETC.

OPERATOR STIFFNESS MODEL, APPENDIX B, DETERMINES THAT

$$\begin{aligned}
 F_R &= 0.531 F_C \text{ for } 8" \text{ A/O} \\
 &= 0.488 F_C \text{ for } 10" \text{ A/O}
 \end{aligned}$$

$$F_C = \frac{\sum M_{SUPPORT}}{2D}$$

$$D = \frac{1}{2} [d_1^2 + d_2^2]^{\frac{1}{2}}$$

	8"	10"
d_1	7.5"	9.5"
d_2	10.0	10.5"



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: <i>E. P. [unclear]</i>	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: <i>A. Z. [unclear]</i>	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-34

TENSILE STRESS DUE TO M_2 :

$$Z P d_1 = M_2, \quad \sigma_{M_2} = \frac{P}{A} = \frac{M_2}{Z d_1 A} = \frac{M_2}{Z d_1 d_1 d_2}$$

③

$$\sigma_{M_2 \text{ tension}} = \frac{M_2}{Z d_1 d_1 d_2}$$

(I.E. LEFT EAR'S TENSION (+) WHEN $M_2 = +$)

Bending due to S_1, S_2 & T_3 :

Shear due to T_3 :

$$F_c = \frac{T_3}{2D}$$

$$D = \text{bolt-circle dia} = \left[(d_1) + (d_2) \right] \frac{1}{2}$$

From derivation of stiffeners model: (SEE APPENDIX B)

$$F_R = X F_c$$

$$X = .531 \text{ for } 9" A_0 \\ = .488 \text{ for } 10" A_0$$

Net force in 1-direction per ear: (any ear)
Due to T_3 only:

$$F_{II} = -(F_c \sin \phi - F_R \cos \phi)$$

$$\phi_{7"} = 53^\circ \\ \phi_{10"} = 48^\circ$$

$$= -(F_c \sin \phi - X F_c \cos \phi)$$

$$F_{II} = -F_c (\sin \phi - X \cos \phi)$$

F_{II}	$\left\{ \begin{array}{l} = -F_c * A \bar{x}_{7"} \\ = -F_c * A \bar{x}_{10"} \end{array} \right.$
----------	--

8"
10"

$$\Delta \bar{x}_{7"} = +.47 \\ \Delta \bar{x}_{10"} = +.42$$



Calculation Sheet

Project: WPPSS Mechanical Equipment Qualification
 Subject: 24" Butterfly Valves
 System: CSP and CEP
 Analysis No.: 361106

Prepared By: E.R. Doushi
 Checked By: D.E. Liarke
 Job No.: 82044
 Rev. No.: 2

Date: 1/10/83
 Date: 3/30/83
 File No.: OT.01/F
 Sheet No.: 361106-4.3-35

△ modification 4/9/83 J.C. Germany 6/9/83

SHEAR FORCE DUE TO τ_3 ON EACH EAR IN THE Z-AXIS DIRECTION.

$$F_{2z} = \begin{cases} (F_c \cos \phi + F_R \sin \phi) \\ \dots (F_c \cos \phi + x F_c \sin \phi) \end{cases}$$

$$F_{2z} = F_c (\cos \phi + x \sin \phi) = A F_y \times F_c$$

$$F_{2z} \begin{cases} (A F_y)_{8"} = 1.03 \\ (A F_y)_{10"} = 1.03 \end{cases} \text{ } \left. \begin{array}{l} \text{SAME } \phi \text{-fn for } 8" \text{ to } 10" \end{array} \right\}$$

F_{11} & F_{2z} ARE SHEAR FORCES DUE TO τ_3 IN THE X AND Z-AXIS DIRECTIONS RESPECTIVELY. S_1 & S_2 ARE SIMILAR SHEAR FORCES OUTPUT FROM THE FINAL PIPING ANALYSIS USING THE MODEL IN APPENDIX B.

FOR THE FOLLOWING BENDING EQ, SEE \rightarrow ROARK, PG. 96, #1b ($w=0$)

BENDING MOMENT AT EITHER END OF THE EAR (SEE REF. FOR GEOMETRY)

$$M = \frac{-W l^2}{2l} = -\frac{W l}{2}$$

NOTE: SEE PAGE 4.3-53 OF RECORDING 2

BENDING STRESS AT EAR-CORNER:

$$\sigma_B \text{ due to } F_{11} + \sigma_B \text{ due to } F_{2z} = \tau_B \text{ DUE TO } \tau_3$$

$$\textcircled{4} \tau_{B \text{ due to } \tau_3} = \left[\left(\frac{F_{11}}{Z} \right) \frac{C_1}{I_x} \right] + \left[\left(\frac{F_{2z}}{Z} \right) \frac{C_2}{I_y} \right]$$

	8"	10"
have =	7.125	4.95
C_1 =	.75	.53
C_2 =	1.25	1.50
	(max)	



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: J. E. Robowski	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: W. E. Shank	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-36

and:

Bending due to S_1 & S_2 :

$$\textcircled{5} \quad \tau_{Bs1} = \frac{S_1 C_1}{4 I_2} \frac{\text{Load}}{z = 8I_2}$$

$$\textcircled{6} \quad \tau_{Bs2} = \frac{S_2 C_2}{4 I_1} \frac{\text{Load}}{z = 8I_1}$$

	8"	10"
$I_1 = \frac{1}{12} b h^3 = \frac{1}{12} l_1 l_2^3 = \frac{1.5^3 \cdot 2.5^3}{12} = 1.95 \text{ IN}^4$		$\frac{1.75^3}{12} = 3.94 \text{ IN}^4$
$I_2 = \frac{1}{12} b h^3 = \frac{1}{12} l_2 l_1^3 = \frac{2.5^3 \cdot 1.5^3}{12} = 0.70 \text{ IN}^4$		$\frac{3}{12} \cdot 1.75^3 = 1.34 \text{ IN}^4$

EAR TENSILE STRESS IS THE ABSOLUTE SUM OF THE ABOVE EXPRESSIONS $\textcircled{1} \rightarrow \textcircled{6}$. [USE 10" A/G PARAMETERS FOR QID361106]

SHEAR STRESS ON EARS

$$\tau = \frac{P}{A}$$

DUE TO $S_1 + F_{11}$ \rightarrow $= \frac{S_1}{4 l_1 l_2} + \frac{F_{11}}{l_1 l_2} = \tau_{11}$

AND

DUE TO $S_2 + F_{22}$ \downarrow $= \tau_{22}$

$$\sum \tau = \frac{S_2}{4 l_1 l_2} + \frac{F_{22}}{l_1 l_2} \downarrow = \tau_{22}$$

EAR SHEAR STRESS RESULTANT = $[\tau_{11}^2 + \tau_{22}^2]^{1/2}$ (VECTOR SUM)



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: () E. D. ...	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: D. E. ...	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-43-37

BOLTS HOLDING BRACKETS TO EARS:

BOLT TENSION IS DUE TO M_1, M_2, T_3
 BOLT SHEAR IS DUE TO S_1, S_2, T_3

	8"	10"
$A_B = \frac{\pi D^2}{4}$	0.31 IN ²	.43 IN ²
D	.6273"	.7387"

TENSION (ABS SUM)

$$\tau_{T_3} = \frac{T_3}{A_B}$$

$$(\tau_T)_{M_1} = \frac{M_1}{2d_z AB}$$

$$(\tau_T)_{M_2} = \frac{M_2}{2d_z AB}$$

Shear:

$$\frac{F_{11}/\text{bolt}}{F_{22}/\text{bolt}} = \frac{F_c * A_{F_x}}{F_c * A_{F_y}} \quad \left\{ \text{PREVIOUS PAGES} \right.$$

$$\tau_1 = \frac{F_{11}}{A_B} = \frac{F_c * A_{F_x}}{A_B} \quad \rightarrow \quad \textcircled{1}$$

$$\tau_2 = \frac{F_{22}}{A_B} = \frac{F_c * A_{F_y}}{A_B} \quad \downarrow \quad \textcircled{2}$$

Similarly: $\tau_{S_1} = \frac{S_1}{4AB} \quad \rightarrow \quad \textcircled{3}$

$$\tau_{S_2} = \frac{S_2}{4AB} \quad \downarrow \quad \textcircled{4}$$

COMBINE IN SAME MANNER AS ON PREVIOUS PAGE FOR EARS BUT SUBSTITUTE A_E FOR A_B



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: <i>E. Robinson</i>	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: <i>D. E. Mark</i>	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-38

METHOD II - THE PREVIOUS EQUATIONS FOR STRESS BY METHOD I ARE APPLICABLE. HOWEVER,

- 1) EXPRESSIONS FOR THE SIX FORCES/MOMENTS ARE DERIVED BELOW IN TERMS OF g -level COMPONENTS IN THE LOCAL AXIS SYSTEM (SUBSEQUENTLY DIRECTION COSINES WILL BE USED TO CONVERT THE $N, E \& V$ ACCELERATION VECTORS, IN TURN, INTO LOCAL AXES). (SEE SECTION 5.4)
- 2) THESE EQUATIONS ARE TO BE USED TO FIND THE FORCES AND MOMENTS ON THE EARS DUE TO THE DEADWEIGHT AND SEATING TORQUE FORCES, FOR CALCULATION OF OPERATING STRESSES, FOR USE IN EITHER METHOD 1 $\&$ 2.

SEE FORCES $\&$ BRACKET ORIENTATION IN LOCAL COORDINATES, NEXT PAGE.

1: T_3 = TORSION ABOUT LOCAL AXIS # 3

$$T_3 = \sum M_{SHAFT} (\oplus) = F_{TR1} e_3 + F_{BR1} e_4 + F_{A02} e_2 + F_{BR2} e_1$$

$$= F_{TR1} e_3 + \bar{W}_{BR} g_1 e_4 + \bar{W}_{A0} g_2 e_2 + \bar{W}_{BR} g_2 e_1$$

$T_3 = (\oplus)$	$= F_{TR1} e_3 + \bar{W}_{BR} g_1 e_4 + g_2 (\bar{W}_{A0} e_2 + \bar{W}_{BR} e_1)$
$T_3 \text{ FIXED} = (\oplus)$	$= W_{ATR1} e_3 + (W_{A02} + F_{ATR2}) e_2 + W_{PR1} e_4 + W_{PR2} e_1$



Calculation Sheet



Project WPPSS Mechanical Equipment Qualification	Prepared By: <i>E. Dolynski</i>	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: <i>H. E. Seale</i>	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT 01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-39

FORCES ON SUPPORT EARS DUE TO LOCAL-AXIS ACCELERATIONS g_1, g_2, g_3

FORCES IN THE LOCAL COORDINATE SYSTEM:

ELEVEN FORCES ACT IN THE LOCAL 1,2,3 A/O AXIS SYSTEM:

- | | | |
|---------------------------------|---|--|
| D
Y
N
A
M
I
C | { | $F_{A02,3} = \bar{W}_{A0} * g_{2,3}$ |
| | | $F_{TR1} = 1$ -AXIS COMPONENT OF DYNAMIC FORCE AT TRUNNION |
| | | $F_{BR1,2,3} = 1,2,3$ -AXIS COMPONENTS OF BRACKET INERTIA = $\bar{W}_{BR} * g_{1,2,3}$ |
| S
T
A
T
I
C | { | $W_{ATR1} =$ FORCE AT TRUNNION IN 1-AXIS <u>DUE TO A/O WEIGHT</u> |
| | | $W_{A02,3} =$ WEIGHT OF A/O IN AXES 1,2,3 |
| | | $W_{BR1,2,3} =$ WEIGHT OF BRACKET IN THE 1,2,3-AXIS DIRECTIONS |
| | | $F_{ST2} =$ SEATING TORQUE FORCE, IS ALWAYS ALONG 2-AXIS. |






Calculation Sheet

Project: WPPSS Mechanical Equipment Qualification
 Subject: 24" Butterfly Valves
 System: CSP and CEP
 Analysis No.: 361106
 Rev. No.: 2
 Prepared By: E. P. [Signature]
 Checked By: G. E. [Signature]
 Job No.: 82044
 Sheet No.: 361106-4.3-40
 Date: 1/10/83
 Date: 3/30/83
 File No.: OT.01/F

FORCE ORIENTATIONS ON EARS: IF $+T_3$




$$\begin{aligned}
 S_1 &= F_{TRI} + F_{BR1} = F_{TRI} + \bar{W}_{BR} g_1 \\
 S_{FIXED} &= \bar{W}_{BR1} + \bar{W}_{ATR1}
 \end{aligned}$$

FROM A FORCE BALANCE OF THE OPERATOR:

$$F_{TRI} = \frac{(L_{ROD} + L_{CG}) \times \bar{W}_{AO} \times g_1}{L_{ROD}} \quad (+ \text{FORCE ON BRKT})$$

$$\bar{W}_{ATR1} = \frac{(L_{ROD} + L_{CG}) \bar{W}_{AO}}{L_{ROD}}$$

	8"		10"	
	OPEN	CLOSED	OPEN	CLOSED
L _{ROD}	40"	25"	40"	25"
L _{CG}	10.96"	14.46"	16.25"	21.5"






Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: E. Polowski	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: A.E. Searle	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-41

$$S_2 = F_{A02} + F_{BR2} = (\bar{w}_{A0} + \bar{w}_{BR}) g_2 \quad \uparrow$$

$$S_{2 \text{ FIXED}} = w_{BR2} + w_{A02} + F_{ST2} \quad \uparrow$$




FOR OUT OF PLANE BENDING:

$$M_1 = \ominus = -F_{A02} e_5 - F_{BR2} e_5 - F_{A03} (e_3 + e_6) - F_{BR3} e_4$$

$$M_1 = -(\bar{w}_{A0} + \bar{w}_{BR}) g_2 e_5 - \bar{w}_{A0} g_3 (e_3 + e_6) - \bar{w}_{BR} g_3 e_4$$

$$M_{1 \text{ FIXED}} = (w_{A02} + w_{BR2} + F_{ST2}) e_5 - w_{A03} (e_3 + e_6) - w_{BR3} e_4$$




+ = TOP ENDS
IN TENSION

$$M_2 = \curvearrowright = +F_{TR1} e_5 + F_{BR1} e_5 - F_{A03} e_2 - F_{BR3} e_1$$

$$M_2 = +(F_{TR1} + \bar{w}_{BR} g_1) e_5 - (\bar{w}_{A0} e_2 + \bar{w}_{BR} e_1) g_3$$

$$M_{2 \text{ FIXED}} = +(w_{ATR1} + w_{BR1}) e_5 - w_{A03} e_2 - w_{BR3} e_1$$



+ = LEFT ENDS
IN TENSION

$$T_3 = \uparrow \downarrow = (\bar{w}_{A0} + \bar{w}_{BR}) g_3 \quad \uparrow \text{3AXIS}$$

$$T_{3 \text{ FIXED}} = w_{A03} + w_{BR3}$$

$T_3, M_1, M_2, S_1, S_2, S_3, T_3$ COMPLETE



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: <i>[Signature]</i>	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: <i>[Signature]</i>	Date 3/22/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-42

4.3.4 Upset Condition Stresses

The cylinder drive rod and valve ears were separately analyzed for upset condition loads for the EPN's and associated response g-levels noted below. All other component faulted stresses are less than the upset allowables except for taper pins and keyway bearing stress. No additional analysis was performed for these components because the stress is controlled by the seating torque only. The allowable stress for the bracket bolts also holds for upset conditions per the AISC manual, 8th Edition. Bolt fatigue is considered as presented in Section 4.3.5.

Upset g-levels (per revised B&R piping analysis, Sec. 5.5)

<u>EPN</u>	<u>N</u>	<u>V</u>	<u>E</u>
CSP-V-3	1.73	1.60	0.96
CSP-V-4	1.14	1.40	1.50
CSP-V-5	0.97	1.40	1.71
CSP-V-6	1.64	1.44	0.59

Component stresses are given in Table 1.2.



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By: E. P. Dowd	Date	1/10/83	
Subject	24" Butterfly Valves	Checked By: A. E. Seale	Date	3/30/83	
System	CSP and CEP	Job No.	82044	File No.	OT.01/F
Analysis No.	361106	Rev. No.	2	Sheet No.	361106 - 4.3-43

Section 4.3.5 - Fatigue Analysis

Discussion

The operator and bracket assembly are not part of the pressure boundary, therefore, the fatigue analysis will be performed in accordance with Appendix B of the AISC Manual for Steel Construction. The following assumptions apply to the fatigue analysis.

- 1) Faulted stresses (based on piping-analysis accelerations) will be used. This is necessary to insure operability after a design basis event.
- 2) The actual stresses used will be the ones calculated in Section 4.3.
- 3) If the alternating portion of the stress has been calculated separately only this part will be used. If the operating loads (i.e. seating torque effects) are already included in the stress analysis it will be conservative to use the calculated stress value. As long as no failures occur, the operating stress does not need to be extracted.
- 4) The allowable stress will be based on Table B3 of Appendix B in the AISC Manual of Steel Construction.
- 5) A factor of 1.5 will be applied to the allowable because of the low number of cycles. (Per Section 1.7 of the Commentary on the AISC Manual).
- 6) The actual stress range is taken as 2 times the maximum stress for components subject to alternating tension and compression.



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	<i>E. P. ...</i>	Date	1/10/83
Subject	24" Butterfly Valves.	Checked By:	<i>J. A. ...</i>	Date	3/30/83
System	CSP and CEP	Job No.	82044	File No.	OT.01/F
Analysis No.	361106	Rev. No.	2	Sheet No.	361106-4.3-44

- 7) Bracket bolting is assumed to be properly tightened and will not be considered for fatigue per Section B3.1 of the AISC Manual.

The table on the following page gives the calculated stress range, stress category, and allowable for the critical components. The following page gives excerpts from Appendix B of the AISC Manual showing the descriptions of the relevant stress categories.



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: <i>E. D. Donohue</i>	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: <i>A. E. Seale</i>	Date 3/30/83
System CSP and CEP	Job No. 82044	File No. OT.01/F
Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-45

Fatigue Analysis (cont.)

ITEM	STRESS TYPE	STRESS (PSI)	STRESS RANGE (PSI)	STRESS CATEGORY	1.5 x ALLOW (FROM AISI)
TRUNNION PIN	T	4108	8216	F ⁽¹⁾	22500
DRIVE ROD (MAX)	T	- SEE TABLE 1.2 -		A	90000
SUPPORT EARS	T	- SEE TABLE 1.2 -		A	90000
MAIN SHAFT	T	9127	18,254	A	90000
	T	8064	16,128	A	90000

NOTES:

- (1) Assume shear stress on nominal area of a stud type shear connection.

Note that this comparison includes all of the load combinations in one conservative comparison using the maximum stress and the total number of cycles ($[3 \times 4478] + 60 = 13494$ cycles).



Calculation Sheet		Prepared By: <i>J.M. Fry</i>	Date 11/19/72
		Checked By: <i>L.K. ...</i>	Date 1/1/73
Project <i>...</i>	Subject <i>M.P. ...</i>	Job No. 36144	File No. OT.01/F
System <i>CEP CEP</i>	Analysis No. 361106	Rev. No. 2	Sheet No. 361106-4.3-46

FATIGUE ANALYSIS (CONT.)

THE TABLE BELOW HAS BEEN CONDENSED FROM APPENDIX B OF THE AISC MANUAL OF STEEL CONSTRUCTION. THE CASES USED ARE MARKED WITH AN ARROW.

General Condition	Situation	Kind of Stress ^a	Stress Category. (See Table B3)
Plain material	Base metal with rolled or cleaned surfaces.	T or Rev.	A
Built-up members	Base metal and weld metal in members, without attachments, built-up of plates or shapes connected by continuous full- or partial-penetration groove welds or continuous fillet welds parallel to the direction of applied stress.	T or Rev.	B
	Calculated flexural stress, f_b , in base metal at toe of welds on girder webs or flanges adjacent to welded transverse stiffeners.	T or Rev.	C
	Base metal at end of partial-length welded cover plates having square or tapered ends, with or without welds across the ends.	T or Rev.	E
Mechanically fastened connections	Base metal at gross section of high-strength-bolted friction-type connections, except connections subject to stress reversal and axially loaded joints which induce out-of-plane bending in connected material.	T or Rev.	B
	Base metal at net section of other mechanically fastened joints.	T or Rev.	D
	Base metal at net section of high-strength bolted bearing connections.	T or Rev.	B
Attachments	Shear stress on nominal area of stud-type shear connectors.	S	F

← (90,000)

← (22,500)



Calculation Sheet


Project	APES - EQUIPMENT OVERHAUL	Prepared By:	W. J. A. L.	Date	4.22.53
Subject	24" BUTTERFLY VALVE	Checked By:	M. J. C.	Date	5/16/53
System	CSP-DEF	Job No.	02044	File No.	17.01.F
Analysis No.	361106	Rev. No.	2	Sheet No.	361106 - 2 of 7

8" MILLER AIR CYLINDER
 WELD STRESS COMPUTATION - VALVE FLANGE, EAR CONNECTIONS

COMPILED PROGRAMS - APPENDIX A - SECTIONS 4
 WILL BE MODIFIED IN THE FOLLOWING MANNER

- 1) EAR PROPERTIES (3rd MOMENT, MOMENT OF INERTIA ETC) PREVIOUSLY HAVE BEEN LED IN THE DISTRIBUTION OF THE TOTAL LOAD ABOUT THE "EAR" GROUP, TO DETERMINE THE STRESSES DUE TO THIS LOADING (ABSOLUTE SUIT/WORST CASE) ON AN INDIVIDUAL EAR. THESE PROPERTIES WILL BE CHANGED TO REFLECT A WELD GROUP AS "EAR" CROSS SECTION.
- 2) PROGRAMS WILL BE REWORN YIELDING STRESSES ON AN INDIVIDUAL WELD GROUP ONLY.

REFERENCE: TELCON L. SEARLE (CES / R. RICCAPITO: CIF) 4128183
 (FIELD SEE)



31V ← TYP. ASSUME 45 DEG; $S_w = 0.01 - \frac{1}{2}$


REF: CLOSURE
 TYPICAL 1.25"

$l_2 = 1.25$
 $l_2 = 2.5$

$$I_{w_2} = .757(.31)(.25)(.25)(1.25) \left[\frac{1.25^2}{3} + \frac{1.25^2}{3} \right] = 1.60 \text{ in}^4$$


$$I_{w_1} = .757(.31)(.25)(.25)(1.25) \left[\frac{1.25^2}{3} + \frac{1.25^2}{3} \right] = 0.74 \text{ in}^4$$

TOTAL SHEAR AREA = $(2)(.25 + 1.25) .757(.31) = 1.77 \text{ in}^2$



Calculation Sheet

PROJECT: WPPSS-EQUIPMENT QUALIFICATION	PREPARED BY: Downs	DATE: 5/5/83
SUBJECT: BIF VALVES / MILLER OPERATORS	CHECKED BY: [Signature]	DATE: 5/16/83
SYSTEM: CEP / CSP	JOB NO: 82044	FILE NO: CT 01.F
AND V/S NO: 01D	REV. NO: 2	SHEET NO: 361106-4.3.48



PROPOSED
BRACKET EARS AND SHEAR PLATE ARRANGEMENT
1/2" PLATES TYP.




Calculation Sheet

Project	WPPSS EQUIPMENT QUALIFICATION	Prepared By:	<i>[Signature]</i>	Date	5/14/23
Subject	24" EIF BUTTERFLY VALVE/13" NELLE/OPK	Checked By:	<i>[Signature]</i>	Date	5/10/23
System	CEP / CSP	Job No.	82044	File No.	17.01.F
Analysis No.	361106	Rev. No.	Z	Sheet No.	361106 - 4.3 - 49

③ *[Signature]* 6/9/23
[Signature] 6/16/23

WEB PLATE DESIGN



THE WEB PLATE RESISTS ONLY THE SHEAR LOADS APPLIED TO THE TOP OF THE SUPPORT EAR CONFIGURATION. THE WORST CASE RESULTS FROM CEP-V-E WILL BE USED FOR DESIGN. THE MOMENTS ARE RESOLVED BY PURE AXIAL LOADS IN THE EAR, AS IS THE TENSILE LOAD. THE SHEAR AND TORSIONAL LOADS PRODUCE STRESSES IN THE WEB PLATE.



$$V_1 = 4772 \text{ lbf}$$

$$V_2 = 3021 \text{ lbf}$$

$$T = 10642 \text{ lbf-in}$$





Calculation Sheet

Project	WPPSS EQUIPMENT QUALIFICATION	Prepared By:	<i>[Signature]</i>	Date	5/15/03
Subject	24" BIF BUTTERFLY VALVE / W 9" MILLER OPER	Checked By:	<i>[Signature]</i>	Date	5/13/03
System	CEP / CSB	Job No.	82044	File No.	17.01. =
Analysis No.	361106	Rev. No.	2	Sheet No.	361106 4.3-50

[Signature] 6/9/03
[Signature] 5/13

FOR R ON 10" SIDE

$$V_{CL}(l_1) = \left[\frac{V_2}{4} + \left(\frac{7.5}{12.5} \right) \left(\frac{T}{2D} \right) \right] l_2$$

$$V_{CL} = \frac{\left[\frac{3021}{4} + \left(\frac{7.5}{12.5} \right) \left(\frac{106643}{2(12.5)} \right) \right] 7.125}{(10/2)}$$

$$= \frac{(755 + 2559) 7.125}{5}$$

$$= 1076 + 3647 = 4723$$

FOR R ON 7.5" SIDE

$$V_{CL}(l_1) = \left[\frac{V_1}{4} + \left(\frac{10}{12.5} \right) \left(\frac{T}{2D} \right) \right] l_2$$

$$V_{CL} = \frac{\left[\frac{4772}{4} + \left(\frac{10}{12.5} \right) \left(\frac{106643}{2(12.5)} \right) \right] 7.125}{(7.5/2)}$$

$$= \frac{(1193 + 3413) 7.125}{3.75}$$


$$= 2267 + 6485 = 8751$$



Calculation Sheet

Project	WPPSS EQUIPMENT QUALIFICATION	Prepared By:	<i>[Signature]</i>	Date	5/15/83
Subject	24" BIF BUTTERFLY VALVE / W9" MILLER OF	Checked By:	<i>[Signature]</i>	Date	5/17/83
System	CET / CSP	Job No.	8204d	File No.	IT-11.F
Analysis No.	361106	Rev. No.	2	Sheet No.	361106 4.3-51 3

THE RESULTING STRESS ON THE WELDMENT IS
A RESULT OF BOTH BENDING STRESS AND
DIRECT SHEAR:



FOR 10" SIDE

$$V_{cl} = 4723 \text{ LB}$$

$$t_1 = 2.5''$$

$$l_1 = 5''$$

$$M = V_{cl} \times l'$$
$$= 4723(3.75)$$

$$l' = 3.75''$$

$$= 17711 \text{ IN LB}$$

DETERMINE THE THE LOAD PER
UNIT LENGTH OF THE WELDMENT
ASSUMING A FILLET WELD ON
EACH SIDE OF THE PLATE.

$$l_w = 2(6'') = 12''$$

$$S_w = \frac{d^2}{3} = \frac{6^2}{3} = 12 \text{ IN}^2$$

$$f_v = \frac{4723 \#}{12 \text{ IN}} = 394 \text{ LB/IN}$$

$$f_b = \frac{17711 \#}{12 \text{ IN}^2} = 1476 \text{ LB/IN}$$

$$f_{tot} = \sqrt{394^2 + 1476^2} = 1528 \#/\text{IN}$$



Calculation Sheet

Project	WPPSS EQUIPMENT REQUALIFICATION	Prepared By:	[Signature]	Date	5/13/83
Subject	24" BIF BUTTERFLY VALVE / W 8"	Checked By:	MILLER [Signature]	Date	5/18/83
System	CEP / CSP	Job No.	02022	File No.	1T.01.F
Analysis No.	361106	Rev. No.	2	Sheet No.	361106-4.3-52 Δ

Δ 6/9/83 J. Germainy 6/11/83

FOR 7 1/2" SIDE

$$V_L = 8751 \quad \begin{matrix} t_1 = 1.5 \\ l_1 = 3.75" \\ l' = 3" \end{matrix}$$

$$M = V_L l' = 26254 \text{ IN LB}$$

THE RESULTING LOAD PER UNIT LENGTH IS THEN:

$$P_a = \frac{8751}{12 \text{ IN}} = 729 \text{ #/IN}$$

$$P_b = \frac{26254}{12 \text{ IN}^2} = 2188 \text{ #/IN}$$

$$P_t = \sqrt{729^2 + 2188^2} = 2306 \text{ #/IN}$$

TO REMAIN BELOW THE ALLOWABLE FATIGUE ALTERNATING STRESS ALLOWABLE OF $(1.5)(15 \text{ ksi}) = 22.5 \text{ ksi}$ THE WORKING STRESS SHOULD BE EQUAL TO OR LESS THAN HALF THAT VALUE

$$P_{\text{ALLOW}} = \frac{22.5}{2} = 11.25 \text{ ksi}$$

$\left(\frac{2306}{(.707)(11.25)} = 10257 \text{ ksi} \right)$ THE REQUIRED WELD LEG SIZE IS THEN

$$\frac{P_{\text{reqd}}}{(.707)(P_{\text{allow}})} = \frac{2306}{11.25(.707)} = .289 \text{ IN} \Rightarrow 5/16 \text{ } \Delta$$



Calculation Sheet

Project	WPPSS Equipment Qualification	Prepared By:	<i>[Signature]</i>	Date	5/3/83
Subject	24" BIF Butterfly Valves/w 8" Miller OP	Checked By:	<i>J. Fernandez</i>	Date	6/9/83
System	CEP & CSP	Job No.	82044	File No.	1T.01.F
Analysis No.	361106	Rev. No.	3	Sheet No.	361106-4.3-53

A REVIEW OF REVISION 2 OF THIS REPORT REVEALED THE MISSJUDGEMENT IN ASSUMING THE OPERATOR BRACKET SUPPORT EARS TO BE A FIXED CANTILEVER AS SHOWN ON PAGE 4.3-B5. THE EFFECT ON THE BALANCE OF THE REPORT IS AS FOLLOWS.


- 1) THE PREVIOUSLY CALCULATED STRESSES FOR THE SUPPORT EARS AND EYE WELDS WOULD BE 2 TIMES THOSE PREVIOUSLY CALCULATED. THIS NECESSITATES MODIFICATION OF THE SUPPORT EARS.
- 2) THE CALCULATED STIFFNESSES USED IN THE BIF PIPING ANALYSIS CAME FROM IN-SITU DEFLECTION TESTS. THIS WOULD REMAIN UNAFFECTED.

THE MODIFICATION OF THE EAR SUPPORT BRACKET WILL BE ON THE FOLLOWING PAGES. CSP-1-5 WILL BE EXAMINED BECAUSE OF THE HIGHEST EAR AND EAR WELD STRESSES. THE ADDITION OF A SHEAR PLATE ON THE SIDE OF THE EAR WILL NEARLY ELIMINATE ALL OF THE BENDING STRESS ON THE EAR. THE STRESS IN THE EAR WELDS WILL BE PRIMARILY TO THE AXIAL LOADS AND SHEAR.



Calculation Sheet

Project	WPPSS Equipment Qualification	Prepared By:	<i>[Signature]</i>	Date	5/2/93
Subject	24" Butterfly Valves with 8" Miller Operator	Checked By:	<i>J. Jernick</i>	Date	6/9/83
System	CEP & CSP	Job No.	82044	File No.	1T.01.F
Analysis No.	361106	Rev. No.	3	Sheet No.	361106-4.3-54





Calculation Sheet


Project	WPPSS Equipment Qualification	Prepared By:	<i>[Signature]</i>	Date	6/3/83
Subject	24" BIF Butterfly Valves with 8" Miller Operator	Checked By:	<i>[Signature]</i>	Date	6/9/83
System	CEP & CSP	Job No.	82044	File No.	1T.01.F
Analysis No.	361106	Rev. No.	3	Sheet No.	361106-4.3-55

REINFORCEMENT PLATES FOR 24 IN. VALVES

CSPV-5

V_1	4772	CHEAK
V_2	3021	CHEAK
T_3	2325	TENSILE
M_1	76145	MOMENT
M_2	37604	MOMENT
T	106643	TORQUE

DESIGN THE PLATE TO LAP THE SIDE OF THE IAK. FROM PAGE 4.3-52 THE $7\frac{1}{2}$ SIDE IS WORST CASE LOADING.





Calculation Sheet

Project	WPPSS Equipment Qualification		Prepared By:	<i>[Signature]</i>	Date	5/2/83
Subject	24" BIF Butterfly Valves with 8" Miller Operator		Checked By:	<i>[Signature]</i>	Date	6/9/83
System	CEP & CSP		Job No.	82044	File No.	1T.01.F
Analysis No.	361106	Rev. No.	3	Sheet No.	361106-4.3-56	


THE SHEAR ON THE WELDMENT IS:

$$V_e = 9376 \text{ IN-LB}$$

THE RESULTING MOMENT IS:

$$M_{\text{WELD}} = V_e L \times 3\frac{1}{2}'' = 32816 \text{ IN-LB}$$

THE MOMENT AND SHEAR ARE RESISTED BY THE FOLLOWING WELD PATTERN



THE SECTION PROPERTIES FROM BUDGETT.

$$A_w = (1 + 6\frac{1}{2}) 2tw = 15tw$$

$$J_w = \frac{(6\frac{1}{2} + 1)^3}{6} = 70.3$$

@ POINT A THE HORIZONTAL COMPONENT OF WELD FORCE IS DUE TO TWISTING ONLY

$$f_h = \frac{(M_{\text{WELD}})C}{J_w} = \frac{32816(3.25)}{70.3} = 1517 \text{ LB/IN}$$

@ POINT A THE VERTICAL COMPONENT OF OF THE WELD FORCE IS DUE TO BOTH SHEAR AND TWISTING:

$$f_v = \frac{V_e}{A_w} + \frac{M_e}{J_w} = \frac{9376}{15} + \frac{32816(1.5)}{70.3} = 625 + 233 = 858 \text{ LB/IN}$$




Calculation Sheet

Project	WPPSS Equipment Qualification		Prepared By:	<i>[Signature]</i>	Date	6/9/83
Subject	24" BIF Butterfly Valves with 8" Miller Operator		Checked By:	<i>[Signature]</i>	Date	6/9/83
System	CEP & CSP		Job No.	82044	File No.	1T.01.F
Analysis No.	361106	Rev. No.	3	Sheet No.	361106-4.3-57	

@ POINT A A VERTICAL COMPONENT OF THE WELD EXISTS DUE TO AXIAL LOAD IN THE EAR ITSELF. ASSUMING THE PLATE AREA EFFECTIVE IN RESISTING AXIAL LOAD IS $\frac{1}{2}$ THE DEPTH THE EFFECTIVE LENGTH WOULD BE $3 \text{ IN} = \frac{6}{2}$.

			%
$A_1 = 1\frac{1}{2} \times 2\frac{1}{2}$	= 3.75		.4545
$A_2 = \frac{1}{2} \times 4$	= 2.00		.2424
$A_3 = \frac{1}{2} \times 5$	= 2.50		.3030
	<u>8.25</u>		



THE TENSILE LOAD APPLIED TO A_1 IS AS FOLLOWS

APPLIED LOAD

$$\begin{aligned}
 V_1 &\Rightarrow 4772 (7.125) / 7.5 (2) = 2267 \\
 V_2 &\Rightarrow 3021 (7.125) / 10 (2) = 1076 \\
 P &\Rightarrow 2325 / 4 = 581 \\
 M_1 &\Rightarrow 7645 / 2 (10) = 3807 \\
 M_2 &\Rightarrow 5760 / 2 (7.5) = 2507 \\
 T. &\Rightarrow (6485 - 3647) = 2838
 \end{aligned}$$

SEE PAGE 4.3-50 FOR DIFFERENCE IN TORSIONAL AXIAL LOADS.


$$13076 =$$



Calculation Sheet

Project	WPPSS Equipment Qualification	Prepared By:	<i>[Signature]</i>	Date	6/8/83
Subject	24" BIF Butterfly Valves with 8" Miller Operator	Checked By:	<i>Z.L. Fernandez</i>	Date	6/9/83
System	CEP & CSP	Job No.	82044	File No.	1T.01.F
Analysis No.	361106	Rev. No.	3	Sheet No.	361106-4.3-58

SINCE PLATE A, CARRIES 24% OF THE AXIAL LOAD @ ϕ THE WELDMENT ABOVE AND BELOW MUST BE CAPABLE OF TAKING THE LOAD INTO AND OUT OF THE PLATE.



ASSUMING A SHEAR DISTRIBUTION MAXIMUM AT EACH END AND GOING TO ZERO AT THE ϕ .

THE RESULTING LOAD @ POINT A WOULD BE

$$\frac{(2424)(13076)(2)}{(15)(2)} = 211 \text{ #/IN}$$

COMBINE THE VERTICAL LOAD COMPONENTS DIRECTLY AND SUM WITH THE HORIZONTAL BY STRESS.

$$f_{TOT} = [(858 + 211)^2 + 1517^2]^{1/2} = 1856 \text{ #/IN}$$

TO REMAIN BELOW THE ALLOWABLE FATIGUE ALTERNATING STRESS VALUE OF $(1.5)(15) = 22.5 \text{ KSI}$ THE WELDMENT STRESS SHOULD REMAIN BELOW HALF OF THAT VALUE.

$$f_{allow} = \frac{22.5}{2} = 11.25 \text{ KSI}$$



Calculation Sheet


Project	WPPSS Equipment Qualification	Prepared By:	<i>[Signature]</i>	Date	6/9/83
Subject	24" BIF Butterfly Valves with 8" Miller Operator	Checked By:	JC Fernandez	Date	6/9/83
System	CEP & CSP	Job No.	82044	File No.	1T.01.F
Analysis No.	361106	Rev. No.	3	Sheet No.	361106-4.3-59

THE REQUIRED WELDMENT IS THEN

$$\frac{1856}{(t_w)(.707)} \leq 11,250 \text{ PSI}$$

$$t_w \geq \frac{1856}{.707(11250)} = .233 \text{ IN MIN } \frac{1}{4} \text{ FILLET WSS } \frac{5}{16}$$

FOR THE 10" SIDES $\sigma_{weld} = \frac{1856}{(.707)(.3125)} = 8401 \text{ PSI}$



FROM PAGE 4.3-50 THE SHEAR @ THE C OF THE FL IS

$$V_c = 4723 \#$$

THE RESULTING MOMENT @ THE C OF THE WELDMENT IS


$$M_{weld} = 4723(4.75) = 22434 \text{ IN LB}$$



Calculation Sheet

Project	WPPSS Equipment Qualification	Prepared By:	<i>[Signature]</i>	Date	5/9/83
Subject	24" BIF Butterfly Valves with 8" Miller Operator	Checked By:	<i>L. L. Fernandez</i>	Date	6/9/83
System	CEP & CSP	Job No.	82044	File No.	1T.01.F
Analysis No.	361106	Rev. No.	3	Sheet No.	361106-4.3-60

THE WELDMENT PROPERTIES ARE AS DEFINED BELOW, TREATED AS A LINE



$$Area = A_w = (5/16 + 2) \cdot 2 = 15 \text{ in}^2$$

$$J_{weld} = \frac{(5/16 + 2)^3}{6} = 70.3$$

$$S_{xx} = bd + \frac{d^2}{3} = (2)(5/16) + \frac{(5/16)^2}{3} = 11 + 10.1 = 21.1$$

@ POINT A THE HORIZONTAL COMPONENT OF THE WELD FORCE DUE TO TWISTING ONLY IS

$$f_h = \frac{(M_{weld}) C_{weld}}{J_w} = \frac{22434(5/16)}{70.3} = 878 \text{ LB/IN}$$

@ POINT A THE VERTICAL COMPONENT OF THE WELD FORCE DUE TO BOTH SHEAR AND TWISTING

$$f_v = \frac{V_{CL}}{A_w} + \frac{(M_{weld}) C_{weld}}{J_w} = \frac{4723}{15} + \frac{22434(5/16)}{70.3} = 315 + 319 = 634 \text{ #/IN}$$

@ POINT A DUE TO AXIAL COMPONENT ON THE EAR

$$f_a = \frac{(.3030)(13076)(2)}{(2)(15)} = 264 \text{ #/IN}$$



Calculation Sheet

Project	WPPSS Equipment Qualification	Prepared By:	<i>[Signature]</i>	Date	5/13/83
Subject	24" BIF Butterfly Valves with 8" Miller Operator	Checked By:	<i>J.C. [Signature]</i>	Date	6/9/83
System	CEP & CSP	Job No.	82044	File No.	1T.01.F
Analysis No.	361106	Rev. No.	3	Sheet No.	361106-4.3-61

THE ECCENTRIC LOAD OF SHEAR TO THE WELD GROUP DUE TO THE PLATE THICKNESS

$$M_e = V(t/2) = (4723)(.5/2) = 1181$$

$$f_p = \frac{M_e}{S_{xx}} = \frac{1181}{21.1} = 56 \text{ #/in}$$

COMBINING THE VERTICAL LOADS DIRECTLY AND SRSS THE PERPENDICULAR COMPONENTS THE TOTAL LOAD IS THEN:

$$f_t = \left(878^2 + (634 + 264)^2 + 56^2 \right)^{1/2} \\ = 1257 \text{ #/in}$$

USING THE ALLOWABLE STRESS OF 11.25 KSI THE REQUIRED WELDMENT IS THEN

$$t_{req} = \frac{1257}{.707(11250)} = .158 \text{ IN} \Rightarrow 3/16 \\ \text{USE } 5/16$$

$$F_{weld} = \frac{1257}{(.707)(.5125)} = 5629$$



Calculation Sheet

Project	WPPSS Equipment Qualification	Prepared By:	<i>[Signature]</i>	Date	4/31/83
Subject	24" BIF Butterfly Valves with 8" Miller Operator	Checked By:	<i>[Signature]</i>	Date	6/9/83
System	CEP & CSP	Job No.	82044	File No.	1T.01.F
Analysis No.	361106	Rev. No.	3	Sheet No.	361106-4.3-62

THE AXIAL LOAD IN THE EAR IS PRODUCED BY THE MOMENTS AND AXIAL LOADS ARE AS FOLLOWS.

FOR CSP-V-5

AXIAL LOADS

$$① \frac{4772(7.125)}{7.5(2)} = 2267$$

$$② \frac{3021(7.125)}{10(2)} = 1067$$

$$③ \frac{2325}{4} = 581$$

$$④ \frac{76145}{2(10.0)} = 3807$$

$$⑤ \frac{57604}{2(7.5)} = 2507$$

$$⑥ 6485 - 3647 = 2838$$

THE DIFFERENCE IN SHEARS DUE TO THE TORSIONAL LOADS FROM PAGE 4.3-50

SHEAR LOADS

$$\frac{4772}{4} = 1193 \# (V_1)$$

$$\frac{3021}{4} = 755 \# (V_2)$$

0

0

0

$$3413 = V_{2T}$$

$$2559 = V_{1T}$$

THE SHEAR DUE TO TORSION IS BROKEN UP INTO THE TWO HORIZONTAL DIRECTIONS ON PAGE 4.3-50

$$\text{TOTAL SUM} = 13076 \frac{\text{LBS}}{\text{EAR}}$$

$$\begin{aligned} \text{TOTAL SUM OF SHEAR} &= ((1193 + 2559)^2 + (755 + 3413)^2)^{1/2} \\ &= 5608 \text{ LBS SHEAR/EAR} \end{aligned}$$



Calculation Sheet

Project	WPPSS Equipment Qualification	Prepared By:	<i>[Signature]</i>	Date	5/31/83
Subject	24" BIF Butterfly Valves with 8" Miller Operator	Checked By:	<i>[Signature]</i>	Date	6/9/83
System	CEP & CSP	Job No.	82044	File No.	1T.01.F
Analysis No.	361106	Rev. No.	3	Sheet No.	361106-4.3-63

THE WELDMENT LENGTH OF THE SUPPORT EAR IS

$$L_w = (1.5" + 2.5") \times 2 = 8"$$

COMBINING THE TENSILE AND SHEAR LOAD BY SRSS AND DIVIDING BY THE LENGTH OF WELD GIVES THE LOAD PER UNIT LENGTH:

$$f_{weld} = \frac{(13076^2 + 5609^2)^{1/2}}{8 \text{ IN}} = 1778 \text{ #/IN}$$

THE RESULTING WELD STRESS FOR A 5/16" WELD IS THEN:

$$\sigma_{weld} = \frac{1778}{(.707)(.3125)} = 8050 \text{ #/IN}^2 \leq 11250 \text{ #/IN}^2$$

OK

THE ALLOWABLE STRESS FOR FATIGUE LOADING OF FILLET WELDS ASSUMING THE ALLOWABLE STRESS TO BE ONE-HALF OF THE AISC ALTERNATING STRESS RANGE AS DEFINED IN APPENDIX B AND COMMENTARY. FOR CATEGORY F, LOADING CONDITION 1, UTILIZING THE 50% INCREASE SPECIFIED IN PARAGRAPH 2 ON PAGE 5-122 OF AISC, THE ALTERNATING STRESS RANGE IS

$$F_{ER} = (15)(1.5) = 22.5 \text{ KSI}$$

THE RESULTING ALLOWABLE STRESS IS THEN

$$F_{M,weld} = F_{ER} / 2 = 22.5 / 2 = 11.25 \text{ KSI}$$



Calculation Sheet

Project	WPPSS Equipment Qualification	Prepared By:	<i>[Signature]</i>	Date	6/3/83
Subject	24" BIF Butterfly Valves with 8" Miller Operator	Checked By:	J.C. Fernandez	Date	6/9/83
System	CEP & CSP	Job No.	82044	File No.	1T.01.F
Analysis No.	361106	Rev. No.	3	Sheet No.	361106- 4.3-64

THE LOADS ON CSP-V-6 HAVE LOWER SHEAR LOADS BUT HIGHER BENDING MOMENTS. REVIEW OF THE BURNS AND ROE LOADS SHOWS THE BRACKET ACCELERATION @ 11.4 g AND THE OPERATING CYLINDER ACCELERATION IN THE SAME DIRECTION AS 2.55 g. THE WEIGHT OF THE BRACKET WAS 277 POUNDS AND THE WEIGHT OF THE CYLINDER WAS: 399 LBS. THE TOTAL ASSEMBLY WAS ACCELERATED @ 11.4 g WHEN IN ACTUALITY THE INDIVIDUAL COMPONENTS SHOULD HAVE BEEN ACCELERATED AT THEIR RESPECTIVE "g" LEVELS. UTILIZING THE PROPER GEOMETRIC AND ACCELERATIONS THE LOADS APPLIED TO THE SUPPORT ENDS IS COMPARABLE TO CSP-V-5. THE BALANCE OF THE COMPONENTS WILL HAVE CONSERVATIVE FINAL STRESSES DUE TO THE HIGH ACCELERATIONS.



Calculation Sheet

Project	Washington Public Power Supply System	Prepared By:	<i>J. P. D. ...</i>	Date	3/25/83
Subject	Equipment Seismic/Hydrodynamic Requal.	Checked By:	<i>J. C. ...</i>	Date	5/30/83
System	CSP & CEP	Job No.	82044	File No.	OT.01/F
Analysis No.	361106	Rev. No.	2	Sheet No.	361106 - 4.3.G5

SECTION 4.4



*modified 6/3/85
J.C. Fernandez 6/19/83*



REFERENCES:

1. BIF Drawings:

D-207110-H, D-207110-G, (Valve Data Sheets)

A-206767, 18", 24" & 30" Butterfly Valve - General

C-26096, "Certified Dimension for Model A-83-B Cylinder"

2. WPPSS Unit 2 Drawings:

CSP-807-81.08	Containment Purge Air Supply
CSP-809-1.2	Suppression Pool Vacuum Breaker
CEP-625-3.4	From Reactor Nozzle X-67 to SGT-Fu-1A, 1B
CEP-625-1.2	From Reactor Nozzle X-67 to SGT-Fu-1A, 1B
D.220-0310	Support and Erection Isometric-IR64 (Johnson Controls)

- BIF Report TR-27234 and TR-27235, "Dynamic Torque Calculation of Butterfly Valve; Sizes 24 and 30 inch", dated November 10, 1982.
- Report #TR-74-7 by McPherson Assoc., Inc., "Design & Seismic Analysis 24" Cylinder operated Butterfly Valve." (Rev. 1) 1/5/76.
- WPPSS letter to Cygna Energy Services, GE-02-RWH-018, 12/17/82.



Calculation Sheet

Project	Washington Public Power Supply System	Prepared By:	L.C. Fernandez	Date	5/27/83
Subject	Equipment Seismic/Hydrodynamic Requal.	Checked By:	<i>[Signature]</i>	Date	5/27/83
System	CSP & CEP	Job No.	82044	File No.	OT.01.F
Analysis No.	QID 361106	Rev. No.	2	Sheet No.	4.3.66

SECTION 4.4

REFERENCES (CONTINUED):

6. Cygna Energy Services Communications Report, R. Ricappito, BIF Valve, and J. Rakowski, CES, "BIF Valve Dimensions", 2/11/83.
7. Cygna Energy Services, Project Manual Design Criteria, DC-1, Rev. 1, November, 1982.
8. Cygna Energy Services, Equipment Qualification Walkdown Verification Forms, Revision 1, dated 1/5/83.
9. WPPSS, WNP-2, Safety Related Mechanical Equipment List Summary Sheets, dated 2/10/83.
10. "AISC Manual of Steel Construction", American Institute of Steel Construction, 8th Edition, 1980.
11. Preliminary Transfer of Final Burns & Roe Piping Loads for CSP-V-1,2,3,4,5,6 and CEP-V-3A&4A, received 4/13/83.
12. Cygna Energy Services, "Equipment Seismic and Hydrodynamic Requalification of 30" Cylinder Operated Butterfly Valves for CSP-V-1, & 2, and CEP-V-1A, & 2A," File No. OS.01.F, QID No. 361104, Revision 1, June, 1983.
13. Cygna Energy Services, "Equipment Seismic and Hydrodynamic Requalification for 8", 10" and 12" Bore Air Cylinder Operators," File No. 1P.01.F, QID No. 018001, Revision 0, May, 1983.
14. USNRC, "Standard Review Plan, NUREG-0800"

APPENDIX A

COMPILED PROGRAMS AND RESULTS FOR

CSP-V-3

CSP-V-4

CSP-V-5

CSP-V-6

CEP-V-3A

CEP-V-4A

1. The first part of the document
describes the general situation
of the country and the
state of the economy.

2. The second part of the document
describes the state of the
economy and the
state of the country.

sbasic csp34
tm
?-BASIC Compiler Version 5.4b

```
0001:00 REM***** BIF VALVE AND AIR OPERATOR SEISMIC STRESS *****
0002:00 REM***** CSP-V/A0-3/4 *****
0003:00 REM**SAME ORIENTATION FOR EPN 3&4,SAME PARAMTERS, VARY G'S
0004:00 REM
0005:00 var i,j,k = integer
0006:00 var lrod,lcg,x,phi,lave,abl,t,11,12,e1,e2,e3,e4,e5 = real
0007:00 var fst2, ca,ia,cb,ib,aa,ab,d1,d2,c1,i1,c2,i2=real
0008:00 var lrod,lcgo,ldr,d, abush, pbush=real
0009:00 var fcof, fco, ma,mb, siga, sigb, fcd, fcd, maf, mbf=real
0010:00 var dear, fcear,fr, f11,f22,la, ci12,ci21,slt3,sem1=real
0011:00 var sem2,set3,ses1,ses2,sr,tau11,tau22,taear,aear=real
0012:00 var btens, taubl, set3f,sem1f,sem2f,fcearf, frf,f11f=real
0013:00 var f22f,slt3f,ses1f,ses2f,srf,tau1f,tau2f,taurf=real
0014:00 var taubf,btf, dsr,dtaur,dtaub,dbten,dsa,dsb,dpb=real
0015:00 var sdraf,sdrbf,pbushf,tau11f,tau22f=real
0016:00 var wao,wbr,ftr1,watr1,s1,s1f,s2,s2f,m1,m1f,m2=real
0017:00 var m2f,t3,t3f,tt3,tt3f,lbr,wtot=real
0018:00 var bs1,bs2,bt3,bm1,bm2,btt3=real
0019:00 dim real av(3)
0020:00 dim real wa(3)
0021:00 dim real wb(3)
0022:00 REM
0023:00 REM *** BURNS 7 ROE EAR FORCES ARE bs1 etc TURN ON WITH K=1***
0024:00 REM
0025:00 REM
0026:00 dim real a(3,3)
0027:00 dim real b(3)
0028:00 dim real glc(3,3)
0029:00 1 - data 7:5, 10, .75, 1.95, 1.25, .7
0030:00 2 data 25,14.46,.531,53.,7.125,.31,1.5,2.5
0031:00 3 data 1150.,.875,.46,.648,.138,2.41,1.4
0032:00 4 data 399,277,5.25,8.5,28.5,15.,6.875
0033:00 5 data 40.,10.96,26.5,30.5,2.075
0034:00 6 data 90.,90.,180.,0.,90.,90.
0035:00 7 data 90.,180.,90.,180.,90.,90.
0036:00 REM DATA 6&7 FOR VALVE/GLOBAL-G ORIENTATIONS AND WEIGHT VECTOR
0037:00 restore
0038:00 read d1,d2,c1,i1,c2,i2
0039:00 restore 2
0040:00 read lrod,lcg,x,phi,lave,abl,t,11,12
0041:00 restore 3
0042:00 read fst2,ca,ia,cb,ib,aa,ab
0043:00 restore 4
0044:00 read wao,wbr,e1,e2,e3,e4,e5
0045:00 restore 5
0046:00 read lrod,lcgo,ldr,d,abush
0047:00 restore 6
0048:00 read a(1,1),a(2,1),a(3,1),a(1,2),a(2,2),a(3,2)
0049:00 restore 7
0050:00 read a(1,3),a(2,3),a(3,3),av(1),av(2),av(3)
0051:00 text 0,& INPUT GLOBAL ACCELERATIONS &
0052:00 input b(1),b(2),b(3)
0053:00 print
0054:00 text 0,& INPUT DATA &
0055:00 print
0056:00 print "GLOBAL G-LEVELS = ";b(1),b(2),b(3)
LES = ";a(1,1),a(2,1),a(3,1)
```

CYGMA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT01/E</u>
SHEET NO. <u>A-1</u>

CSR 34

INPUT GLOBAL ACCELERATIONS
? .66, 2.99, 3.76

INPUT DATA

GLOBAL G-LEVELS	=	2.66	2.99	3.76
NORTH VECTOR ANGLES	=	90	90	180
VERTICAL VECTOR ANGLES	=	0 90	90	
EAST VECTOR ANGLES	=	90	180	90
WEIGHT VECTOR ANGLES	=	180	90	90

LOCAL G-LEVELS

-1.01471E-5	2.99	-1.43433E-5
-1.01471E-5	-1.14059E-5	-3.76
-2.66	-1.14059E-5	-1.43433E-5

OPERATING DRIVE ROD STRESS AT A 5525.52
 OPERATING DRIVE ROD STRESS AT B 8542.57
 OPERATING CYLINDER BRG PRESSURE -98.4646
 OPERATING VALVE EAR TENSILE STR 3795.21
 OPERATING VALVE EAR SHEAR STRES 244.962
 OPERATING EAR BOLT SHEAR STRESS 2963.25
 OPERATING EAR BOLT TENSILE STR 2615.86

D. AMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 15094.5
 DRIVE ROD TENSILE STRESS AT B 23086.2
 BUSHING PRESSURE 294.409
 VALVE EAR TENSILE STRESS 14765.9
 VALVE EAR SHEAR STRESS 967.76
 EAR BOLT SHEAR STRESS 11706.8
 EAR BOLT TENSILE STRESS 14229.2

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 20620.1
 DRIVE ROD TENSILE STRESS AT B 31628.7
 PUSHING PRESSURE 392.874
 VALVE EAR TENSILE STRESS 18561.1
 VALVE EAR SHEAR STRESS 1212.72
 EAR BOLT SHEAR STRESS 14670
 EAR BOLT TENSILE STRESS 16845.1

3.01 72

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>DT.01/F</u>
SHEET NO. <u>A-2</u>

esp34

INPUT GLOBAL ACCELERATIONS

(MILTED WELD)

? : 2.66, 2.99, 3.76

INPUT DATA

GLOBAL G-LEVELS	=	2.66	2.99	3.76
NORTH VECTOR ANGLES	=	90	90	180
VERTICAL VECTOR ANGLES	=	0 90	90	
EAST VECTOR ANGLES	=	90	180	90
WEIGHT VECTOR ANGLES	=	180	90	90

LOCAL G-LEVELS

-1.01471E-5	2.99	-1.43433E-5
-1.01471E-5	-1.14059E-5	-3.76
-2.66	-1.14059E-5	-1.43433E-5

OPERATING DRIVE ROD STRESS AT A 5525.52
 OPERATING DRIVE ROD STRESS AT B 8542.57
 OPERATING CYLINDER BRG PRESSURE -98.4646
 OPERATING EAR WELD TENSILE STR 4338.59
 OPERATING EAR WELD SHEAR STRESS 519.72
 OPERATING EAR BOLT SHEAR STRESS 2963.24
 OPERATING EAR BOLT TENSILE STR 2615.86

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 15094.5
 DRIVE ROD TENSILE STRESS AT B 23086.2
 BUSHING PRESSURE 294.409
 EAR WELD TENSILE STRESS 16435.2
 EAR WELD SHEAR STRESS 2053.24
 EAR BOLT SHEAR STRESS 11706.8
 EAR BOLT TENSILE STRESS 14229.2

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 20620.1
 DRIVE ROD TENSILE STRESS AT B 31628.7
 PUSHING PRESSURE 392.874
 EAR WELD TENSILE STRESS 20773.8
 EAR WELD SHEAR STRESS 2572.96
 EAR BOLT SHEAR STRESS 14670
 EAR BOLT TENSILE STRESS 16845.1

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>DT.01/F</u>
SHEET NO. <u>A-3</u>

csp34

INPUT GLOBAL ACCELERATIONS

? 36, 2.99, 3.76

INPUT DATA

GLOBAL G-LEVELS	=	2.66	2.99	3.76
NORTH VECTOR ANGLES	=	90	90	180
VERTICAL VECTOR ANGLES	=	0 90	90	
EAST VECTOR ANGLES	=	90	180	90
WEIGHT VECTOR ANGLES	=	180	90	90

LOCAL G-LEVELS

-1.01471E-5	2.99	-1.43433E-5
-1.01471E-5	-1.14059E-5	-3.76
-2.66	-1.14059E-5	-1.43433E-5

OPERATING DRIVE ROD STRESS AT A 5525.52
OPERATING DRIVE ROD STRESS AT B 8542.57
OPERATING CYLINDER BRG PRESSURE -98.4646
OPERATING VALVE EAR TENSILE STR 3795.21
OPERATING VALVE EAR SHEAR STRES 244.962
OPERATING EAR BOLT SHEAR STRESS 2963.25
OPERATING EAR BOLT TENSILE STR 2615.86

s1 -906.782
s2f= 1150
t3f=-2.57873E-3
m1f=-7906.15
m2f=-6234.1
tt3f=-12328.8

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 15094.5
DRIVE ROD TENSILE STRESS AT B 23086.2
BUSHING PRESSURE 294.409
VALVE EAR TENSILE STRESS 14765.9
VALVE EAR SHEAR STRESS 967.76
EAR BOLT SHEAR STRESS 11706.8
EAR BOLT TENSILE STRESS 14229.2

s1d= 2711.27
s2d= 2541.76
t3d= 1798.16
m1d= 59281.6
m2d= 22662.6
tt3d= 68555.7

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 20620.1
DRIVE ROD TENSILE STRESS AT B 31628.7
PUSHING PRESSURE 392.874
VALVE EAR TENSILE STRESS 18561.1
VALVE EAR SHEAR STRESS 1212.72

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>DT.OI.F</u>
SHEET NO. <u>A-4</u>

EAR BOLT SHEAR STRESS 14670
EAR BOLT TENSILE STRESS 16845.1

s1t= 3618.06
s2t= 3691.76
t3t= 1798.16
m1t= 67187.8
m2 28896.7
tt3t= 80884.5

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>0T.01.F</u>
SHEET NO. <u>A-5</u>

csp34

INPUT GLOBAL ACCELERATIONS
? 2.96, 3.17, 4.19

INPUT DATA

GLOBAL G-LEVELS	=	2.96	3.17	4.19
NORTH VECTOR ANGLES	=	90	90	180
VERTICAL VECTOR ANGLES	=	0	90	90
EAST VECTOR ANGLES	=	90	180	90
WEIGHT VECTOR ANGLES	=	180	90	90

LOCAL G-LEVELS

-1.12915E-5	3.17	-1.59836E-5
-1.12915E-5	-1.20926E-5	-4.19
-2.96	-1.20926E-5	-1.59836E-5

OPERATING DRIVE ROD STRESS AT A 5525.52
OPERATING DRIVE ROD STRESS AT B 8542.57
OPERATING CYLINDER BRG PRESSURE -98.4646
OPERATING VALVE EAR TENSILE STR 3795.21
OPERATING VALVE EAR SHEAR STRESS 244.962
OPERATING EAR BOLT SHEAR STRESS 2963.25
OPERATING EAR BOLT TENSILE STR 2615.86

D. AMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 16003.2
DRIVE ROD TENSILE STRESS AT B 24476
BUSHING PRESSURE 312.133
VALVE EAR TENSILE STRESS 15743
VALVE EAR SHEAR STRESS 1034.29
EAR BOLT SHEAR STRESS 12511.6
EAR BOLT TENSILE STRESS 15776.8

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 21528.7
DRIVE ROD TENSILE STRESS AT B 33018.6
PUSHING PRESSURE 410.597
VALVE EAR TENSILE STRESS 19538.2
VALVE EAR SHEAR STRESS 1279.26
EAR BOLT SHEAR STRESS 15474.9
EAR BOLT TENSILE STRESS 18392.7

3. 33

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01/E</u>
SHEET NO. <u>A-B</u>

sp34
INPUT GLOBAL ACCELERATIONS
? : 16, 3.17, 4.19

FAULTED WELD)

INPUT DATA

GLOBAL G-LEVELS	=	2.96	3.17	4.19
NORTH VECTOR ANGLES	=	90	90	180
VERTICAL VECTOR ANGLES	=	0 90	90	
EAST VECTOR ANGLES	=	90	180	90
WEIGHT VECTOR ANGLES	=	180	90	90

LOCAL G-LEVELS

-1.12915E-5	3.17	-1.59836E-5
-1.12915E-5	-1.20926E-5	-4.19
-2.96	-1.20926E-5	-1.59836E-5

OPERATING DRIVE ROD STRESS AT A 5525.52
OPERATING DRIVE ROD STRESS AT B 8542.57
OPERATING CYLINDER BRG PRESSURE -98.4646
OPERATING EAR WELD TENSILE STR 4338.59
OPERATING EAR WELD SHEAR STRESS 519.72
OPERATING EAR BOLT SHEAR STRESS 2963.24
OPERATING EAR BOLT TENSILE STR 2615.86

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 16003.2
DRIVE ROD TENSILE STRESS AT B 24476
BUSHING PRESSURE 312.133
EAR WELD TENSILE STRESS 17548.3
EAR WELD SHEAR STRESS 2194.4
EAR BOLT SHEAR STRESS 12511.6
EAR BOLT TENSILE STRESS 15776.8

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 21528.7
DRIVE ROD TENSILE STRESS AT B 33018.6
PUSHING PRESSURE 410.597
EAR WELD TENSILE STRESS 21886.9
EAR WELD SHEAR STRESS 2714.12
EAR BOLT SHEAR STRESS 15474.9
EAR BOLT TENSILE STRESS 18392.7

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.OI.F</u>
SHEET NO. <u>A-7</u>

csp34

INPUT GLOBAL ACCELERATIONS

? 96,3.17,4.19

INPUT DATA

GLOBAL G-LEVELS	=	2.96	3.17	4.19
NORTH VECTOR ANGLES	=	90	90	180
VERTICAL VECTOR ANGLES	=	0 90	90	
EAST VECTOR ANGLES	=	90	180	90
WEIGHT VECTOR ANGLES	=	180	90	90

LOCAL G-LEVELS

-1.12915E-5	3.17	-1.59836E-5
-1.12915E-5	-1.20926E-5	-4.19
-2.96	-1.20926E-5	-1.59836E-5

OPERATING DRIVE ROD STRESS AT A 5525.52
 OPERATING DRIVE ROD STRESS AT B 8542.57
 OPERATING CYLINDER BRG PRESSURE -98.4646
 OPERATING VALVE EAR TENSILE STR 3795.21
 OPERATING VALVE EAR SHEAR STRESS 244.962
 OPERATING EAR BOLT SHEAR STRESS 2963.25
 OPERATING EAR BOLT TENSILE STR 2615.86

s1 -906.782
 s2+ 1150
 t3f=-2.57873E-3
 m1f=-7906.15
 m2f=-6234.1
 tt3f=-12328.8

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 16003.2
 DRIVE ROD TENSILE STRESS AT B 24476
 BUSHING PRESSURE 312.133
 VALVE EAR TENSILE STRESS 15743
 VALVE EAR SHEAR STRESS 1034.29
 EAR BOLT SHEAR STRESS 12511.6
 EAR BOLT TENSILE STRESS 15776.8

s1d= 2874.49
 s2d= 2832.44
 t3d= 2000.96
 m1d= 65975.4
 m2d= 24418.8
 tt3d= 72951.2

F .ED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 21528.7
 DRIVE ROD TENSILE STRESS AT B 33018.6
 PUSHING PRESSURE 410.597
 VALVE EAR TENSILE STRESS 19538.2
 VALVE EAR SHEAR STRESS 1279.26
 EAR BOLT SHEAR STRESS 15474.0

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>DT.OI.F</u>
SHEET NO. <u>A-8</u>

EAR BOLT TENSILE STRESS

18392.7

s1t= 3781.28
s2t= 3982.44
s3t= 2000.96
m1t= 73881.5
m2t= 30652.9
t.t.= 85280

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>GT.01.F</u>
SHEET NO. <u>A-9</u>

csp34

INPUT GLOBAL ACCELERATIONS
? : 0, 1.97, 1.71

EMERGENCY (ENVELOPES CSA-V-3)

INPUT DATA

GLOBAL G-LEVELS	=	2.8	1.97	1.71
NORTH VECTOR ANGLES	=	90	90	180
VERTICAL VECTOR ANGLES	=	0 90	90	
EAST VECTOR ANGLES	=	90	180	90
WEIGHT VECTOR ANGLES	=	180	90	90

LOCAL G-LEVELS

1.06811E-5	1.97	-6.52313E-6
-1.06811E-5	-7.51495E-6	-1.71
2.8	-7.51495E-6	-6.52313E-6

OPERATING DRIVE ROD STRESS AT A 5525.52
 OPERATING DRIVE ROD STRESS AT B 8542.57
 OPERATING CYLINDER BRG PRESSURE -98.4646
 OPERATING EAR WELD TENSILE STR 4338.59
 OPERATING EAR WELD SHEAR STRES 519.72
 OPERATING EAR BOLT SHEAR STRESS 2963.24
 OPERATING EAR BOLT TENSILE STR 2615.86

D. MIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 9945.23
 DRIVE ROD TENSILE STRESS AT B 15210.7
 BUSHING PRESSURE 193.975
 EAR WELD TENSILE STRESS 10668.6
 EAR WELD SHEAR STRESS 1296.94
 EAR BOLT SHEAR STRESS 7394.64
 EAR BOLT TENSILE STRESS 14365.1

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 15470.8
 DRIVE ROD TENSILE STRESS AT B 23753.2
 PUSHING PRESSURE 292.44
 EAR WELD TENSILE STRESS 15007.2
 EAR WELD SHEAR STRESS 1816.66
 EAR BOLT SHEAR STRESS 10357.9
 EAR BOLT TENSILE STRESS 16980.9

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>A-10</u>

sp34
INPUT GLOBAL ACCELERATIONS
14, 1.40, 1.5

UPSET

ENVELOPES (SP-1-3)

INPUT DATA

GLOBAL G-LEVELS	=	1.14	1.4	1.5
NORTH VECTOR ANGLES	=	90	90	180
VERTICAL VECTOR ANGLES	=	0 90	90	
EAST VECTOR ANGLES	=	90	180	90
WEIGHT VECTOR ANGLES	=	180	90	90

LOCAL G-LEVELS

-4.34875E-6	1.4	-5.72204E-6
-4.34875E-6	-5.34057E-6	-1.5
-1.14	-5.34057E-6	-5.72204E-6

OPERATING DRIVE ROD STRESS AT A 5525.52
OPERATING DRIVE ROD STRESS AT B 8542.57
OPERATING CYLINDER BRG PRESSURE -98.4646
OPERATING EAR WELD TENSILE STR 4338.59
OPERATING EAR WELD SHEAR STRES 519.72
OPERATING EAR BOLT SHEAR STRESS 2963.24
OPERATING EAR BOLT TENSILE STR 2615.86

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 7067.68
DRIVE ROD TENSILE STRESS AT B 10809.6
BUSHING PRESSURE 137.85
EAR WELD TENSILE STRESS 7558.92
EAR WELD SHEAR STRESS 940.809
EAR BOLT SHEAR STRESS 5364.13
EAR BOLT TENSILE STRESS 6129.04

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 12593.2
DRIVE ROD TENSILE STRESS AT B 19352.2
PUSHING PRESSURE 236.315
EAR WELD TENSILE STRESS 11897.5
EAR WELD SHEAR STRESS 1460.53
EAR BOLT SHEAR STRESS 8327.37
EAR BOLT TENSILE STRESS 8744.9

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>A-11</u>

sbasic csp5
tm
S-BASIC Compiler Version 5.4b

```
J001:00 REM***** BIF VALVE AND AIR OPERATOR SEISMIC STRESS *****
0002:00 REM***** CSP-V/A0-5 *****
0003:00 REM
0004:00 var i,j,k = integer
0005:00 var lrod,lcg,x,phi,lave,ablt,l1,l2,e1,e2,e3,e4,e5 = real
0006:00 var fst2, ca,ia,cb,ib,aa,ab,d1,d2,c1,i1,c2,i2=real
0007:00 var lrodo,lcgo,ldr,d, abush, pbush=real
0008:00 var fcof, fco, ma,mb, siga, sigb, fcdr, fcdrf,maf, mbf=real
0009:00 var dear, fcear,fr, fl1,f22,la, ci12,ci21,slt3,sem1=real
0010:00 var sem2,set3,ses1,ses2,sr,taul1,tau22,tauear,aear=real
0011:00 var btens, taubl, set3f,sem1f,sem2f,fcearf, frf,fl1f=real
0012:00 var f22f,slt3f,ses1f,ses2f,srf,taulf,tau2f,taurf=real
0013:00 var taubf,btf, dsr,dtaur,dtaub,dbten,dsa,dsb,dpb=real
0014:00 var sdraf,sdrbf,pbushf,taul1f,tau22f=real
0015:00 var wao,wbr,ftr1,watr1,s1,s1f,s2,s2f,m1,m1f,m2=real
0016:00 var m2f,t3,t3f,tt3,tt3f,lbr,wtot=real
0017:00 var bs1,bs2,bt3,bm1,bm2,btt3=real
0018:00 dim real av(3)
0019:00 dim real wa(3)
0020:00 dim real wb(3)
0021:00 REM
0022:00 REM *** BURNS 7 ROE EAR FORCES ARE bs1 etc TURN ON WITH K=1***
0023:00 REM
0024:00 REM
0025:00 dim real a(3,3)
0026:00 dim real b(3)
0027:00 dim real glc(3,3)
0028:00 1 data 7.5, 10, .75, 1.95, 1.25, .7
0029:00 2 data 25,14.46,.531,53.,7.125,.31,1.5,2.5
0030:00 3 data 0.,.875,.46,.648,.138,2.41,1.4
0031:00 4 data 399,277,5.25,8.5,28.5,15.,6.875
0032:00 5 data 40.,10.96,26.5,30.5,2.075
0033:00 6 data 42.5,47.5,90.,90.,90.,0.
0034:00 7 data 47.5,137.5,90.,180.,90.,90.
0035:00 REM DATA 6&7 FOR VALVE/GLOBAL-G ORIENTATIONS AND WEIGHT VECTOR
0036:00 restore
0037:00 read d1,d2,c1,i1,c2,i2
0038:00 restore 2
0039:00 read lrod,lcg,x,phi,lave,ablt,l1,l2
0040:00 restore 3
0041:00 read fst2,ca,ia,cb,ib,aa,ab
0042:00 restore 4
0043:00 read wao,wbr,e1,e2,e3,e4,e5
0044:00 restore 5
0045:00 read lrodo,lcgo,ldr,d,abush
0046:00 restore 6
0047:00 read a(1,1),a(2,1),a(3,1),a(1,2),a(2,2),a(3,2)
0048:00 restore 7
0049:00 read a(1,3),a(2,3),a(3,3),av(1),av(2),av(3)
0050:00 text 0,& INPUT GLOBAL ACCELERATIONS &
0051:00 input b(1),b(2),b(3)
0052:00 print
0053:00 text 0,& INPUT DATA &
```

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01/E</u>
SHEET NO. <u>A-12</u>

isp5

INPUT GLOBAL ACCELERATIONS

? 2.96, 3.44, 5.42

INPUT DATA

GLOBAL G-LEVELS	=	2.96	3.44	5.42
NORTH VECTOR ANGLES	=	42.5	47.5	90
VERTICAL VECTOR ANGLES	=	90	90	0
EAST VECTOR ANGLES	=	47.5	137.5	90
WEIGHT VECTOR ANGLES	=	180	90	90

LOCAL G-LEVELS

2.18234	-1.31225E-5	3.66169
1.99974	-1.31225E-5	-3.99606
-1.12915E-5	3.44	-2.06756E-5

OPERATING DRIVE ROD STRESS AT A 5048.35
OPERATING DRIVE ROD STRESS AT B 7721.14
OPERATING CYLINDER BRG PRESSURE -98.4646
OPERATING VALVE EAR TENSILE STR 4664.25
OPERATING VALVE EAR SHEAR STRES 297.614
OPERATING EAR BOLT SHEAR STRESS 3600.17
OPERATING EAR BOLT TENSILE STR 1340.69

D. AMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 21519.6
DRIVE ROD TENSILE STRESS AT B 32912.8
BUSHING PRESSURE 419.724
VALVE EAR TENSILE STRESS 20190.5
VALVE EAR SHEAR STRESS 1312.91
EAR BOLT SHEAR STRESS 15882
EAR BOLT TENSILE STRESS 19507

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 26567.9
DRIVE ROD TENSILE STRESS AT B 40633.9
PUSHING PRESSURE 518.189
VALVE EAR TENSILE STRESS 24854.8
VALVE EAR SHEAR STRESS 1610.53
EAR BOLT SHEAR STRESS 19482.2
EAR BOLT TENSILE STRESS 20847.7

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01/F</u>
SHEET NO. <u>A-13</u>

csp5

INPUT GLOBAL ACCELERATIONS
? 26, 3.44, 5.42

FAULTED WELD STRENGTH

INPUT DATA

GLOBAL G-LEVELS	=	2.96	3.44	5.42
NORTH VECTOR ANGLES	=	42.5	47.5	90
VERTICAL VECTOR ANGLES	=	90	90	0
EAST VECTOR ANGLES	=	47.5	137.5	90
WEIGHT VECTOR ANGLES	=	180	90	90

LOCAL G-LEVELS

2.18234	-1.31225E-5	3.66169
1.99974	-1.31225E-5	-3.99606
-1.12915E-5	3.44	-2.06756E-5

OPERATING DRIVE ROD STRESS AT A 5048.35
 OPERATING DRIVE ROD STRESS AT B 7721.14
 OPERATING CYLINDER BRG PRESSURE -98.4646
 OPERATING EAR WELD TENSILE STR 5107.51
 OPERATING EAR WELD SHEAR STRES 631.431
 OPERATING EAR BOLT SHEAR STRESS 3600.17
 OPERATING EAR BOLT TENSILE STR 1340.69

D. DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 21519.6
 DRIVE ROD TENSILE STRESS AT B 32912.8
 BUSHING PRESSURE 419.724
 EAR WELD TENSILE STRESS 22736.7
 EAR WELD SHEAR STRESS 2785.52
 EAR BOLT SHEAR STRESS 15882
 EAR BOLT TENSILE STRESS 19507

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 26567.9
 DRIVE ROD TENSILE STRESS AT B 40633.9
 PUSHING PRESSURE 518.189
 EAR WELD TENSILE STRESS 27844.2
 EAR WELD SHEAR STRESS 3416.95
 EAR BOLT SHEAR STRESS 19482.2
 EAR BOLT TENSILE STRESS 20847.7

CYGNA
ATTACHMENT
JOB NO. <u>02044</u>
FILE NO. <u>07.01.F</u>
SHEET NO. <u>A-14</u>

sp5

INPUT GLOBAL ACCELERATIONS

? 96,3.44,5.42

INPUT DATA

GLOBAL G-LEVELS	=	2.96	3.44	5.42
NORTH VECTOR ANGLES	=	42.5	47.5	90
VERTICAL VECTOR ANGLES	=	90	90	0
EAST VECTOR ANGLES	=	47.5	137.5	90
WEIGHT VECTOR ANGLES	=	180	90	90

LOCAL G-LEVELS

2.18234	-1.31225E-5	3.66169
1.99974	-1.31225E-5	-3.99606
-1.12915E-5	3.44	-2.06756E-5

OPERATING DRIVE ROD STRESS AT A 5048.35
 OPERATING DRIVE ROD STRESS AT B 7721.14
 OPERATING CYLINDER BRG PRESSURE -98.4646
 OPERATING VALVE EAR TENSILE STR 4664.25
 OPERATING VALVE EAR SHEAR STRESS 297.614
 OPERATING EAR BOLT SHEAR STRESS 3600.17
 OPERATING EAR BOLT TENSILE STR 1340.69

s1 -906.782
 s2f=-2.57874E-3
 t3f=-2.57873E-3
 m1f= 9.89667E-2
 m2f=-6234.1
 tt3f=-22103.8

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 21519.6
 DRIVE ROD TENSILE STRESS AT B 32912.8
 BUSHING PRESSURE 419.724
 VALVE EAR TENSILE STRESS 20190.5
 VALVE EAR SHEAR STRESS 1312.91
 EAR BOLT SHEAR STRESS 15882
 EAR BOLT TENSILE STRESS 19507

s1d= 3865.34
 s2d= 3020.7
 t3d= 2325.44
 m1d= 76145
 m2d= 31369.7
 tt3d= 84539.5

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 26567.9
 DRIVE ROD TENSILE STRESS AT B 40633.9
 PUSHING PRESSURE 518.189
 VALVE EAR TENSILE STRESS 24854.8
 VALVE EAR SHEAR STRESS 1610.53

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.OI.F</u>
SHEET NO. <u>A-15</u>

CSRS

INPUT GLOBAL ACCELERATIONS
? .97, 1.4, 1.71

UPSET

INPUT DATA

GLOBAL G-LEVELS	=	.97	1.4	1.71
NORTH VECTOR ANGLES	=	42.5	47.5	90
VERTICAL VECTOR ANGLES	=	90	90	0
EAST VECTOR ANGLES	=	47.5	137.5	90
WEIGHT VECTOR ANGLES	=	180	90	90

LOCAL G-LEVELS

.715158	-5.34057E-6	1.15526
.655321	-5.34057E-6	-1.26075
-3.70025E-6	1.4	-6.52313E-6

OPERATING DRIVE ROD STRESS AT A 5048.35
 OPERATING DRIVE ROD STRESS AT B 7721.14
 OPERATING CYLINDER BRG PRESSURE -98.4646
 OPERATING EAR WELD TENSILE STR 5107.51
 OPERATING EAR WELD SHEAR STRES 631.431
 OPERATING EAR BOLT SHEAR STRESS 3600.17
 OPERATING EAR BOLT TENSILE STR 1340.69

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 6859.18
 DRIVE ROD TENSILE STRESS AT B 10490.7
 BUSHING PRESSURE 133.784
 EAR WELD TENSILE STRESS 7323.31
 EAR WELD SHEAR STRESS 892.936
 EAR BOLT SHEAR STRESS 5091.16
 EAR BOLT TENSILE STRESS 7599.75

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 11907.5
 DRIVE ROD TENSILE STRESS AT B 18211.9
 PUSHING PRESSURE 232.249
 EAR WELD TENSILE STRESS 12430.8
 EAR WELD SHEAR STRESS 1524.37
 EAR BOLT SHEAR STRESS 8691.33
 EAR BOLT TENSILE STRESS 8940.43

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.OI.F</u>
SHEET NO. <u>A-18</u>

sbasic csp6
tm
S-BASIC Compiler Version 5.4b

```
J01:00 REM***** BIF VALVE AND AIR OPERATOR SEISMIC STRESS *****
0002:00 REM***** CSP-V/A0-6 *****
0003:00 REM
0004:00 var i,j,k = integer
0005:00 var lrod,lcg,x,phi,lave,ablt,l1,l2,e1,e2,e3,e4,e5 = real
0006:00 var fst2,ca,ia,cb,ib,aa,ab,d1,d2,c1,i1,c2,i2=real
0007:00 var lrodo,lcgo,ldr,d, abush, pbush=real
0008:00 var fcof, fco, ma,mb, siga, sigb, fcdr, fcdrf,maf, mbf=real
0009:00 var dear, fcear,fr, f11,f22,la, ci12,ci21,slt3,semi=real
0010:00 var sem2,set3,ses1,ses2,sr,tau11,tau22,tauear,aear=real
0011:00 var btens, taubl, set3f,sem1f,sem2f,fcearf, frf,f11f=real
0012:00 var f22f,slt3f,ses1f,ses2f,srf,tau1f,tau2f,taurf=real
0013:00 var taubf,btf, dsr,dtaur,dtaub,dbten,dsa,dsb,dpb=real
0014:00 var sdraf,sdrbf,pbushf,tau1f,tau2f=real
0015:00 var wao,wbr,ftr1,watr1,s1,s1f,s2,s2f,m1,m1f,m2=real
0016:00 var m2f,t3,t3f,tt3,tt3f,lbr,wtot=real
0017:00 var bs1,bs2,bt3,bm1,bm2,btt3=real
0018:00 dim real av(3)
0019:00 dim real wa(3)
0020:00 dim real wb(3)
0021:00 REM
0022:00 REM *** BURNS 7. ROE EAR FORCES ARE bs1 etc TURN ON WITH K=1***
0023:00 REM
0024:00 REM
0025:00 dim real a(3,3)
0026:00 dim real b(3)
0027:00 dim real glc(3,3)
0028:00 1 data 7.5, 10, .75, 1.95, 1.25, .7
0029:00 2 data 25,14.46,.531,53.,7.125,.31,1.5,2.5
0030:00 3 data 0.,.875,.46,.648,.138,2.41,1.4
0031:00 4 data 399,277,5.25,8.5,28.5,15.,6.875
0032:00 5 data 40.,10.96,26.5,30.5,2.075
0033:00 6 data 90.,90.,0.,0.,90.,90.
0034:00 7 data 90.,0.,90.,180.,90.,90.
0035:00 REM DATA 6&7 FOR VALVE/GLOBAL-G ORIENTATIONS AND WEIGHT VECTOR
0036:00 restore
0037:00 read d1,d2,c1,i1,c2,i2
0038:00 restore 2
0039:00 read lrod,lcg,x,phi,lave,ablt,l1,l2
0040:00 restore 3
0041:00 read fst2,ca,ia,cb,ib,aa,ab
0042:00 restore 4
0043:00 read wao,wbr,e1,e2,e3,e4,e5
0044:00 restore 5
0045:00 read lrodo,lcgo,ldr,d,abush
0046:00 restore 6
0047:00 read a(1,1),a(2,1),a(3,1),a(1,2),a(2,2),a(3,2)
0048:00 restore 7
0049:00 read a(1,3),a(2,3),a(3,3),av(1),av(2),av(3)
0050:00 text 0,& INPUT GLOBAL ACCELERATIONS &
0051:00 input b(1),b(2),b(3)
0052:00 print
0053:00 text 0,& INPUT DATA &
0054:00 print
0055:00 print "GLOBAL G-LEVELS = ";b(1),b(2),b(3)
0056:00 print "NORTH VECTOR ANGLES = ";a(1,1),a(2,1),a(3,1)
```

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>0T.01/E</u>
SHEET NO. <u>A-19</u>

```

0060:00 print
0061:00 for i=1 to 3
0062:02   a(j,i)=a(j,i)*2.*3.1416/360.
0063:02   glc(j,i)=b(i)*cos(a(j,i))
0064:02 next j
0065:01 next i
0066:00 for j=1 to 3
0067:01   av(j)=av(j)*2.*3.1416/360.
0068:01 next j
0069:00 print
0070:00 text 0,& LOCAL G-LEVELS &
0071:00 print
0072:00 print glc(1,1),glc(1,2),glc(1,3)
0073:00 print glc(2,1),glc(2,2),glc(2,3)
0074:00 print glc(3,1),glc(3,2),glc(3,3)
0075:00 REM WEIGHT COMPONENTS
0076:00 for j=1 to 3
0077:01   wa(j)=wao*cos(av(j))
0078:01   wb(j)=wbr*cos(av(j))
0079:01 next j
0080:00 phi=phi*2.*3.1416/360.
0081:00 la=lave/2
0082:00 ci12=c1/i2
0083:00 ci21=c2/i1
0084:00 aear=l1*l2
0085:00 REM CALCULATE EAR FORCES USE B&R LOADS AS OPTION LATER
0086:00 REM FIXED COMPONENTS ARE ALWAYS THERE
0087:00 lbr=lrod+lcg
0088:00 watr1=lbr*wa(1)/lrod
0089:00 s1f=wb(1)+watr1
0090:00 wtot=wao+wbr
0091:00 s2f=wb(2)+wa(2)+fst2
0092:00 t3f=wa(3)+wb(3)
0093:00 m1f=-(wa(2)+wb(2)+fst2)*e5-wa(3)*(e3+lcg)-wb(3)*e4
0094:00 m2f=(watr1+wb(1))*e5-wa(3)*e2-wb(3)*e1
0095:00 tt3f=watr1*e3+(wa(2)+fst2)*e2+wb(1)*e4+wb(2)*e1
0096:00 fcdrf=lcg*wa(1)/lrod
0097:00 maf=fcdrf*(lrod-13.5)
0098:00 mbf=fcdrf*7.125
0099:00 sdrarf=fst2/aa+abs(maf*ca/ia)
0100:00 sdrbf=fst2/ab+abs(mbf*cb/ib)
0101:00 fcof=lco*wa(1)/lrodo
0102:00 pbushf=fcof*(ldr+d)/(d*abush)
0103:00 REM STRESSES FROM FIXED COMPONENTS
0104:00 dear=(d1*d1+d2*d2)**.5
0105:00 set3f=abs(t3f/(4*aear))
0106:00 sem1f=abs(m1f/(2*d2*aear))
0107:00 sem2f=abs(m2f/(2*d1*aear))
0108:00 fcearf=tt3f/(2*dear)
0109:00 frf=x*fcearf
0110:00 f11f=-(fcearf*sin(phi)-frf*cos(phi))
0111:00 f22f=fcearf*cos(phi)+frf*sin(phi)
0112:00 stt3f=abs(f11f*la*ci12)+abs(f22f*la*ci21)
0113:00 ses1f=abs(s1f*ci12*la/4.)
0114:00 ses2f=abs(s2f*ci21*la/4.)
0115:00 srf=set3f+sem1f+sem2f+ses1f+ses2f+stt3f
0116:00 REM EAR SHEAR
0117:00 tau11f=abs(s1f/(4*aear))+abs(f11f/aear)
0118:00 tau22f=abs(s2f/(4*aear))+abs(f22f/aear)
0119:00 taurf=(tau11f*tau11f+tau22f*tau22f)**.5
0120:00 taubf=taurf*aear/abl
0121:00 REM EARBOLT TENSION
0122:00 btf=(set3f+sem1f+sem2f)*aear/abl
0123:00 print
0124:00 print"OPERATING DRIVE ROD STRESS AT A ";sdrarf
0125:00 print"OPERATING DRIVE ROD STRESS AT B ";sdrbf

```

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>ST.01/E</u>
SHEET NO. <u>A-90</u>

```

0126:00 print"OPERATING CYLINDER BRG PRESSURE ";pbushf
0127:00 print"OPERATING VALVE EAR TENSILE STR ";srf
0128:00 print"OPERATING VALVE EAR SHEAR STRESS ";taurf
0129:00 print"OPERATING EAR BOLT SHEAR STRESS ";taubf
0130:00 print"OPERATING EAR BOLT TENSILE STR ";btf
0131:00 print
^132:00 REM
 133:00 REM CALCULATE VARIABLE COMPONENTS
0134:00 REM
0135:00 dsr=0.
0136:00 dtaur=0.
0137:00 dtaub=0.
0138:00 dbten=0.
0139:00 dsa=0.
0140:00 dsb=0.
0141:00 dpb=0.
0142:00 for j=1 to 3
0143:01 fco=lcgo*wao*glc(1,j)/lrodo
0144:01 pbush=fco*(ldr+d)/(d*abush)
0145:01 ftr1=lbr*wao*glc(1,j)/lrod
0146:01 s1=ftr1+wbr*glc(1,j)
0147:01 s2=wtot*glc(2,j)
0148:01 t3=wtot*glc(3,j)
0149:01 m1=-wtot*glc(2,j)*e5-wao*glc(3,j)*(e3+lcg)-wbr*glc(3,j)*e4
0150:01 m2=(ftr1+wbr*glc(1,j))*e5-(wao*e2+wbr*e1)*glc(3,j)
0151:01 tt3=ftr1*e3+wbr*glc(1,j)*e4+glc(2,j)*(wao*e2+wbr*e1)
0152:01 fcdr=lcg*wao*glc(1,j)/lrod
0153:01 ma=fcdr*(lrod-13.5)
0154:01 mb=fcdr*7.125
0155:01 siga=ma*ca/ia
0156:01 sigb=mb*cb/ib
0157:01 REM CALCULATE EAR TENSION
 58:01 set3=abs(t3/(4*aeear))
 159:01 sem1=abs(m1/(2*d2*aeear))
0160:01 sem2=abs(m2/(2*d1*aeear))
0161:01 fcear=tt3/(2*dear)
0162:01 fr=x*fcear
0163:01 f11=-(fcear*sin(phi)-fr*cos(phi))
0164:01 f22=fcear*cos(phi)+fr*sin(phi)
0165:01 stt3=abs(f11*la*ci12)+abs(f22*la*ci21)
0166:01 ses1=abs(s1*ci12*la/4.)
0167:01 ses2=abs(s2*ci21*la/4.)
0168:01 sr=set3+sem1+sem2+ses1+ses2+stt3
0169:01 REM EAR SHEAR
0170:01 tau11=abs(s1/(4.*aeear))+abs(f11/aeear)
0171:01 tau22=abs(s2/(4.*aeear))+abs(f22/aeear)
0172:01 tauear=(tau11*tau11+tau22*tau22)**.5
0173:01 taubl t=tauear*aeear/abl t
0174:01 REM EARBOLT TENSION
0175:01 btens=(set3+sem1+sem2)*aeear/abl t
0176:01 dsa=dsa+siga*siga
0177:01 dsb=dsb+sigb*sigb
0178:01 dpb=dpb+pbush*pbush
0179:01 dsr=dsr+sr*sr
0180:01 dtaur=dtaur+tauear*tauear
0181:01 dtaub=dtaub+taubl t*taubl t
0182:01 dbten=dbten+btens*btens
^183:01 next j
 84:00 REM COMBINE STRESSES
0185:00 dsa=dsa**.5
0186:00 dsb=dsb**.5
0187:00 dpb=dpb**.5
0188:00 dsr=dsr**.5
0189:00 dtaur=dtaur**.5
0190:00 dtaub=dtaub**.5
0191:00 dbten=dbten**.5

```

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01/E</u>
SHEET NO. <u>A21</u>

```

0192:00 print
0193:00 text 0,& DYNAMIC COMPONENTS &
0194:00 print
0195:00 print "DRIVE ROD TENSILE STRESS AT A";dsa
0196:00 print "DRIVE ROD TENSILE STRESS AT B";dsb
0197:00 print "BUSHING PRESSURE";dpb
0198:00 print "VALVE EAR TENSILE STRESS";dsr
0199:00 print "VALVE EAR SHEAR STRESS";dtaur
0200:00 print "EAR BOLT SHEAR STRESS";dtaub
0201:00 print "EAR BOLT TENSILE STRESS";dbten
0202:00 dsa=dsa+abs(sdraf)
0203:00 dsb=dsb+abs(sdrbf)
0204:00 dpb=dpb+abs(pbushf)
0205:00 dsr=dsr+abs(srf)
0206:00 dtaur=dtaur+abs(taurf)
0207:00 dtaub=dtaub+abs(taubf)
0208:00 dbten=dbten+abs(btff)
0209:00 print
0210:00 text 0,& FIXED PLUS DYNAMIC COMPONENTS &
0211:00 print
0212:00 print "DRIVE ROD TENSILE STRESS AT A";dsa
0213:00 print "DRIVE ROD TENSILE STRESS AT B";dsb
0214:00 print "PUSHING PRESSURE";dpb
0215:00 print "VALVE EAR TENSILE STRESS";dsr
0216:00 print "VALVE EAR SHEAR STRESS";dtaur
0217:00 print "EAR BOLT SHEAR STRESS";dtaub
0218:00 print "EAR BOLT TENSILE STRESS";dbten
0219:00 end
0220:00
0221:00
0222:00
0223:00
0224:00
0225:00

```

***** End of program *****

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01/F</u>
SHEET NO. <u>A-22</u>

csp6

INPUT GLOBAL ACCELERATIONS

? 11.39, 3.33, 5.85

INPUT DATA

GLOBAL G-LEVELS	=	11.39	3.33	5.85
NORTH VECTOR ANGLES	=	90	90	0
VERTICAL VECTOR ANGLES	=	0	90	90
EAST VECTOR ANGLES	=	90	0	90

LOCAL G-LEVELS

-4.34494E-5	3.33	-2.2316E-5
-4.34494E-5	-1.27029E-5	5.85
11.39	-1.27029E-5	-2.2316E-5

OPERATING DRIVE ROD STRESS AT A 5048.35
OPERATING DRIVE ROD STRESS AT B 7721.14
OPERATING CYLINDER BRG PRESSURE -98.4646
OPERATING VALVE EAR TENSILE STR 4664.25
OPERATING VALVE EAR SHEAR STRESS 297.614
OPERATING EAR BOLT SHEAR STRESS 3600.17
OPERATING EAR BOLT TENSILE STR 1340.69

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 16811
DRIVE ROD TENSILE STRESS AT B 25711.4
BUSHING PRESSURE 327.887
VALVE EAR TENSILE STRESS 17822.1
VALVE EAR SHEAR STRESS 1154.32
EAR BOLT SHEAR STRESS 13963.6
EAR BOLT TENSILE STRESS 57543

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 21859.4
DRIVE ROD TENSILE STRESS AT B 33432.5
PUSHING PRESSURE 426.352
VALVE EAR TENSILE STRESS 22486.4
VALVE EAR SHEAR STRESS 1451.93
EAR BOLT SHEAR STRESS 17563.7
EAR BOLT TENSILE STRESS 58883.7

23 11 77

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>DT.011F</u>
SHEET NO. <u>A-23</u>

csp6

INPUT GLOBAL ACCELERATIONS
? .39, 3.33, 5.85

INPUT DATA

GLOBAL G-LEVELS	=	11.39	3.33	5.85
NORTH VECTOR ANGLES	=	90	90	0
VERTICAL VECTOR ANGLES	=	0 90	90	
EAST VECTOR ANGLES	=	90	0	90

LOCAL G-LEVELS

-4.34494E-5	3.33	-2.2316E-5
-4.34494E-5	-1.27029E-5	5.85
11.39	-1.27029E-5	-2.2316E-5

OPERATING DRIVE ROD STRESS AT A 5048.35
OPERATING DRIVE ROD STRESS AT B 7721.14
OPERATING CYLINDER BRG PRESSURE -98.4646
OPERATING EAR WELD TENSILE STR 5107.51
OPERATING EAR WELD SHEAR STRES 631.431
OPERATING EAR BOLT SHEAR STRESS 3600.17
OPERATING EAR BOLT TENSILE STR 1340.69

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 16811
DRIVE ROD TENSILE STRESS AT B 25711.4
BUSHING PRESSURE 327.887
EAR WELD TENSILE STRESS 21586.2
EAR WELD SHEAR STRESS 2449.05
EAR BOLT SHEAR STRESS 13963.6
EAR BOLT TENSILE STRESS 57543

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 21859.4
DRIVE ROD TENSILE STRESS AT B 33432.5
PUSHING PRESSURE 426.352
EAR WELD TENSILE STRESS 26693.7
EAR WELD SHEAR STRESS 3080.48
EAR BOLT SHEAR STRESS 17563.7
EAR BOLT TENSILE STRESS 58883.7

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>A-24</u>

sp6

INPUT GLOBAL ACCELERATIONS

? .39,3.33,5.85

INPUT DATA

GLOBAL G-LEVELS	=	11.39	3.33	5.85
NORTH VECTOR ANGLES	=	90	90	0
VERTICAL VECTOR ANGLES	=	0	90	90
EAST VECTOR ANGLES	=	90	0	90

LOCAL G-LEVELS

-4.34494E-5	3.33	-2.2316E-5
-4.34494E-5	-1.27029E-5	5.85
11.39	-1.27029E-5	-2.2316E-5

OPERATING DRIVE ROD STRESS AT A 5048.35
 OPERATING DRIVE ROD STRESS AT B 7721.14
 OPERATING CYLINDER BRG PRESSURE -98.4646
 OPERATING VALVE EAR TENSILE STR 4664.25
 OPERATING VALVE EAR SHEAR STRES 297.614
 OPERATING EAR BOLT SHEAR STRESS 3600.17
 OPERATING EAR BOLT TENSILE STR 1340.69

1f=-906.782
 s2=-2.57874E-3
 t3f=-2.57873E-3
 m1f= 9.89667E-2
 m2f=-6234.1
 tt3f=-22103.8

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 16811
 DRIVE ROD TENSILE STRESS AT B 25711.4
 BUSHING PRESSURE 327.887
 VALVE EAR TENSILE STRESS 17822.1
 VALVE EAR SHEAR STRESS 1154.32
 EAR BOLT SHEAR STRESS 13963.6
 EAR BOLT TENSILE STRESS 57543

s1d= 3019.58
 s2d= 3954.6
 t3d= 7699.63
 m1d= 2.44083E+5
 m2d= 58968.3
 tt3d= 78875.3

ED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 21859.4
 DRIVE ROD TENSILE STRESS AT B 33432.5
 PUSHING PRESSURE 426.352
 VALVE EAR TENSILE STRESS 22486.4
 VALVE EAR SHEAR STRESS 1451.93
 EAR BOLT SHEAR STRESS 17563.7

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.OI.F</u>
SHEET NO. <u>A-25</u>

EAR BOLT TENSILE STRESS

58883.7

s1t= 3926.36
s2t= 3954.6
t3t= 7699.64
m1t= 2.44083E+5
m2t= 65202.4
tt = 1.00979E+5

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>0T.01.F</u>
SHEET NO. <u>A-26</u>

CEP4

II IT GLOBAL ACCELERATIONS EMERGENCY
? 11.37,3.18,5.83

INPUT DATA

GLOBAL G-LEVELS	=	11.37	3.18	5.83
NORTH VECTOR ANGLES	=	90	90	0
VERTICAL VECTOR ANGLES	=	0 90	90	
EAST VECTOR ANGLES	=	90	0	90

LOCAL G-LEVELS

-4.33731E-5	3.18	-2.22397E-5
-4.33731E-5	-1.21307E-5	5.83
11.37	-1.21307E-5	-2.22397E-5

OPERATING DRIVE ROD STRESS AT A 5048.35
OPERATING DRIVE ROD STRESS AT B 7721.14
OPERATING CYLINDER BRG PRESSURE -98.4646
OPERATING EAR WELD TENSILE STR 5107.51
OPERATING EAR WELD SHEAR STRESS 631.431
OPERATING EAR BOLT SHEAR STRESS 3600.17
OPERATING EAR BOLT TENSILE STR 1340.69

D. MIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 16053.7
DRIVE ROD TENSILE STRESS AT B 24553.2
BUSHING PRESSURE 313.117
EAR WELD TENSILE STRESS 20967
EAR WELD SHEAR STRESS 2365.96
EAR BOLT SHEAR STRESS 13489.8
EAR BOLT TENSILE STRESS 57426.5

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 21102.1
DRIVE ROD TENSILE STRESS AT B 32274.4
PUSHING PRESSURE 411.582
EAR WELD TENSILE STRESS 26074.5
EAR WELD SHEAR STRESS 2997.39
EAR BOLT SHEAR STRESS 17090
EAR BOLT TENSILE STRESS 58767.2

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>A-27</u>

csp6

INPUT GLOBAL ACCELERATIONS UPSET
? 2.69, 3.09, 1.48

IN. JT DATA

GLOBAL G-LEVELS	=	2.69	3.09	1.48
NORTH VECTOR ANGLES	=	90	90	0
VERTICAL VECTOR ANGLES	=	0	90	90
EAST VECTOR ANGLES	=	90	0	90

LOCAL G-LEVELS

-1.02615E-5	3.09	-5.64575E-6
-1.02615E-5	-1.17874E-5	1.48
2.69	-1.17874E-5	-5.64575E-6

OPERATING DRIVE ROD STRESS AT A 5048.35
 OPERATING DRIVE ROD STRESS AT B 7721.14
 OPERATING CYLINDER BRG PRESSURE -98.4646
 OPERATING EAR WELD TENSILE STR 5107.51
 OPERATING EAR WELD SHEAR STRES 631.431
 OPERATING EAR BOLT SHEAR STRESS 3600.17
 OPERATING EAR BOLT TENSILE STR 1340.69

DYNAMIC COMPONENTS

DR : ROD TENSILE STRESS AT A 15599.4
 DRIVE ROD TENSILE STRESS AT B 23858.3
 BUSHING PRESSURE 304.256
 EAR WELD TENSILE STRESS 16110.8
 EAR WELD SHEAR STRESS 1976.81
 EAR BOLT SHEAR STRESS 11271
 EAR BOLT TENSILE STRESS 14173.8

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 20647.7
 DRIVE ROD TENSILE STRESS AT B 31579.4
 PUSHING PRESSURE 402.72
 EAR WELD TENSILE STRESS 21218.3
 EAR WELD SHEAR STRESS 2608.24
 EAR BOLT SHEAR STRESS 14871.2
 EAR BOLT TENSILE STRESS 15514.5

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. 07.01.F
SHEET NO. A-28

sbasic cep3a
 tm
 S-BASIC Compiler Version 5.4b

```

001:00 REM***** BIF VALVE AND AIR OPERATOR SEISMIC STRESS *****
J002:00 REM***** CEP-V/AO-3A *****
0003:00 REM
0004:00 var i,j,k = integer
0005:00 var lrod,lcg,x,phi,lave,abl1,12,e1,e2,e3,e4,e5 = real
0006:00 var fst2, ca,ia,cb,ib,aa,ab,d1,d2,c1,i1,c2,i2=real
0007:00 var lrodo,lcgo,ldr,d, abush, pbush=real
0008:00 var fcof, fco, ma,mb, siga, sigb, fcdr, fcdrf,maf, mbf=real
0009:00 var dear, fcear,fr, f11,f22,1a, ci12,ci21,slt3,sem1=real
0010:00 var sem2,set3,ses1,ses2,sr,tau11,tau22,tauear,aear=real
0011:00 var btens, taubl1, set3f,sem1f,sem2f,fcearf, frf,f11f=real
0012:00 var f22f,slt3f,ses1f,ses2f,srf,taul1f,tau2f,taurf=real
0013:00 var taubf,btf, dsr,dtaur,dtaub,dbten,dsa,dsb,dpb=real
0014:00 var sdraf,sdrbf,pbushf,tau11f,tau22f=real
0015:00 var wao,wbr,ftr1,watr1,s1,s1f,s2,s2f,m1,m1f,m2=real
0016:00 var m2f,t3,t3f,tt3,tt3f,lbr,wtot=real
0017:00 var bs1,bs2,bt3,bm1,bm2,btt3=real
0018:00 dim real av(3)
0019:00 dim real wa(3)
0020:00 dim real wb(3)
0021:00 REM
0022:00 REM *** BURNS 7 ROE EAR FORCES ARE bs1 etc TURN ON WITH K=1***
0023:00 REM
0024:00 REM
0025:00 dim real a(3,3)
0026:00 dim real b(3)
0027:00 dim real glc(3,3)
0028:00 1 data 7.5, 10, .75, 1.95, 1.25, .7
0029:00 2 data 25,14.46,.531,53.,7.125,.31,1.5,2.5
0030:00 3 data 1150.,.875,.46,.648,.138,2.41,1.4
0031:00 4 data 399,277,5.25,8.5,28.5,15.,6.875
0032:00 5 data 40.,10.96,26.5,30.5,2.075
0033:00 6 data 90.,90.,0.,90.,0.,90.
0034:00 7 data 180.,90.,90.,90.,180.,90.
0035:00 REM DATA 6&7 FOR VALVE/GLOBAL-G ORIENTATIONS AND WEIGHT VECTOR
0036:00 restore
0037:00 read d1,d2,c1,i1,c2,i2
0038:00 restore 2
0039:00 read lrod,lcg,x,phi,lave,abl1,12
0040:00 restore 3
0041:00 read fst2,ca,ia,cb,ib,aa,ab
0042:00 restore 4
0043:00 read wao,wbr,e1,e2,e3,e4,e5
0044:00 restore 5
0045:00 read lrodo,lcgo,ldr,d,abush
0046:00 restore 6
0047:00 read a(1,1),a(2,1),a(3,1),a(1,2),a(2,2),a(3,2)
0048:00 restore 7
0049:00 read a(1,3),a(2,3),a(3,3),av(1),av(2),av(3)
0050:00 text 0,& INPUT GLOBAL ACCELERATIONS &
0051:00 input b(1),b(2),b(3)
0052:00 print
0053:00 text 0,& INPUT DATA &
0054:00 print
0055:00 print "GLOBAL G-LEVELS = ";b(1),b(2),b(3)
0056:00 print "NORTH VECTOR ANGLES = ";a(1,1),a(2,1),a(3,1)
0057:00 print "VERTICAL VECTOR ANGLES=" ";a(1,2),a(2,2),a(3,2)
0058:00 print "EAST VECTOR ANGLES = ";a(1,3),a(2,3),a(3,3)
    
```

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>07.01/E</u>
SHEET NO. <u>A-24</u>

Compilation complete

ce. a

INPUT GLOBAL ACCELERATIONS
? 4.57, 1.26, .86

CEP-V-3A (FAULTED)

INPUT DATA

GLOBAL G-LEVELS	=	4.57	1.26	.86
NORTH VECTOR ANGLES	=	90	90	0
VERTICAL VECTOR ANGLES	=	90	0	90
EAST VECTOR ANGLES	=	180	90	90
WEIGHT VECTOR ANGLES	=	90	180	90

LOCAL G-LEVELS

-1.74332E-5	-4.80652E-6	-.86
-1.74332E-5	1.26	-3.28064E-6
4.57	-4.80652E-6	-3.28064E-6

OPERATING DRIVE ROD STRESS AT A 477.198
OPERATING DRIVE ROD STRESS AT B 821.458
OPERATING CYLINDER BRG PRESSURE -3.75613E-4
OPERATING VALVE EAR TENSILE STR 1136.52
OPERATING VALVE EAR SHEAR STRES 89.1706
OPERATING EAR BOLT SHEAR STRESS 1078.68
OPERATING EAR BOLT TENSILE STR 525.595

s1f=-3.4591E-3
s2f= 474
t3f=-2.57873E-3
m1f=-3258.67
m2f=-5.29623E-3
tt3f= 4929.17

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 4341.57
DRIVE ROD TENSILE STRESS AT B 6640.18
BUSHING PRESSURE 84.6795
VALVE EAR TENSILE STRESS 4711.31
VALVE EAR SHEAR STRESS 285.935
EAR BOLT SHEAR STRESS 3458.89
EAR BOLT TENSILE STRESS 22999.3

s1d= 779.831
s2d= 851.76
t3d= 3089.31
m1d= 97498.6
m2d= 22785
t1 = 19965.7

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 4818.76
DRIVE ROD TENSILE STRESS AT B 7461.64
PUSHING PRESSURE 84.6799

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>A-30</u>

VALVE EAR TENSILE STRESS	5847.84
VALVE EAR SHEAR STRESS	375.106
EAR BOLT SHEAR STRESS	4537.57
EAR BOLT TENSILE STRESS	23524.9

s1t= 779.835
s2t= 1325.76
t5 3089.32
m1t= 1.00757E+5
m2t= 22785
tt3t= 24894.9

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>A-31</u>

Compilation complete

cep3-
GLOBAL ACCELERATIONS
? 4.57,1.26,0.86

INPUT DATA

GLOBAL G-LEVELS	=	4.57	1.26	.86
NORTH VECTOR ANGLES	=	90	90	0
VERTICAL VECTOR ANGLES	=	90	0	90
EAST VECTOR ANGLES	=	180	90	90
WEIGHT VECTOR ANGLES	=	90	180	90

LOCAL G-LEVELS

-1.74332E-5	-4.80652E-6	-.86
-1.74332E-5	1.26	-3.28064E-6
4.57	-4.80652E-6	-3.28064E-6


OPERATING DRIVE ROD STRESS AT A 477.198
OPERATING DRIVE ROD STRESS AT B 821.458
OPERATING CYLINDER BRG PRESSURE -3.75613E-4
OPERATING EAR WELD TENSILE STR 1326.01
OPERATING EAR WELD SHEAR STRESS 189.188
OPERATING EAR BOLT SHEAR STRESS 1078.68
OPERATING EAR BOLT TENSILE STR 525.595

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 4341.57
DRIVE ROD TENSILE STRESS AT B 6640.18
BUSHING PRESSURE 84.6795
EAR WELD TENSILE STRESS 6247.02
EAR WELD SHEAR STRESS 606.65
EAR BOLT SHEAR STRESS 3458.89
EAR BOLT TENSILE STRESS 22999.3

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 4818.76
DRIVE ROD TENSILE STRESS AT B 7461.64
PUSHING PRESSURE 84.6799
EAR WELD TENSILE STRESS 7573.03
EAR WELD SHEAR STRESS 795.838
EAR BOLT SHEAR STRESS 4537.57
EAR BOLT TENSILE STRESS 23524.9



sbasic cep4a
tm

7-BASIC Compiler Version 5.4b

```
0001:00 REM***** BIF VALVE AND AIR OPERATOR SEISMIC STRESS *****
0002:00 REM***** CEP-V/AO-4A *****
0003:00 REM
0004:00 var i,j,k = integer
0005:00 var lrod,lcg,x,phi,lave,ablt,l1,l2,e1,e2,e3,e4,e5 = real
0006:00 var fst2,ca,ia,cb,ib,aa,ab,d1,d2,c1,i1,c2,i2=real
0007:00 var lrodo,lcgo,ldr,d,abush,pbush=real
0008:00 var fcof,fco,ma,mb,siga,sigb,fcdr,fcdrf,maf,mbf=real
0009:00 var dear,fcear,fr,f11,f22,la,ci12,ci21,stt3,sem1=real
0010:00 var sem2,set3,ses1,ses2,sr,tau11,tau22,taear,aear=real
0011:00 var btens,taublt,set3f,sem1f,sem2f,fcearf,frf,f11f=real
0012:00 var f22f,stt3f,ses1f,ses2f,srf,tau1f,tau2f,taurf=real
0013:00 var taubf,btf,dsr,dtaur,dtaub,dbten,dsa,dsb,dpb=real
0014:00 var sdraf,sdrbf,pbushf,tau11f,tau22f=real
0015:00 var wao,wbr,ftr1,watr1,s1,s1f,s2,s2f,m1,m1f,m2=real
0016:00 var m2f,t3,t3f,tt3,tt3f,lbr,wtot=real
0017:00 var bs1,bs2,bt3,bm1,bm2,btt3=real
0018:00 dim real av(3)
0019:00 dim real wa(3)
0020:00 dim real wb(3)
0021:00 REM
0022:00 REM *** BURNS 7 ROE EAR FORCES ARE bs1 etc TURN ON WITH K=1***
0023:00 REM
0024:00 REM
0025:00 dim real a(3,3)
0026:00 dim real b(3)
0027:00 dim real glc(3,3)
0028:00 1 data 7.5, 10, .75, 1.95, 1.25, .7
0029:00 2 data 25,14.46,.531,53.,7.125,.31,1.5,2.5
0030:00 3 data 1150.,.875,.46,.648,.138,2.41,1.4
0031:00 4 data 399,277,5.25,8.5,28.5,15.,6.875
0032:00 5 data 40.,10.96,26.5,30.5,2.075
0033:00 6 data 90.,-38.,52.,90.,52.,142.
0034:00 7 data 180.,90.,90.,90.,-128.,-38.
0035:00 REM DATA 6&7 FOR VALVE/GLOBAL-G ORIENTATIONS AND WEIGHT VECTOR
0036:00 restore
0037:00 read d1,d2,c1,i1,c2,i2
0038:00 restore 2
0039:00 read lrod,lcg,x,phi,lave,ablt,l1,l2
0040:00 restore 3
0041:00 read fst2,ca,ia,cb,ib,aa,ab
0042:00 restore 4
0043:00 read wao,wbr,e1,e2,e3,e4,e5
0044:00 restore 5
0045:00 read lrodo,lcgo,ldr,d,abush
0046:00 restore 6
0047:00 read a(1,1),a(2,1),a(3,1),a(1,2),a(2,2),a(3,2)
0048:00 restore 7
0049:00 read a(1,3),a(2,3),a(3,3),av(1),av(2),av(3)
0050:00 text 0,& INPUT GLOBAL ACCELERATIONS &
0051:00 input b(1),b(2),b(3)
0052:00 print
0053:00 text 0,& INPUT DATA &
0054:00 print
0055:00 print "GLOBAL G-LEVELS = ";b(1),b(2),b(3)
0056:00 print "NORTH VECTOR ANGLES = ";a(1,1),a(2,1),a(3,1)
0057:00 print "VERTICAL VECTOR ANGLES = ";a(1,2),a(2,2),a(3,2)
0058:00 print "EAST VECTOR ANGLES = ";a(1,3),a(2,3),a(3,3)
```

CYGNA
ATTACHMENT
JOB NO. <u>62044</u>
FILE NO. <u>OT.01/E</u>
SHEET NO. <u>A-33</u>


```

0059:00 print "WEIGHT VECTOR ANGLES = ";av(1),av(2),av(3)
0060:00 print
0061:00 for i=1 to 3
0062:01 for j=1 to 3
0063:02 a(j,i)=a(j,i)*2.*3.1416/360.
0064:02 glc(j,i)=b(i)*cos(a(j,i))
0065:02 next j
0066:01 next i
0067:00 for j=1 to 3
0068:01 av(j)=av(j)*2.*3.1416/360.
0069:01 next j
0070:00 print
0071:00 text 0,& LOCAL G-LEVELS &
0072:00 print
0073:00 print glc(1,1),glc(1,2),glc(1,3)
0074:00 print glc(2,1),glc(2,2),glc(2,3)
0075:00 print glc(3,1),glc(3,2),glc(3,3)
0076:00 REM WEIGHT COMPONENTS
0077:00 for j=1 to 3
0078:01 wa(j)=wao*cos(av(j))
0079:01 wb(j)=wbr*cos(av(j))
0080:01 next j
0081:00 phi=phi*2.*3.1416/360.
0082:00 la=lave/2
0083:00 ci12=c1/i2
0084:00 ci21=c2/i1
0085:00 aear=l1*i2
0086:00 REM CALCULATE EAR FORCES USE B&R LOADS AS OPTION LATER
0087:00 REM FIXED COMPONENTS ARE ALWAYS THERE
0088:00 lbr=lrod+lcg
0089:00 watr1=lbr*wa(1)/lrod
0090:00 s1f=wb(1)+watr1
0091:00 wtot=wao+wbr
0092:00 s2f=wb(2)+wa(2)+fst2
0093:00 t3f=wa(3)+wb(3)
0094:00 m1f=-(wa(2)+wb(2)+fst2)*e5-wa(3)*(e3+lcg)-wb(3)*e4
0095:00 m2f=(watr1+wb(1))*e5-wa(3)*e2-wb(3)*e1
0096:00 tt3f=watr1*e3+(wa(2)+fst2)*e2+wb(1)*e4+wb(2)*e1
0097:00 fcdrf=lcg*wa(1)/lrod
0098:00 maf=fcdrf*(lrod-13.5)
0099:00 mbf=fcdrf*7.125
0100:00 sdrarf=fst2/aa+abs(maf*ca/ia)
0101:00 sdrbf=fst2/ab+abs(mbf*cb/ib)
0102:00 fcof=lco*wa(1)/lrod
0103:00 pbushf=fcof*(ldr+d)/(d*abush)
0104:00 REM STRESSES FROM FIXED COMPONENTS
0105:00 dear=(d1*d1+d2*d2)**.5
0106:00 set3f=abs(t3f/(4*aear))
0107:00 sem1f=abs(m1f/(2*d2*aear))
0108:00 sem2f=abs(m2f/(2*d1*aear))
0109:00 fcearf=tt3f/(2*dear)
0110:00 frf=x*fcearf
0111:00 f11f=-(fcearf*sin(phi)-frf*cos(phi))
0112:00 f22f=fcearf*cos(phi)+frf*sin(phi)
0113:00 stt3f=abs(f11f*la*ci12)+abs(f22f*la*ci21)
0114:00 ses1f=abs(s1f*ci12*la/4.)
0115:00 ses2f=abs(s2f*ci21*la/4.)
0116:00 srf=set3f+sem1f+sem2f+ses1f+ses2f+stt3f
0117:00 REM EAR SHEAR
0118:00 tau11f=abs(s1f/(4*aear))+abs(f11f/aear)
0119:00 tau22f=abs(s2f/(4*aear))+abs(f22f/aear)
0120:00 taurf=(tau11f*tau11f+tau22f*tau22f)**.5
0121:00 taubf=taurf*aear/abl t
0122:00 REM EARBOLT TENSION
0123:00 btff=(set3f+sem1f+sem2f)*aear/abl t
0124:00 print

```

CYGNA

ATTACHMENT

JOB NO. 82044

FILE NO. OT.01/E

SHEET NO. A-34

```

0125:00 print"OPERATING DRIVE ROD STRESS AT A ";sdraf
0126:00 print"OPERATING DRIVE ROD STRESS AT B ";sdrbf
0127:00 print"OPERATING CYLINDER BRG PRESSURE ";pbushf
0128:00 print"OPERATING VALVE EAR TENSILE STR ";srf
0129:00 print"OPERATING VALVE EAR SHEAR STRESS ";taurf
0130:00 print"OPERATING EAR BOLT SHEAR STRESS ";taubf
0131:00 print"OPERATING EAR BOLT TENSILE STR ";btf
      i32:00 print
0133:00 REM
0134:00 REM CALCULATE VARIABLE COMPONENTS
0135:00 REM
0136:00 dsr=0.
0137:00 dtaur=0.
0138:00 dtaub=0.
0139:00 dbten=0.
0140:00 dsa=0.
0141:00 dsb=0.
0142:00 dpb=0.
0143:00 for j=1 to 3
0144:01 fco=lcg*wao*glc(1,j)/lrodo
0145:01 pbush=fco*(ldr+d)/(d*abush)
0146:01 ftr1=lbr*wao*glc(1,j)/lrod
0147:01 s1=ftr1+wbr*glc(1,j)
0148:01 s2=wtot*glc(2,j)
0149:01 t3=wtot*glc(3,j)
0150:01 m1=-wtot*glc(2,j)*e5-wao*glc(3,j)*(e3+lcg)-wbr*glc(3,j)*e4
0151:01 m2=(ftr1+wbr*glc(1,j))*e5-(wao*e2+wbr*e1)*glc(3,j)
0152:01 tt3=ftr1*e3+wbr*glc(1,j)*e4+glc(2,j)*(wao*e2+wbr*e1)
0153:01 fcdr=lcg*wao*glc(1,j)/lrod
0154:01 ma=fcdr*(lrod-13.5)
0155:01 mb=fcdr*7.125
0156:01 siga=ma*ca/ia
0157:01 sigb=mb*cb/ib
0158:01 REM CALCULATE EAR TENSION
0159:01 set3=abs(t3/(4*aeear))
0160:01 sem1=abs(m1/(2*d2*aeear))
0161:01 sem2=abs(m2/(2*d1*aeear))
0162:01 fcear=tt3/(2*dear)
0163:01 fr=x*fcear
0164:01 f11=-(fcear*sin(phi)-fr*cos(phi))
0165:01 f22=fcear*cos(phi)+fr*sin(phi)
0166:01 stt3=abs(f11*1a*ci12)+abs(f22*1a*ci21)
0167:01 ses1=abs(s1*ci12*1a/4.)
0168:01 ses2=abs(s2*ci21*1a/4.)
0169:01 sr=set3+sem1+sem2+ses1+ses2+stt3
0170:01 REM EAR SHEAR
0171:01 tau11=abs(s1/(4.*aeear))+abs(f11/aeear)
0172:01 tau22=abs(s2/(4.*aeear))+abs(f22/aeear)
0173:01 tauear=(tau11*tau11+tau22*tau22)**.5
0174:01 taubl t=tauear*aeear/abl t
0175:01 REM EARBOLT TENSION
0176:01 btens=(set3+sem1+sem2)*aeear/abl t
0177:01 dsa=dsa+siga*siga
0178:01 dsb=dsb+sigb*sigb
0179:01 dpb=dpb+pbush*pbush
0180:01 dsr=dsr+sr*sr
0181:01 dtaur=dtaur+tauear*tauear
0182:01 dtaub=dtaub+taubl t*taubl t
0183:01 dbten=dbten+btens*btens
0184:01 next j
0185:00 REM COMBINE STRESSES
0186:00 dsa=dsa**.5
0187:00 dsb=dsb**.5
0188:00 dpb=dpb**.5
0189:00 dsr=dsr**.5
0190:00 dtaur=dtaur**.5

```

CYGNA
ATTACHMENT
JOB NO. <u>B2044</u>
FILE NO. <u>OT-01/E</u>
SHEET NO. <u>A-35</u>

```
0191:00 dtaub=dtaub**.5
0192:00 dbten=dbten**.5
0193:00 print
0194:00 text 0,& DYNAMIC COMPONENTS &
0195:00 print
0196:00 print "DRIVE ROD TENSILE STRESS AT A";dsa
0197:00 print "DRIVE ROD TENSILE STRESS AT B";dsb
0198:00 print "BUSHING PRESSURE";dps
0199:00 print "VALVE EAR TENSILE STRESS";dsr
0200:00 print "VALVE EAR SHEAR STRESS";dtaur
0201:00 print "EAR BOLT SHEAR STRESS";dtaub
0202:00 print "EAR BOLT TENSILE STRESS";dbten
0203:00 dsa=dsa+abs(sdra)
0204:00 dsb=dsb+abs(sdrb)
0205:00 dps=dps+abs(psbush)
0206:00 dsr=dsr+abs(srf)
0207:00 dtaur=dtaur+abs(taurf)
0208:00 dtaub=dtaub+abs(taubf)
0209:00 dbten=dbten+abs(bt)
0210:00 print
0211:00 text 0,& FIXED PLUS DYNAMIC COMPONENTS &
0212:00 print
0213:00 print "DRIVE ROD TENSILE STRESS AT A";dsa
0214:00 print "DRIVE ROD TENSILE STRESS AT B";dsb
0215:00 print "PUSHING PRESSURE";dps
0216:00 print "VALVE EAR TENSILE STRESS";dsr
0217:00 print "VALVE EAR SHEAR STRESS";dtaur
0218:00 print "EAR BOLT SHEAR STRESS";dtaub
0219:00 print "EAR BOLT TENSILE STRESS";dbten
0220:00 end
0221:00
0222:00
0223:00
0224:00
0225:00
0226:00 ***** End of program *****
```

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01/F</u>
SHEET NO. <u>A-36</u>

cep4a

INPUT GLOBAL ACCELERATIONS

? 35, 1.34, .86

INPUT DATA

GLOBAL G-LEVELS	=	3.35	1.34	.86
NORTH VECTOR ANGLES	=	90	-38	52
VERTICAL VECTOR ANGLES	=	90	52	142
EAST VECTOR ANGLES	=	180	90	90
WEIGHT VECTOR ANGLES	=	90	-128	-38

LOCAL G-LEVELS

-1.27792E-5	-5.11169E-6	-.86
2.63983	.824984	-3.28064E-6
2.06246	-1.05594	-3.28064E-6

OPERATING DRIVE ROD STRESS AT A 477.198
OPERATING DRIVE ROD STRESS AT B 821.458
OPERATING CYLINDER BRG PRESSURE -3.75613E-4
OPERATING VALVE EAR TENSILE STR 1946.57
OPERATING VALVE EAR SHEAR STRESS 128.033
OPERATING EAR BOLT SHEAR STRESS 1548.79
OPERATING EAR BOLT TENSILE STR 4771.17

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 4341.57
DRIVE ROD TENSILE STRESS AT B 6640.18
BUSHING PRESSURE 84.6795
VALVE EAR TENSILE STRESS 5948.81
VALVE EAR SHEAR STRESS 379.211
EAR BOLT SHEAR STRESS 4587.24
EAR BOLT TENSILE STRESS 13246.5

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 4818.76
DRIVE ROD TENSILE STRESS AT B 7461.64
PUSHING PRESSURE 84.6799
VALVE EAR TENSILE STRESS 7895.38
VALVE EAR SHEAR STRESS 507.244
EAR BOLT SHEAR STRESS 6136.03
EAR BOLT TENSILE STRESS 18017.7

CYGNA

ATTACHMENT

JOB NO. 82044

FILE NO. 07.01/F

SHEET NO. A-37

A>b:

B>cep4a

INPUT GLOBAL ACCELERATIONS

? ? 35, 1.34, .86

INPUT DATA

FAULTED WELD;

GLOBAL G-LEVELS	=	3.35	1.34	.86
NORTH VECTOR ANGLES	=	90	-38	52
VERTICAL VECTOR ANGLES	=	90	52	142
EAST VECTOR ANGLES	=	180	90	90
WEIGHT VECTOR ANGLES	=	90	-128	-38

LOCAL G-LEVELS

-1.27792E-5	-5.11169E-6	-.86
2.63983	.824984	-3.28064E-6
2.06246	-1.05594	-3.28064E-6

OPERATING DRIVE ROD STRESS AT A 477.198
OPERATING DRIVE ROD STRESS AT B 821.458
OPERATING CYLINDER BRG PRESSURE -3.75613E-4
OPERATING EAR WELD TENSILE STR 2592.98
OPERATING EAR WELD SHEAR STRESS 271.64
OPERATING EAR BOLT SHEAR STRESS 1548.79
OPERATING EAR BOLT TENSILE STR 4771.17

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 4341.57
DRIVE ROD TENSILE STRESS AT B 6640.18
BUSHING PRESSURE 84.6795
EAR WELD TENSILE STRESS 7493.12
EAR WELD SHEAR STRESS 804.547
EAR BOLT SHEAR STRESS 4587.22
EAR BOLT TENSILE STRESS 13246.5

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 4818.76
DRIVE ROD TENSILE STRESS AT B 7461.64
PUSHING PRESSURE 84.6799
EAR WELD TENSILE STRESS 10086.1
EAR WELD SHEAR STRESS 1076.19
EAR BOLT SHEAR STRESS 6136.01
EAR BOLT TENSILE STRESS 18017.7

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>07.01.F</u>
SHEET NO. <u>A-38</u>

cep
CEP?

B> cep4a

INPUT GLOBAL ACCELERATIONS
?, 3.35, 1.34, .86

INPUT DATA

GLOBAL G-LEVELS	=	3.35	1.34	.86
NORTH VECTOR ANGLES	=	90	-38	52
VERTICAL VECTOR ANGLES	=	90	52	142
EAST VECTOR ANGLES	=	180	90	90
WEIGHT VECTOR ANGLES	=	90	-128	-38

LOCAL G-LEVELS

-1.27792E-5	-5.11169E-6	-.86
2.63983	.824984	-3.28064E-6
2.06246	-1.05594	-3.28064E-6

OPERATING DRIVE ROD STRESS AT A 477.198
OPERATING DRIVE ROD STRESS AT B 821.458
OPERATING CYLINDER BRG PRESSURE -3.75613E-4
OPERATING VALVE EAR TENSILE STR 1946.57
OPERATING VALVE EAR SHEAR STRESS 128.033
OPERATING EAR BOLT SHEAR STRESS 1548.79
OPERATING EAR BOLT TENSILE STR 4771.17

s1f=-3.4591E-3
s2f= 733.811
t3f= 532.695
m1f=-21826.4
m2f=-3818.52
tt3f= 6791.56

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 4341.57
DRIVE ROD TENSILE STRESS AT B 6640.18
BUSHING PRESSURE 84.6795
VALVE EAR TENSILE STRESS 5948.81
VALVE EAR SHEAR STRESS 379.211
EAR BOLT SHEAR STRESS 4587.24
EAR BOLT TENSILE STRESS 13246.5

s1d= 779.831
s2d= 1869.64
t3d= 1566.33
m1d= 59205.9
m2d= 12442.3
tt = 23258.6

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 4818.76
DRIVE ROD TENSILE STRESS AT B 7461.64
PUSHING PRESSURE 84.6799

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. OT.01.F
SHEET NO. A-39

VALVE EAR TENSILE STRESS
VALVE EAR SHEAR STRESS
EAR BOLT SHEAR STRESS
EAR BOLT TENSILE STRESS

7895.38
507.244
6136.03
18017.7

s1t= 779.835
s2t= 2603.45
t3 2099.02
m1t= 81032.3
m2t= 16260.8
tt3t= 30050.1

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>07.01.F</u>
SHEET NO. <u>A-40</u>

APPENDIX B

VALVE/AIR OPERATOR MODEL FOR
FINAL PIPING RESPONSE G-LEVEL CALCULATION.



Faint, illegible text located in the upper left quadrant of the page.



Faint, illegible text located in the lower left quadrant of the page.






Calculation Sheet


Project	WPPSS ER	Prepared By:	<i>J. E. K...</i>	Date	1/3/83
Subject	BIF VALVE / ACTUATOR MODEL SUMMARY	Checked By:	<i>H. E. J...</i>	Date	3/24/83
System	CSP	Job No.	82044	File No.	OT.01/F
Analysis No.	361104 +106	Rev. No.	0	Sheet No.	361106-4.3-B1

SUMMARY

A) MODEL CONFIGURATION



B) ACTUAL STRUCTURE



STRUCTURAL MEMBER DIRECTIONS

- ① +X
- ② -Y
- ③ -Z
- ④ +X
- ⑤ YZ-PLANE
- ⑥ +X
- ⑦ +Y
- ⑧ +Y
- ⑨ -Y



Calculation Sheet

Project	WPPSS	Prepared By:	[Signature]	Date	11/153
Subject	BIF VALVE / ACTUATOR MODEL	Checked By:	[Signature]	Date	3/24/83
System	CSP	Job No.	82024	File No.	OT.01F
Analysis No.	361104-3 361106	Rev. No.	0	Sheet No.	361106-4.3-B3

① VALVE EARS

8" CYL (24" VALVE)

$$\begin{aligned}
 A_x &= A_y = A_z = 15 \text{ IN}^2 \\
 I_{xx} &= 106 \text{ IN}^4 \\
 I_{yy} &= 11.2 \text{ IN}^4 \\
 I_{zz} &= 31.2 \text{ IN}^4 \\
 C_y &= 5.80 \text{ IN} \\
 C_z &= 3.75 \text{ IN} \\
 E &= 28 \times 10^6 \text{ PSI} \quad E_s = 11.6 \times 10^6 \text{ PSI} \\
 l &= 7.125 \text{ IN}
 \end{aligned}$$



- (21)
- (657)
- (21.4)
- (63)
- (5.25)
- (4.75)
- (4.85")

② BRACKET

(Purt P = 0 & odd 277# 15" down) 321#

$$\begin{aligned}
 A_x &= A_y = A_z = 6.84 \text{ IN}^2 \\
 I_{xx} &= 102 \text{ IN}^4 \\
 I_{yy} &= 1000 \text{ IN}^4 \\
 I_{zz} &= 2.16 \text{ IN}^4 \\
 C_x &= .25 \text{ IN} \\
 C_z &= 6.84 \text{ IN} \\
 E &= 28 \times 10^6 \text{ PSI} \quad E_s = 11.6 \times 10^6 \text{ PSI} \\
 l &= 28.5 \text{ IN} \text{ (15" down to CG)}
 \end{aligned}$$

- (8.5)
- (255)
- (1000 IN⁴)
- (4.22 IN⁴)
- (.313)
- (8.5)

③ & ④ BRACKET OFFSETS $L_3 = 8.8 \text{ IN}$ $L_4 = 3.375 \text{ IN}$
 (8.5") (8.0")

③ MASSLESS, RIGID LINK, 8.8" LONG (8.5)

④ " " , 6.875" " (8.0)

(END RELEASE FOR INSTANT)
 θ_{xx} ON ④



Calculation Sheet

Project	WPPSS EQ	Prepared By:	[Signature]	Date	11/7/83
Subject	BIF VALVE/ACTIVATOR MODEL	Checked By:	[Signature]	Date	5/22/83
System	CSP	Job No.	82044	File No.	OT.01/F
Analysis No.	361106-361104	Rev. No.	0	Sheet No.	361106-4.3-B3

⑤ SHAFT OFFSET

RIGID LINK 14.48" LONG (14.30)
AT 52.6° ↑ AS SHOWN

⑥ SHAFT

$$\begin{aligned}
 A_x = A_y = A_z &= 3.98 \text{ IN}^2 && (4.91) \\
 I_{xx} &= 2.52 \text{ IN}^4 && (3.04) \\
 I_{yy} &= 4 \text{ " } && (5.75) \\
 I_{zz} &= 1.26 \text{ " } && (1.92) \\
 C_y &= 1.125 && (1.25) \\
 C_z &= 1.125 && (1.25) \\
 E &= 29 \times 10^6 \text{ PSI} \quad E_s = 11.6 \times 10^6 \text{ PSI} \\
 L &= 14 \text{ in.} && (12.85 \text{ "})
 \end{aligned}$$


⑦ DRIVE ROD

$$\begin{aligned}
 A_x = 2.41 \quad A_y = 2.41 \quad A_z &= 2.41 \text{ IN}^2 && (2.41 \text{ IN}^2) \\
 I_{xx} = I_{zz} &= .46 \text{ IN}^4 && (.46 \text{ IN}^4) \\
 I_{yy} &= .92 \text{ IN}^4 && (.92 \text{ IN}^4) \\
 C_x = C_z &= .875 \text{ IN} && (.875 \text{ IN}) \\
 \text{HIGH STRENGTH} \quad E &= 30 \times 10^6 \text{ PSI} \quad E_s = 12 \times 10^6 \text{ PSI}
 \end{aligned}$$

⑧ & ⑨ CYLINDER


(PLUG P=0. → ADD 399# AT END.) → (593#)

$$\begin{aligned}
 L_8 &= 13.5 \text{ " } && (13.5 \text{ "}) \\
 L_9 &= 14.0 \text{ " } && (19 \text{ "}) \\
 I_{yy} &= 74 \text{ IN}^4 && (180 \text{ IN}^4) \\
 I_{xx} = I_{zz} &= 52 \text{ IN}^4 && (127 \text{ IN}^4) \\
 A_x = A_y = A_z &= 50 \text{ IN}^2 && (78 \text{ IN}^2) \\
 C_x = C_z &= 4 \text{ " } && (5 \text{ IN})
 \end{aligned}$$



Calculation Sheet

Project	WPPSS EQ	Prepared By:	A. E. Radomirski	Date	1/3/93
Subject	SAP MODEL - EIF VALVE/AO	Checked By:	W. E. Smith	Date	3/24/93
System	CSP	Job No.	82044	File No.	OT.0F/01
Analysis No.	361104 + 361106	Rev. No.	0	Sheet No.	361104-4.1 - B4



DESCRIPTION OF AO MODEL INCLUDING 4 VALVE EARS:


8" AO

① Derive Eon Model

$$K_{zz} = 4 * \text{stiffness of 1 ear}$$

$$= 4 * F_z / \Delta z$$

Use Roark, Pg 96, # 1b.:






Calculation Sheet

Project	WPPST. EO	Prepared By:	(Signature)	Date	1/3/83
Subject	REF. VALVE / ACTUATOR MODEL SUMMARY	Checked By:	(Signature)	Date	3/24/83
System	RSP	Job No.	82044	File No.	07.01/F
Analysis No.	361104-1-1716	Rev. No.	0	Sheet No.	361104-4.3-135

made 4/2/83
3/24/83
 Δ $M_A = 0$ $W \frac{(l-a)^2}{2l}$ $\theta_A = 0$

NOTE: SEE PAGE 4.3-53 OF REVISION 13

$$y_A = \frac{-W}{12EI} (l-a)^2 (l+2a) = \frac{-W}{12EI} l^3$$



$$\therefore \frac{F_z}{\Delta z} = \frac{12EI}{(l)^3} (a=0) = \frac{12 * 29 * 10^6 * 0.7}{(7.125)^3 * (4.85)^3} = .693 * 10^6 \frac{lb}{in}$$

(units) $= \frac{F}{L^2} * \frac{L^4}{L^2} = \frac{F}{L}$ (OK)

$$E_{200} \approx 29 * 10^6 \text{ PSI}$$

$$l = 7.125" (4.85")$$

$$I_{min} (\text{for } z\text{-axis}) = 0.70 \text{ in}^4$$

$$\left(\frac{1}{12} * 3.175^3 = 1.34\right)$$

$$I_{max} (\text{for } y\text{-axis}) = 1.95 \text{ in}^4$$


$$\left(\frac{1}{12} * 1.75 * .3 = 3.94\right)$$

$$K_{zz} = 4 * \frac{Ez}{\Delta z} = \frac{(16.34)}{2.694} * 10^6 \frac{lb}{in}$$

THE SECOND VALUES IN PARENTHESES ARE FOR 30" VALUES IN SIZE OF 22"

$$K_{yy} = 4 * \frac{Fy}{\Delta y} = 4 * \frac{12 EI_{max}}{l^3} = K_{zz} * \frac{1.95}{.7} = 7.52 * 10^6 \frac{lb}{in}$$

(3.94/1.34 = 2.94)




CONSIDER THE EAR-SYSTEM STIFFNESS IN THESE MODES VERY LARGE. BECAUSE OPERATION BRACKET BENDING WILL CONTROL



Calculation Sheet


Project	WPP3? EQ	Prepared By:	(Signature)	Date	1/13/73
Subject	BIF VALVE/ACTUATOR MODEL SUMMARY	Checked By:	(Signature)	Date	5/24/73
System	CSP	Job No.	82044	File No.	OT.01/E
Analysis No.	361104 & 106	Rev. No.	0	Sheet No.	361106-4.3-B6



The attached plate forces the axis to deflect tangent to the circle. The force on each axis is:

$$4F_c R = T \quad , \quad R = \left[\frac{3.75^2 + 25}{4.75^2 + 5.25^2} \right]^{1/2} = 6.25''$$


$$\text{Stiffness} = \frac{T}{\Delta \theta_x} = \frac{4F_c (7.08)}{\Delta \theta_x}$$



There is a reaction force which acts through the plate opposing the own deflection on the circle. This must be a radially-directed force: FR (no tangential contribution)

$$\Delta Y = - (F_c \cos \phi + F_R \sin \phi) \left[\frac{2^3}{12EI_{max}} + \frac{l}{k=1.5AG} \right]$$

$$\Delta Z = - (F_c \sin \phi - F_R \cos \phi) \left[\frac{2^3}{12EI_{min}} \right]$$



Calculation Sheet

Project	WPP-2 ED	Prepared By:	E. P. J. [Signature]	Date	1/3/83
Subject	BTF VALVE/ACTUATOR MODEL SUMMARY	Checked By:	[Signature]	Date	5/24/83
System	CSP	Job No.	82041	File No.	DT.01/E
Analysis No.	261104 1 Inb	Rev. No.	0	Sheet No.	361106-4.3-B7

$$\tan \phi = \frac{-\Delta z}{-\Delta y} = \frac{\Delta z}{\Delta y} = \frac{I_{max} (F_c \sin \phi - F_R \cos \phi)}{I_{min} (F_c \cos \phi + F_R \sin \phi)} = \frac{1.327}{1.105}$$

$$\frac{I_{max}}{I_{min}} = \frac{3.94}{1.34} = 2.94, \quad \sin \phi = .799 \quad (.742)$$

$$\cos \phi = .602 \quad (.671)$$

$$\therefore \frac{1.105}{2.94} = \frac{F_c (.799) - .602 F_R}{.602 F_c + .799 F_R} = \frac{.476}{.376}$$

$$.799 F_c - .602 F_R = .278 F_c + .353 F_R$$

$$(.464) = .21 F_c = .982 F_R \quad (.950)$$

$$F_R = .531 F_c \quad (.488)$$

NOTE: Another force F_R acts on valve stem - include in stress analysis.

2

★ SIGN CHANGES FOR F_R ON ALTERNATE ENDS.

To find θ :

$$\Delta \theta = \frac{\Delta C}{R} = \frac{-\Delta y}{R \cos \phi} = \frac{+(F_c \cos \phi + F_R \sin \phi) l^3}{R \cos \phi \cdot 12EI_{max}}$$

$$= \frac{l^3}{12EI_{max}} \left(\frac{F_c}{R} + \frac{.531 F_c}{R} \tan \phi \right)$$

$$\Delta \theta_x = \frac{l^3}{12REI_{max}} F_c \left(\frac{1.540}{1.704} \right) = \frac{14.64}{51.362} F_c \quad (1.105)$$

$$H \Delta \theta_x = \frac{T}{\Delta \theta_x} = \frac{4F_c R}{51.362 F_c} = \frac{4}{51.362} R^2 EI_{max}$$

$$= \frac{4}{(1.327)^2} F_c l^3 = F_c l^3 (1.327)^2$$




Calculation Sheet

Project	APPSS-ED	Prepared By:	J. E. Robinson	Date	3/25/83
Subject	BIF. PLATE - ACT. FOR. ACT. SUPPORT	Checked By:	M. J. Smith	Date	3.22.83
System	CSP	Job No.	02044	File No.	0T.011F
Analysis No.	361106-361106	Rev. No.	0	Sheet No.	361106-4.3-B3

$$K_{\theta\theta} = \frac{.078(6.25)^2 (29)(10)^6 (1.95)}{(7.08)(3.94)(1565)} = 172(10)^6 \text{ in lb/rad}$$

$$K_{\theta\theta} = \frac{1.72(10)^8 \text{ in lb/rad}}{(1.565(10)^7) \text{ "}}$$

SUPPORT BRACKET PLATE BENDING



FOR CALCULATION OF BRACKET FLEXIBILITY, THE FOLLOWING MEASUREMENTS WERE TAKEN ON CSP-A0-5 § 3. DATA IS APPROXIMATE.

DEFLECTION AT END OF CYL (IN) : .125 , .125 , .153
 FORCE AT END OF CYL (LB) : 85 , 150 , 170



Calculation Sheet

Project	Prepared By:	Date
Subject	Checked By:	Date
System	Job No.	File No.
Analysis No	Rev. No.	Sheet No.

SECTION 4.2

SUMMARY OF RESULTS



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	L.C. Fernandez	Date	6/13/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	M.A. Scott	Date	6/13/83
System	CAC & CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	OID 361104	Rev. No.	1	Sheet No.	4.1.1

4.1 Conclusions

Four 30" BIF butterfly valves with Miller Fluid Power cylinder operators have been analyzed for structural integrity and operability to the seismic and hydrodynamic piping analysis loads. These Burns and Roe piping analysis loads are in the form of operator response g-levels. (see Ref. 9).

All four EPN's, i.e., CSP-v-1, CSP-V-2, CEP-V-1A and CEP-V-2A qualify with the following modifications:

- 1.. Manufacturer supplied A-307 bolts must be replaced with A-325 bolts.
2. Shear plates must be added to reduce the ear weld stress (see sheets.4.3.30 through 4.3.48).

Valve operability was also demonstrated (see p. 4.3.20) while cylinder operability is addressed in QID No. 018001.



Calculation Sheet

Project	WPPSS Mechanical Equipment	Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By:	<i>[Signature]</i>	Date	6/16/83
System	CSP & CEP	Job No.	82044	File No.	0S.01.F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.2.1

SUMMARY OF RESULTS

Parametric data for the four subject valves in this report is given in Table 1.1. Results of the requalification analyses, which include a comparison of calculated stresses to the allowables are given in Table 1.2. Allowable stresses for the various material types are given in Table 1.3.



Calculation
Sheet

Project: WPPSS Mechanical Equipment Qualification
Subject: 30" Butterfly Valves
System: CSP and CEP
Analysis No.: 361104
Rev. No.: 1
Job No.: 82044
File No.: OS.01/F
Checked By: L. C. Fawcett
Date: 4/24/83
Prepared By: J. E. Rakowski
Date: 3/25/83
Sheet No.: 4.2.2

SUMMARY TABLE 1.1
30" VALVE PARAMETRIC DATA

EPN	HYDRO LOADS	FUNCTION	ELEV. 'R'	PIPE ORIENT	G LOADS FAULTED CONDITION*		
					NORTH	VERT	EAST
CSP-V-1	Y	CONTAINMENT ISOLATION	508	H	1.46	3.67	1.74
CSP-V-2	Y	CONTAINMENT ISOLATION	508	H	1.44	3.57	1.90
CEP-V-1A	Y	DRYWELL EXHAUST	558	V	1.93	2.23	1.85
CEP-V-2A	Y	DRYWELL EXHAUST	558	V	0.96	2.11	1.16

* TRANSMITTED FROM THE FINAL PIPING ANALYSIS, REFER TO SECTION 5.6.5, AT VALVE OPERATOR. (REFER TO SECTION 5.5)



Calculation
Sheet

Project: WPPSS Mechanical Equipment Regualification
 Subject: 30" Cylinder Operated Butterfly Valve
 System: CSP and CEP
 Prepared By: I.C. Fernandez
 Checked By: M.A. Scott
 Date: 6/15/83
 Job No.: 82044
 File No.: OS.01.F
 Rev. No.: 1
 Sheet No.: 4.3.3
 QID: 361104

SUMMARY TABLE 1.2 ~ FAULTED CONDITIONS
(STRESS IN PSI)

MEMBER	MATERIAL TYPE	TYPE STRESS	VALVE EPNS				MATERIAL ALLOWABLE
			CSP-V-1	CSP-V-2	CEP-V-1A ¹	CEP-V-2A ¹	
TRUNNION PINS	SA-276	S	4108 MAX				11840
TAPERED PINS	SA-276	S	8985 MAX				11840
DRIVE LEVER	A-395	T	12169 MAX				43200
LEVER KEYWAY	A-395	T	27381 MAX				43200
MAIN SHAFT	SA-479	S	9127 MAX				14500
DRIVE ROD	4140	T	44732 MAX	30082			86400
EAR BOLTS	A-325 ²	T	12150 MAX	8790			66000
		S	9500 MAX	7539			26250
SHEAR R WELD	E60	S	12577				28800
VALVE EAR WELD	E60	S	13277				28800

~ FATIGUE RESULTS (STRESS RANGE IN PSI)

						ALLOWABLE STRESS RANGE
TAPER PINS	SA-276	S ³	35940 MAX			90000
DRIVE ROD	4140	T	86826 MAX	57526		90000
TRUNNION PINS	SA-276	S ³	16432 MAX			22500
SHEAR R WELD	E60	S	25154			28000
VALVE EAR WELD	E60	S	26554			28000

¹ EPNS CEP-V-1A AND CEP-V-2A ENVELOPED BY CSP-V-2 BY A WIDE MARGIN
² AS INSTALLED BOLTS ARE CURRENTLY A-307 REQUIRE CHANGING TO A-325
³ FATIGUE EVALUATION OF A SHEAR LOAD RESOLVES INTO A TENSILE STRESS RANGE AS FOLLOWS: $\sigma_{MAX} = 2 \tau_{MAX}$ $SR = 2 \sigma_{MAX} = 4 \tau_{MAX}$

1008 00



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By:	L.C. Fernandez	Date	4/29/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.264

△ M. [Signature] 6/14/83
J. Fernandez 6/15/83

THIS SHEET NOT USED



Calculation Sheet

Project	WPPSS EQ	Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30' Butterfly Valves	Checked By:	L.C. Fernandez	Date	4/29/83
System	CSP & CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.2.5

SUMMARY TABLE 1.3

ALLOWABLE STRESSES

Since operability is required, the stresses for the faulted condition will be kept below yield*. The table below is based on AISC criteria and the yield stresses at temperature (340°F) from PG. 9 of REF. 4 for conservatism.

MATERIAL	YIELD STRES (PSI)	LEVEL A & B		LEVEL D	
		.6 Fy	.4 Fy	1.6x.6 Fy = 0.96 Fy	1.6x.4 Fy = 0.64 Fy
		BENDING ALLOW.	SHEAR ALLOW.	BENDING ALLOW.	SHEAR ALLOW.
AISI - 4140 HEAT TREATED	90,000	54,000	36,000	86,400	57,600
SA-276 , GR 304	18,500	11,100	7,400	17,760	11,840
ASTM A-395-60-45-15	45,000	27,000	18,000	43,200	28,800
SA-307	23,300	13,980	9,320	22,370	14,900
AISI - 1018 (MIN YIELD)	35,000	21,000	14,000	33,600	22,400
SA-193, GR 83, 304SS	31,000	18,600	12,400	29,760	19,840
SA-479, 304SS	22,650	13,590	9,060	21,744	14,500
SA-516, GR 60	28,000	16,800	11,200	26,880	17,920

* BRACKET BOLT ALLOWABLES TAKEN FROM AISC, 8TH ED., SEC. I.5.2.2

SECTION 4.3

ANALYSIS



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	L.C. Fernandez	Date	6/13/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	M.A. Scott	Date	6/13/83
System	CAC & CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	QID 361104	Rev. No.	1	Sheet No.	4.3.1

EQUIPMENT REQUALIFICATION FOR QID NO. 361104 BIF 30"CYLINDER OPERATED BUTTERFLY VALVES

4.3.1 Introduction

The four valves in this file are classified according to the parametric data given in Summary Table 1.1.

Since hydrodynamic loads apply (Ref. 7) fatigue analyses were provided for components with the highest stress range.

The analysis method calculates stress from north, vertical and east components of operator response g-levels. These g-levels are the result of the Burns & Roe piping analyses. (Ref. 9)

An SRSS analysis was set up in a computer program for each valve assembly in its specific orientation. The SRSS is taken at the maximum stress level due to seismic g-loading. Operating loads due to seating torque force and dead weight are combined with the seismic stress by absolute sum. Valve ear bending stress components due to any one response g-level component are combined by absolute sum.



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By	J.E.Rakowski	Date	1/10/83
Subject	30" Butterfly Valves	Checked By	L. C. Fernandez	Date	4/28/83
System	CSP & CEP	Job No.	82044	File No.	OS.01/F
Analysis No	361104	Rev. No.	1	Sheet No.	4.3.2

The computer analysis addresses only the more highly stressed components in the valve operator assembly. Separate analysis is given for the remaining components using a simpler approach with upper bound loads. This applies to all valve operator EPN's in QID 361106 (24" Valve/8" cylinders) and QID 361104 (30" valves/10" operators). Hand calculations which check selected portions of computer output is shown in Appendix C.

Appendix B of this section describes the air operator mass/stiffness model which was incorporated in the final piping analysis for calculation of operator response g-levels. The computer program includes an option for using the valve ear forces and moments which are directly output from the piping analysis with the valve/operator model included. This was not finally utilized, however, to qualify the subject equipment.

The equipment locations and elevations were taken from the P&ID's in section 6.0. Natural frequency calculations are given for the air operator assemblies in Section 4.3.2.1.

Preliminary analyses were performed which showed that, for operator response g-levels greater than approximately 3 g's, the air cylinder spring preload force would be exceeded and hence some disk flutter would occur when the valve is in the open position. The calculation in section 4.3.2.2 shows that the magnitude of the valve disk flutter vibration angle due to upper bound g-levels which occur in the hydrodynamic frequency range is approximately 6 degrees. This flutter was evaluated to have no detrimental effect on system safety function as noted in Reference 5.

Valve operability was addressed in the following manner. All valves have a Use Code of 1-3. It is noted that the g-levels pertaining to CSP-V-2 envelope CEP-V-1A and CEP-V-2A.



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By: J.E.Rakowski	Date 1/10/83
Subject 30" Butterfly Valves	Checked By: L.C. Fernandez	Date #129/83
System CSP and CEP	Job No. 82044	File No. O/S 01/E
Analysis No. 361104	Rev. No. 1	Sheet No. 4.3.3

For valves CSP-V-1 and 2, which must operate from open to fail closed during an event, the following additional evaluations were made:

- 1) Dynamic flow torques were assessed per Ref. 3 and found to be less than the seating torque which controlled the equipment stresses. Furthermore these flow torques tend to move the valve disk toward the fail-closed position, as noted in the above report.
- 2) The details of BIF drawing 206 767, parts of which are shown in figures 1.1 and 1.2, allow the following conclusions to be made for valve operability:
 - A) Figure 1.1 shows that thrust bearings are part of the shaft bearing design. This design prevents lateral movement of the disk in the direction of the shaft to eliminate interference with the valve body when closing. Further, it is noted on Page 26 of Ref. 3 that frictional torques in the shaft bearing system are negligible.
 - B) Figures 1.1 and 1.2 show a circular valve cross section having an internal rim within which the valve seats in the closed position. The only mechanism remaining to affect valve closing which can be postulated is out-of-round distortion of the section due to DBE piping loads and dynamic loads on the valve.


These loads were accounted for in Ref. 4 in the overall valve sizing calculations, where analysis showed that the stress intensity in the 0.5 inch thick valve body remained below 1.2 Sm, or approximately 0.8 of yield. Stress contribution from dynamic loads on the valve and operator were relatively small. Further, as shown in the figures:



Calculation Sheet

Project: WPPSS Mechanical Equipment Qualification Prepared By: J.E. Rakowski Date: 1/10/83
Subject: 30th Butterfly Valves Checked By: L.C. Ferrández Date: 4/29/83
System: CEP and CSP Job No. 82044 File No. OS.01.F
Analysis No. 361104 Rev. No.) Sheet No. 4.3.4

FIGURE 1.1 BIF DRAWING 206767





Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By J.E. Rakowski	Date 1/10/83
Subject 30" Butterfly Valves	Checked By L.C. Ferminde	Date 4/27/83
System CEP and CSP	Job No. 82044	File No. OS.01.F
Analysis No. 361104	Rev. No. 1	Sheet No. 4.3.5




FIGURE 1.2 BIF DRAWING 206767, DETAIL A



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By:	L. C. Fernandez	Date	4/28/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.6

1. The valve seat forms a heavily reinforced section made up of the valve body, internal hub and external flanges (including the mating flange of the piping). Hence the stress levels in this section are much lower than in the valve body and hence no distortion of the section could occur to affect seating of the valve. Valve flange dimensions are given below. Note the relatively large internal radial clearance of 1/8 inch.
2. Stress analysis of the valve extended structures are given in this report. Air operator operability is addressed in QID 018001.

The design data used in the analyses are given in Summary Table 1.1 (pipe-orientations and elevations are taken from the appropriate P&ID's in Section 6.0). Other pertinent data is given below.

- 1) Spring preload per communication report in Section 7.0 of QID 018001 are:

Fail Closed Preload = 2800

Final = 4800

- 2) Cylinder C.G.'s shown on the following sketches represent data received from BIF in the communication report of Section 7.0 of QID 018001.
- 3) Closing torque values are taken from Ref. 3.
- 4) Valve component dimensions: (Ref. Feb. 10, 11/83 communication report - Section 7)


Flange: width = 3.88", thickness - 2.625"
Radial Clearance Disk/Seat 1/8"




Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By:	L.C. Fernandez	Date	4/27/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No	4.3.7

OPEN POSITION



CLOSED POSITION





Calculation Sheet


Project	WPPSS Mechanical Equipment Qualification	Prepared By: H. Abolhoda	Date	3/25/83
Subject	30" Butterfly Valves	Checked By: J.E. Rakowski	Date	4/27/83
System	CSP and CEP	Job No. 82044	File No.	OS.01/F
Analysis No.	361104	Rev. No. 1	Sheet No.	4.3.0

4.3.2 CALCULATIONS

4.3.2.1 NATURAL FREQUENCY CALCULATIONS

SINCE THE 10" CYLINDERS ARE SIMILAR TO THE 8" CYLINDERS IN QID 361106, THE LOWEST NATURAL FREQUENCY OCCURS WHEN THE CYLINDER IS IN THE OPEN POSITION DUE TO THE GREATER FLEXIBILITY OF THE EXTENDED DRIVE ROD.

A SAP - ANALYSIS WAS PERFORMED TO CALCULATE NATURAL FREQUENCY. THE MODEL IS DESCRIBED BELOW.





Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By	B.H. Abolhoda	Date	3/25/83
Subject	30" Butterfly Valves	Checked By	<i>A. Jank</i>	Date	4.30/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.		Sheet No.	4.3.9

IN THE MODEL, NO MOMENT RESISTANCE TAKES PLACE AT NODE 4 (SHAFT PINNED AT NODE 4), AND AT THE PISTON DISK, NODE 8.

PRESENTED BELOW ARE CALCULATIONS FOR THE GEOMETRICAL AND STRUCTURAL PROPERTIES OF THE MODEL ELEMENTS. THE COMPUTER INPUT AND OUTPUT ARE SHOWN ON PAGE 4.3.A.3.

$$\text{ROD AREA} = \pi/4 (D)^2 = \pi/4 (1.75)^2 = 2.405 \text{ IN}^2$$

$$\text{CYL. AREA} = \pi/4 (D_o^2 - D_i^2) = 3.976 \text{ IN}^2$$

$$\text{Total length of drive rod} = 25.92 + (50.75 - 42.625)$$

$$= 33.145 \text{ inches}$$

$$\text{mass of rod per inch} = 2.4053 \times \frac{.233}{386.4} = .0017$$

$$\text{Total mass of Rod} = 33.145 \times .0017 = .056$$

$$\text{mass of cylinder per inch} = 3.9761 \times \frac{.236}{386.4} = .0023$$

$$\text{Total mass of cylinder} = .0023 \times 64 = .1791$$

$$\left\{ \begin{array}{l} \text{Total mass of system} = \frac{595}{386.4} = 1.5347 \\ \text{C.G.} = 34.50'' \text{ from cylinder end} \end{array} \right.$$



Calculation Sheet


Project	WPPSS Mechanical Equipment Qualification	Prepared By:	H. Abolhoda	Date	3/25/83
Subject	30" Butterfly Valves	Checked By:	J.E. Rakowski	Date	4/28/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.10

$$C.G. \text{ of Rod} = \frac{33.145}{2} + (64 - 6.375) = 74.20$$

$$C.G. \text{ of cylinder} = 32$$

total mass = mass of Rod & cylinder = 1.3006
 a concentrated mass should be placed in certain distance (see below) to obtain an equivalent

C.G. for total system



$$X = \frac{34.25(1.5347) - .178(32) - 74.20(.056)}{1.3006} = 32.84$$

CALCULATION OF STIFFNESS

$$I_{ROD} = \frac{\pi * 1.75^4}{64} = .4604 \quad J_{ROD} = 0.9208$$

$$I_{CYL} = \frac{\pi}{64} (10.25^4 - 10.0^4) = 50.96 \text{ IN}^4 \quad J_{CYL} = 101.92 \text{ IN}^4$$

(CYLINDER THICKNESS MODELED AS 0.125")



CALCULATION SHEET

PROJECT <u>SUPPLY SYSTEM JED 201/21</u>		PREPARED BY <u>[Signature]</u>	DATE <u>7/15/82</u>
SUBJECT <u>30" Butterfly Valve</u>		CHECKED BY <u>R. Hsieh</u>	DATE <u>7/15/82</u>
SYSTEM <u>CEP/CEP</u>		JOB NO. <u>8204</u>	FILE NO. <u>7-11F</u>
ANALYSIS NO. <u>11/15</u>		REV. NO. <u>1</u>	
		SHEET NO. <u>4.3.11</u>	

Computer Input to SAP RD

WFD = WPSSØS
 SAP INPUT-FILE = BV3Ø OFRS
 SAP OUTPUT-FILE = BV3Ø RS OUT

SLIST BV3ØPRS
 CALCULATION OF NATURAL FREQUENCY OF 30 INCHES BUTTERFLY VALVE (OPEN)

15	1	0	1	3						
1	1	1	1	1	1	0		5.0		
2	0	0	1	1	1	0	8.923	5.0		
4	0	0	1	1	1	0	26.77	5.0		1
5	0	0	1	1	1	0	33.145	5.0		
6	0	0	1	1	1	0	26.77	0.0		
7	0	0	1	1	1	0	33.145	0.0		
8	1	1	1	1	1	0	40.02	0.0	0.0	
9	0	0	1	1	1	0	48.48			
14	0	0	1	1	1	0	90.780	0.0	0.0	1
15	1	1	1	1	1	1	0.0	20.0		
2	14	2		1						
129000000. 3 0007										
1	2.41						.921	.4604	.4604	
2	3.98						101.92	50.96	50.96	

1	1	2	15	1	1					
4	4	6	15	1	1					
5	4	6	3	1	2				1	1
6	3	7	4	1	2		010001			
7	6	7	15	1	2				1	
14	13	14	15	1	2					1
10	0	1.3006		1.3006						

386.4 386.4 0.0 1
 * RESPONSE SPECTRUM WITH CONSTANT ACCELERATION OF 1 G

.01 1.0
 100. 1.0

$f_{n1} = 11.45 \text{ Hz}$ (OUTPUT)



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By:	L.C. Fernandez	Date	4/28/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/E
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.12

CALCULATION OF f_N PARALLEL TO THE DRIVE ROD AND TRUNNION PINS:

APP. B
PG. 43.83

BRACKET STIFFNESS IS: (CANTILEVER BEAM OF EFFECTIVE I_{zz})

$$K = \frac{P}{\delta} = \frac{3EI}{l^3} = \frac{3 \times 2.9(10)^7 \times 4.22}{(28.5)^3} \quad \begin{matrix} (2.16 \text{ IN}^4 \text{ FOR } 8" \text{ CYL}) \\ (3.54 \text{ IN}^4 \text{ FOR } 10" \text{ CYL}) \end{matrix}$$

$$= 15920 \text{ lb/in}$$

$$M = \frac{(\bar{W}_{A0} + \bar{W}_{BR})}{g} = \frac{(593 + 321)}{384.6} = 2.38 \frac{\text{lb} \cdot \text{sec}^2}{\text{in}}$$

$$f = \frac{1}{2\pi} \sqrt{\frac{K}{M}} = \frac{1}{6.28} \sqrt{\frac{15920}{2.38}} = 12.98 \text{ Hz}$$

B) PARALLEL TO DRIVE ROD

APP. B, PG 43.86

SAME MASS, STIFFNESS = EAR BENDING STIFFNESS
EAR STIFFNESS = $K_{yy} = 48 \times 10^6 \text{ lb/in (10")}$, $= 7.5(10) \frac{\text{lb}}{\text{in}} (8")$

$$f_{N/10"} = \frac{10^3}{2\pi} \sqrt{\frac{48}{2.38}} = 715 \text{ Hz}$$

$$f_{N/8"} = \frac{10^3}{2\pi} \sqrt{\frac{7.5}{1.76}} = 328 \text{ Hz}$$




Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By	L.C. Fernandez	Date	4/28/83
System	CSP and CEP	Job No.	82044	File No.	OS_01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.13

4.3.2.2 APPROXIMATE VALVE FLUTTER MAGNITUDE

USING DIMENSIONS FROM FIGURE 1.3 :



CONSERVATIVELY ASSUME THAT THE MAX ACCELERATION COMPONENT OUTPUT FROM THE PIPING ANALYSIS FOR CSP-V-5 (OPEN / FAIL-OPEN) PRODUCES DISPLACEMENTS OF THE AIR OPERATOR RELATIVE TO THE PIPE IN THE FORM OF

$$d = \frac{A}{\omega_n^2} \quad \text{WHERE } A = 9.35 g^2 \times 386.4 \text{ } \frac{1}{s^2} \quad (\text{TABLE 1.1})$$

FROM THE SPECTRA IN SECTION 5.1, FOR HYDRODYNAMIC LOADS:

$$\omega_n |_{\text{MIN}} = 2\pi (15 \text{ Hz}) \left(\frac{R}{s} \right)$$

$$\theta_1 = \tan^{-1} \frac{d}{11.0} = \tan^{-1} \left(\frac{19.35 \times 386.4}{11 \times (94.2)^2} \right) = \left(\frac{.41}{11} \right) = \tan^{-1} (.04)$$

$$\theta_1 = 2.13^\circ$$

$$\therefore \theta_2 \sim 3 \times \theta_1 \sim 6^\circ \quad (\text{SMALL})$$



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	1/10/83
Subject	30" Butterfly Valves	Checked By:	L.C. Fernandez	Date	4/28/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.14

△ *End Date 6/14/83*
J.C. Fernandez 6/15/83

4.3.2.3 STRESS ANALYSIS

The procedures for the analysis of the subject valves are outlined below:

1. Recalculate the valve appurtenance stresses addressed in Ref. 4 using response g-levels from the Burns & Roe piping analysis. Incorporate the current seating torque given in Ref. 3. Compare stresses to the lower yield strengths in Summary Table 1.3.
2. If faulted condition stresses exceed the upset condition allowable stresses, repeat the analysis for the affected components using upset accelerations from the piping analysis.
3. Perform a fatigue analysis on significantly stressed components. Determine allowable alternating stress ranges from AISC 8th Edition, Appendix B, noting commentary.

The fatigue analysis is to be performed only for those EPN's subject to hydrodynamic loads. The number of respective load cycles is given below.

LOAD COMBINATIONS & STRESS CYCLES

The following table lists the load combinations and the number of expected stress cycles for each combination. (From the design criteria)

	<u>Combination</u>	<u>Cycles</u>
1.	SRV Alone	3(4500)=13500
2.	OBE+SRV	50
3.	OBE+SRV+Chugging	2000
4.	SSE+SRV+Chugging/ SSE+AP	10

Note: Load combination #4 with 15560 cycles can be used to conservatively bound all combinations.



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By:	L.C. Fernandez	Date	4/29/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.15

STRESS ANALYSIS OF VALVE AND AIR OPERATOR COMPONENTS NOT COVERED IN QID 018001

1) TRUNNION PINS

TRUNNION PINS WERE ANALYZED AND THE SHEAR STRESS WAS FOUND TO BE PRIMARILY DEPENDENT ON OVERTURNING IN THE 3-AXIS DIRECTION. WHEN ANALYZED WITH AN ACCELERATION IN THIS DIRECTION OF 13.9 g's, THE SHEAR STRESS WAS ONLY 35 PERCENT OF THE ALLOWABLE. THEREFORE THE PINS ARE SUFFICIENT FOR ALL EPN'S.

THIS CALCULATION FOLLOWS:
[10" A/O ENVELOPED BELOW]

$$L_{ROD} = 25" \text{ (CLOSED)} \quad L_{CG} = 14.46"$$

	8"	10"
LCG	14.46	21.50"
X	12.75	13.38"
ATP	2.41IN	2.41IN

$$M_1 = \bar{W}_{A0} g_3 L_{CG} = (399)(13.9)(14.46) = 80,139 \text{ IN}\cdot\#$$

$$F_{23} = \frac{M_1}{X} = \frac{80139}{12.75} = 6285 \# \text{ (CONTROLS STRESS, ENVELOPES 10" A/O G'S BY WIDE MARGIN)}$$

$$F_{11} = \frac{(L_{ROD} + L_{CG})}{L_{ROD}} \frac{\bar{W}_{A0} g_1}{Z} = \frac{39.46}{25 \times 2} (399)(1.04) = 327 \#$$

$$F_{22} = \frac{\bar{W}_{A0} g_2}{Z} = \frac{399(1.66)}{2} = 332 \#$$

$$F_{ST2} = \frac{1201 \#}{2} = 601 \# \quad \left. \begin{array}{l} \\ \\ \end{array} \right\} \text{801 FIXED}$$

$$F_{WEIGHT(2)} = \frac{399}{2} = 200 \#$$

$$F'_{ST2} = \frac{\text{SEAT TRIGUE} \times \cos 11.82^\circ}{11.75"} \\ \text{FOR 8"} \\ = \frac{13808 \#}{11.75} \times 0.86 = 1150 \# \\ \text{FOR 10"} \\ = \frac{221174 \#}{11.75} \times 0.86 = 1897 \#$$

SEE BIF RPT & McPHEMSON RPT

CONSERVATIVE COMBINATION

$$\sigma = \frac{1}{.75(2.41)} \left\{ \left[(F_{23} + F_{22})^2 + F_{11}^2 \right]^{\frac{1}{2}} + F_{FIXED} \right\} = 4108 \text{ PSI} < 11,840 \text{ PSI (OK)}$$



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By:	L.O. Fernandez	Date	4/28/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.16

CLEVIS

4, 32

THE TOTAL LOAD ON THE CLEVIS IS THE VECTOR SUM OF $F_C \rightarrow$ AND $F_{ST} \downarrow$.

$$F_{CLEVIS} = [F_C^2 + F_{STZ}^2]^{\frac{1}{2}}$$

	8"	10"
F _{STZ}	1201# (MAX)	1847#
CLEVIS AREA	2.44"²	2.44"²

4, 33

ASSUME UPPER LIMIT OF $g_1 = 15g$'s JUST FOR THIS MEMBER, $F_{STZ} = 1847#$, $W_{A0} = 539#(10")$, $L_{CG} = 21.5"$

$$F_{CLEVIS} = [1847^2 + 6953^2]^{\frac{1}{2}} = 7199#$$

$$\sigma_{CLEVIS} = 7199# / 2.44" = 2949 \text{ PSI} < 28,800 \text{ (OK)}$$

CLEVIS PIN


$$\tau = 7199# / 3.53 \text{ IN}^2 * \frac{4}{3} = 2717 \text{ PSI} < 11,840 \text{ (OK)}$$

4, 32

∴ CLEVIS & PIN ARE GOOD FOR ALL 8" & 10" A/O EPN'S.

DRIVE LEVER

IMPOSE THE SEATING TORQUE LOAD AND DYNAMIC REACTION FORCE ON THE DRIVE LEVER IN THEIR RESPECTIVE DIRECTIONS:



REF 4, Pg 35

LOAD F_C WILL INCREASE THE AXIAL FORCE IN THE DRIVE LEVER, HOWEVER, THE MAXIMUM TORQUE ON THE LEVER IS THE SEATING TORQUE. THE AIR OPERATOR TRUNNIONS AND INTERNAL SPRING HOLD THE VALVE STABLE IN THE CLOSED POSITION.



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By	L.C. Fernandez	Date	4/22/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No	361104	Rev. No.	1	Sheet No	4.3.17

MAX NORMAL FORCE ON DRIVE LEVER :

$$F_{ST} \cos \theta + F_C \sin \theta = 2529 \text{ LB (ENVELOPE)}$$

$$1847 \times .99 + 6953 \times .10 =$$

MAX AXIAL FORCE ON DRIVE LEVER :

$$F_{ST} \sin \theta + F_C \cos \theta = 706.8 \text{ LB (ENVELOPE)}$$

$$1847 \times .10 + 6953 \times .99 =$$

REF 4, Pg. 34

MINIMUM DRIVE LEVER AREA = 1.875 in²,
CONSIDERING FAILURE MODES.

AXIAL STRESS:

MAX BENDING MOMENT = 22,174 IN-LB (CONSERVATIVE FOR
USE ON MIN. AREA OUT NEAR CLEVIS PIN)

$$\sigma_{AXIAL} = \frac{Mc}{I} + \frac{F_{AX}}{A}$$

REF 4, Pg. 35

$$\sigma_{AXIAL} = 22,174 \times \frac{1.625}{4.29} + \frac{706.8}{1.875} = 12,169 \text{ PSI}$$

$$12,169 < 43,200 \text{ PSI OK}$$

SHEAR STRESS:

$$\tau = \frac{2529}{1.875} = 1346 \text{ PSI} < 28,800 \text{ PSI OK}$$

DRIVE LEVER
SUFFICIENT
ON BOTH
8" & 10"
A/O'S.



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By:	L.C. Fernandez	Date	4/22/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.13

KEY WAY BEARING STRESS - DUE TO SEATING TORQUE
30" VALVE PARAMETERS:

REF 4, PG 36
 REF 3, PG 3
 REF 4, PG 36

$$A_B = 0.448 \text{ IN}^2$$

$$M = 13,800 \text{ IN-LB}$$

$$\frac{D_{MIN}}{2} = 1.125 \text{ IN}$$

$$A_B = .675 \text{ IN}^2$$

$$M = 22,174 \text{ IN-LB}$$

$$\frac{D_{MIN}}{2} = 1.25 \text{ IN}$$

$$F_{BRG} = \frac{M \times Z}{D_{MIN}} = 12,267 \text{ LB} \quad (17,739)$$

$$\sigma_{BRG} = \frac{F_{BRG}}{A_B} = 27,381 \text{ PSI} \quad (26,280) \therefore 24" \text{ VALVE CONTROLS}$$

27,381 < 43,200 PSI OK MARGIN = 58%

REF 4, PG 37

SHEAR AREA OF KEY = 1.33 IN².

THEREFORE - BEARING STRESS CONTROLS.

MAIN SHAFT:

PRELIMINARY ANALYSIS SHOWS THIS IS NOT A HIGHLY STRESSED COMPONENT, \therefore ANALYZE FOR ENVELOPE LOADS.

$$\text{STRESS} = \text{STRESS DUE TO SEATING TORQUE} +$$

$$\text{STRESS DUE TO SHEAR OF } F_{STZ} +$$

$$\text{STRESS DUE TO BENDING OF } F_{STZ}.$$



Calculation Sheet

Project WPPSS Mechanical Equipment Qualification Prepared By: J.E. Rakowski Date 3/25/83
 Subject 30" Butterfly Valves Checked By: L.C. Fernandez Date 4/28/83
 System CSP and CEP Job No. 82044 File No. OS.01/F
 Analysis No. 361104 Rev. No. 1 Sheet No. 4.3.19

	8"	10"
r	1.1248"	1.25"
$J = 2I =$	2.514 IN ⁴	3.83 IN ⁴
$r_5 =$	6.005"	6.32"
$r_6 =$	10.31"	11.18"
$I_s =$	1.257	1.916
$T_s =$	13,808 IN ⁴	22,174 IN ⁴

REF 4, PG 4A

① $\tau_T = \frac{T_s P}{J} = \frac{13,808 (1.1248)}{2.514} = 6174 \text{ PSI}$ $\left\{ \frac{22174 (1.25)}{3.83} = 7237 \text{ PSI} \right\}$

② $\tau_{AVE} = \frac{F_{COMB.}}{A}$ FROM FIG. ON PAGE 4.3.16 & PG 4.3.17:
 $F_{COMB.} = [2524^2 + 7068^2]^{\frac{1}{2}} = 7505 \text{ LB}$

$\tau_{AVE} = \frac{7505}{3.97} = 1890 \text{ PSI}$

③ $M = \frac{1847 (6.32)(11.18)}{16.315 = (r_6 r_5)} = 7999 \text{ IN-LB}$

$\sigma = \frac{MC}{I} = \frac{7999 (1.1248)}{1.257} = 7158 \text{ PSI}$

CONSERVATIVELY ADDING SHEAR STRESSES

$\tau = 7237 + 1890 = 9127 \text{ PSI} < 14,500 \text{ OK}$
$\sigma = 7158 \text{ PSI} < 21744 \text{ OK}$

RESULT GOOD FOR BOTH 24" & 30" VALUES



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	1/10/83
Subject	30" Butterfly Valves	Checked By:	L.C. Fernandez	Date	4/29/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.20

Disc

The stresses in the disc were shown on page 51 of Ref. 4 to be due almost entirely to the pressure load. Since the stress found in Ref. 4 of 4540 PSI will not change significantly for the new accelerations, the disc is acceptable.

Taper Pins

The stress in these pins is due only to the seating torque. The stress in Ref. 4, page 53, is 11265 PSI and is therefore acceptable. For the new, lower seating torque, the stress becomes 8985 PSI.

Analysis for: Drive Rod, cylinder bushing pressure, valve ears and valve ear bolts.

Method I: Use element forces and moments output from the piping analysis (Summary Table 1.1) and the absolute sum of stresses. The conservatism of SRSS summing of the component stresses cannot be assured because the independence of the six element forces (/moments) cannot be determined without analysis of modal participation.



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	1/10/83
Subject	30' Butterfly Valves	Checked By:	L.C. Fernandez	Date	4/29/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.21

Method II: Use the north, east and vertical operator accelerations output from the piping analysis. Absolute sum for stresses with each component then SRSS over results for N,E and V.

Note 1: Analysis of the distribution of stress on 4 valve ears to predict the maximum tensile stress cannot confirm a maximum value lower than the absolute sum of the elemental tensile stresses due to the six forces (from one acceleration direction, N,E or V). Therefore the absolute sum will be used at this level.

Note 2: Add stress due to the vector sum of deadweight plus seating torque force after above SRSS combinations are performed. (ABS)


Note 3: 10" A/O parameters are shown for use in QID 361104.

Analysis of Seating Torque Forces

1) Seating Torque loads control the stress in the valve lever arm, keyway, shaft and taper pins. These stresses were less than allowables for the valves of seating torque given in Ref. 3, for all valves.

2) For valve EPN's which are Fail-Open with Use-Code 2, no seating torque forces are applied during the faulted and upset conditions (CSP-V-5,6).

3) For the Fail-Closed valves, the forces at the trunnion pins are shown below, along the cylinder axis, for +z-axis g-loading:





Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By	J.E. Rakowski	Date	1/10/83
Subject	30" Butterfly Valves	Checked By:	L.C. Fernandez	Date	4/29/83
System	CSP and CEP	Job No.	82044	File No.	OS .01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.22

As the bracket deflects in +2, under dynamic loads, the seating torque force is relieved. The extent of relief depends on the relative stiffness of the bracket and valve ears relative to the valve seat. Since the steel buckets and ears are very stiff in this direction, little relief can be expected. Hence seating torque forces will be added as an ABS sum to the valve ears. However, seating torque force will oppose operator weight when the brackets hang downward from horizontal pipes.

Operator Drive Rod

Drive rod dyanmic stress is due only to g_1 because g_2 and g_3 forces are taken out by trunnion pins. Add seating torque stresses.

$$F_c = \frac{L_{CG} \bar{W} g_1}{L_{ROD}}$$


TWO POINTS ARE CRITICAL, PT A AT THE BUSHING AND PT B AT THE REDUCED THREAD DIAMETER

$$M_A = F_c (L_{ROD} - 13.5")$$

$$\sigma_A = \frac{M_A C_A}{I_A}$$

$$M_B = 7.125 F_c$$

$$\sigma_B = \frac{M_B C_B}{I_B}$$



	8"	10"
IA	.4604 IN ⁴	
CA	.875 IN	↑ Some -
IB	1.383 IN	Some
CB	.6478 IN	↓ Slugg
AB	1.405 IN ²	
AA	2.41 IN ²	2.41 IN ²



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification		Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves		Checked By:	L.C. Fernandez	Date	4/29/83
System	CSP and CEP		Job No.	82044	File No.	OS.01/F
Analysis No	361104	Rev. No.	1	Sheet No.	4.3.23	

FINALLY:

$$\left. \begin{aligned} \sigma_{A/OPERATING} &= \left(\frac{F_{STZ}}{A_A} + \frac{MAC}{IA} \right) / DW \\ \sigma_{B/OPERATING} &= \left(\frac{F_{STZ}}{A_B} + \frac{MBC}{IB} \right) / DW \end{aligned} \right\} \text{ADD AS ABS SUM AFTER SRSS OF DYNAMIC COMPONENTS}$$

SEISMIC / DYNAMIC FORCES ON VALVE EARS


A SAP-TYPE* MASS / STIFFNESS MODEL WAS PREPARED FOR THE PIPING MODEL TO CALCULATE A/O RESPONSE G-LEVELS (SEE ATTACHMENT). THE VALVE-EAR SYSTEM BENDING AND TORSIONAL FLEXIBILITY WAS INCLUDED IN THE MODEL AND SRSS FORCES AND MOMENTS WILL ALSO BE OUTPUT FOR CONVERSION INTO VALVE EAR STRESSES. THE EQUATIONS ARE:

Tension due to M_1 & T_3 :
(SEE LOCAL COORD. DEF'N - NEXT PG)

$$2Pd_1 = M_1$$

$$\sigma_{M_1} = \frac{P}{A} = \frac{M_1}{2d_1 A}$$


$A = l_1 l_2$	8"	10"
$l_2 =$	2.5"	3"
$l_1 =$	1.5"	1.75"
$d_1 =$	7.5"	9.5"
$d_2 =$	10.0"	10.5"



① $\sigma_{T_3} = \frac{P}{4A} = \frac{T_3}{4l_1 l_2}$
Tension due to T_3
+ WHEN T_3 IS +

② $\sigma_{T_3 \text{ due to } M_1} = \frac{M_1}{2d_1 l_1 l_2}$

SAP-MODEL:
(SEE ATTCHMNT)
(APPENDIX B)



TOP IN TENSION (+) WHEN M_1 IS +


* STRUCTURAL ANALYSIS PROGRAM, SEE APPENDIX A FOR ADDITIONAL DETAILS.



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By:	L.C. Fernandez	Date	4/29/83
System	CSP and CEP	Job No	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.24

COORDINATE SYSTEM (LOCAL)





Calculation Sheet

Project	WPPSS Mechanical Equipment	Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By:	L.C. Ferrández	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1.	Sheet No.	4.3.25

⚠ *Reviewed 6/14/83
L.C. Ferrández 6/15/83*

BOLTS HOLDING BRACKETS TO EARS:

BOLT TENSION IS DUE TO M_1, M_2, T_3
 BOLT SHEAR IS DUE TO S_1, S_2, T_3

		AREA	
		8"	10"
Tension (ABS SUM)	$\tau_{T_3} = \frac{T_3}{4 A_B}$	0.31 IN^2	$.43 \text{ IN}^2$
	$(\tau_T)_{M_1} = \frac{M_1}{2 d A_B}$	$.6273"$	$.7387"$
	$(\tau_T)_{M_2} = \frac{M_2}{2 d A_B}$		

$A_B = \frac{\pi D^2}{4}$

Shear:

$\frac{F_{11}}{\text{bolt}} = F_c * A_{F_x}$
 $\frac{F_{22}}{\text{bolt}} = F_c * A_{F_y}$ } (PREVIOUS PAGES 4.3.26,27)

$\tau_1 = \frac{F_{11}}{A_B} = \frac{F_c * A_{F_x}}{A_B} \rightarrow$ ①

$\tau_2 = \frac{F_{22}}{A_B} = \frac{F_c * A_{F_y}}{A_B} \downarrow$ ②

Similarly: $\tau_{S_1} = \frac{S_1}{4 A_B} \rightarrow$ ③

$\tau_{S_2} = \frac{S_2}{4 A_B} \downarrow$ ④

COMBINE IN SAME MANNER AS ON PREVIOUS PAGE, FOR EARS BUT SUBSTITUTE A_B FOR $A_{1,2}$



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification		Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves		Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP		Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No	4.3.26	

METHOD II - THE PREVIOUS EQUATIONS FOR STRESS BY METHOD I ARE APPLICABLE. HOWEVER,

- 1) EXPRESSIONS FOR THE SIX FORCES/MOMENTS ARE DERIVED BELOW IN TERMS OF g-level COMPONENTS IN THE LOCAL AXIS SYSTEM (SUBSEQUENTLY DIRECTION COSINES WILL BE USED TO CONVERT THE N, E & V ACCELERATION VECTORS, IN TURN, INTO LOCAL AXES). (SEE SECTION 5.4)
- 2) THESE EQUATIONS ARE TO BE USED TO FIND THE FORCES AND MOMENTS ON THE EARS DUE TO THE DEADWEIGHT AND SEATING TORQUE FORCES, FOR CALCULATION OF OPERATING STRESSES, FOR USE IN EITHER METHOD 1 & 2.

SEE FORCES & BRACKET ORIENTATION IN LOCAL COORDINATES, NEXT PAGE.

1: T_3 = TORSION ABOUT LOCAL AXIS # 3

$$T_3 = \sum M_{SHAFT} (\oplus) = F_{TR1} e_3 + F_{BR1} e_4 + F_{A02} e_2 + F_{BR2} e_1$$

$$= F_{TR1} e_3 + \bar{W}_{BR} g_1 e_4 + \bar{W}_{A0} g_2 e_2 + \bar{W}_{BR} g_2 e_1$$

$T_3 = (\oplus)$	$= F_{TR1} e_3 + \bar{W}_{BR} g_1 e_4 + g_2 (\bar{W}_{A0} e_2 + \bar{W}_{BR} e_1)$
$T_3 \text{ FIXED} = (\oplus)$	$= \bar{W}_{A0} g_1 e_3 + (\bar{W}_{A0} g_2 + F_{ST2}) e_2 + \bar{W}_{BR1} e_4 + \bar{W}_{BR2} e_1$





Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J. E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By:	L. C. Fernández	Date	6/15/93
System	CSP and CEP	Job No.	82044	File No.	J OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.27

FORCES ON SUPPORT EARS DUE TO LOCAL-AXIS ACCELERATIONS 9.19.93

FORCES IN THE LOCAL COORDINATE SYSTEM:

- ELEVEN FORCES ACT IN THE LOCAL 1,2,3 A/O AXIS SYSTEM:
- DYNAMIC**
- $F_{A02,3} = \bar{W}_{A0} * g_{2,3}$
 - $F_{TR2} = 1$ - AXIS COMPONENT OF DYNAMIC FORCE AT TRUNNION
 - $F_{BR1,2,3} = 1,2,3$ AXIS COMPONENTS OF BRACKET INERTIA = $\bar{W}_{BR} * g_{1,2,3}$
- STATIC**
- $W_{ATR1} =$ FORCE AT TRUNNION IN 1-AXIS DUE TO A/O WEIGHT
 - $W_{A02,3} =$ WEIGHT OF A/O IN AXES 1,2,3
 - $W_{BR1,2,3} =$ WEIGHT OF BRACKET IN THE 1,2,3-AXIS DIRECTIONS
 - $F_{ST2} =$ SEATING TORQUE FORCE, IS ALWAYS ALONG 2-AXIS.






Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No	361104	Rev. No.	1	Sheet No.	4.3.28

FORCE ORIENTATIONS ON EARS: IF (+ T₃)



$$S_1 = F_{TRI} + F_{BR1} = F_{TRI} + \bar{W}_{BR} g_1$$


$$S_{FIXED} = \bar{W}_{BR1} + \bar{W}_{ATR1}$$

FROM A FORCE BALANCE OF THE OPERATOR:

$$F_{TRI} = + \frac{(L_{ROD} + L_{CG}) \times \bar{W}_{AO} \times g_1}{L_{ROD}} \quad (+ \text{FORCE ON BRKT})$$

$$\bar{W}_{ATR1} = + \frac{(L_{ROD} + L_{CG})}{L_{EOD}} \bar{W}_{AO1}$$

	LENGTH			
	8"		10"	
	OPEN	CLOSED	OPEN	CLOSED
L _{EOD}	40"	25"	40"	25"
L _{CG}	10.96"	14.46"	16.25"	21.5"






Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.29

$$S_2 = F_{A02} + F_{BR2} = (\bar{w}_{A0} + \bar{w}_{BR}) g_2 \quad \uparrow$$

$$S_{2 \text{ FIXED}} = w_{BR2} + w_{A02} + F_{ST2} \quad \uparrow$$




FOR OUT OF PLANE BENDING:

$$M_1 = \uparrow = -F_{A02} e_5 - F_{BR2} e_5 - F_{A03} (e_3 + \frac{e_4}{\sqrt{3}}) - F_{BR3} e_4$$

$$M_1 = -(\bar{w}_{A0} + \bar{w}_{BR}) g_2 e_5 - \bar{w}_{A0} g_3 (e_3 + \frac{e_4}{\sqrt{3}}) - \bar{w}_{BR} g_3 e_4$$

$$M_{1 \text{ FIXED}} = (w_{A02} + w_{BR2} + F_{ST2}) e_5 - w_{A03} (e_3 + \frac{e_4}{\sqrt{3}}) - w_{BR3} e_4$$




+ = TOP FACES IN TENSION

$$M_2 = \uparrow = +F_{TR1} e_5 + F_{BR1} e_5 + F_{A03} e_2 - F_{BR3} e_1$$

$$M_2 = +(F_{TR1} + \bar{w}_{BR} g_1) e_5 - (\bar{w}_{A0} e_2 + \bar{w}_{BR} e_1) g_3$$

$$M_{2 \text{ FIXED}} = +(w_{ATR1} + w_{BR1}) e_5 - w_{A03} e_2 - w_{BR3} e_1$$



+ = LEFT FACES IN TENSION

$$T_3 = \uparrow_{+3 \text{ AXIS}} = (\bar{w}_{A0} + \bar{w}_{BR}) g_3 \quad T_{3 \text{ FIXED}} = w_{A03} + w_{BR3}$$

$T_3, M_1, M_2, S_1, S_2, \& T_3$ COMPLETE



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	QID 361104	Rev. No.	1	Sheet No.	4.3.30

Section 4.3.4 - Ear Support Weld Stress

Comparison of a similar file (QID No. 361106) to this file noted the unconservative assumption of considering the bracket support ears to be a guided cantilever (fixed-fixed). The resulting ear weld stresses exceeded the allowable stresses. The ear weld stresses can be lowered by the addition of shear plates to stiffen the whole assembly. The resulting weld stresses (both existing and modified) are to be kept within the fatigue allowable stress, i.e., $\frac{1}{2}$ stress range. The allowable fatigue stress range from AISC for fillet welds in shear with less than 20000 cycles of loading is:

$$SR = (1.5)(15000) = 22500 \text{ PSI}$$

This includes the 50% increase due to fewer than 20000 cycles. The weld stresses are calculated using faulted loads. These loads produce less than one percent of the total 15560 cycles of faulted/hydrodynamic loading. Since the upset and emergency conditions are considerably lower in magnitude, small margins of overstress in fatigue will be tolerated for faulted stress levels. The following allowables will be adhered to in the ear weld stress calculations.

Allowable stress for welds for faulted conditions:

$$\sigma_{\text{allow}} = 1.6(0.3)F_u = 28800 \text{ PSI}$$

Allowable stress for welds subject to fatigue. This is $\frac{1}{2}$ the allowable stress range of AISC Appendix B:

$$\sigma_{\text{allow fat}} = \frac{1.25(1.5)(15)}{2} = 14 \text{ KSI}$$


1.25 = 25% increase due to previous comments

1.5 = 50% increase due to AISC commentary



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No	OS.01.F
Analysis No.	QID 361104	Rev. No.	1	Sheet No.	4.3.31



ALL WELD METAL E7018
PREHEAT 200°F MIN
3/4" MAX FILLET
EXEMPTED FOR POST WELD
HEAT TREATMENT PER
ASME III NC-4622.7.


TO BE REPAIRED UNDER
SECTION II GUIDELINES



Calculation Sheet


Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS 01 F
Analysis No.	OTD 361104	Rev. No.	1	Sheet No.	4.3.32

CSP-V-1



APPLIED LOADS @ TOP OF SUPPORT EARS

	S_1	S_2	t_3	M_1	M_2	T_3
OPERATING	0	2761	0	21398	0	22425
DYNAMIC	5094	3309	3270	148924	142329	15403
COMBINED	5094	6070	3270	170322	142329	176439



$$\frac{V_2}{2} = V_2' = \frac{S_2}{4} + \left(\frac{9.5}{14.16}\right) \left(\frac{T}{28.32}\right)$$

$$= 1274 + 4180 = 5454 \#$$

$$\frac{V_1}{2} = V_1' = \frac{S_1}{4} + \left(\frac{10.5}{14.16}\right) \left(\frac{T}{28.32}\right)$$


$$= 1518 + 4620 = 6138 \#$$




Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valve	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	OTD 361104	Rev. No.	1	Sheet No.	4.3.33

FOR THE 10 1/2" SIDE, DUE TO THE RELATIVE STIFFNESS OF THE EARS TO THE PLATE ATTACH THE SHEAR FL TO THE FLANGE OF THE VALVE.



THE RESULTING WELD PROPERTIES @ THE FLANGES ARE THEN



$$A = (2[3 + 1.75]2 + 2(6\frac{1}{2}))t_w =$$

$$= (19.0 + 13.0)t_w = 32 t_w \text{ in}^2$$

$$I_2 = \left(2 \left[\frac{3(1.75)^2}{12} + \frac{3^3}{6} \right] + \frac{6.5^3}{6} + 2 \left[19.0(5.25)^2 \right] \right) t_w$$

I ear weld = weld A l²

$$= t_w [18.188 + 45.771 + 1047.375] = 1111.33 t_w \text{ in}^4$$



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	QID 361104	Rev. No.	1	Sheet No.	4.3.34

THE RESULTING SECTION MODULUS IS THEN

$$S = \frac{1111.33 tw}{(5.25 + 1.5)} = 164.6 tw \text{ in}^3$$

THE SECTION PROPERTIES OF THE WELDMENT OF THE EARS ABOUT THE 1-1 AXIS WILL IGNORE THE CONTRIBUTION OF THE SHEAR FL WELDMENT. SINCE THE STRESS CALCULATIONS WILL ONLY USE THE INDIVIDUAL EAR THE PROPERTIES WILL BE CALCULATED THUS.

$$A_{\text{EAR WELD}} = t_w(3 + 1.75)2 = 9.5 t_w \text{ in}^2$$

$$S_{1, \text{EAR}} = \left[3(1.75) + \frac{1.75^2}{3} \right] = 6.271 t_w \text{ in}^2$$



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	Rev. No.	Sheet No.			
OID 361104	1	4.3.35			

THE STRESSES ON THE WELDMENT ABOUT THE I-I AXIS IS DUE TO THE FOLLOWING LOAD

MOMENT @ WELDMENT

$$M_{II} = 170322 + 2(5454)(5") = 224862 \text{ IN-LB}$$

54540


$$V_1 = 2(5454) = 10908 \text{ LB}$$

THE RESULTING WELD LOAD IS THEN:

$$f_{bA} = M/S = 224862/164.6 = 1366 \text{ LB/IN}$$

$$f_{vHA} = V/A = 10908/32 = 341 \text{ LB/IN}$$

THE V_2 SHEAR AND THE M_1 MOMENT APPLICATION TO THE EAR GROUP IS TREATED AS FOLLOWS





Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis	QID 361104	Rev. No.	1	Sheet No.	4.3.36

IN REVIEWING THE PROPORTIONS OF THE MEMBERS, THE BENDING DEFLECTIONS WILL BE NEGLIGABLE IN COMPARISON TO SHEAR. THE RESULTING RESPONSE OF BENDING OF THE EAR IN COMPARISON TO THE HORIZONTAL SHEAR DEFLECTION OF THE PLATE



$$\delta_b = \frac{Pl^3}{3EI} = \frac{6138(5)^3}{3(30E^6)\left(\frac{3(1.75)^3}{12}\right)} = .00636$$

ASSUMING THE 1/2" PL AND THE EARS ARE EFFECTIVE IN SHEAR

$$A_s = 2(3)(1.75) + 7.75(.5) = 14.375$$

$$\delta_s = \frac{PL}{AE_s} = \frac{2(6138)(5.0)}{14.375(12E^6)} = .000356$$


$$\frac{\delta_b}{\delta_s} = 17.88 \Rightarrow \text{SHEAR STIFFNES IS ABOUT 18 TIMES AS STIFF AS BENDING}$$

OO ASSUME THAT THE RESULTING LOAD GOES PRIMARILY TO AXIAL AND SHEAR ON THE WELD MOUNT.



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	QID 361104	Rev. No.	1	Sheet No.	4.3.37



$$R = \frac{6138(5)}{4.75} = 6461 \text{ lb}$$

THE VERTICAL LOAD ON THE WELD DUE TO SHEAR AND BENDING MOMENT IS

$$f_{\text{axial}} = \frac{P}{A} + \frac{M_z}{d_z A_g} = \frac{6461}{9.5} + \frac{142329}{32}$$

$$= 680 + 460 = 1140 \text{ #/IN}$$

THE HORIZONTAL LOAD PRODUCES THE FOLLOWING SHEAR LOAD ON THE WELD.

$$P_{\text{shear}} = \frac{V_z}{A_s} = \frac{6138}{9.5} = 646 \text{ #/IN}$$

SINCE THE BENDING DOES CONTRIBUTE TO THE WELD STRESS CONSERVATIVELY ASSUME THE BENDING TO BE 10% EFFECTIVE OF TOTAL BENDING, NEGLECTING SHEAR STIFFNESS.



Calculation Sheet

Project	WPPSS Mechanical Equipment Regualification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	OID 361104	Rev. No.	1	Sheet No.	4.3.38

FROM KLEINLOGEL'S "RIGID FRAME FORMULAS"
FOR FRAME 5

$$I_1 = \frac{3(1.75)^3}{12} = 1.34 \text{ in}^4$$

$$I_2 = \frac{.15(4)^3}{12} = 2.67 \text{ in}^4$$

$$l_1 = 3 \text{ in}$$



$$l_2 = 9.5/2 = 4.75 \text{ in}$$

SINCE A PORTION OF THE SHAFT RATE IS PART OF THE EAR MODIFY THE STIFFNESS (I) TO COMPENSATE FOR THE "RIGID" PORTION

$$\frac{I_2}{l^3} = \frac{I_2'}{l'^3}$$

$$I_2' = \frac{I_2 l^3}{l'^3} = \frac{(2.67)(4.75)^3}{(4.75 - 1.75/2)^3}$$

$$= 4.917$$



FROM KLEINLOGEL

$$K = \frac{I_2'}{I_1} \cdot \frac{h}{l} = \frac{4.917(3.0)}{1.34(4.75)} = 2.318$$

$$N = 3K + 1 = 7.954$$



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	QID 361104	Rev. No.	1	Sheet No.	4.3.39

$$M_B = \frac{3Phk}{2N} = \frac{3\left(\frac{5}{3}\right)(6138)(3.0)(2318)}{2(7.954)} = 13415 \text{ IN LB}$$

$$M_A = -Ph + M_B = -\left(\frac{5}{3}\right)(6138)(3.0) + 13415$$
$$= -30690 + 13415 = -17274$$

THE AXIAL VERTICAL REACTION @ EITHER A OR C DUE TO HORIZONTAL STRESS

$$V_C = -V_A = \frac{M_B}{l} = \frac{13415}{4.75} = 2824 \text{ LB}$$

THE RESULTING LOAD IN THE WELD IN THE EAR: AXIAL DIRECTION DUE TO BENDING IS THEN

$$f_b = \frac{M}{S} = \frac{17274}{6.271} = 2755$$

TEN PERCENT OF THIS VALUE IS THEN

$$f_b' = 2755(.10) = 276 \text{ #/IN}$$



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis	OID 361104	Rev. No.	1	Sheet No.	4.3.40

TOTAL COMBINED LOAD

THE AXIAL LOAD t_3 WHEN APPLIED TO THE TOTAL AREA OF ATTACHMENT TO THE FLANGES PRODUCES THE FOLLOWING AXIAL LOAD ON THE WELD

$$P_1 = \frac{t_3}{2A} = \frac{3270}{2(32)} = 51.1 \text{ LB/IN}$$

THE TOTAL COMBINED LOAD ON THE WELD IS THEN

$$P_{\text{tot}} = \left[(1366 + 1148 + 276 + 51)^2 + (341^2 + 6d_0^2) \right]^{1/2}$$
$$= 2933 \text{ LB/IN}$$

THE RESULTING WELD STRESS IS THEN

$$\sigma_{\text{weld}} = \frac{2933}{(.707)(.3125)} = 13277 \text{ PSI} \leq 14000$$

* THIS STRESS LEVEL IS SOMEWHAT GREATER THAN THE ALLOWABLE STRESS FOR FATIGUE BUT CONTAINS THE OPERATING LOADS WHICH WOULD BRING THE ACTUAL ALTERNATING STRESS RANGE WITHIN ACCEPTABLE LIMITS.



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	QID 361104	Rev. No.	1	Sheet No.	4.3.41

THE STRESS LEVEL IN THE CORNER WELD DUE TO OPERATING LOADS IS

BENDING ABOUT THE 1-1 AXIS

$$V_2' = \frac{S_2}{4} + \left(\frac{9.5}{14.16} \right) \left(\frac{T}{28.32} \right)$$

$$V_2' = 690.3 + 531.3 = 1222 \text{ LB}$$

$$V_2 = 2V_2' = 2444$$

$$M_{11} = 21398 + 2444(5) = 33618$$

$$f_{b_{11}} = \frac{M_{11}}{S_{11}} = \frac{33618}{164.6} = 204 \text{ #/IN}$$

SHEAR ALONG THE 2-2 AXIS

$$f_{V_{22}} = \frac{V_2'}{A} = \frac{1222}{32} = 38 \text{ #/IN}$$

LOAD DUE TO SHEAR IN 1-1 DIRECTION

$$V_1' = \left(\frac{10.5}{14.16} \right) \left(\frac{T}{28.32} \right) = 587 \text{ #}$$

THE SHEAR ALONG THE 1-1 AXIS IS THEN:

$$f_{V_{11}} = \frac{587}{9.5} = 62 \text{ #/IN}$$



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	QID 361104	Rev. No.	1	Sheet No.	4.3.42

THE AXIAL LOAD ON THE WELD IS THEN

$$f_a = \frac{587(5)}{(4.75)9.5} = 65 \text{ #/IN}$$

THE 10 PERCENT CONTRIBUTION FROM BENDING IS THEN

$$f_b = 276 \left(\frac{587}{6138} \right) = 26 \text{ #/IN}$$

THE COMBINED LOAD FOR OPERATING IS THEN

$$f_t = \left[(204 + 65 + 26)^2 + (38^2 + 62^2) \right]^{1/2}$$
$$= 303.8 \text{ #/IN}$$

THE RESULTING STRESS LEVEL IS THEN

$$\sigma_{weld} = \frac{303.8}{.707(.3125)} = 1375 \text{ PSI}$$



Calculation Sheet


Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	QID 361104	Rev. No.	1	Sheet No.	4.3.43

THE WELD STRESS ON THE STIFFENING PLATE OF THE 10.5" DIRECTION IS CALCULATED AS FOLLOWS. CONSERVATIVELY COMBINE WORST CASE TENSILE AND SHEAR STRESS.

THE AREA OF WELD MENT OF PL TO FLANGE
 $A_F = 2(6\frac{1}{2}) = 13 \text{ in}^2$

GROSS PL & EAR PROP
 $Q_{\text{WELD}} = (5.25)(5.75) = 30.2$

$I_g = \frac{3(13.5)^3}{12} - \frac{2.5(7.5)^3}{12}$
 $= 527.2$



$$\rightarrow \frac{M_z \left(\frac{13}{2}\right)}{d_z A} + \frac{t_s \left(\frac{13}{2}\right)}{2A} + \frac{V Q (2)}{I}$$

$$= \frac{468(6.5)}{4} + \frac{(51.1)6.5}{4} + \frac{2(5454) \cdot 30.2 \cdot (-2)}{527.2}$$

$$= 761 + 83 + 1250 = 2094 \text{ lb/in}$$

TO GET PEAK STRESS @ END


WELD SHEAR LOAD



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	OID 361104	Rev. No.	1	Sheet No.	4.3.44

THE MAXIMUM TENSILE LOAD IS THEN



ASSUMING PIVED @ THE BOTTOM AND EQUATING MOMENTS,

$$steel \cdot l = \frac{w \cdot l}{2} \cdot \frac{2}{3} l$$

$$w = \frac{5454(3)}{l} = 4091 \text{ \#/IN}$$

COMBINE THE TENSILE AND THE SHEAR TO COME UP WITH THE REQUIRED WELD SIZE

$$f_{bt} = (4091^2 + 2094^2)^{1/2} = 4596 \text{ LB/IN}$$

TO STAY BELOW THE STRESS VALUE OF 11,500 PSI FOR FATIGUE AND USING 2 WELDS ALONG THE LENGTH

$$t_w = \frac{4596}{(11,500)(.707)(2)} = .283 \text{ IN}$$

⇒ USE 5/16
FILLET EA SIDE

FOR THE WELDMENT @ THE BOTTOM OF THE SHEAR PLATE THE LOADS AND RESULTING STRESSES ARE AS FOLLOWS.



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	QID 361104	Rev. No.	1	Sheet No.	4.3.45

THE SHEAR LOAD PER LENGTH IS

$$f_v = \frac{(5454)(2)}{32} = 341 \text{ LB/IN}$$

THE AXIAL LOAD DUE TO AXIAL OVERTURNING AND MOMENT LOADS IS THEN:

$$\begin{aligned} f_a &= \frac{M_1}{d_2 A} + \frac{t_2}{2A} + \frac{M c'}{I} = \\ &= 560 + 51.1 + \frac{196869(6.5/2)}{1111.33} \\ &= 560 + 51.1 + 575.7 = 1187 \text{ #/IN} \end{aligned}$$

THE TOTAL COMBINED LOAD

$$f_c = (1187^2 + 341^2)^{1/2} = 1235 \text{ #/IN}$$

ASSUMING A 5/16" WELD ON EACH SIDE OF THE PLATE THE RESULTING WELD STRESS IS THEN


$$\tau_{\text{WELD}} = \frac{1235}{(.707)(.3125)2} = 2795 \text{ PSI} \leq 14000$$




Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis ID	QID 361104	Rev. No.	1	Sheet No.	4.3.46

THE MAXIMUM LOADS ON THE WELD OF THE OTHER PLATES ARE AS FOLLOWS. SINCE THE BASIC RESISTANCE TO DEFLECTION IS BY SHEAR RESISTANCE OF THE PLATE THE PLATE IS BASICALLY ACTING LIKE A DIAGONAL MEMBER AS SHOWN BELOW.



$$6461 = \frac{6138(5)}{4.75}$$



FROM THE ORIGINAL FREEBODY THE ϕ SHEAR WAS 6461 # AND THE MOMENT WOULD BE $6461(3.875) = 25036$ IN LB. $J = \frac{2W(4)^2}{6} = 2.67$



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	QID 361104	Rev. No.	1	Sheet No.	4.3.47

THE RESULTING LOAD FROM THIS APPROACH

$$F_b = \frac{M}{S} = \frac{25036}{2.67} = 9377 \text{ \#/IN}$$

THE RESULTING SHEAR LOAD WOULD BE

$$F_v = \frac{V}{A} = \frac{6461}{4} = 1615 \text{ \#/IN}$$

THE COMBINED LOAD WOULD BE


$$F_t = \sqrt{(9377^2 + 1615^2)} = 9515$$

FOR A 5/16 WELDMENT ON EITHER SIDE THE RESULTING WELD STRESS WOULD THEN BE

$$\sigma_{\text{WELD}} = \frac{9515}{(.707)(.3125)(2)} = 21533 \text{ LB/IN}^2$$

TOO HIGH

IF THIS WERE CHANGED TO A FL ON THE OUTSIDE OF THE ENDS WITH A WELDMENT WITH THE FOLLOWING PROPORTIONS



$$A = 2(4 + 1.25) = 10.5 \text{ IN}$$

$$J = \frac{(b+d)^3}{6} = \frac{(4+1.25)^3}{6} = 24.1$$



Calculation Sheet

Project	WPPSS Mechanical Equipment Requalification	Prepared By:	M.A. Scott	Date	6/15/83
Subject	30" Cylinder Operated Butterfly Valves	Checked By:	L.C. Fernandez	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01.F
Analysis No.	OID 361104	Rev. No.	1	Sheet No.	4.3.48

THE MOMENT WOULD BE

$$.6461 (3.875 + (1.25/2)) = (4.5)(.6461) = 29075$$

THE HORIZONTAL SHEAR LOAD @ THE TOP WOULD BE

$$f_h = \frac{Mc_v}{J} = \frac{29075 (2")}{24.1} = 2413 \# / IN$$

THE VERTICAL SHEAR LOAD @ THE TOP WOULD BE

$$\begin{aligned} \Sigma_v &= \frac{Mc_h}{J} + \frac{V}{A} = \frac{29075 (.625)}{24.1} + \frac{.6461}{10.5} \\ &= 754 + 615 = 1369 \# / IN \end{aligned}$$

THE TOTAL LOAD ON THE WELD IS THEN

$$f_{tot} = (2413^2 + 1369^2)^{1/2} = 2774$$

THE RESULTING WELD STRESS IS THEN

$$\sigma_{weld} = \frac{2774}{.707 (.3125)} = 12557 \text{ PSI} \leq 14000 *$$

* THIS LOAD IS SOMEWHAT HIGH BUT CONTAINS THE OPERATING LOADS SO THE ACTUAL FATIGUE RANGE IS LOWER AND IS IN ACCEPTABLE



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By	J.E. Rakowski	Date	1/10/83
Subject	30" Butterfly Valves	Checked By	L.C. Fernández	Date	6/15/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No	361104	Rev. No.	1	Sheet No	4.3.49

Section 4.3.5 - Fatigue Analysis

Discussion

The operator and bracket assembly are not part of the pressure boundary, therefore, the fatigue analysis will be performed in accordance with Appendix B of the AISC Manual for Steel Construction. The following assumptions apply to the fatigue analysis.

- 1) Faulted stresses (based on piping-analysis accelerations) will be used. This is necessary to insure operability after a design basis event.
- 2) The actual stresses used will be the ones calculated in Section 4.3.
- 3) If the alternating portion of the stress has been calculated separately only this part will be used. If the operating loads (i.e. seating torque effects) are already included in the stress analysis it will be conservative to use the calculated stress value. As long as no failures occur, the operating stress does not need to be extracted.
- 4) The allowable stress will be based on Table B3 of Appendix B in the AISC Manual of Steel Construction.
- 5) A factor of 1.5 will be applied to the allowable because of the low number of cycles. (Per Section 1.7 of the Commentary on the AISC Manual).
- 6) The actual stress range is taken as 2 times the maximum stress for components subject to alternating tension and compression.



Calculation Sheet

Project	Prepared By:	J.E. Rakowski	Date	1/10/83
WPPSS Mechanical Equipment Qualification	Checked By:	L.C. Fernandez	Date	4/29/83
Subject	Job No.	82044	File No.	0
30" Butterfly Valves				08.01/F
System	Analysis No.	Rev. No.	Sheet No.	
CSP and CEP	361104	1	4.3.50	

- 7) Bracket bolting is assumed to be properly tightened and will not be considered for fatigue per Section B3.1 of the AISC Manual.

The table on the following page gives the calculated stress range, stress category, and allowable for the critical components. The following page gives excerpts from Appendix B of the AISC Manual showing the descriptions of the relevant stress categories.



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	1/10/83
Subject	30" Butterfly Valves	Checked By:	L.C. Fernandez	Date	4/29/83
System	CSP and CEP	Job No.	82044	File No.	O'S.01/E
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.51

Fatigue Analysis (cont.)

ITEM	STRESS TYPE	STRESS (PSI)	STRESS RANGE (PSI)	STRESS CATEGORY	1.5 x ALLOW (FROM AISC)
TRUNNION PIN	T	4108	8216	F ⁽¹⁾	22500
DRIVE ROD (MAX)	T	- SEE TABLE 1.2 -		A	90000
SUPPORT EARS	T	- SEE TABLE 1.2 -		A	90000
MAIN SHAFT	T	9127	18254	A	90000
		7158	14316	A	90000

NOTES:

- (1) Assume shear stress on nominal area of a stud type shear connection.

Note that this comparison includes all of the load combinations in one conservative comparison using the maximum stress and the total number of cycles ($3 \times 4500 + 2000 + 60 = 15560$).



<h1>Calculation Sheet</h1>		Prepared By:	Date
		Checked By:	Date
Project	Subject	Job No.	File No.
System	Analysis No.	Rev. No.	Sheet No.

Project: SUPPLY SYSTEM
 Subject: 30' BUTTERFLY VALVE
 System: CSP & CEP
 Analysis No.: 361104 Rev. No.: 1
 Job No.: 82044 File No.: OS.01/F
 Sheet No.: 4.3.52

FATIGUE ANALYSIS (CONT.)

THE TABLE BELOW HAS BEEN CONDENSED FROM APPENDIX B OF THE AISC MANUAL OF STEEL CONSTRUCTION. THE CASES USED ARE MARKED WITH AN ARROW.

General Condition	Situation	Kind of Stress*	Stress Category. (See Table B3)
Plain material	Base metal with rolled or cleaned surfaces.	T or Rev.	A
Built-up members	Base metal and weld metal in members, without attachments, built-up of plates or shapes connected by continuous full- or partial-penetration groove welds or continuous fillet welds parallel to the direction of applied stress.	T or Rev.	B
	Calculated flexural stress, f_b , in base metal at toe of welds on girder webs or flanges adjacent to welded transverse stiffeners.	T or Rev.	C
	Base metal at end of partial-length welded cover plates having square or tapered ends, with or without welds across the ends.	T or Rev.	E
Mechanically fastened connections	Base metal at gross section of high-strength-bolted friction-type connections, except connections subject to stress reversal and axially loaded joints which induce out-of-plane bending in connected material.	T or Rev.	B
	Base metal at net section of other mechanically fastened joints.	T or Rev.	D
	Base metal at net section of high-strength bolted bearing connections.	T or Rev.	B
Attachments	Shear stress on nominal area of stud-type shear connectors.	S	F

← (90,000)

← (22,500)



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By:	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valve	Checked By:	L.C. Fernandez	Date	4/29/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.53

4.4 REFERENCES

1) BIF Drawings

	Drawing #	Rev#	Description
a	A-206763	F	General Arrangement
b	CEP-625-10		From Reactor Nozzle X-3 to SGT-FU-1A, 1B
c	CEP-625-11.12	H	From Reactor Nozzle X-3 to SGT-FU-1A, 1B
d	C-26095		Model A-83B Cylinder
e	A-206767		Valve Assembly
f	DOC-D-220-0310-IR-66	O	Tube erection isometric
g	D-207110	F	Valve Data Sheet
h	M-144		General Arrangement plan mis level
k	CSP-807-3.4		Containment purge air supply system



Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By	L.C. Fernández	Date	7/29/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	4.3.54

Reference cont'n

Formulas for Natural Frequency and Mode Shapes,
Robert D. Blevins
Van Nostrand Reinhold Company
1979 Edition

- 3) BIF Report TR-27234 and TR-27235, "Dynamic Torque Calculation of Butterfly Valve; Sizes 24 and 30 inch", dated November 10, 1982.
- 4) Report TR-74-8 by McPherson Assoc., Inc., "Design & Seismic Analysis 30" Cylinder operated Butterfly Valve". (Rev. 1) 12/31/75.
- 5) WPPSS letter to Cygna Energy Services, GE-02-RWH-018, 12/17/82.
- 6) WPPSS, WNP-2 SRM Equipment List Summary Sheets dated 2/10/83.
- 7) Cygna Energy Services, Equipment Qualification Walkdown Verification Form dated 7/14/82 and 7/19/82.
- 8) Cygna Energy Services, "Project Manual Design Criteria," DC-1, Rev. 1, 10/82.
- 9) Burns and Roe Revised Piping Analysis Loads for CSP-V-1 and 2 (dated 4/12/83) and CEP-V-1A and 1B (dated 11/15/82).
- 10) Communications Report, R. Ricappito of BIF and J. Rakowski of CES, "BIF Valve Dimensions", 2/11/83

APPENDIX A

COMPILED PROGRAMS AND RESULTS FOR

CSP-V-1

CSP-V-2

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>05.01.F</u>
SHEET NO. <u>4.3.A1</u>

sbasic csp12
tm
S-BASIC Compiler Version 5.4b

```
0001:00 REM***** BIF VALVE AND AIR OPERATOR SEISMIC STRESS *****
0002:00 REM***** CSP-V/AO-1/2 *****
0003:00 REM***** 10 INCH AO PARAMETERS *****
0004:00 REM
0005:00 var i,j,k = integer
0006:00 var lrod,lcg,x,phi,lave,ablt,l1,l2,e1,e2,e3,e4,e5 = real
0007:00 var fst2, ca,ia,cb,ib,aa,ab,d1,d2,c1,i1,c2,i2=real
0008:00 var lrodo,lcgo,ldr,d, abush, pbush=real
0009:00 var fcof, fco, ma,mb, siga, sigb, fcdr, fcdrf,maf, mbf=real
0010:00 var dear, fcear,fr, f11,f22,la, cil2,ci21,slt3,semi=real
0011:00 var sem2,set3,ses1,ses2,sr,tau11,tau22,tauear,aeear=real
0012:00 var btens, taubl, set3f,sem1f,sem2f,fcearf, frf,f11f=real
0013:00 var f22f,slt3f,ses1f,ses2f,srf,tau1f,tau2f,taurf=real
0014:00 var taubf,btf, dsr,dtaur,dtaub,dbten,dsa,dsb,dpb=real
0015:00 var sdraf,sdrbf,pbushf,tau11f,tau22f=real
0016:00 var wao,wbr,ftr1,watr1,s1,s1f,s2,s2f,m1,m1f,m2=real
0017:00 var m2f,t3,t3f,tt3,tt3f,lbr,wtot=real
0018:00 var bs1,bs2,bt3,bm1,bm2,btt3=real
0019:00 dim real av(3)
0020:00 dim real wa(3)
0021:00 dim real wb(3)
0022:00 REM
0023:00 REM *** BURNS 7 ROE EAR FORCES ARE bs1 etc TURN ON WITH K=1***
0024:00 REM
0025:00 REM
0026:00 dim real a(3,3)
0027:00 dim real b(3)
0028:00 dim real glc(3,3)
0029:00 1 data 9.5, 10.5, .88, 3.94, 1.50,1.34
0030:00 2 data 25,21.50,.488,48.,4.85,.627,1.75,3.0
0031:00 3 data 1847.,.875,.46,.648,.138,2.41,1.4
0032:00 4 data 593.,321.,5.25,8.5,28.5,15.,7.75
0033:00 5 data 40.,16.25,26.5,43.,2.075
0034:00 6 data 135.,90.,135.,90.,180.,90.
0035:00 7 data 45.,90.,135.,90.,0.,90.
0036:00 REM DATA 6&7 FOR VALVE/GLOBAL-G ORIENTATIONS AND WEIGHT VECTOR
0037:00 restore
0038:00 read d1,d2,c1,i1,c2,i2
0039:00 restore 2
0040:00 read lrod,lcg,x,phi,lave,ablt,l1,l2
0041:00 restore 3
0042:00 read fst2,ca,ia,cb,ib,aa,ab
0043:00 restore 4
0044:00 read wao,wbr,e1,e2,e3,e4,e5
0045:00 restore 5
0046:00 read lrodo,lcgo,ldr,d,abush
0047:00 restore 6
0048:00 read a(1,1),a(2,1),a(3,1),a(1,2),a(2,2),a(3,2)
0049:00 restore 7
0050:00 read a(1,3),a(2,3),a(3,3),av(1),av(2),av(3)
0051:00 text 0,& INPUT GLOBAL ACCELERATIONS &
0052:00 input b(1),b(2),b(3)
0053:00 print
0054:00 text 0,& INPUT DATA &
0055:00 print
0056:00 print "GLOBAL G-LEVELS = ";b(1),b(2),b(3)
0057:00 print "NORTH VECTOR ANGLES = ";a(1,1),a(2,1),a(3,1)
0058:00 print "VERTICAL VECTOR ANGLES=" ;a(1,2),a(2,2),a(3,2)
```

CYGNA
ATTACHM. #
JOB NO. <u>82044</u>
FILE NO. <u>05.01.F</u>
SHEET NO. <u>4.3.AZ</u>

```

0059:00 print "EAST VECTOR ANGLES   = ";a(1,3),a(2,3),a(3,3)
0060:00 print "WEIGHT VECTOR ANGLES = ";av(1),av(2),av(3)
0061:00 print
0062:00 for i=1 to 3
0063:01 for j=1 to 3
0064:02   a(j,i)=a(j,i)*2.*3.1416/360.
0065:02   glc(j,i)=b(i)*cos(a(j,i))
0066:02 next j
0067:01 next i
0068:00 for j=1 to 3
0069:01 av(j)=av(j)*2.*3.1416/360.
0070:01 next j
0071:00 print
0072:00 text 0,& LOCAL G-LEVELS &
0073:00 print
0074:00 print glc(1,1),glc(1,2),glc(1,3)
0075:00 print glc(2,1),glc(2,2),glc(2,3)
0076:00 print glc(3,1),glc(3,2),glc(3,3)
0077:00 REM WEIGHT COMPONENTS
0078:00 for j=1 to 3
0079:01 wa(j)=wao*cos(av(j))
0080:01 wb(j)=wbr*cos(av(j))
0081:01 next j
0082:00 phi=phi*2.*3.1416/360.
0083:00 la=lave/2
0084:00 cil2=c1/i2
0085:00 ci21=c2/i1
0086:00 aear=l1*12
0087:00 REM CALCULATE EAR FORCES USE B&R LOADS AS OPTION LATER
0088:00 REM FIXED COMPONENTS ARE ALWAYS THERE
0089:00 lbr=lrod+lcg
0090:00 watr1=lbr*wa(1)/lrod
0091:00 slf=wb(1)+watr1
0092:00 wtot=wao+wbr
0093:00 s2f=wb(2)+wa(2)+fst2
0094:00 t3f=wa(3)+wb(3)
0095:00 m1f=-(wa(2)+wb(2)+fst2)*e5-wa(3)*(e3+lcg)-wb(3)*e4
0096:00 m2f=(watr1+wb(1))*e5-wa(3)*e2-wb(3)*e1
0097:00 tt3f=watr1*e3+(wa(2)+fst2)*e2+wb(1)*e4+wb(2)*e1
0098:00 fcdrf=lcg*wa(1)/lrod
0099:00 maf=fcdrf*(lrod-13.5)
0100:00 mbf=fcdrf*7.125
0101:00 sdraf=fst2/aa+abs(maf*ca/ia)
0102:00 sdrbf=fst2/ab+abs(mbf*cb/ib)
0103:00 fcof=lcgo*wa(1)/lrodo
0104:00 pbushf=fcof*(ldr+d)/(d*abush)
0105:00 REM STRESSES FROM FIXED COMPONENTS
0106:00 dear=(d1*d1+d2*d2)**.5
0107:00 set3f=abs(t3f/(4*aear))
0108:00 sem1f=abs(m1f/(2*d2*aear))
0109:00 sem2f=abs(m2f/(2*d1*aear))
0110:00 fcearf=tt3f/(2*dear)
0111:00 frf=x*fcearf
0112:00 f11f=-(fcearf*sin(phi)-frf*cos(phi))
0113:00 f22f=fcearf*cos(phi)+frf*sin(phi)
0114:00 stt3f=abs(f11f*la*cil2)+abs(f22f*la*ci21)
0115:00 ses1f=abs(slf*ci12*la/4.)
0116:00 ses2f=abs(s2f*ci21*la/4.)
0117:00 srf=set3f+sem1f+sem2f+ses1f+ses2f+stt3f
0118:00 REM EAR SHEAR
0119:00 tau11f=abs(slf/(4*aear))+abs(f11f/aear)
0120:00 tau22f=abs(s2f/(4*aear))+abs(f22f/aear)
0121:00 taurf=(tau11f*tau11f+tau22f*tau22f)**.5
0122:00 taubf=taurf*aear/abl t
0123:00 REM EARBOLT TENSION
0124:00 btf=(set3f+sem1f+sem2f)*aear/abl t
0125:00 print

```

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>05.01.F</u>
SHEET NO. <u>43.A3</u>

```

0126:00 print"OPERATING CYLINDER BRG PRESSURE ";pbush+
0127:00 print"OPERATING VALVE EAR TENSILE STR ";srf
0128:00 print"OPERATING VALVE EAR SHEAR STRES ";taurf
0129:00 print"OPERATING EAR BOLT SHEAR STRESS ";taubf
0130:00 print"OPERATING EAR BOLT TENSILE STR ";btf
0131:00 print
0132:00 REM
0133:00 REM CALCULATE VARIABLE COMPONENTS
0134:00 REM
0135:00 dsr=0.
0136:00 dtaur=0.
0137:00 dtaub=0.
0138:00 dbten=0.
0139:00 dsa=0.
0140:00 dsb=0.
0141:00 dpb=0.
0142:00 for j=1 to 3
0143:01 fco=lcg*wao*glc(1,j)/lrodo
0144:01 pbush=fco*(ldr+d)/(d*abush)
0145:01 ftr1=lbr*wao*glc(1,j)/lrod
0146:01 s1=ftr1+wbr*glc(1,j)
0147:01 s2=wtot*glc(2,j)
0148:01 t3=wtot*glc(3,j)
0149:01 m1=-wtot*glc(2,j)*e5-wao*glc(3,j)*(e3+lcg)-wbr*glc(3,j)*e4
0150:01 m2=(ftr1+wbr*glc(1,j))*e5-(wao*e2+wbr*e1)*glc(3,j)
0151:01 tt3=ftr1*e3+wbr*glc(1,j)*e4+glc(2,j)*(wao*e2+wbr*e1)
0152:01 fcdr=lcg*wao*glc(1,j)/lrod
0153:01 ma=fcdr*(lrod-13.5)
0154:01 mb=fcdr*7.125
0155:01 siga=ma*ca/ia
0156:01 sigb=mb*cb/ib
0157:01 REM CALCULATE EAR TENSION
0158:01 set3=abs(t3/(4*aeear))
0159:01 sem1=abs(m1/(2*d2*aeear))
0160:01 sem2=abs(m2/(2*d1*aeear))
0161:01 fcear=tt3/(2*dear)
0162:01 fr=x*fcear
0163:01 f11=-(fcear*sin(phi)-fr*cos(phi))
0164:01 f22=fcear*cos(phi)+fr*sin(phi)
0165:01 stt3=abs(f11*la*ci12)+abs(f22*la*ci21)
0166:01 ses1=abs(s1*ci12*la/4.)
0167:01 ses2=abs(s2*ci21*la/4.)
0168:01 sr=set3+sem1+sem2+ses1+ses2+stt3
0169:01 REM EAR SHEAR
0170:01 tau11=abs(s1/(4.*aeear))+abs(f11/aeear)
0171:01 tau22=abs(s2/(4.*aeear))+abs(f22/aeear)
0172:01 tauear=(tau11*tau11+tau22*tau22)**.5
0173:01 taubl t=tauear*aeear/abl t
0174:01 REM EARBOLT TENSION
0175:01 btens=(set3+sem1+sem2)*aeear/abl t
0176:01 dsa=dsa+siga*siga
0177:01 dsb=dsb+sigb*sigb
0178:01 dpb=dpb+pbush*pbush
0179:01 dsr=dsr+sr*sr
0180:01 dtaur=dtaur+tauear*tauear
0181:01 dtaub=dtaub+taubl t*taubl t
0182:01 dbten=dbten+btens*btens
0183:01 next j
0184:00 REM COMBINE STRESSES
0185:00 dsa=dsa**.5
0186:00 dsb=dsb**.5
0187:00 dpb=dpb**.5
0188:00 dsr=dsr**.5
0189:00 dtaur=dtaur**.5
0190:00 dtaub=dtaub**.5

```

CYGNA
ATTACHMENT
JOB NO. <u>F2044</u>
FILE NO. <u>05.01.F</u>
SHEET NO. <u>4.3.A4</u>

```

0192:00 print
0193:00 text 0,& DYNAMIC COMPONENTS &
0194:00 print
0195:00 print "DRIVE ROD TENSILE STRESS AT A";dsa
0196:00 print "DRIVE ROD TENSILE STRESS AT B";dsb
0197:00 print "BUSHING PRESSURE";dpb
0198:00 print "VALVE EAR TENSILE STRESS";dsr
0199:00 print "VALVE EAR SHEAR STRESS";dtaur
0200:00 print "EAR BOLT SHEAR STRESS";dtaub
0201:00 print "EAR BOLT TENSILE STRESS";dbten
0202:00 dsa=dsa+abs(sdraf)
0203:00 dsb=dsb+abs(sdrbf)
0204:00 dpb=dpb+abs(pbushf)
0205:00 dsr=dsr+abs(srf)
0206:00 dtaur=dtaur+abs(taurf)
0207:00 dtaub=dtaub+abs(taubf)
0208:00 dbten=dbten+abs(btf)
0209:00 print
0210:00 text 0,& FIXED PLUS DYNAMIC COMPONENTS &
0211:00 print
0212:00 print "DRIVE ROD TENSILE STRESS AT A";dsa
0213:00 print "DRIVE ROD TENSILE STRESS AT B";dsb
0214:00 print "PUSHING PRESSURE";dpb
0215:00 print "VALVE EAR TENSILE STRESS";dsr
0216:00 print "VALVE EAR SHEAR STRESS";dtaur
0217:00 print "EAR BOLT SHEAR STRESS";dtaub
0218:00 print "EAR BOLT TENSILE STRESS";dbten
0219:00 end
0220:00
0221:00
0222:00
0223:00
0224:00
0225:00

```

***** End of program *****

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>05.01.F</u>
SHEET NO. <u>4.3.A5</u>

cspi

INPUT GLOBAL ACCELERATIONS
? 2.26, 3.62, 2.8

INPUT DATA


GLOBAL G-LEVELS	=	2.26	3.62	2.8
NORTH VECTOR ANGLES	=	135	90	135
VERTICAL VECTOR ANGLES	=	90	180	90
EAST VECTOR ANGLES	=	45	90	135
WEIGHT VECTOR ANGLES	=	90	0	90

LOCAL G-LEVELS

-1.59807	-1.38092E-5	1.97989
-8.62121E-6	-3.62	-1.06811E-5
-1.59807	-1.38092E-5	-1.97991

OPERATING DRIVE ROD STRESS AT A 766.432
 OPERATING DRIVE ROD STRESS AT B 1319.35
 OPERATING CYLINDER BRG PRESSURE -7.15824E-4
 OPERATING VALVE EAR TENSILE STR 2111.01
 OPERATING VALVE EAR SHEAR STRES 293.896
 OPERATING EAR BOLT SHEAR STRESS 2460.85
 OPERATING EAR BOLT TENSILE STR 1625.1

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A	28384.4	
DRIVE ROD TENSILE STRESS AT B	43412.2	- reduced core section check to insure it is
BUSHING PRESSURE	477.447	
VALVE EAR TENSILE STRESS	8282.34	* SEE SHEETS 4.3.30 - 4.3.48 
VALVE EAR SHEAR STRESS	840.657	
EAR BOLT SHEAR STRESS	7039	
EAR BOLT TENSILE STRESS	10524.9	

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A	29150.9	
DRIVE ROD TENSILE STRESS AT B	44731.6	
PUSHING PRESSURE	477.448	
VALVE EAR TENSILE STRESS	10393.3	*
VALVE EAR SHEAR STRESS	1134.55	
EAR BOLT SHEAR STRESS	9499.86	
EAR BOLT TENSILE STRESS	12150	

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>05.01.F</u>
SHEET NO. <u>4.3.A6</u>

CSP 2
 INPUT GLOBAL ACCELERATIONS
 2.6, 3.62, 2.8

INPUT DATA

GLOBAL G-LEVELS	=	2.26	3.62	2.8
NORTH VECTOR ANGLES	=	135	90	135
VERTICAL VECTOR ANGLES	=	90	180	90
EAST VECTOR ANGLES	=	45	90	135
WEIGHT VECTOR ANGLES	=	90	0	90

LOCAL G-LEVELS

-1.59807	-1.38092E-5	1.97989
-8.62121E-6	-3.62	-1.06811E-5
-1.59807	-1.38092E-5	-1.97991

OPERATING DRIVE ROD STRESS AT A 766.432
 OPERATING DRIVE ROD STRESS AT B 1319.35
 OPERATING CYLINDER BRG PRESSURE -7.15824E-4
 OPERATING EAR WELD TENSILE STR 3090.43
 OPERATING EAR WELD SHEAR STRES 735.124
 OPERATING EAR BOLT SHEAR STRESS 2460.86
 OPERATING EAR BOLT TENSILE STR 1625.1

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 28384.4
 DRIVE ROD TENSILE STRESS AT B 43412.2
 BUSHING PRESSURE 477.447
~~EAR WELD TENSILE STRESS 12091.7~~
~~EAR WELD SHEAR STRESS 2102.74~~
 EAR BOLT SHEAR STRESS 7039
 EAR BOLT TENSILE STRESS 10524.9

* SEE SHEETS 4.3.30 - 4.3.38 ▲

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 29150.9
 DRIVE ROD TENSILE STRESS AT B 44731.6
 PUSHING PRESSURE 477.448
~~EAR WELD TENSILE STRESS 15182.1~~
~~EAR WELD SHEAR STRESS 2837.86~~
 EAR BOLT SHEAR STRESS 9499.86
 EAR BOLT TENSILE STRESS 12150

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>05.01.F</u>
SHEET NO. <u>4.3.A7</u>

csp ②
INPUT GLOBAL ACCELERATIONS
? 1.44, 3.54, 1.9

INPUT DATA

GLOBAL G-LEVELS	=	1.44	3.54	1.9
NORTH VECTOR ANGLES	=	135	90	135
VERTICAL VECTOR ANGLES	=	90	180	90
EAST VECTOR ANGLES	=	45	90	135
WEIGHT VECTOR ANGLES	=	90	0	90

LOCAL G-LEVELS

-1.01824	-1.3504E-5	1.3435
-5.49316E-6	-3.54	-7.24792E-6
-1.01824	-1.3504E-5	-1.34351

OPERATING DRIVE ROD STRESS AT A 766.432
OPERATING DRIVE ROD STRESS AT B 1319.35
OPERATING CYLINDER BRG PRESSURE -7.15824E-4
OPERATING VALVE EAR TENSILE STR 2111.01
OPERATING VALVE EAR SHEAR STRESS 293.896
OPERATING EAR BOLT SHEAR STRESS 2460.85
OPERATING EAR BOLT TENSILE STR 1625.1

DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 18806
DRIVE ROD TENSILE STRESS AT B 28762.8
BUSHING PRESSURE 316.332
~~VALVE EAR TENSILE STRESS 5755.57~~
~~VALVE EAR SHEAR STRESS 606.432~~
EAR BOLT SHEAR STRESS 5077.94
EAR BOLT TENSILE STRESS 7164.63

* SEE SHEETS 4.3.30 - 4.3.42 ⚠

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 19572.5
DRIVE ROD TENSILE STRESS AT B 30082.1
PUSHING PRESSURE 316.333
~~VALVE EAR TENSILE STRESS 7866.59~~
~~VALVE EAR SHEAR STRESS 900.348~~
EAR BOLT SHEAR STRESS 7538.79
EAR BOLT TENSILE STRESS 8789.72

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OS.01.F</u>
SHEET NO. <u>4.3.A8</u>

CS01(2)
 INPUT GLOBAL ACCELERATIONS
 14, 3.54, 1.9

INPUT DATA

GLOBAL G-LEVELS	=	1.44	3.54	1.9
NORTH VECTOR ANGLES	=	135	90	135
VERTICAL VECTOR ANGLES	=	90	180	90
EAST VECTOR ANGLES	=	45	90	135
WEIGHT VECTOR ANGLES	=	90	0	90


LOCAL G-LEVELS

-1.01824	-1.3504E-5	1.3435
-5.49316E-6	-3.54	-7.24792E-6
-1.01824	-1.3504E-5	-1.34351

OPERATING DRIVE ROD STRESS AT A 766.432
 OPERATING DRIVE ROD STRESS AT B 1319.35
 OPERATING CYLINDER BRG PRESSURE -7.15824E-4
 OPERATING EAR WELD TENSILE STR 3090.43
 OPERATING EAR WELD SHEAR STRESS 735.124
 OPERATING EAR BOLT SHEAR STRESS 2460.86
 OPERATING EAR BOLT TENSILE STR 1625.1

MIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 18806
 DRIVE ROD TENSILE STRESS AT B 28762.8
 BUSHING PRESSURE 316.332
~~EAR WELD TENSILE STRESS 8415.88~~
~~EAR WELD SHEAR STRESS 1516.92~~
 EAR BOLT SHEAR STRESS 5077.96
 EAR BOLT TENSILE STRESS 7164.63

* SEE SHEETS 4.3.30 - 4.3.43 

FIXED PLUS DYNAMIC COMPONENTS

DRIVE ROD TENSILE STRESS AT A 19572.5
 DRIVE ROD TENSILE STRESS AT B 30082.1
 PUSHING PRESSURE 316.333
~~EAR WELD TENSILE STRESS 11506.3~~
~~EAR WELD SHEAR STRESS 2252.04~~
 EAR BOLT SHEAR STRESS 7538.81
 EAR BOLT TENSILE STRESS 8789.72

CYGNA
ATTACHMENT
JOB NO. <u>02044</u>
FILE NO. <u>OS.01.F</u>
SHEET NO. <u>4.3.49</u>

APPENDIX B

VALVE/AIR OPERATOR MODEL FOR
FINAL PIPING RESPONSE G-LEVEL CALCULATION.

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OS 01.F</u>
SHEET NO. <u>4.3.B1</u>

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

CALCULATION CONTINUATION SHEET

CALC NO. 361104

SHEET 4.3.82 OF

APPENDICES B & C REMOVED.
IDENTICAL TO SAME APPENDICES
IN QID 361106 (24" VALVES)

REVISION INDICATIONS

CHECKED (INITIALS/DATE)

RWJ

SECTION 5.0

APPENDICES

CONTENTS

- ~~5.1~~ ~~Response Spectra~~ REM. (SAME AS
IN SQR SUMMARY)
- 5.2 Walkdown Sheets
- 5.3 Valve Local Coordinate Systems
- ~~5.4~~ ~~SRM Sheets~~ REM (ADMINISTRATIVE)
- 5.5 Revised Burns and Roe
Piping Analysis Accelerations
- 5.6 Load Comparative Sheets



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

PAGE 1 OF 2

EPN CSP-V-1

QID# 361104

COORDS M.517.6

BLDG R

FLOOR EL 501

MFR BIF

COMPONENT EL 508

DSCRIP 'BUTTERFLY VAL'

MODEL# 0657

SERIAL# N127232-1

MAT'L S1516 G270

45 PSI @ 340 °F

ASME CLASS 2

LBS SIZE 30


YOKE ORIENTATION

⊥ TO AXIS OF PIPE ()
 // TO AXIS OF PIPE () N/A
 YOKE LENGTH _____
 (FLANGE TO FLANGE)


MOUNTING CONDITION

NO OF BOLTS _____
 BOLT TYPE _____ BOLT Ø 1/4" (UNF)
 WELD TYPE & SIZE FLANGE CLASS 327
 PIPE MOUNTED YES (X) NO ()

PERMANENT OBSTRUCTION (WITHIN 2").....YES () NO (X)
 IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES (X) NO ()
 DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO (X)



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

OPERATOR EPN <u>CSP-HO-1</u>	MANUFACTURER <u>MILLER FLUID MOTION</u>
MODEL NO <u>(3)</u>	SERIAL NO _____
TYPE _____ SIZE _____	ORDER NO _____


MOTOR EPN <u>N/A</u>	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
ID NO _____ INS CLASS _____	1-PHASE () 3-PHASE () AC _____ DC _____

TYPE OF CONDUIT CONNECTION: RIGID () FLEX (X)


- NOTES: 1. Definition (N/F = Not Found)
 2. (2) NAMCO LIMIT SWITCHES SERIAL # CA176080100
 3. THERE WERE NO AIR OPERATOR MFG MODEL/IDENTIFICATION TAGS FOUND

2


PREPARED BY Don Seagle DATE 6/6/83 REVIEWED BY L C Fernandez DATE 6/20/83
 (SIGNATURE) (SIGNATURE)
DON SEAGLE L C FERNANDEZ




Project	WINP #2	Prepared By	Jim Seale	Date	12/2
Subject	EQUIP. QUALIFICATION	Checked By	E. Robinson	Date	1/4/83
System	CSP-V-1	Job No.	82046	File No	
Analysis No	010361104	Rev No		Sheet No	2 OF 2



CSP-V-1,2 (TOP VIEW)



PLAN VIEW (B-B)



$\theta \approx 7^\circ$ - CSP-V-1
 $\theta \approx 6^\circ$ - CSP-V-2

SECTION VIEW A-A

FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION, ONLY)



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

PAGE 1 OF 2

EPN CSP-V-2

QID# 361104

COORDS M.S/74

BLDG R

FLOOR EL 501

MFR BIF

COMPONENT EL 508

DSCRIP BUTTERFLY VALV

MODEL# 0657

SERIAL# N-27234-2

MAT'L SA516 G270

45 PSI @ 340 °F

ASME CLASS 2

LBS N/F SIZE 30


YOKE ORIENTATION

⊥ TO AXIS OF PIPE ()
 // TO AXIS OF PIPE () N/A
 YOKE LENGTH _____
 (FLANGE TO FLANGE)


MOUNTING CONDITION

NO OF BOLTS _____
 BOLT TYPE _____ BOLT Ø 1/2 (As Viewed)
 WELD TYPE & SIZE LAD 1/327
 PIPE MOUNTED YES (X) NO ()

PERMANENT OBSTRUCTION (WITHIN 2").....YES () NO (X)
 IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES (X) NO ()
 DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO (X)



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

OPERATOR EPN <u>CSPAO-2</u>	MANUFACTURER <u>MILLER FLUID POWER</u>
MODEL NO <u>③</u>	SERIAL NO _____
TYPE _____ SIZE _____	ORDER NO _____

MOTOR EPN <u>N/A</u>	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
ID NO _____ INS CLASS _____	1-PHASE () 3-PHASE () AC _____ DC _____

TYPE OF CONDUIT CONNECTION: RIGID () FLEX (X)

NOTES: 1. Definition (N/F = Not Found)

2. NAMCO LIMIT SWITCHES SERIAL # EA 74060100


3. THERE WERE NO AIR OPERATOR MFG MODEL/IDENTIFICATION TAGS FOUND

PREPARED BY Don Scoble DATE 4/16/83 REVIEWED BY L.C. Fernandez DATE 6/20/83
 (SIGNATURE) (SIGNATURE)


DON SCOBLE

L.C. FERNANDEZ


Project: <u>WIP #2</u>	Prepared By: <u>H. [unclear]</u>	Date: <u>12/2</u>
Subject: <u>EQUIP. QUALIFICATION</u>	Checked By: <u>E. [unclear]</u>	Date: <u>1/4/83</u>
System: <u>CSP-V-2</u>	Job No: <u>82044</u>	File No:
Analysis No: <u>QID 361104</u>	Rev. No:	Sheet No: <u>2 OF 2</u>



CSP-V-1, 2 (TOP VIEWS)




PLAN VIEW (E-E)



$\theta = 7^\circ$ - CSP-V-1
 $\theta = 6^\circ$ - CSP-V-2

SECTION VIEW A-A

FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION, ONLY)



BLDG R
MFR AIF
MODEL# 0657
150 PSI @ 275 °F

FLOOR EL 471
COMPONENT EL 478
SERIAL# 27235-1
ASME CLASS 2

EPR CST-V-3
QID# 361106
COORDS 7.6/11.6
DSCRIP BUTTERFLY VAL
MAT'L SAS16-6E70
LBS 150 SIZE 24


YOKE ORIENTATION

MOUNTING CONDITION


<u>1</u> TO AXIS OF PIPE ()
<u>//</u> TO AXIS OF PIPE () <u>N/A</u>
YOKE LENGTH _____
(FLANGE TO FLANGE)

NO OF BOLTS <u>20</u>
BOLT TYPE _____ BOLT Ø <u>1/2"</u>
WELD TYPE & SIZE <u>150° FLANGES</u>
PIPE MOUNTED YES (X) NO ()

PERMANENT OBSTRUCTION (WITHIN 2").....YES () NO (X)
IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES (X) NO ()
DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES (X) NO ()



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

OPERATOR EPR <u>CST-V-3</u>	MANUFACTURER <u>MILLER FLOW CONTROL</u>
MODEL NO <u>(3)</u>	SERIAL NO _____
TYPE _____ SIZE _____	ORDER NO _____


MOTOR EPR <u>1.11F</u>	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
ID NO _____ JNS CLASS _____	1-PHASE () 3-PHASE () AC _____ DC _____

TYPE OF CONDUIT CONNECTION: RIGID () FLEX ()


- NOTES: 1. Definition (N/F = Not Found)
 2. (2) N/A CO UNIT SWITCHES SERIAL# CA74080100
 3. THERE WERE NO AIR OPERATOR MFG MODEL/IDENTIFICATION TAGS FOUND

PREPARED BY Don Searle DATE 6/18/03 REVIEWED BY J.C. Fernandez DATE 6/20/02
(SIGNATURE) (SIGNATURE)
DON SEARLE L.C. FERNANDEZ

Project: WINP#2	Prepared By: L. J. [unclear]	Date: 12/82
Subject: EQUIP. QUALIFICATION	Checked By: E. K. [unclear]	Date: 1/4/83
System: CEP/CSP - CSP-V-3 Δ	Job No: 82044	File No:
Analysis No: QID#361106	Rev No:	Sheet No: 2 OF 3



PLAN CSP-V-3,4 (TOP VIEW)



CSP-V-3 - $\theta \sim 7^\circ$
 CSP-V-4 - $\theta \sim 6^\circ$

FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION ONLY)




Calculation Sheet

Project WPPSS Mechanical Equipment Qualification	Prepared By	Date 1/10/83
Subject 24" Butterfly Valves	Checked By: <i>Honshank</i>	Date 3/22/83
System CSP and CEP	Job No 82044	File No OT 01/F
Analysis No 361106	Rev. No.	Sheet No 3 of 3


SUPPLEMENTAL INFORMATION : (AIR OPERATOR PICTURES)

CSP-AO-3


△



CSP-AO-3 (CLOSE-UP)
SUPPORT BRACKET & DRIVE LEVER



CSP-AO-3 (MILLER OPERATOR)
VIEW LOOKING SOUTH-EAST



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

BLDG R FLOOR EL 471 EPN CSP-V-4
 MFR B/E COMPONENT EL 477 QID# 361106
 MODEL# 0657 SERIAL# 27235-2 COORDS 7.6/M.6
150 PSI @ 275 °F ASME CLASS 2 DSCRIP BUTTERFLY VALVE
 MAT'L SAS16-6E70 LBS 150 SIZE 24


YOKE ORIENTATION

1 TO AXIS OF PIPE ()
 // TO AXIS OF PIPE () N/A
 YOKE LENGTH _____
 (FLANGE TO FLANGE)


MOUNTING CONDITION

NO OF BOLTS 20
 BOLT TYPE _____ BOLT Ø 1 1/2"
 WELD TYPE & SIZE 150# FULL PEN
 PIPE MOUNTED YES (X) NO ()

PERMANENT OBSTRUCTION (WITHIN 2").....YES () NO (X)
 IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES (X) NO ()
 DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES (X) NO ()



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

OPERATOR EPN <u>CSP-A0-4</u>	MANUFACTURER <u>MILLER FLUID POWER</u>
MODEL NO <u>③</u>	SERIAL NO _____
TYPE _____ SIZE _____	ORDER NO _____

MOTOR EPN <u>N/A</u>	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
ID NO _____ INS CLASS _____	1-PHASE () 3-PHASE () AC _____ DC _____


TYPE OF CONDUIT CONNECTION: RIGID () FLEX ()

- NOTES: 1. Definition (N/F = Not Found)
 2. (2) N/A100 LIMIT SWITCHES SERIAL# EA74080100
 3. THERE WERE NO AIR OPERATOR MFG MODEL/IDENTIFICATION TAGS FOUND


PREPARED BY Don Scoble DATE 6/10/83 REVIEWED BY L.C. Fernandez DATE 6/20/83
 (SIGNATURE) (SIGNATURE)
DON SCOBLE L.C. FERNANDEZ



Project	WINP#2	Prepared By	Amir J. Al-Jarrah	Date	12/22/87
Subject	EQUIP. QUALIFICATION	Checked By	E. Al-Jarrah	Date	1/4/83
System	CEP/CSP - / CSP-V-4 Δ	Job No	82044	File No	
Analysis No	QID#361106	Rev No		Sheet No	2 of 2



PLAN CSP-V-3,4 (TYP VIEW)



SECTION A-A

CSP-V-3 - $0 \sim 7^\circ$
 CSP-V-4 - $0 \sim 6^\circ$

FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION ONLY)



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

PAGE 1 OF 2

EPN CSP-V-5

QID# 361106

COORDS M.7/B.3

DSCRPT BUTTERFLY VALVE

MAT'L SAS16 G270

LBS 150 SIZE 24"

BLDG R

FLOOR EL 471

MFR BTE

COMPONENT EL 475

MODEL# 0657

SERIAL# 27236-1

150 PSI @ 275 °F

ASME CLASS 2


YOKE ORIENTATION

<u>1</u> TO AXIS OF PIPE ()
// TO AXIS OF PIPE ()
YOKE LENGTH <u>N/A</u> (FLANGE TO FLANGE)


MOUNTING CONDITION

NO OF BOLTS <u>20</u>
BOLT TYPE _____ BOLT ϕ <u>1/4"</u>
WELD TYPE & SIZE <u>ISO# ANSI FLANGES</u>
PIPE MOUNTED YES (X) NO ()

PERMANENT OBSTRUCTION (WITHIN 2").....YES () NO (X)
 IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES (X) NO ()
 DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES (X) NO ()



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

OPERATOR EPN <u>CSP-A0-5</u>	MANUFACTURER <u>MILLER FLUID POWER</u>
MODEL NO <u>③</u>	SERIAL NO _____
TYPE _____ SIZE _____	ORDER NO _____


MOTOR EPN <u>N/A</u>	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
ID NO _____ INS CLASS _____	1-PHASE () 3-PHASE () AC _____ DC _____

TYPE OF CONDUIT CONNECTION: RIGID () FLEX (X)

- NOTES: 1. Definition (N/F = Not Found)
 2. (2) NAMCO LIMIT SWITCHES SERIAL # CA74080100
 3. THERE WERE NO AIR OPERATOR MFG MODEL IDENTIFICATION TAGS FOUND


⚠

PREPARED BY Downs DATE 6/18/05 REVIEWED BY L.C. Fernandez DATE 6/20/05
 (SIGNATURE) (SIGNATURE)
Downs L.C. FERNANDEZ



Calculation Sheet


Project	W. 112	Prepared By	John Jack	Date	12/22/82
Subject	EQUIP. QUALIFICATION	Checked By	J. E. K... ..	Date	1/4/83
System	CSP-V-5	Job No	82026	File No	
Analysis No	Q12-11106	Rev No.		Sheet No	2 OF 2



CSP-V-5

4702 11

24" CSP(1)-1 f



PLAIN VIEW

FIELD SKETCH (FOR THE PURPOSE OF SHOWING OPERATOR ORIENTATION)



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

BLDG R

FLOOR EL 471

EPN CSP-V-6

MFR BIF

COMPONENT EL 480

QID# 361106

MODEL# 0657

SERIAL# 27236-2

COORDS H.S/5.3

150 PSI @ 275 °F

ASME CLASS 2

DSCRIP Butter

MAT'L SAS16 GR70

LBS 150 SIZE 24


YOKE ORIENTATION

<u>L</u> TO AXIS OF PIPE ()
// TO AXIS OF PIPE () <u>N/A</u>
YOKE LENGTH (FLANGE TO FLANGE)


MOUNTING CONDITION

NO OF BOLTS <u>20</u>
BOLT TYPE _____ BOLT Ø <u>1/4"</u>
WELD TYPE & SIZE <u>FLANGED ENDS</u>
PIPE MOUNTED YES (X) NO ()

PERMANENT OBSTRUCTION (WITHIN 2").....YES () NO (X)
 IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES (X) NO ()
 DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES (X) NO ()



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

OPERATOR EPN <u>CSP-A0-6</u>	MANUFACTURER <u>MILLER FLUID POWER</u>
MODEL NO <u>(3)</u>	SERIAL NO _____
TYPE _____ SIZE _____	ORDER NO _____

MOTOR EPN <u>N/A</u>	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
ID NO _____ INS CLASS _____	1-PHASE () 3-PHASE () AC ___ DC ___

TYPE OF CONDUIT CONNECTION: RIGID () FLEX (X)

NOTES: 1. Definition (N/F = Not Found)


2. (2) NAMCO UNIT SWITCHES SERIAL # 74080100

3. THERE WERE NO AIR OPERATOR MFG MODEL/IDENTIFICATION TAGS FOUND.




PREPARED BY Don Searle DATE 6/18/83 REVIEWED BY L.C. Fernandez DATE 6/20/83
 (SIGNATURE) (SIGNATURE)
DON SEARLE L.C. FERNANDEZ


Project: <i>Unit 2</i>	Prepared By: <i>J. J. ...</i>	Date: <i>12/22/82</i>
Subject: <i>EQUIP QUALIFICATION</i>	Checked By: <i>J. J. ...</i>	Date: <i>1/4/83</i>
System: <i>CEP/CS / CSP-V-6</i>	Job No: <i>1988044</i>	File No:
Analysis No: <i>OID# 361106</i>	Rev No:	Sheet No: <i>2 OF 2</i>



PLAN VIEW CSP-V-6



SECTION A-A



FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION, ONLY)



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

PAGE 1 OF 1

EPN CSD-V-9

QID# 361106

BLDG R

FLOOR EL 471

COORDS M, 9/5.1

MFR BIF

COMPONENT EL 490

DSCR Butterfly

MODEL# 0657

SERIAL# N27236-3

MAT'L _____

150 PSI @ 275 °F

ASME CLASS 2

LBS _____ SIZE 24"


YOKE ORIENTATION

L TO AXIS OF PIPE ()
 // TO AXIS OF PIPE () N/A
 YOKE LENGTH _____
 (FLANGE TO FLANGE)


MOUNTING CONDITION

NO OF BOLTS 20
 BOLT TYPE _____ BOLT Ø _____
 WELD TYPE & SIZE Fluenco Ends
 PIPE MOUNTED YES (X) NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO (X)
 IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES (X) NO ()
 DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO (X)



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

OPERATOR EPN <u>CSD-A0-9</u>	MANUFACTURER <u>MILLER FLUID POWER</u>
MODEL NO <u>(3)</u>	SERIAL NO _____
TYPE _____ SIZE _____	ORDER NO _____


MOTOR EPN <u>N/A</u>	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
ID NO _____ JNS CLASS _____	1-PHASE () 3-PHASE () AC _____ DC _____

TYPE OF CONDUIT CONNECTION: RIGID () FLEX (X)


- NOTES: 1. Definition (N/F = Not Found)
 2. (2) NAMCO LIMIT SWITCHES SERIAL # 74080100
 3. THERE WERE NO AIR OPERATOR MFG. MODEL/IDENTIFICATION TAGS FOUND

PREPARED BY Don Searle DATE 6/16/83 REVIEWED BY L.C. Fernandez DATE 6/20/83
 (SIGNATURE) (SIGNATURE)
DON SEARLE L.C. FERNANDEZ

Project: JIP 2	Prepared By: J. Maxfield	Date: 12/22/02
Subject: EQUIP QUALIFICATION	Checked By: JEP	Date: 1/4/03
System: CCP/CS / CSP-V-6	Job No: 82044	File No:
Analysis No: WID# 361106	Rev. No.:	Sheet No: 2 OF 2




PLAN VIEW CSP-V-6



SECTION A-A


L
 W
 ← ON

FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION) ONLY




Calculation Sheet


Project	WNP #2	Prepared By:	Jim [unclear]	Date	12/22/82
Subject	EQUIP. QUALIFICATION	Checked By:	E. [unclear]	Date	1/4/83
System		Job No.	82044	File No.	
Analysis No.	01D361104	Rev. No.		Sheet No.	2 OF 2




CSP-V-1,2 (TOP VIEW)



CSP-V-2



PLAN VIEW (B-B)




SECTION VIEW A-A

$\theta \approx 7^\circ$ — CSP-V-1
 $\theta \approx 6^\circ$ — CSP-V-2

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. 05.01.F
SHEET NO. 5.2.4

FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION, ONLY)

EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM



EPN# CEP-V-1A
QID# 361104
COORDS J4/5.4
DSCRIP 30" Butterfly
MAT'L SA-516-6R7D
LBS N/A SIZE 30
ASME CLASS 2

BLDG R FLOOR EL 548
MFR BIF COMPONENT EL 558
MOD# A-206763 SERIAL# 27234-3
45 PSI @ 340 °F


YOKE ORIENTATION

L TO AXIS OF PIPE () N/A
// TO AXIS OF PIPE () N/A
YOKE LENGTH N/A
(FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS N/A
BOLT TYPE N/A BOLT Ø N/A
WELD TYPE & SIZE N/A
PIPE MOUNTED YES () NO () bolted flanges

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()
IS COMP BETWEEN CONT & 1ST ANC. (FULL 6 WAY ANC) YES () NO ()
DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO ()



CYGNA
ATTACHMENT
JOB NO. 82048
FILE NO. 05.01.F
SHEET NO. 5.2.5

GLOBAL CO-ORDINATE SYSTEM

VALVE STEM ORIENTATION

OPERATOR EPN N/A MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
TYPE _____ SIZE _____ ORDER NO _____

MOTOR EPN N/A MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
ID NO _____ INS CLASS _____ I-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: 2 Limit Switches Found
Model: 1703100
EA74080100

EPN's: not known
Manufacturer: Nanco Controls

PREPARED BY Dave Tarr DATE 7/14/82 REVIEWED BY William Cunha DATE 7/14/82
(SIGNATURE) (SIGNATURE)
DARR TARR WILLIAM CUNHA



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

EPN# CEP-V-2A

OID# 361104

BLDG R

FLOOR EL 548

COORDS J.4 / 5.4

MFR BIF

COMPONENT EL 558

DSCRIP 30" Butterfly

MOD# 0657

SERIAL# 27234-4

MAT'L SA-516-GR 70

45 PSI @ 340 °F

LBS N/A SIZE 30

ASME CLASS 2

YOKE ORIENTATION



⊥ TO AXIS OF PIPE ()
// TO AXIS OF PIPE () N/A
 YOKE LENGTH N/A
 (FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS N/A
 BOLT TYPE N/A BOLT Ø N/A
 WELD TYPE & SIZE N/A
 PIPE MOUNTED YES () NO () bolted flanges

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()
 IS COMP BETWEEN CONT & 1ST ANC. (FULL 6 WAY ANC) YES () NO ()
 DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO ()

CYGNA
ATTACHMENT
 JOB NO. 82044
 FILE NO. 05.01.F
 SHEET NO. 5.2.6



GLOBAL CO-ORDINATE SYSTEM

VALVE STEM ORIENTATION

OPERATOR EPN N/A MANUFACTURER _____
 MODEL NO N/A SERIAL NO _____
 TYPE _____ SIZE _____ ORDER NO _____

MOTOR EPN N/A MANUFACTURER _____
 MODEL NO _____ SERIAL NO _____
 ID NO _____ INS CLASS _____ 1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: 2 Limit Switches found

Manufactures: Nanco Controls

Model #: 1703100

EPN: CEP-LMS-2A

: EA 74080100

PREPARED BY Dave Doxel
(SIGNATURE)

DATE 7/14/82 REVIEWED BY William Carter
(SIGNATURE) DATE 7/14/82

5.3 Valve Local Coordinate Systems

CSP-V-1

CSP-V-2

AIR OPERATOR


CSP-V-1,2

REFERENCE

CSP-V-1,2 FIELD WARDEN SHEETS


PREPARED BY *A. Stone* 2/11/83

REVIEWED BY: *J. E. ...* 2/11/83




CYGNA	
ATTACHMENT	
JOB NO.	82044
FILE NO.	05.01.F
SHEET NO.	5.3.1


$$\begin{aligned} \theta_{N1} &= 135^\circ & \cos \theta_{N1} &= -0.707 \\ \theta_{N2} &= 90^\circ & \cos \theta_{N2} &= 0 \\ \theta_{N3} &= 45^\circ & \cos \theta_{N3} &= 0.707 \end{aligned}$$



$$\begin{aligned} \theta_{E1} &= 45^\circ & \cos \theta_{E1} &= 0.707 \\ \theta_{E2} &= 90^\circ & \cos \theta_{E2} &= 0 \\ \theta_{E3} &= 135^\circ & \cos \theta_{E3} &= -0.707 \end{aligned}$$



$$\begin{aligned} \theta_{V1} &= 90^\circ & \cos \theta_{V1} &= 0 \\ \theta_{V2} &= 180^\circ & \cos \theta_{V2} &= -1 \\ \theta_{V3} &= 90^\circ & \cos \theta_{V3} &= 0 \end{aligned}$$



5.5 REVISED BURNS & ROE
PIPING ANALYSIS ACCELERATIONS

Handwritten mark

MAY 11 1983

RECEIVED

MAY 31 1983

CYGNA-RICHLAND

Subject: W. O. 3900/4000
Washington Public Power Supply System
WNP-2
Qualification of Mechanical Pipe
Mounted Equipment; Forwarding of
Information

April 29, 1983
DRWP-83-078

Mr. L. T. Harrold
Assistant Director
Washington Public Power Supply System
3000 George Washington Way
Richland, Washington 99352

Attention: Mr. E. A. Holmberg

- References:
- (a) WPBR-83-17, dated 3/16/83.
 - (b) WPBR-83-28, dated 4/12/83.
 - (c) WPBR-83-29, dated 4/12/83.
 - (d) Telecopy, E. A. Holmberg to
J. J. Verderber, dated 4/4/83.

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>05.01.F</u>
SHEET NO. <u>5.5.1</u>

Gentlemen:

In response to the request of references (a), (b), (c) and (d), this letter is forwarding refined valve accelerations. The valve acceleration sheets for the five (5) CSP valves represent the second iteration of the refinement task. Valve sheets for the other four (4) valves represent the first iteration of the refinement task. Please inform the Woodbury Office if efforts should be made to reduce accelerations further.

Very truly yours,

ORIGINAL SIGNED BY J. J. VERDERBER

John J. Verderber
Project Engineering Manager

JJV/BPM/es
Att.

- CC: Mr. W. S. Chin - EPA - 1 w/1
 Mr. J. R. Rhodes - WPPSS - 1 w/1
 Mr. F. Buck - WPPSS - 1 w/1 Mail Drop 575

ATTACHMENT

Data forwarded with BRWP-83-078, dated April 29, 1983

<u>Valve #</u>	<u>Anchor Group</u>	<u>Calc. No.</u>
CSP-V-1	125	8.14.129
CSP-V-2	125	8.14.129
CSP-V-3	125	8.14.129
CSP-V-4	125	8.14.129
CSP-V-5	125	8.14.129
RCIC-V-31	107	8.14.112A
RHR-V-17B	31	8.14.121
RHR-V-53A	29	8.14.62C
RHR-V-53B	31	8.14.121B

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OS.01.F</u>
SHEET NO. <u>552</u>

WUTING AND HULL, INC.

W.O. No. 3900-10 Date 4/12/83 Book No. 8.14.129 Page No. 8 of
Drawing No. M200-31 Calc. No. 8.14.129

By L.S. Checked Approved
Title WNP-2 Status As-Built Verification of Pipeline Calculated

ORIGINAL ATTACHMENT
JOB NO. 87044
FILE NO. 05.01.F
SHEET NO. 5.5.3

CSP-V-1 Valve Qualification

B&R File No. Dwg. 68-00-0008

Operation I.D. No. _____

B&R M200 Iso. No. 172

Anchor Group 125

VALVE ACCELERATIONS

Location	Nodal Pt. No.	Mass Wt. (lb.)	Condition	Accelerations (g)			Comments
				X	Y	Z	
Valve Operator (Bracket)	25	321	Upset	0.65	1.27	0.65	
			Emergency	0.88	1.58	1.87	
			Faulted	1.31	2.69	2.13	
Valve Operator (Cylinder)	33	593	Upset	0.76	1.41	0.88	
			Emergency	1.07	2.95	1.40	
			Faulted	1.46	3.67	1.74	

B&R File No. 68-00-0008

Operation I.D. No. CEP-V-1A

B&R M200 Iso No. 171 REV 2A

Anchor Group 123

Calc. No. 8.14.125

Valve Acceleration

CEP-V-1A

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>05.01.F</u>
SHEET NO. <u>5.5.5</u>

Location	Node Pt. No.	Mass Wt. M (lb.)	Conditions	Loads (lb.)			Acceleration (g)		Comments
				FX	FY	FZ	Horizontal $\frac{\sqrt{FX^2+FZ^2}}{M}$	Vertical $\frac{FY}{M}$	
Valve Body	53	1870	Upset	1970	3018	2040	1.51	1.61	
			Emergency	1975	3027	2044	1.52	1.62	
			Faulted	2382 1.21	3322 1.77	2313 1.23	1.77	1.77	slss = 2.50
Valve Operator	555	1352	Upset	2148	2752	2219	2.28	2.04	
			Emergency	2157	2759	2229	2.3	2.04	
			Faulted	2413 2.23	3009 2.23	2490 1.85	2.67	2.23	slss = 3.

W.O. No. 3900-10 Date 11/15/58 Book No. 8.14.125 Page No. 2

Drawing No. 11200-SII.171/REV 2A Calc. No. 8.14.125 Approved

By R.A. Checked by R.R. Sheet 1 Cont. on Sheet 2

Title SILENT TOWER VIBRATION ANALYSIS 11200-SII.171/REV. 2A

BULKHEAD NO. 104, 105.

W.O. No. 3900-10 Date 4/17/83 Book No. 8, 14, 129 Page No. of
Drawing No. M200 Sh. 172 Rev. 2, 4 Calc. No. 8, 14, 129 Sheet

By P. S. F. (S. F.) Checked Approved
Title WNP-2 Status ds-Built Verification of Piping Calculations

ATTACHMENT
JOB NO. 82044
FILE NO. 05, 01, F
SHEET NO. 5, 54

CSP-V-2 Valve Qualification

B&R File No. Draw. 68-00-0008 Operation I.D. No. _____
B&R M200 Iso No. 172 Anchor Group 125

VALVE ACCELERATIONS

Location	Nodal Pt. No.	Mass Wt. (lb.)	Condition	Accelerations (g)			Comments
				X	Y	Z	
Valve Operator (Bracket)	8	321	Upset	0.61	1.27	0.64	
			Emergency	0.81	1.51	1.56	
			Faulted	1.26	2.65	1.86	
Valve Operator (Cylinder)	17	593	Upset	0.66	1.33	0.79	
			Emergency	1.06	2.82	1.61	
			Faulted	1.44	3.57	1.90	

B&R File No. 68-00-0008

Operation I.D. No. CEP-V-2A

B&R M200 Iso No. 171 REV 2A

Anchor Group 123

Calc. No. 8.14.125

CYGNA
ATTACHMENT
JOB NO. 62044
FILE NO. 05.01.F
SHEET NO. 5.5.6

Valve Acceleration

CEP-V-2A

Location	Nodal Pt.No.	Mass Wt., M (lb.)	Conditions	Loads (lb.)			Acceleration (g)		Comments
				FX	FY	FZ	Horizontal $\frac{\sqrt{FX^2+FZ^2}}{M}$	Vertical $\frac{FY}{M}$	
Valve Body	661	1870	Upset	1240	3012	1588	1.08	1.61	
			Emergency	1277	3020	1623	1.1	1.61	
			Faulted	1464 0.79	3315 1.77	1918 1.02	1.29	1.77	SRSS = 2.14
Valve Operator	664	1352	Upset	1112	2600	1282	1.26	1.92	
			Emergency	1176	2608	1361	1.33	1.93	
			Faulted	1300	2856	1562	1.50	2.11	SRSS = 2.51

WO No. 3900-10 Date 11/15/1982 Book No. 8.14.125 Page No. 1
 Drawing No. 11200-SIT-77.12A Calc. No. 8.14.125 Approved RR Sheet 1 Cont. on Sheet 2
 The STRESS ANALYSIS DESIGN: H200-SIT-77/REV: 2A




Calculation Sheet

Project	WPPSS-EO	Prepared By:	J. E. Robinson	Date	3/24/83
Subject	BIF-VALVE ACTUATOR MODEL SUMMARY	Checked By:	M. E. Bank	Date	3/24/83
System	CSP	Job No.	82044	File No.	OT.01/E
Analysis No.	361104-361106	Rev. No.	0	Sheet No.	361106-4.3-E9

$$\text{AVERAGE FLEXIBILITY} = 1.27(10)^{-3} \text{ in/lb}$$

CALCULATE EFFECTIVE MOMENT OF INERTIA OF A CANTILEVER BEAM USED TO REPRESENT THE BRACKET. USE THE FOLLOWING DIMENSIONS



$$\Delta = \Delta_1 + 38\theta_1 = 150 \text{ lb} \times .00127 \text{ in/lb} = 0.190 \text{ (ass. } 150 \text{ lb } \theta_2 = F)$$

$$\Delta_1 = \frac{FL^3}{2EI} + \frac{(38F)L^2}{2EI} = \frac{FL^2}{EI} \left(\frac{L}{3} + 19 \right) = \frac{FL^2}{EI} \left(\frac{28.5}{3} + 19 \right)$$

$$\frac{FL^2}{EI} = \frac{150 + (28.5)}{2.9(10)^7 I_{zz}} = \frac{4.2(10)^4 (10)^{-7}}{I_{zz}} = \frac{.0042}{I_{zz}}$$

$$\Delta_1 = \frac{.0042}{I_{zz}} \times \left(\frac{28.5}{3} + 19 \right) = \frac{.120}{I_{zz}} \text{ in}$$

$$\Delta = \frac{.120}{I_{zz}} + 38\theta_1$$



Calculation Sheet

Project	WPPSS-EQ	Prepared By:	J E Rabinovich	Date	3/24/83
Subject	BIF VALVE/ACTUATOR MODEL SUMMARY	Checked By:	Lie Jordan	Date	3.24.83
System	CSP	Job No.	82044	File No.	0T.01/F
Analysis No.	361104 & 361106	Rev. No.	0	Sheet No.	361106-4.3-B10

$$\theta_1 = \theta_1 \text{ due to } F + \theta_1 \text{ due to } M = 38F$$

$$= \frac{Fl^2}{2EI} + \frac{(38F)l}{EI} = \frac{Fl}{EI} \left(\frac{l}{2} + 38 \right)$$

$$\theta_1 = \frac{150(28.5)}{2.9(10)^7 I_{zz}} \left(\frac{28.5}{2} + 38 \right) = \frac{7.7(10)^4 \times 10^{-7}}{I_{zz}} = \frac{7.7(10)^{-3}}{I_{zz}}$$

$$38\theta_1 = \frac{.293}{I_{zz}}$$

$$\therefore \Delta = \frac{.122}{I_{zz}} + \frac{.293}{I_{zz}} = .19$$

$$\frac{.415}{I_{zz}} = .19$$

$$I_{zz} = 2.16 \text{ IN}^4 \quad 8" \text{ A/O}$$

FOR THE 10" CYLINDER, RATIO UP INERTIA, I.E.

$$I_{zz}|_{10} = I_{zz}|_8 + \left(\frac{5/8}\right)^3 = I_{zz}|_8 + 1.95$$

$$I_{zz}|_{10} = 4.22 \text{ IN}^4$$

BRACKET TORSIONAL RESISTANCE : SET TO A HIGH VALUE SINCE BENDING + TORSION BOTH REPRESENTED IN ABOVE FLEXIBILITY. (1000 IN⁴)



Calculation Sheet

Project	WPPSS-EO	Prepared By:	J. E. Robinson	Date	3/24/83
Subject	BIF VALVE/ACTUATOR MODEL SIMULATION	Checked By:	J. E. Robinson	Date	3/24/83
System	CSP	Job No.	82044	File No.	OT.01/F
Analysis No.	361104:361106	Rev. No.	0	Sheet No.	361106-4.3-B15

FOR THE BRACKET ELEMENT:

(MAKE $e = 0$ & PUT 277# 15" DOWN)

<(321#)>

$$\text{LENGTH} = 28.5 (15 + 13.5)$$

$$\langle \sqrt{28.5} \rangle$$

$$\text{WEIGHT} = 277 \text{ LB}$$

$$\langle 321 \# \rangle$$

$$A_x = A_y = A_z = 6.84 \text{ IN}^2$$

$$\langle 10.6 \text{ IN}^2 \rangle$$

$$C_z = 6.84 \text{ IN}$$

$$\langle 8.5 \text{ IN} \rangle$$

$$C_x = .25 \text{ IN}$$

$$\langle .313 \text{ IN} \rangle$$

$$I_{xx} = 102 \text{ IN}^4 \text{ (BELOW)}$$

$$\langle 255 \text{ IN}^4 \rangle$$

$$I_{yy} = 1000 \text{ IN}^4 \text{ (PAGE 7/13)}$$

$$\langle 1000 \text{ IN}^4 \rangle$$

$$I_{zz} = 2.16 \text{ IN}^4 \text{ (PAGE 7/13)}$$

$$\langle 4.22 \text{ IN}^4 \rangle$$

IN PLANE BENDING INERTIA OF BRACKET PLATE:

$$I_{xx} = \frac{1}{12} b d^3 = \frac{1}{12} (0.5)(13.5)^3 = 102 \text{ IN}^4$$

$\langle 255 \rangle$




Calculation Sheet

Project	WPPSS EQ	Prepared By:	J E K... ..	Date	1/3/83
Subject	BIF VALVE/ACTUATOR MODEL	Checked By:	A E Shank	Date	3/24/83
System	CSP	Job No.	82044	File No.	DT.011E
Analysis No.	361104 & 106	Rev. No.	0	Sheet No.	361106-4.3-B16


DRIVE ROD & CYLINDER:

IMPORTANT DISTANCES ARE:

MODEL:



← Release restrained
restrained on xx axis



①: DRIVE ROD:

$$L = 26.5 \text{ inches}$$

$$A = \pi/4 D^2 = 2.41 \text{ IN}^2$$

$$C = .875 \text{ inches}$$

$$I = .46 \text{ IN}^4 = I_{xx} = I_{zz}$$

$$I_{yy} = \sqrt{2} * I_{xx} = .92 \text{ IN}^4 \quad \langle 0.92 \text{ for } 10 \rangle$$

② ^{<10>} 8" CYL: (say P=0 AND PUT ^{<593#>} 399# AT CG)

③

$$L_2 = 13.5$$

$$L_3 = 14.0 \langle 19 \rangle$$

$$I_{yy} = 74 \text{ IN}^4 \langle 180 \rangle$$

$$I_{xx} = I_{zz} = 52.2 \text{ IN}^4 \quad (\text{larger } \langle 125 \rangle^4)$$


$$A = \pi/4 8^2 = 50.3 \text{ IN}^2 \langle 78 \rangle = 127$$

$$C = 4 \langle 5 \rangle$$




Calculation Sheet

Project	WPP33-EO	Prepared By:	A E [unclear]	Date	1/3/83
Subject	RIF VALVE/ACTUATOR MODEL SUMMARY	Checked By:	[unclear]	Date	3/22/83
System	CCP	Job No.	82044	File No.	OT.01/F
Analysis No.	361104 # 106	Rev. No.	0	Sheet No.	361106-4.3-811



zz BENDING, FLOW calc'd.
 xx - STIFF
 I_{yy} - TORSIONAL STIFFNESS

PICK I_z & A_z for I_{yy} STIFFNESSES, THEN DO OTHERS.






Calculation Sheet

Project	WPPSS - EQ	Prepared By:	A. E. Edwards	Date	1/3/83
Subject	KTF VALVE/ACTUATOR MODEL SUMMARY	Checked By:	A. E. Edwards	Date	3/22/83
System	CSP	Job No.	22044	File No.	OT.01/
Analysis No.	361104 & 106	Rev. No.	0	Sheet No.	3.61106-4.3-1312

① FARS:

< > = VALUES FOR 10" OPERATORS



$$A_x = 1.5 \times 2.5 \times 4 = 15 \text{ IN}^2$$

INERTIAS:

$$I_{xx} = J$$

Define I_{xx} for proper $\phi = \frac{Tl}{G I_x}$

$$I_{xx} = \frac{Tl}{\phi G}$$

from p. 12.5:9
 $\langle 1.565(10)^8 \rangle$

$$K_{\theta, \theta} = 1.72(10)^8 \quad \omega_{\theta} = \frac{T}{\phi}$$

$$\therefore I_{xx} = \frac{l}{G} K_{\theta, \theta} = \frac{\langle 4.85 \rangle}{7.125} \times \frac{1.72(10)^8}{.4(10)^6 \times 29} \times \langle 1.565(10)^8 \rangle$$

UNITS: $\frac{F \times L^3}{L^2} = L^4 \text{ OK}$

$$I_{xx} = 1.06 \times 10^2 \text{ in}^4 = 106 \text{ IN}^4$$

$$\langle 106 \times \frac{15.65}{1.72} \times \frac{4.85}{7.125} = 657 \text{ IN}^4 \rangle$$



Calculation Sheet

Project	WPPSS EQ	Prepared By:	V E K... 1/3/93	Date	1/3/93
Subject	BIF VALVE / ACTUATOR MODEL SUMMARY	Checked By:	A E... 3/24/83	Date	3/24/83
System	CSP	Job No.	82044	File No.	OT.01/E
Analysis No.	361104 & 106	Rev. No.	0	Sheet No.	361106-4-3-B13

3 added 6/3/03 JCFerminey 4/9/93

$$I_z = 4 * I_{MAX} \left(\frac{3.94}{1.95} \right)$$

$$I_z = 7.80 \text{ in}^4 \left(15.76 \text{ in}^4 \right)$$

$$I_y = 4 \cdot I_{min} \left(\frac{1.34}{0.70} \right) = 2.80 \text{ in}^4 \left(5.36 \text{ in}^4 \right)$$

$$C_z = \frac{3.75 \text{ in}}{4.75}, \quad C_y = \frac{5.00 \text{ in}}{5.25}$$

$$E = 29 \times 10^6 \text{ PSI}, \quad G = E_s = 11.6 \times 10^6 \text{ PSI}$$

BECAUSE OF BENDING OF EARS IN MODE BELOW, ADJUST I_y & I_z TO ACCOUNT. (THIS WAS DONE IN ANALYSIS FOR K_{ex} & K_{ey}):

NOTE: SEE PAGE 4-3-53 REV 1

$$Y_{max} = \frac{-w}{12EI} l^3 \quad \text{FOR EARS: } \left[\text{Diagram of a cantilever beam with a downward load } w \text{ and a deflection } \downarrow \right]$$

$$Y_{max} = \frac{-w}{6EI} (2l)^3 \quad \text{for } \left[\text{Diagram of a cantilever beam with a downward load } w \text{ and a deflection } \downarrow \right]$$

$$\therefore Y_{max-ear} = \frac{1}{4} Y_{max} \text{ (mode below)}$$

Since $Y_{max} \propto \frac{1}{I}$, multiply I mode below by 4.


$I_z = 7.8 * 4 = 31.2 \text{ in}^4$	$\left(\frac{15.76}{63} \right)$
$I_y = 2.8 * 4 = 11.2 \text{ in}^4$	$\left(\frac{5.36}{21.4} \right)$



Calculation Sheet

Project	WPPSS EQ	Prepared By:	J. E. Johnson	Date	1/3/85
Subject	BIF VALVE / ACTUATOR MODEL SUMMARY	Checked By:	J. E. Johnson	Date	3/22/85
System	10P	Job No.	02044	File No.	0T.01/F
Analysis No.	361104 & 106	Rev. No.	0	Sheet No.	361106-4.3-B14


BRACKET OFFSETS



Ⓐ & Ⓑ ARE MASSLESS, RIGID LINKS

SHAFT

$$\begin{aligned}
 \text{DIA} &= 2.25'' \quad \left(\text{from McPherson, 24" valve} \right) \\
 C &= 1.125'' \\
 I &= 1.26 \text{ IN}^4 = I_{yy} \\
 I_{xx} &= \sqrt{2} I_{yy} = 2.52 \text{ IN}^4 \\
 A &= \frac{\pi D^2}{4} = 3.98 \text{ IN}^2
 \end{aligned}$$



$$\begin{aligned}
 L &= 7.125 + 6.875 = 14'' \\
 &= 4.85 + 8 = 12.85''
 \end{aligned}$$

SHAFT TO BE SOFT FOR Y-DEFLECTION & STIFF FOR Z-DEFLECTION (L NOT IMPORTANT) (NO STRESS)

THEREFORE; SINCE SHAFT IS MODELED HERE OF GREATER THAN ACTUAL LENGTH, USE:

$$\begin{aligned}
 I_{xx} &= 1.78 \text{ IN}^4 \\
 I_{yy} &= 3 \times I_{zz} = 4 \text{ IN}^4 \\
 I_{zz} &= 1.26 \text{ IN}^4
 \end{aligned}$$

APPENDIX C

SAMPLE HAND CALCULATIONS
TO CHECK PROGRAM
CEP-V-3A

1. 1950-1951
2. 1952-1953
3. 1954-1955

nbif CEP-V-3A
 INPUT GLOBAL ACCELERATIONS
 ? 13.89, 1.66, 1.04
 INPUT ANGLES OF NORTH VECTOR
 ? 90, 90, 0
 INPUT ANGLES OF VERTICAL VECTOR
 ? 90, 0, 90
 INPUT ANGLES OF EAST VECTOR
 ? 0, 90, 90

Calculation Sheet

Prepared By	E. Rudowski	Date	3/25/83
Checked By	A. Exler	Date	3/30/83
Job No.	82044	File No.	OT.01/F

INPUT DATA
 GLOBAL G-LEVELS = 13.89
 NORTH VECTOR ANGLES = 90
 VERTICAL VECTOR ANGLES = 90
 EAST VECTOR ANGLES = 0 90

1.66	1.04	<u>361106-C-1</u>
90	0	
0	90	
90		

INPUT ANGLES OF WEIGHT VECTOR
 ? 90, 180, 90

SAMPLE CHECK CALC'S.

LOCAL G-LEVELS
 -5.29861E-5 -6.33239E-6 1.04
 -5.29861E-5 1.66 -3.96728E-6
 13.89 -6.33239E-6 -3.96728E-6

EAR TENSILE STRESS

$$T_{3F} = (F_{ST} - W_{A0}) * 8.5 - 277 * 5.25$$

$$= (1150 - 399) * 8.5 - 277 * 5.25$$

$$T_{3F} = 4939, F_c = \frac{4939}{25} = 198 \#$$

OPERATING DRIVE ROD STRESS AT A 477.198
 OPERATING DRIVE ROD STRESS AT B 821.458
 OPERATING CYLINDER BRG PRESSURE -3.75613E-4
 OPERATING VALVE EAR TENSILE STR 1136.52
 OPERATING VALVE EAR SHEAR STRESS 89.1706
 OPERATING EAR BOLT SHEAR STRESS 1078.68
 OPERATING EAR BOLT TENSILE STR 525.595

$$F_{11} = -.48 * T_{3F} = -95$$

$$F_{22} = +1.03 * T_{3F} = 203$$

$$S_{EARS} = \left| \frac{-95 * 7.125 * .75}{.70} \right| + \left| \frac{203 * 7.125 * 1.25}{1.95} \right|$$

$$= 826 \text{ PSI}$$

glc(1,j) = j = -5.29861E-5 ✓ 1
 fcdR = -1.22282E-2
 sigma = -.267492
 sigb = -.409114
 Fc due to T3 = -5.71181E-2
 f11 = 2.73638E-2
 f22 = -5.85968E-2
 dsa = .071552
 dsr = 3.3257E+7
 dbten = 4.86604E+9

M₁ due to dwd bending = (W_{A0} + W_{BR} - F_{ST2}) * e_S

$$\Gamma_{M1} = \frac{M_1}{2d_2 + 2l_1 l_2} = \frac{3259}{2 * 10 * 1.5 * 2.5} = 44 \text{ PSI}$$

glc(1,j) = j = -6.33239E-6 2
 fcdR = -1.4614E-3
 sigma = -3.19681E-2
 sigb = -4.88934E-2
 Fc due to T3 = 321.752
 f11 = 154.143
 f22 = 330.082 (NEXT PAGE)
 dsa = .072574
 dsr = 3.7607E+7
 dbten = 4.86759E+9

F_{due to dwd shear} = $\frac{(W_{ACT} W_{BR} - F_{ST2}) * C_2 * l_{dw}}{4 * l_1 * l_2}$

F_{due to shear} = $\frac{474}{4} * \frac{1.125}{1.95} + \frac{7.125}{2} = 271 \text{ PSI}$

glc(1,j) = j = 1.04 3
 fcdR = 240.013
 sigma = 5250.28
 sigb = 8029.99
 Fc due to T3 = 919.516
 f11 = -440.516
 f22 = 943.322
 dsa = 2.75454E+7

TOTAL DWD EAR TENSILE STRESS =
 826 + 44 + 271 = 1141 VS ~ 1137 (OK)

CHECK Fc'

$$F_{TR1} = \frac{(25 + 14.46) * 399 * 1.04}{25} = 655 \#$$

$$T_3 = \frac{(655 * 28.5 + 277 * 1.04 * 15)}{25} = 919.25 \text{ (OK)}$$



Calculation Sheet

Project	WPPSS-EQUIPMENT QUALIFICATION	Prepared By:	J. E. R. [Signature]	Date	3/25/83
Subject	24" BIF BUTTERFLY VALVES	Checked By:	A. E. [Signature]	Date	3/30/83
System	CEP + CSP	Job No.	82044	File No.	OT.01/F
Analysis No.	361106	Rev. No.	0	Sheet No.	361106-C-2

CHECK EAR TENSILE STRESS CALCS:

$$\frac{f_{11}}{f_c} = \frac{-154}{322} = -0.48 \checkmark \quad \frac{+330}{322} = +1.03 \checkmark \quad \text{(OK)}$$

↓ SIGNS (OK) ↓

$$T_3 = 2D F_c = 2 \times 12.5 \times 322 = 8050 \text{ \#}$$

CHECK:

$$T_3 = F_{TL1} \times 28.5 + \bar{w}_{BR} \times q_1 \times 15 + \bar{w}_{A0} \times q_2 \times 8.5 + \bar{w}_{BR} \times q_2 \times 5.25$$

$$= 20 \text{ (i.e. } q_{1,2} = 0) + 399 \times 1.66 \times 8.5 + 277 \times 1.66 \times 5.25$$

$$T_3 = 8044 \text{ \#} \text{ vs } 8050 \text{ \#} \quad \text{(OK)}$$

CONCLUSIONS OF CHECK CASE CEP -V-3A:

1. FIXED STRESSES ON EARS CHECK
2. NEW VALVE EAR BENDING STRESS COMPONENTS CHECK
3. BEARING PRESSURE CHECKS (NOT SHOWN)
4. DRIVE ROD STRESS CHECKS (NOT SHOWN)
5. BOLT TENSION CHECKS (NOT SHOWN)

SECTION 5.0

QID# 361106


APPENDICES


CONTENTS

- 5.1 Response Spectra
- 5.2 Walkdown Sheets
- 5.3 Valve Local Coordinate Systems
- ~~5.4~~ ~~SRM Sheets~~ REM (ADMINISTRATIVE)
- 5.5 Final Pipe Mounted Equipment
Response G-Levels

Revision 3


5.1 Response Spectra





WPPSS REACTOR BLDG. SRSS OF SRV SSE AP/CHUG.
 MASS. NO. 182 EL. 500 FT. HORIZ. TRANSLATION
 CONTAINMENT VESSEL DAMPING= .005, .01, .02, .04

CYGN
ATTACHMENT
JOB NO. 82044
FILE NO. OT.01/E
SHEET NO. 5.1-1



WPPSS REACTOR BLDG. SRSS OF SRV SSE AP/CHUG.
 MASS NO. 182 EL. 500 FT. VERT. TRANSLATION
 CONTAINMENT VESSEL

DAMPING = .005, .01, .02, .04

CYEMA
ATTACHMENT
JOB NO. 8204H
FILE NO. 0101/E
SHEET NO. S.1-2


5.2 Walkdown Sheets

PA S H
A B L

PA S H
A B L

EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

JOB NO. 101-12



EPR# 101-V-3

OID# 11116

COORDS M. 1. 17. 6

DSCRPT 24" BFLY Cont Isol Valve

MAT'L SA-516-GR-70

LBS N/F SIZE 24"

ASME CLASS N/F

LOG R

FLOOR EL 501

M.R. BTF 0657

COMPONENT EL 481

MOD# DWG A26764

SERIAL# W27235-1

150 PSI @ 275 °F

YOKE ORIENTATION

TO AXIS OF PIPE (✓)

// TO AXIS OF PIPE (✓)

YOKE LENGTH 0'-4 1/2"
(FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS N/A

BOLT TYPE N/A BOLT Q. N/A



WELD TYPE & SIZE N/A

PIPE MOUNTED YES () NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()

IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES () NO () N/F

DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO () N/F



GLOBAL CO-ORDINATE SYSTEM

VALVE STEM ORIENTATION

OPERATOR EPR# COVERED W/ PLASTIC MANUFACTURER _____

MODEL NO _____ SERIAL NO _____

PIPE _____ SIZE _____ ORDER NO _____

OPERATOR EPR# N/A NOT MOTOR OPERATED MANUFACTURER _____

MODEL NO _____ SERIAL NO _____

NO _____ INS CLASS _____ 1-PHASE () 3-PHASE () AC _____ DC _____

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT-01/F</u>
SHEET NO. <u>5.2-1</u>

REMARKS: Definition (N/F = Not Found)

CSP-LMS-3
1. LENGTH OF PIPE HAS NOT BEEN INSTALLED FROM VALVE TO CONTAINMENT.

PREPARED BY William Cunha DATE 7/21/07 REVIEWED BY Doug True DATE 7/21/07
(SIGNATURE) (SIGNATURE)


William Cunha
15163

Doug True
()




Calculation Sheet

Project	WNPT#2	Prepared By	L. M. Jack	Date	2/22/83
Subject	EQUIP. QUALIFICATION	Checked By	L. E. K. [unclear]	Date	1/4/83
System	CEP/CSP	Job No.	82044	File No.	
Analysis No	QID#361106	Rev. No.		Sheet No.	



PLAN CSP-V-3,4 (TYP VIEW)

CYGNA
ATTACHMENT
 JOB NO. 82044
 FILE NO. OT.01/F
 SHEET NO. 5.2-2



SECTION A-A

CSP-V-3 - $\theta \sim 7^\circ$
 CSP-V-4 - $\theta \sim 6^\circ$

FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION ONLY)




Calculation Sheet


Project WPPSS Mechanical Equipment Qualification	Prepared By	Date 1/10/83
Subject 24" Butterfly Valves	Checked By <i>[Signature]</i>	Date 5/22/83
System CSP and CEP	Job No 82044	File No. OT 01/F
Analysis No. 361106	Rev. No.	Sheet No.

SUPPLEMENTAL INFORMATION: (AIR OPERATOR PRACTICE)

CSP-AO-3




CSP-AO-3 (CLOSE-UP)
SUPPORT STRUCTURE & LADDER



CEP-AO-3 (MILLER OPERATOR)
VIEW LOOKING SOUTH-EAST

CYGMA
ATTACHMENT
JOB NO. 82044
FILE NO. OT 01/F
SHEET NO. 5.2-3



EQUIPMENT QUALIFICATION
BREAKDOWN VERIFICATION FORM



EPN# CSP-V-4
QID# 361106
COORDS 7.6 / N. 6
DESCR 24" 8 FLY
CONT. ISOL VALVE
MAT'L SA-516-GR-70
LBS N/F SIZE 24"
ASME CLASS N/F

BLDG R FLOOR EL 47'
MFR B.I.F COMPONENT EL 47.8
MOD# DWG 157-7-4 6657 SERIAL# 272-35-2
150 PSI @ 5.75 °F


YOKE ORIENTATION

TO AXIS OF PIPE ()
 TO AXIS OF PIPE ()
YOKE LENGTH 6' - 4 1/2"
(FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS N/A
BOLT TYPE N/A BOLT Ø N/A
WELD TYPE & SIZE N/A
PIPE MOUNTED YES () NO ()


PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()
IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES () NO () N/F
DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO () N/F



GLOBAL CO-ORDINATE SYSTEM



SECT OF PIPE NOT INSTALLED
SEE COMMENT #1



VALVE STEM ORIENTATION

OPERATOR EPN# <u>CSP-V-4</u> <u>COVERED W/ PLASTIC</u>	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
TYPE _____ SIZE _____	ORDER NO _____
MOTOR EPN# <u>N/A</u> <u>NOT MOTOR OPERATED</u>	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
ID NO _____ INS CLASS _____	1-PHASE () 3-PHASE ()

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. OT.01/F
SHEET NO. 5.2-4

COMMENTS: Definition (N/F = Not Found)
1. LENGTH OF PIPE HAS NOT BEEN INSTALLED FROM
VALVE TO CONTAINMENT.

PREPARED BY William Carter DATE 7/21/82 REVIEWED BY Doug True DATE 7/21/82
(SIGNATURE) (SIGNATURE)

William Carter 7/21/82
W. Carter 7/21/82



Doug True



Calculation Sheet


Project	WNP#2	Prepared By	L. J. ...	Date	12/22/82
Subject	EQUIP. QUALIFICATION	Checked By:	E. K. ...	Date	1/4/83
System	CEP/CSP	Job No.	82044	File No.	
Analysis No.	QID#361106	Rev. No.		Sheet No.	

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. OT.01/F
SHEET NO. 5.2-5



CSP-V-3 - 0~7°
 CSP-V-4 - 0~6°

FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION ONLY)



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

PAGE 1 OF 2

EPN# CSF-Y-5

QID# 361106

BLDG R

FLOOR EL 471

COORDS M.7/P.3

MFR GIF

COMPONENT EL 475

DSCR 24" BFLY

MOD# DWG A20765

SERIAL# 27236-1

MAT'L _____

PSI @ _____ °F

LBS _____ SIZE _____

ASME CLASS _____


YOKE ORIENTATION

⊥ TO AXIS OF PIPE ()
// TO AXIS OF PIPE ()
 YOKE LENGTH _____
 (FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS _____
 BOLT TYPE _____ BOLT Ø _____
 WELD TYPE & SIZE _____
 PIPE MOUNTED YES () NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()
 IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES () NO ()
 DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO ()



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION



OPERATOR EPN _____	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
TYPE _____ SIZE _____	ORDER NO _____

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01/F</u>
SHEET NO. <u>5.2-6</u>

MOTOR EPN _____	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
ID NO _____ INS CLASS _____	1-PHASE () 3-PHASE () AC _____ DC _____

Δ VISUAL INSPECTION MADE 12/22/82 IT WAS NOTED VALVE INSTALLED SEE SHEET 20F2
 COMMENTS: Definition (N/F = Not Found)

Valve not installed as of 7/21/82

PREPARED BY William T. P. [Signature] DATE 7/21/82 REVIEWED BY Doug [Signature] DATE 7/21/82
 (SIGNATURE) (SIGNATURE)


Δ [Signature] 11/5/83

[Signature]




Calculation Sheet

Project	<i>1/1/82</i>	Prepared By:	<i>John Jank</i>	Date	<i>12/22/82</i>
Subject:	<i>EQUIP. QUALIFICATION</i>	Checked By:	<i>E. K...</i>	Date	<i>1/4/83</i>
System		Job No.	<i>82044</i>	File No.	
Analysis No	<i>01D-161106</i>	Rev No.		Sheet No.	<i>2 OF 2</i>




CSP-V-5



CYGNA
ATTACHMENT
JOB NO. <i>82044</i>
FILE NO. <i>OT.01/F</i>
SHEET NO. <i>5.2-7</i>

24° CSP(1)-1 E



PLAN VIEW

FIELD SKETCH (FOR THE PURPOSE OF SHOWING OPERATOR ORIENTATION)

CJL

EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

EPN: CS1-V-6
 QID: 361106
 COORDS N.5/7.7
 DSCRPT 24" BFLY
 MAT'L _____
 LBS _____ SIZE _____
 ASME CLASS _____

BLDG R FLOOR EL 471
 MFR BIF COMPONENT EL 480
 MOD# A-206765 SERIAL# _____
 _____ PSI @ _____ °F


YOKE ORIENTATION

| TO AXIS OF PIPE ()
// TO AXIS OF PIPE ()
 YOKE LENGTH _____
 (FLANG TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS _____
 BOLT TYPE _____ BOLT Ø _____
 WELD TYPE & SIZE _____
 PIPE MOUNTED YES () NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()
 IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES () NO ()
 DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO ()



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION



OPERATOR EPN _____	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
TYPE _____ SIZE _____	ORDER NO _____

CYGNA
ATTACHMENT
 JOB NO. 82044
 FILE NO. OT.01/F
 SHEET NO. 5-2-8

MOTOR EPN _____	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
ID NO _____	INS CLASS _____
1-PHASE () 3-PHASE () AC _____ DC _____	

COMMENTS: Definition (N/F = Not Found)

X CSP-LMS-6

1. Not installed as of 7/21/82

Δ VISUAL INSPECTION MADE 12/22/82 & IT WAS NOTED VALVE INSTALLED SEE SHEET 20FZ
 PREPARED BY William Conner DATE 12/22/82 REVIEWED BY Doug True DATE 7/21/82
 (SIGNATURE) (SIGNATURE)


WILLIAM CONNER 11/5/83

Doug True




Calculation Sheet

Project	WIND#2	Prepared By:	A. MAX. [unclear]	Date	12/22/82
Subject	EQUIP. QUALIFICATION	Checked By:	E. P. [unclear]	Date	1/4/83
System	CEP/CES	Job No.	82044	File No.	
Analysis No	QID# 361106	Rev. No.		Sheet No.	2 OF 2



CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01/F</u>
SHEET NO. <u>5.2-9</u>

PLAN VIEW CEP-V-6



SECTION A-A



FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION ONLY)



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

EPN# CSP-V-9

QID# 361106

BLDG R

FLOOR EL 471

COORDS M9/S.1

MFR BIF

COMPONENT EL 490

DSCRPT 24" BFLY

MOD# A20765

SERIAL# _____

MAT'L _____

PSI @ _____ °F

LBS _____ SIZE _____

ASME CLASS _____

YOKE ORIENTATION

⊥ TO AXIS OF PIPE ()

// TO AXIS OF PIPE ()

YOKE LENGTH _____
(FLANGE TO FLANGE)

MOUNTING CONDITION


NO OF BOLTS _____

BOLT TYPE _____ BOLT Ø _____

WELD TYPE & SIZE _____

PIPE MOUNTED YES () NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()
IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES () NO ()
DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO ()



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION



OPERATOR EPN _____	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
TYPE _____ SIZE _____	ORDER NO _____
MOTOR EPN _____	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
ID NO _____ INS CLASS _____	1-PHASE () 3-PHASE () AC _____ DC _____

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. OT.01/F
SHEET NO. 5.2-10

COMMENTS: Definition (N/F = Not Found)


Note: not installed as of 7/21/82

PREPARED BY William Smith DATE 7/21/82 REVIEWED BY Doug True DATE 7/21/82
(SIGNATURE) (SIGNATURE)

William Smith

Doug True

EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM



EPN: C100001
 OID: 301100
 COORDS H.5/5.4
 DSCRIP 24. BIFY SUPP Chamber Exhaust
 MAT'L SA-516-70 - N/F
 LBS N/F SIZE 24"
 ASME CLASS N/F

ELDG 1 FLOOR EL 471
 MFR BTF COMPONENT EL 495
 MOD# DRG-A-20674 SERIAL# N272353
15.0 PSI @ 275 °F



YOKE ORIENTATION

TO AXIS OF PIPE (✓)
 // TO AXIS OF PIPE (✓)
 YOKE LENGTH 0' - 4 1/2"
 (FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS N/A
 BOLT TYPE N/A BOLT Q. N/A
 WELD TYPE & SIZE N/A
 PIPE MOUNTED YES (✓) NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO (✓)
 IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES (✓) NO ()
 DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO (✓)



GLOBAL CO-ORDINATE SYSTEM

VALVE STEM ORIENTATION

OPERATOR EPN <u>N/A</u>	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
TYPE _____ SIZE _____	ORDER NO _____

CYGNA
ATTACHMENT
 JOB NO. 82044
 FILE NO. OT.01/F
 SHEET NO. 5.2-11

MOTOR EPN <u>N/A</u>	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
ID NO _____ INS CLASS _____	1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: Definition (N/F = Not Found)

* CERLMS-3A

Δ SEE SHEET 2092 FOR OPERATOR ORIENTATION

PREPARED BY William Carter DATE 7/21/82 REVIEWED BY Doug True DATE 7/21/82
 (SIGNATURE) (SIGNATURE)

William Carter
 Δ to search 1/5/83

Doug True
 ✓






Calculation Sheet

Project	WPPS MECH. E.Q.	Prepared By	J. E. Radkowski	Date	12/18/82
Subject	BIF VALVE & AO	Checked By	M. E. Jank	Date	12/20/82
System	CSP / CEP	Job No	82044	File No.	
Analysis No		Rev No		Sheet No	2/2




CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. OT.01/F
SHEET NO. 5-2-12

WALKDOWN
 VALVE & OPERATOR ORIENTATIONS
 CEP - V - 3A & 4A

CEP - V - 3A :



CEP - V - 4A :



EQUIPMENT QUALIFICATION
 WELDING VERIFICATION FORM

△

EIN: CEP-V-4A
 CID: 361106
 COORDS 1.5/5.4
 DSCRIP 24" BFLY
 MAT'L SA-516 GR-70
 LES N/F SIZE 24"
 ASME CLASS N/F

BLDG K FLOOR EL 471
 MFR BIF COMPONENT EL 495
 MOD: ~~DW 6 A 200204~~ 0657 SERIAL# N 27235-4
150 PSI @ 275 °F


YOKE ORIENTATION

⊥ TO AXIS OF PIPE (✓)
// TO AXIS OF PIPE (✓)
 YOKE LENGTH 0'-4 1/2"
 (FLANGE TO FLANGE)


MOUNTING CONDITION

NO OF BOLTS N/A
 BOLT TYPE N/A BOLT Ø N/A
 WELD TYPE & SIZE N/A
 PIPE MOUNTED YES (✓) NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO (✓)
 IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES (✓) NO ()
 DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO (✓)



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

OPERATOR EPN <u>N/A</u>	MANUFACTURER _____	CYGNA ATTACHMENT JOB NO. <u>82044</u> FILE NO. <u>OT.01/F</u> SHEET NO. <u>52-13</u>
MODEL NO _____	SERIAL NO _____	
TYPE _____ SIZE _____	ORDER NO _____	
MOTOR EPN <u>N/A</u>	MANUFACTURER _____	
MODEL NO _____	SERIAL NO _____	
ID NO _____	INS CLASS _____	1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: Definition (N/F = Not Found)

* CEP-LMS-4A not found
 △ SEE SHEET 2 OF 2 FOR OPERATOR ORIENTATION

PREPARED BY [Signature] DATE 7/1/02 REVIEWED BY [Signature] DATE 7/21/02
 (SIGNATURE) (SIGNATURE)

[Signature] [Signature] 1/5/03 [Signature]






Calculation Sheet

Project	WPBS MECH. E.Q.	Prepared By	J. E. Rukowicki	Date	12/18/82
Subject	BIF VALVE & AO	Checked By	M. E. Jurek	Date	12/20/82
System	CSP / CEP	Job No	82044	File No	
Analysis No		Rev No		Sheet No.	2/2




WALKDOWN
 VALVE & OPERATOR ORIENTATIONS
 CEP - V - 3A & 4A

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. OT.01/F
SHEET NO. 5-2-14

CEP - V - 3A :



CEP - V - 4A :



5.3 Valve Local Coordinate Systems

CSP-V-3


CSP-V-4

CSP-V-5


CSP-V-6

PREPARED BY: A. S. ...
 REVIEWED BY: J. P. ...
 2/11/83


CSP-V-3, 4 (typical)




$\theta_{N1} = 90^\circ \checkmark$	$\cos \theta_{N1} = 0 \checkmark$
$\theta_{N2} = 90^\circ \checkmark$	$\cos \theta_{N2} = 0 \checkmark$
$\theta_{N3} = 180^\circ \checkmark$	$\cos \theta_{N3} = -1$



$\theta_{E1} = 90^\circ$	$\cos \theta_{E1} = 0$
$\theta_{E2} = 180^\circ$	$\cos \theta_{E2} = -1$
$\theta_{E3} = 90^\circ$	$\cos \theta_{E3} = 0$




$\theta_{V1} = 0^\circ$	$\cos \theta_{V1} = 1$
$\theta_{V2} = 90^\circ$	$\cos \theta_{V2} = 0$
$\theta_{V3} = 90^\circ$	$\cos \theta_{V3} = 0$



CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. OT.01/F
SHEET NO. 5.3-1


CSF-1-5

PREPARED BY: [Signature]
 REVIEWED BY: [Signature] 2/11/83




TRANSPOSE TO LOCAL COORDINATE SYSTEM


$$\begin{aligned} \theta_{N1} &= 42\frac{1}{2}^\circ & \cos \theta_{N1} &= 0.737 \\ \theta_{N2} &= 47\frac{1}{2}^\circ & \cos \theta_{N2} &= 0.676 \\ \theta_{N3} &= 90^\circ & \cos \theta_{N3} &= 0 \end{aligned}$$



$$\begin{aligned} \theta_{E1} &= 47\frac{1}{2}^\circ & \cos \theta_{E1} &= 0.676 \\ \theta_{E2} &= 137\frac{1}{2}^\circ & \cos \theta_{E2} &= -0.737 \\ \theta_{E3} &= 90^\circ & \cos \theta_{E3} &= 0 \end{aligned}$$



$$\begin{aligned} \theta_{V1} &= 90^\circ & \cos \theta_{V1} &= 0 \\ \theta_{V2} &= 90^\circ & \cos \theta_{V2} &= 0 \\ \theta_{V3} &= 0^\circ & \cos \theta_{V3} &= 1 \end{aligned}$$




CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. 0101/F
SHEET NO. 5.3-2

CSP-V-6

PREPARED BY: J. J. L. 2/11/83


REVIEWED BY: J. E. F. 2/11/83



$$\theta_{N1} = 90^\circ \quad \cos \theta_{N1} = 0$$

$$\theta_{N2} = 90^\circ \quad \cos \theta_{N2} = 0$$


$$\theta_{N3} = 0^\circ \quad \cos \theta_{N3} = 1$$



$$\theta_{E1} = 90^\circ \quad \cos \theta_{E1} = 0$$

$$\theta_{E2} = 0^\circ \quad \cos \theta_{E2} = 1$$


$$\theta_{E3} = 90^\circ \quad \cos \theta_{E3} = 0$$



$$\theta_{V1} = 0^\circ \quad \cos \theta_{V1} = 1$$

$$\theta_{V2} = 90^\circ \quad \cos \theta_{V2} = 0$$

$$\theta_{V3} = 90^\circ \quad \cos \theta_{V3} = 0$$




CYGNA
ATTACHMENT
JOB NO. 82044...
FILE NO. OT. 01/E
SHEET NO. 5.3-3



Calculation Sheet

Project	INDPSS EQ	Prepared By:	<i>[Signature]</i>	Date	1/5/83
Subject	BIF VALUES / MILLER A10	Checked By:	<i>[Signature]</i>	Date	1/5/83
System	CEP	Job No.	82044	File No.	OT.01/F
Analysis No.	361106	Rev. No.	0	Sheet No.	

CEP-V-4A



ANGLE S

	(1-AXIS)	(2-AXIS)	(3-AXIS)
NORTH	90	-38	52
VERTICAL	90	52	142
EAST	180	90	90
WEIGHT	90	-128	-38

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01/F</u>
SHEET NO. <u>5.3-4</u>

5.5 Final Pipe-Mounted Equipment
Response G-Levels

Tracy

MAY 11 1983

RECEIVED

MAY 31 1983

CYGNA-RICHLAND

April 29, 1983
BRWP-83-078

Subject: W. O. 3900/4000
Washington Public Power Supply System
WNP-2
Qualification of Mechanical Pipe
Mounted Equipment; Forwarding of
Information

Mr. L. T. Harrold
Assistant Director
Washington Public Power Supply System
3000 George Washington Way
Richland, Washington 99352

Attention: Mr. B. A. Holmberg

CYGNA
ATTACHMENT
JOB NO. <u>R2044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>S.S.1</u>

- References:
- (a) WPBR-83-17, dated 3/16/83.
 - (b) WPBR-83-28, dated 4/12/83.
 - (c) WPBR-83-29, dated 4/12/83.
 - (d) Telecopy, B. A. Holmberg to J. J. Verderber, dated 4/4/83.

Gentlemen:

In response to the request of references (a), (b), (c) and (d), this letter is forwarding refined valve accelerations. The valve acceleration sheets for the five (5) CSP valves represent the second iteration of the refinement task. Valve sheets for the other four (4) valves represent the first iteration of the refinement task. Please inform the Woodbury Office if efforts should be made to reduce accelerations further.

Very truly yours,

ORIGINAL SIGNED BY J. J. VERDERBER

John J. Verderber
Project Engineering Manager

JJV/BPM/es
Att.

- CC: Mr. W. S. Chin - BPA - 1 w/1
 Mr. J. E. Rhodes - WPPSS - 1 w/1
 Mr. P. Buck - WPPSS - 1 w/1 Mail Drop 575

ATTACHMENT

Data forwarded with BRWP-83-078, dated April 29, 1983

<u>Valve #</u>	<u>Anchor Group</u>	<u>Calc. No.</u>
CSP-V-1	125	8.14.129
CSP-V-2	125	8.14.129
CSP-V-3	125	8.14.129
CSP-V-4	125	8.14.129
CSP-V-5	125	8.14.129
RCIC-V-31	107	8.14.112A
RHR-V-17B	31	8.14.121
RHR-V-53A	29	8.14.62C
RHR-V-53B	31	8.14.121B

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>55.2</u>

BURNS AND HOE, INC.

W.O. No. 3900-10 Date 4/12/83 Book No. 8.14.129 Page No. _____ of _____
 Drawing No. M200-5A Calc. No. 8.14.129
 By P.S. Checked G.Z. Approved
 Title WNP-2 Status As-Built Modification 2110 C. Kula 129

ATTACHMENT
 JOB NO. 22000
 FILE NO. 07 31.F
 SHEET NO. 55.5

CSP-V-5 Valve Qualification

B&R File No. Dwg. 68-00-0010 Operation I.D. No. _____

B&R M200 Iso No. 172 Anchor Group 125

VALVE ACCELERATIONS

Location	Nodal Pt. No.	Mass Wt. (lb.)	Condition	Accelerations (g)			Comments
				X	Y	Z	
Valve Operator (Bracket)	128	277	Upset	0.95	1.31	1.71	
			Emergency	2.80	1.82	5.32	
			Faulted	2.96	2.87	5.42	
Valve Operator (Cylinder)	137	399	Upset	0.97	1.54	1.60	
			Emergency	1.29	2.77	2.34	
			Faulted	1.62	3.52	2.55	

W.O. No. 3900-10 Date 3/31/83 Book No. 8.14.125 Page No. _____
 Drawing No. M200 Sh. 168 Rev. 22 Calc. No. 3.14.125 Sheet _____ of _____
 By AS Checked CT Approved _____
 Title VIB-P-2 Status 15-Built Verification of Pivots Calculated

CSP-V-6 Valve Qualification

B&R File No. _____ Operation I.D. No. _____
 B&R M200 Iso No. 168 Anchor Group 123

VALVE ACCELERATIONS

CYOMA
 ATTACHMENT
 JOB NO. 1204
 FILE NO. 1P01.F
 SHEET NO. 55.6

Location	Nodal Pt. No.	Mass Wt. (lb.)	Condition	Accelerations			Comments
				X	Y	Z	
Valve Operator (Bracket)	74	277	Upset	2.69	1.24	0.38	
			Emergency	11.37	1.50	0.55	
			Faulted	11.39	1.78	0.75	
Valve Operator (Cylinder)	71	399	Upset	2.33	3.09	1.48	
			Emergency	2.49	3.18	5.83	
			Faulted	2.55	3.33	5.85	



QID# 361106

7.0 TRANSMITTAL, PRIOR CALCULATIONS
AND REPORTS


CONTENTS

- 7.1 Communication Reports
- 7.2 Old Requalification and SQRT Forms
- 7.3 BIF Report: Dynamic Torque Calculations
of Butterfly Valve (Excerpt)*
- 7.4 McPherson Associates Report:
Design and Seismic Analysis
of 24" Cylinder-Operated
Butterfly Valve. (Excerpt)*

*NOTE 1

See Cygna Energy Services Project File; "Equipment Seismic and Hydrodynamic for 24" Cylinder Operated Butterfly Valves", File No. OT.01.F, QID# 361106, Revision 3, June, 1983 for complete report.

Revision 3



6.0 Drawings

By P.S. Checked As-Built Verification of Piping Calculations Approved

CYEMA
 ATTACHMENT
 JOB NO. 22004
 FILE NO. OT-11.F
 SHEET NO. 5 of 4

CSP-V-4 Valve Qualification

B&R File No. Dwg. 68-00-0009 Operation I.D. No.

B&R M200 Iso No. 172 Anchor Group 125

VALVE ACCELERATIONS

Location	Nodal Pt. No.	Mass Wt. (lb.)	Condition	Accelerations (g)			Comments
				X	Y	Z	
Valve Operator (Bracket)	103	277	Upset	1.01	1.40	0.85	
			Emergency	3.10	1.97	1.71	
			Faulted	3.25	2.94	1.99	
Valve Operator (Cylinder)	111	399	Upset	1.14	1.49	1.50	
			Emergency	1.60	1.87	4.07	
			Faulted	1.87	2.87	4.19	

W.O. No. 3900-10 Date 4/12/83 Book No. 8,111,129 Page No. _____
 Drawing No. M200-54.172 Rev. 3A Calc. No. 8,111,129 Sheet _____ of _____
 BY _____ Checked _____ Approved _____

Title WNP-2 Status 45-Built Verification of Piping Calculation

CSP-V-3 Valve Qualification

ATTACHMENT
JOB NO. 8204
FILE NO. PT. 31.F
SHEET NO. 5.5.3

B&R File No. DWG 68-00-0009 Operation I.D. No. _____
 B&R M200 Iso No. 172 Anchor Group 125

VALVE ACCELERATIONS

Location	Nodal Pt. No.	Mass Wt. (lb.)	Condition	Accelerations (g)			Comments
				X	Y	Z	
Valve Operator (Bracket)	86	2.77	Upset	0.72	1.37	0.70	
			Emergency	2.48	1.77	1.14	
			Faulted	2.66	2.81	1.53	
Valve Operator (Cylinder)	95	3.99	Upset	1.23	1.86	0.96	
			Emergency	1.80	2.30	3.62	
			Faulted	2.04	3.17	3.76	

BURNS AND ROE, INC.

W.O. No. 3900-10 Date 3/31/83 Book No. 2, 14, 125 Page No.
Drawing No. M200-168 Rev 2A Calc. No. 2, 14, 125 Sheet of
By JS Checked CT Approved
Title WNP-2 Status As-Built Verification of Piping Calculations

ATTN:
JOB NO. 82044
FILE NO. 1P01/F
SHEET NO. 55.8

CEP-V-4A Valve Qualification

B&R File No.

Operation I.D. No.

B&R M200 Iso No. 168

Anchor Group 123

VALVE ACCELERATIONS

Location	Nodal Pt. No.	Mass Wt. (lb.)	Condition	Accelerations (g)			Comments
				X	Y	Z	
Valve Body	31	847	Upset	1.05	0.84	0.51	
			Emergency	3.66	0.90	0.73	
			Faulted	3.71	1.33	0.89	
Valve Operator	34	626	Upset	0.94	0.89	0.40	
			Emergency	3.31	0.93	0.69	
			Faulted	3.35	1.34	0.86	

W.O. No. 3900-10 Date 3/31/83 Book No. 8,14,125 Page No. _____ of _____
 Drawing No. M200-SH-168 Rev 2A Calc. No. 8,14,125 Sheet _____ of _____
 By RS Checked CT Approved _____
 Title WNP-2 status Is-built Verification of Pipe No Calculation

CEP-V-3A Valve Qualification

B&R File No. _____


Operation I.D. No. _____

B&R M200 Iso No. 168

Anchor Group 123

VALVE ACCELERATIONS


Location	Nodal Pt. No.	Mass Wt. (lb.)	Condition	Accelerations (g)			Comments
				X	Y	Z	
Valve Body	21	847	Upset	0.90	0.70	0.51	
			Emergency	3.06	0.78	0.74	
			Faulted	3.10	1.25	0.90	
Valve Operator	24	626	Upset	1.20	0.74	0.41	
			Emergency	4.54	0.81	0.69	
			Faulted	4.57	1.26	0.86	


 ATTACHMENT
 JOB NO. 82044
 FILE NO. R011E
 SHEET NO. 551



QID# 361106

7.1 Communication Reports & Correspondence





Communications Report

Company: CES Telecon Conference Report

Project: W PDS EQ Job No. _____

Subject: BIF VALVE DIMENSIONS Date: Below

Participants: Jim Foley of CES - BAO

Rick Ricapito 401-885-1000 of BIF

Jim Rohowski of CES - BAO

Time: Below

Place: RBO

Item	Comments	Req'd Action By												
	<p><u>2/10/83 - J. Foley / J. Rohowski</u></p> <p><u>BIF VALVE FLANGE DIMENSIONS</u></p> <table border="0"> <tr> <td>24" thickness</td> <td>1.75"</td> <td>30"</td> <td>2.125"</td> </tr> <tr> <td>I.d.</td> <td>25"</td> <td></td> <td>31"</td> </tr> <tr> <td>O.d.</td> <td>32"</td> <td></td> <td>38.75"</td> </tr> </table> <p>BOLTS : $1\frac{3}{8}"$ (20) $1\frac{3}{8}"$ (28)</p> <p><u>2/11/83 - Rick Ricapito / J. Rohowski</u></p> <p>Radial Clearance of 24" & 30" valves.</p> <p>— approx $\frac{1}{8}$ inch —</p> <div data-bbox="1044 1583 1328 1873" style="border: 1px solid black; padding: 5px; margin-top: 10px;"> <p>CYGNA</p> <p>ATTACHMENT</p> <p>JOB NO. <u>82044</u></p> <p>FILE NO. <u>OT.OI.F</u></p> <p>SHEET NO. <u>7.1.1</u></p> </div>	24" thickness	1.75"	30"	2.125"	I.d.	25"		31"	O.d.	32"		38.75"	
24" thickness	1.75"	30"	2.125"											
I.d.	25"		31"											
O.d.	32"		38.75"											

Signed: _____ Page _____ of _____

Distribution: _____

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

December 17, 1982
GE-02-RWH-82-018

Cygn Energy Services
141 Battery Street
Suite 400
San Francisco, CA 94111

Attention: Mr. T. Wittig, Project Manager

Subject: NUCLEAR PROJECT 2
CONTRACT C-0892

Investigation of the CSB and CEB systems shows that during a dynamic event the systems are not degraded in any way by the butterfly valves fluttering. Therefore, all work on Work Release Nos. 14 and 17 which address valve stability should be terminated.



R. W. Hickman - 575
Senior Engineer,
Equipment Qualification

RWH/sms

cc: F. Khanachet, Cygna Richland

RECEIVED

DEC 22 1982

CYGNA-RICHLAND

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.OI.F</u>
SHEET NO. <u>7.1.2</u>




H. Reeser

Communications Report

CR-030

Company: CES	<input checked="" type="checkbox"/> Telecon	<input type="checkbox"/> Conference Report
Project: WPPSS	Job No. 82044	Date: 7/29/82
Subject: QID 361110 - 18" BUTTERFLY VALVE	Time: 9:40 A.M.	Place: SDAO
Participants:	Dick Hickman of Supply System	
	Hal Reeser of CES, SDAO	
	of _____	

Item	Comments	Req'd Action By
	<p>I called Dick re. dynamic instability of BIF valve while in open position. I also requested permission to contact GE re. use of faulted or upset allowables for RHR valves.</p> <ul style="list-style-type: none"> o Dick said we should complete the requalification analysis of the valves and flag the dynamic instability issue as a separate subject that will require Supply System action for resolution. o Supply System has granted a contract to BIF for operability studies on their valves. The contract administrator at BIF is John McDonald (401/885-1000). Our action should be to determine the scope of the BIF study and to make certain that we do not overlap our efforts with theirs. Also we should attempt to assure that our work does not conflict with the BIF effort. o Dick said we may contact GE direct. Our contact at GE for the decision on faulted or upset allowables is: Arlan DeVault (408/925-2208). <p>*ACTION: Rajan, this resolution should be documented via revised criteria in our Project Manual.</p>	<p>H. Abolhoda</p> <p>M. Rajan*</p>



HR/sak *HR*

Signed: H. Reeser	Page 1	- of 1
Distribution: T. Wittig, H. Abolhoda, F. Khanachet, P. Guglielmo, B. Schlafer, M. Rajan, J. Minichiello, P. Patel, Project Files (SD), (SF), (RB)		



Communications Report

CR-027

Company: CES	<input checked="" type="checkbox"/> Telecon	<input type="checkbox"/> Conference Report
Project: WPPSS	Job No. 82046	Date: 7/20/82
Subject: APPLICABILITY OF HYDRODYNAMIC LOADS	Time: P.M.	Place: SDAO
Participants:	W. Schlafer of CES, SDAO	H. Reeser of CES, RBO

Item	Comments	Req'd Action By
1.	The Hydrodynamic Load Column in the WPPSS SRM list is known to have errors. A "no" listing is <u>not</u> to be trusted.	
2.	For packages in analysis Cygna will trace down the P & ID to determine the applicability of hydrodynamic loads to line mounted equipment.	
3.	To accomplish this, Cygna will: <ul style="list-style-type: none"> a. Check the line routing to see if it penetrates the primary containment. If not, hydrodynamic loads do not apply. b. If the line penetrates the primary containment, hydrodynamic loads will apply unless: <ul style="list-style-type: none"> 1. An anchor point appears first in that line, or 2. The line first connects with floor mounted equipment outside the primary containment and it is sufficiently sturdy to eliminate the propagation of pipe line hydrodynamic loads beyond it. 	
4.	If a line mounted equipment fails to qualify due to hydrodynamic loads, estimate it's fragility level. This information will be used by WPPSS when they receive the B & R final piping analysis and examine actual pipe accelerations.	

CYGNA
ATTACHMENT
JOB NO. <u>82046</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>7.1.4</u>

WS/sak

1020.00




Communications Report

CR-027

Company: CES	<input checked="" type="checkbox"/> Telecon	<input type="checkbox"/> Conference Report
Project: WPPSS	Job No. _____	Date: _____
Subject: APPLICABILITY OF HYDRODYNAMIC LOADS	Time: _____	Place: _____
Participants: _____	of _____	
_____	of _____	
_____	of _____	

Item	Comments	Req'd Action By
5.	<p>For packages whose analysis is complete and where hydrodynamic loads were not considered because the SRM said "No":</p> <ol style="list-style-type: none"> Review the line as in 3 (first page of this telecon). If we feel hydrodynamic loads really do apply, send a memo to the S. S. indicating the package may need rework. Send memo to F. Khanachet requesting supply system concurrence that hydro loads do apply and added analysis is required. 	



Signed: W. Schlafer Page 2 of 2

Distribution:



Communications Report

CR-023

Company: CES	<input checked="" type="checkbox"/> Telecon	<input type="checkbox"/> Conference Report
Project: WPPSS	Job No. 82046	Date: July 20, 1982
Subject: Hydrodynamic Loads	Time: 9 A.M.	Place: San Diego
Participants:	J. Minnachiello	of SFAO
	P. K. Patel	of SDAO
		of

Item	Comments	Req'd Action By
	<p>During the conversation we discussed the following:</p> <ol style="list-style-type: none"> 1. If attenuation data on hydrodynamic loads are not available, one does not have any choice but to take into account hydrodynamic loads on all line mounted equipments. 2. One should use 1.5X peak acceleration unless the system frequency (line plus equipment) indicates otherwise. 3. If the equipment satisfies the allowable stress limits, then one should perform fatigue analysis using the fatigue design curves given for Class 1 components. To calculate the fatigue damage for normal operation (excluding all dynamic events) one might take a conservative approach by assuming the calculated stresses are equal to the allowable stress limits. 	

CYGNA
ATTACHMENT
 JOB NO. 82044
 FILE NO. 07.01.E
 SHEET NO. 7.1.6

PK

Signed: P. K. Patel Page 1 of 1

Distribution: H. Reeser, ~~R. H. Steh~~ Rajan, H. Abolhoda, P. Curry

COPY

BIF

July 7, 1982

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>01-01-7</u>
SHEET NO. <u>1.1.1</u>

RECEIVED

JUL 13 1982

Sygna Energy Service
225 Stevens Street
Solana Beach, CA 92075

LA - SAN DIEGO

Attention: Mr. "Bill" Schlafer

Subject: Butterfly Valves for Nuclear
Applications with IEEE Qualification
Requirements

Dear Sir:

This information is provided in response to your recent phone call.

1. Enclosed please find some catalog information describing BIF's line of butterfly valves, including our current models as well as our new Model 0668 design (which will shortly replace our 0652 and 0658 models).
2. The following are our best estimates for budget purposes only of what it would cost to replace the valves and operators originally furnished to WPPSS in the 1970's (which did not require IEEE qualifications) with valves and operators that are fully qualified to IEEE-382-1972, IEEE-323-1971 and IEEE-344-1975.

It is almost impossible to obtain prices from IEEE qualified actuator vendors without a detailed specification showing exactly what is required; therefore, these are our best guesstimates of what the replacements would cost. They could be high or low by 10 to 20%, depending upon the wording used in the engineer's resultant specification.

Replacements for Valves Furnished Originally on N-27232

14 - 18" BV's with electric operators (See NODS - 11/1/79)	\$40,000 ea. if qty. = 1 or \$25,000 ea. if qty. = 14
--	--

Replacements for Valves Furnished Originally on N-27233

2 - 18" BV's with spring to <u>open</u> cylinder operators	\$60,000 ea. if qty. = 1 or \$45,000 ea. if qty. = 2
--	---

Sygna Energy Service
July 7, 1982
Page 2

Replacements for Valves Furnished Originally on N-27234

4 - 30" BV's with spring to close \$75,000 ea. if qty. = 1
cylinder operators or \$60,000 ea. if qty. = 4

Replacements for Valves Furnished Originally on N-27235

4 - 24" BV's with spring to close \$60,000 ea. if qty. = 1
cylinder operators or \$50,000 ea. if qty. = 4

Replacements for Valves Furnished Originally on N-27236

3 - 24" BV's with spring to open \$60,000 ea. if qty. = 1
cylinder operators or \$50,000 ea. if qty. = 3


We trust that this information will be of some help to you, and are sorry that our prices cannot be more precise.

Sincerely,


George E. Sayer
George E. Sayer
BV Sales Applications Engineer

Enclosures: 650.20-4
BPD-668-45-1
BPD-668-1
NODS-11/1/79

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>7.1.8</u>




ITEM 22, HEAT SHRUNK & SEALED WITH LOCKTITE



SECTION A-A

MECHANICALLY RETAINED ADJUSTABLE SEAT, FIELD REPLACEABLE WITHOUT REMOVING VALVE FROM PIPE LINE.

ITEM 5 SECURED WITH NYLON INSERT



ALTERNATE ADJUSTABLE VEE PACKING

ITEM	MATERIAL	MATERIAL
1	VALVE BODY	CAST IRON ASTM A126 CL B
2	RUBBER SEAT	BUNA-N ASTM D2000
3	CLAMPING RING	TYPE 304 ST. ST'L
4	CLAMPING RING LOCK	TYPE 304 ST. ST'L
5	HALF DOG POINT SET SCREW	TYPE 304 ST. ST'L
6	SHAFT BEARING	REINFORCED TEFLON BRZ OR PHENOLIC BACKED
7	STUFFING BOX PACKING	VEE PACKING, BUNA-N
8	STUFFING BOX GLAND	CAST BRONZE ASTM B62
9	HEX HEAD CAP SCREW	TYPE 304 ST. ST'L
10	OPERATOR SHAFT	TYPE 304 ST. ST'L
11	HALF DOG POINT SET SCREW	TYPE 304 ST. ST'L
12	VALVE DISC	CAST IRON ASTM A48 CL40 OR DUCTILE IRON ASTM A536 GR. 65-45-12
13	WASHER	TYPE 18-8 ST. ST'L
14	DISC PIN	TYPE 304 ST. ST'L
15	KEY	ST'L
16	HEX NUT	TYPE 304 ST. ST'L
17	THRUST COLLAR	TYPE 303 ST. ST'L
18	THRUST BEARING COVER	CAST IRON ASTM A126 CL B
19	HEX HEAD CAP SCREW	TYPE 304 ST. ST'L
20	O-RING	BUNA-N
21	THRUST BEARING	REINFORCED TEFLON, PHENOLIC BACKED
22	DISC SEATING RING	TYPE 316 ST. ST'L


CYQMA
ATTACHMENT
JOB NO. 82044
FILE NO. DT-DIF
SHEET NO. 7.1.9

BIF


A UNIT OF GENERAL SIGNAL

AWWA BUTTERFLY VALVES MODEL 0668 30" THRU 120"


PARTS



DETAIL
THRUST ADJUSTMENT PARTS.



MECHANICALLY RETAINED ADJUSTABLE SEAT
FIELD REPLACEABLE WITHOUT
REMOVING VALVE FROM PIPE
LINE



ITEM 27 HEAT SHRUNK
AND SEALED WITH LOCKTITE


SECTION A-A
(FOR 30" THRU 48" B.V.)

SECTION A-A
(FOR 54" THRU 120" B.V.)

ITEM	MATERIAL	MATERIAL
1	VALVE BODY	CAST IRON ASTM A126 CL B
2	RUBBER SEAT	BUNA-N ASTM D2000
3	CLAMPING RING	TYPE 304 ST. ST'L
4	CLAMPING RING LOCK	TYPE 304 ST. ST'L
5	HALF DOG POINT SET SCREW	TYPE 304 ST. ST'L
6	SHAFT BEARING	REINFORCED TEFLON BRZ OR PHENOLIC BACKED
7	STUFFING BOX PACKING	VEE PACKING, BUNA-N
8	STUFFING BOX GLAND	CAST BRONZE ASTM B62
9	HEX HEAD CAP SCREW	TYPE 304 ST. ST'L
10	OPERATOR SHAFT	TYPE 304 ST. ST'L
11	STUB SHAFT	TYPE 304 ST. ST'L
12	VALVE DISC	CAST IRON ASTM A48 CL40 OR DUCTILE IRON ASTM A536 GR. 65-45-12
13	WASHER	TYPE 18-8 ST. ST'L
14	DISC PIN	TYPE 304 ST. ST'L
15	KEY	ST'L
16	HEX. NUT	TYPE 304 ST. ST'L
17	THRUST COLLAR	TYPE 303 ST. ST'L
18	THRUST BEARING COVER	CAST IRON ASTM A126 CL B
19	HEX HEAD CAP SCREW	TYPE 304 ST. ST'L
20	O-RING	BUNA-N
21	THRUST BEARING	REINFORCED TEFLON, PHENOLIC BACKED
22	THRUST ADJUSTING SCREW	TYPE 304 ST. ST'L
23	JAM NUT	TYPE 304 ST. ST'L
24	THRUST BEARING PLATE	STEEL ASTM A36
25	SEAL	SILICONE RUBBER
26	HEX HEAD CAP SCREW	TYPE 304 ST. ST'L
27	SEATING EDGE	TYPE 316 ST. ST'L

CYGNIA
ATTACHMENT
JOB NO. 87044
FILE NO. 07.01.P
SHEET NO. 7.1.10

LIMITORQUE VALVE CONTROLS



LIMITORQUE CORPORATION • P. O. BOX 11318 • LYNCHBURG, VIRGINIA 24506

IEEE 323 (1974) and IEEE 382 (1972)
NUCLEAR QUALIFICATION DATA
FOR SAFETY RELATED SERVICE

	THREE PHASE ONLY		D.C.
	Nuclear Containment (See Option 8 Price Adders)	Outside Containment (Standard Prices)††	Containment—Inside or Outside (See Option 8 Price Adders)
Design Life	40 years (2000 cycles)*	40 years (2000 cycles)*	40 years (2000 cycles)*
Ambient Temperature (Continuous)	140°F	120°F	120°F
Ambient Humidity	60-100%	30-100%	30-100%
Aging	Motor Stator only 180°C for 100 hours	Entire Unit 165°F for 200 hours at 100% relative humidity	Motor Armature, Field Coils, & Brush Box only 180°C for 100 hours
Total Radiation (40 yrs. Integrated)	2.04x10 ⁶ rads	2x10 ⁷ rads	1.0x10 ⁷ rads
Seismic Ref: IEEE344	**6.0 g's (SMB/SB) ***3.0 g's (SMB/HBC) ****6.0 g's (SMB/HBC)	** 6.0 g's (SMB/SB) *** 3.0 g's (SMB/HBC) **** 6.0 g's (SMB/HBC)	16.0 g's (SMB/SB) ***3.0 g's (SMB/HBC) ****6.0 g's (SMB/HBC)
Number of Transients	2	2	1
Transient Temperature	340°F (BWR) 300°F (PWR)	250°F	340°F
Test Humidity	100% (saturated)	100% (saturated)	100% (saturated)
Profile	PWR/IEEE382-73, Page 12, Table 1 BWR/IEEE382-73, Page 12, Table 2	ANSI (yet to be published)	Special
Length of Test	30 Days	15 Days	25 Hours
Completed Test Date	PWR—September 1974 (600456) BWR—September 1972 (6000376)	February 1975 (600461)	October 31, 1975 (B0009)

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>7.1.11</u>

*During BWR test, 500 cycles were used as a design life per IEEE382.

During PWR test, 2000 cycles were used as a design life of which 500 were incorporated prior to test and 1500 after test.

During test for outside containment, 200 cycles were incorporated while the actuators were being aged, and 1800 were added prior to irradiating.

During D.C. test, all 2000 cycles were incorporated prior to irradiating.

**As of 7/26/75, seismic tests were completed to IEEE344-1975 for both SMB and SB units to 6.0 g's vertical and 3.2 g's horizontal. Since no cross coupling was noted between axes, the test qualifies the SMB/SB to 6.0 g's in both vertical and horizontal axis. Maximum g-level dwells in each of the three axes qualify the units for any mounting position. (Seismic Qualification Report No. B0021). Qualification extends through 35 Hz.

††Standard Class "B" insulated motors only.

**Standard units without spur attachments.

***Standard units with seismic support bracket and without spur attachments.

NOTE: SMC-04 and SMC-05 actuators are qualified for "Outside Containment" service per above levels based on their similarity to the SMB actuator.




Communications Report

Company:	CES	<input checked="" type="checkbox"/> Telecon	<input type="checkbox"/> Conference Report
Project:	WPPSS		Job No. 82046/CR-019
			Date: 7/1/82
Subject:	Hydrodynamic Loads for Line Mounted Equipment		Time: 11:20 a.m.
			Place: SDAO
Participants:	Bruce Linderman & Don Harkness of Bechtel, Norwalk, CA		
	W. Schlafer of CES, SDAO		
	of _____		

Item	Comments	Req'd Action By
1.	Called the Seismic Qualification Working Group to determine their current criteria for line mounted equipment subjected to hydrodynamic loads.	
2.	<p>Their current test requirements for in line equipment subjected to hydrodynamic loads are:</p> <p>a) One SSE + SRV Event: Required Input Motion (RIM) of sine beat testing at 1/3 Octave Intervals from 1 to 200 Hertz, each for 15 seconds, at 6.0 g.</p> <p>b) Two OBE + SRV Events: Required Input Motion (RIM) of two sine sweeps at 1 Octave/Minute from 2 to 200 to 2 Hertz at 2/3*6.0 g = 4.0 g.</p> <p>c) In-Plant Vibration: Required Input Motion of sine sweep testing at 2 Octaves/Minute from 5 to 200 to 5 Hertz for 90 minutes at .75 g.</p>	
3.	This type of environment is distinctly more severe and more correct than that proposed in the WPPSS interim dynamics criteria memo # 856. Eventually WPPSS will need to be informed of current industry practice such as this.	

WS:lgn






Communications Report

Company: CES	<input checked="" type="checkbox"/> Telecon	<input type="checkbox"/> Conference Report
Project: WPPSS	Job No. 82046/CR-018	Date: 6/29/82
Subject: EQ of BIF Butterfly Valves QID 361104, 361106	Time: 12:05 p.m.	Place: SDAO
Participants:		
Bill Schlafer	of	CES, SDAO
John Henry	of	John Henry Associates
	of	

Item	Comments	Req'd Action By
1.	Called John Henry because he was the engineer who approved the original seismic calculations for BIF Butterfly Valves.	
2.	His recollection of these analyses was vague but did mention they, as consulting engineers, never tried to assure operability. Operability was the manufacturer's responsibility.	
3.	He recommended testing a similar valve.	



BS:lgn


Signed: Bill Schlafer <i>BS</i>	Page 1	of 1
Distribution: L. Kammerzell, J. Read, H. Abolhoda, R. Hsieh, P. Patel, P. Curry		



Communications Report

Company:	CES	<input checked="" type="checkbox"/> Telecon	<input type="checkbox"/> Conference Report
Project:	WPPSS		Job No. 82046/CR017
			Date: 6/29/82
Subject:	EQ of BIF Butterfly Valves QID 361104, 361106		Time: a.m.
			Place: SDAO
Participants:	Bill Schlafer of CES, SDAO		
	George Sayer of BIF, 401-885-1000		
	of _____		

Item	Comments	Req'd Action By
1.	Called George Sayer, the BIF sales agent to get a budget price for BIF 18", 24", 30" air-operated butterfly valves and an 18" motor actuated butterfly valve. These valves are similar to ones in WPPSS QID files but do not use the same air-actuators. The original BIF valve serial numbers (for reference) are N-27234-F, N-27235-F, N-27236-F and N-27232-1.	
2.	He required a few days to work out a price and will also send descriptive brochures.	



BS:lgn

Signed: Bill Schlafer *BS* Page 1 of 1
 Distribution: L. Kammerzell, J. Read, H. Abolhoda, ~~R. Hsieh~~ P. Patel, P. Curry




Communications Report

Company:	CES	<input checked="" type="checkbox"/> Telecon	<input type="checkbox"/> Conference Report
Project:	WPPSS	Job No.	82046/CR016
		Date:	6/29/82
Subject:	EQ of BIF Butterfly Valves QID 761104, 361106	Time:	a.m.
		Place:	SDAO
Participants:	Bill Schlafer	of	CES, SDAO
	Allan Berger	of	BIF 401-885-1000
		of	

Item	Comments	Req'd Action By
1.	Called Allan Berger, a BIF engineer, to get technical drawings for the 18", 24" and 30" air-operated butterfly valve actuators.	
2.	Requested drawings of Miller air cylinders showing details of <ul style="list-style-type: none"> a) Cylinder dimensions b) Piston dimensions c) Rod/piston connections 	
3.	Conversation indicated <ul style="list-style-type: none"> a) There is a bearing and seal around the piston rod where it exits the cylinder b) The piston rod fits through a clearance hole in the piston and is bolted on. c) No seismic functional tests have been done on the Miller air cylinder d) For dimensional data to verify functional operability of the motor actuated valve, contact Limitorque in Lynchburg, Virginia 	

BS:lgn



Signed: Bill Schlafer *BS* Page 1 of 1
 Distribution: L. Kammerzell, J. Read, H. Abolhoda, ~~R. Hsien~~, P. Patel, P. Curr



Memorandum

PROJECT MEMO: SDCM-002
T.001

To: H. Reiss

Date: 6/17/82

From: R. Hsieh

Job No: 82046
WPPSS

Subject: MISSING DATA REQUEST
(CID[#] 361106, PK₃[#] T)

Copies: _____
Project File

- 1. DRAWING A-208293 (CYL. SUPPT. BRACKET)
- 2. DRAWING D-206661 (MILLER CYL.)
- 3. SPEC[#] 280E-68
- 4. DRAWING B-211830 (DRIVE LEVER)
- 5. DRAWING B-211832-1 (CLEVIS)

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>07.01.F</u>
SHEET NO. <u>7.1.16</u>

NOTE: Please sign and return the attached copy of this memorandum as acknowledgement of receipt of this memo. THANK YOU.

Received by: _____

Date Received: _____



Memorandum

To: P. Guglielmino
J. Minichiello,

Date: June 17, 1982

From: W. Schlafer, PK: Patel

Job No: 82046/SDM-003

Subject: Analysis for Operability

OK

CYGMA
ATTACHMENT
JOB NO. <u>82046</u>
FILE NO. <u>OT.OI.F</u>
SHEET NO. <u>7.1.17</u>

Copies: L. Kammerzell
J. Read
H. Reeser
G. Shipway (Wyle)
T. Wittig
Project File

In order to assess operability by analysis of mechanical equipment which can be modelled to correctly predict its stress and deformation responses relevant to operation, the following criteria are to be considered in conjunction with Section 3.E.1 of the Design Criteria.

If an equipment in Group II is expected to perform during the seismic and/or hydrodynamic event then the following requirements shall be met:

- (1) Elastic displacement calculations shall be performed to assure non-interference between mating parts, and
- (2) The calculated stresses shall be within the allowable stress limits.

If the calculated stresses for any service loading are such that permanent deformations might have occurred due to high allowable stress limits, a displacement analysis as in (3) shall be performed.

- (3) A comprehensive elastic-plastic analysis should be conducted in these cases to assure non-interference between mating parts.

For an equipment in Group I which is expected to operate after the seismic and/or hydrodynamic event then the following requirements shall be met:

- (4) Total stresses in the part must be limited to a yield strength of the material, OR
- (5) Satisfy the requirements of Group II equipment.


WS:lgn



Communications Report


Company:	CES	<input checked="" type="checkbox"/> Telecon	<input type="checkbox"/> Conference Report
Project:	WPPSS	Job No.	82046/CR-014
Subject:	Wyle Data Bank	Date:	6/16/82
Participants:	W. Schlafer	Time:	a.m.
	G. Shipway	Place:	SDAO
			CES, SDAO
		of	Wyle, Norco
		of	

Item	Comments	Req'd Action By
1.	Asked George to initiate a search in their testing data bank for seismic or seismic/hydrodynamic tests on BIF 18", 24" & 30" Butterfly Valves.	G. Shipway
2.	These valves are in QID files 361106 and 361104.	
3.	George is skeptical test data exists for those butterfly valves experiencing the extended frequency range of the hydrodynamic event.	



WS:lgn

Signed: W. Schlafer *WS* Page 1 of 1
 Distribution: L. Kammerzell, J. Read, H. Abolhoda, R. Hsien, Project File



RECEIVED
COPY JUN 28 1982
 CYGMA - SAN DIEGO

Communications
 Report
(Group Leader)
(Laurie)

Company: <u>Cygna/Wyle</u>	<input checked="" type="checkbox"/> Telecon	<input type="checkbox"/> Conference Report
Project: <u>Equipment Seismic/Hydrodynamic Regualifi- cation</u>	Job No. <u>82044</u>	Date <u>6/15/82</u>
Subject: <u>Interim Dynamic Loads Criteria and Fatigue Criteria</u>	Time <u>11:00</u>	Place: <u>Richland Office</u>
Participants: <u>Joe Braverman</u>	CYGMA ATTACHMENT JOB NO. <u>82044</u> FILE NO. <u>OT.O.I.F</u> SHEET NO. <u>71.19</u>	of <u>Burns & Roe</u>
<u>Jim Foreman</u>		of <u>Wyle Laboratories</u>
		of <u> </u>

Item	Comments	Req'd Action By
	<p>Joe Braverman of Burns and Roe was contacted by telephone on June 15, 1982 to get a clarification on the subject criteria for use in the Regualification of Equipment for Seismic and Hydrodynamic effects.</p> <p>Joe concurred that the acceleration values shown in the table of the attachment to the conference notes were intended to be used for rigid line mounted components only and not for flexible components. i.e., those having natural frequencies below the cutoff frequency. To be consistent with B&R recommendation for qualification of line mounted components by test would indicate that for the analysis of flexible line mounted components a static load would be applied at the C.G. of the extended structure equal to the amplification factor for sinusoidal motion at a justifiable damping value. For example, for an SSE condition the amplification at 3% damping would be 50 divided by 3 = 16.7. This loading may be in some cases present a very conservative loading on the line mounted components. A somewhat more realistic input motion would be</p>	



Communications Report

Company: Cygna/Wyle Telecon Conference Report

Project: Equipment Seismic/Hydrodynamic Requalification Job No. 82044
 Date: 6/15/82

Subject: Interim Dynamic Loads Criteria and Fatigue Criteria Time: 11:00
 Place: Richland Office

Participants: Joe Braverman of Burns and Roe
Jim Foreman of Wyle Laboratories

CYGNA
ATTACHMENT
 JOB NO. 82044
 FILE NO. 01.01.F
 SHEET NO. 7.1.20

Item	Comments	Req'd Action By
	<p>continuous sine beats of 12-15 oscillations per beat as recommended by the IEEE-382 draft "American Standard of Safety Related Valve Actuators". The amplification for a 15 oscillation sine beat at resonance for 3% damping is approximately 11.5.</p> <p>If the static loadings given above show an overstressed condition or deflections which would cause operational malfunction, the alternative to develop a more realistic approach would be to perform in-situ testing from which the data could be used to develop response spectra at valve locations. The in-situ tests would allow the determination of the natural frequencies and mode shapes of a sufficient part of the piping system along with the valve and extended structure to validate the mathematical models used to generate response spectra at the valve location and/or component locations on the extended structure. The response spectra at component locations allow direct comparisons with component test data. It is felt that a combined test and analysis would be a feasible and cost effective approach.</p>	

Signed: [Signature] Page 2 of 3
 Distribution: Standard Distribution



COMMUNICATIONS Report

Company Cygna/Wyle

Telecon

Conference Report

Project

Equipment Seismic/Hydrodynamic Regu-
lification

Job No. 82044

Date: 6/15/82

Subject

Interim Dynamic Loads Criteria and
Fatigue Criteria

Time: 11:00

Place: Richland Office

Participants:

Joe Braverman

of Burns and Roe

Jim Foreman

of Wyle Laboratories

Item	Comments	Req'd Action By
	<p>Burns and Roe is checking to see if fatigue criteria have been developed for WNP-2 and will notify Cygna/Wyle not later than June 17, 1982 if such criteria exists.</p> <div data-bbox="982 1024 1263 1312" style="border: 1px solid black; padding: 5px; margin: 10px auto; width: fit-content;"> <p style="text-align: center; font-weight: bold; font-size: 1.2em;">CYGNA</p> <p style="text-align: center; font-weight: bold;">ATTACHMENT</p> <p>JOB NO. <u>82044</u></p> <p>FILE NO. <u>OT.DL.F</u></p> <p>SHEET NO. <u>7.1.21</u></p> </div>	

Signed: JWF

Page 3 of 3

Distribution: Standard Distribution

6/25/82 W. Schaffer

Why In-situ Testing By G. Shipway

1. Verify analytical model
2. Verify rigidity
3. Reduce stress analysis conservatism
4. Demonstrate operability
5. Include piping influences into modeling

Considerations

1. Must be closely coupled with analytical work
2. Previous in-situ programs will be reviewed for possible guidance.
3. Assume site accessibility is no problem.

Which items

First estimate attached

Refine 1st guess with walk down inspection

Refine again with similarity review

Refine again with review of analytical work

Methods

Select desired scenario depending on objective + items

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. OT101.F
SHEET NO. 7.1.22

In situ Scenarios

1. Static equivalent pull test for operability.
 - a. From analytical analysis, compute static equivalent load to be applied to actuator coil, and the direction of the load.
 - b. Determine location of, and access to, the item in question.
 - c. Consider potential synergism of pressure, temperature, flow, etc.
 - d. If the absence of any of the potential synergistic parameters cannot be justified, the effect of that parameter must be accounted for.
 - e. Apply required static load.
 - f. Monitor operation ^{of item} as required to verify acceptable operation.
2. Determine acceptance criteria for operation of the item.

Caution - O. static pull test must
be performed with care.
Personnel will know what.

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. OT, OLF
SHEET NO. 7.1.23

In-situ Scenarios

2. Resonance frequency determination
 [To be used to verify rigidity, i.e. the absence of resonances at low frequencies.]
- a. Determine location of, and access to, the item in question.
 - b. Determine the mounting arrangement and any other interfaces for the item.
 - c. Compare the in-situ mounting + interfaces with that used in the analytical model.
 - d. Consider the probability of the item having no low frequency resonances. (If the probability of rigidity is not high this technique may not be the best choice).
 - e. Using an appropriate size of hammer and a rubber pad, impact excite the item at the location(s) most likely to produce resonance responses.
 - f. Monitor the response of the item with an accelerometer and the micro FFT analyzer to determine the lowest frequency of amplified response motion.
 - g. Care must be used to insure the excite of the lowest response frequency by proper use of the hammer and the location of the impact.

In-situ Scenarios3. Modal Survey

a. Determine location of, and access to, the item in question.

b. Determine the mounting arrangement and any other interfaces for the item.

c. Compare the in-situ mounting and interfaces with that used in the analytical model.

d. Determine the mode shapes and frequencies predicted by the analytical work, and use this information as a guide for the experimental work.

f. If the item is relatively simple, and has low impedance, use an instrumented hammer for excitation. Otherwise, use a 30 to 50 lb shaker for excitation.

e. Determine the frequency range of interest, i.e. with, or without, hydrodynamic loads.

g. Using the HP 5423, monitor the item response at selected locations to gather experimental modal data for comparison with the analytical data.

h. Iterate analytical and experimental results to achieve convergence.

Prepared by HPE Date 24 June 82 Subject WPPSS WNP-2 Safety Related Mechanical Equipment

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. OT.01.F
SHEET NO. 7.1.26

Potential In Situ Test Items

QID No	DESCRIPTION	EQUIPMENT NO	LOCATION	TEST
118002	Engine / P.P. Elect	DSA-ENG. 1A2 1B2	D 441, P.2/7.0 D 443, P.7/6.7	F
128002	Filter / Electro Motive DG-ENG. 1A 1B Lube Oil Filter Inlet Filter Turbo Charger Supply Filter Intake	DLO-F-1A1 DLO-F-1A2 DLO-F-1B1 DLO-F-1B2 DLO-F-2A1 F-2A2 F-2B1 F-2B2 F-3A1 F-3A2 F-3B1 F-3B2	D 441, F.3/6.0 D 441, R.5/6.0 D 441, P.3/8.0 D 441, T.5/8.0 D 441, F.3/6.0 " R.5/6.2 " F.3/8.0 " R.5/8.0 " P.3/6.2 " R.5/6.0 " P.3/8.0 " R.5/8.0	F F
133001	FC Valve / Fischer Flow Control X-99 2.5" Flow Control	CAC-FCV-1B -1B -3A -3B -4A -4B	R 575 M.2/5.2 R 564 J.6/6.7 R 495 M.8/4.7 R 496 J.0/7.4 R 495 N.4/6.0 R 495 N.4/6.0	F, S 3 F ₂ 18 F ₃ 15 F, S
133002	FC Valve / Fisher 3.0" MD Globe RHR Min Flow	RHR-FCV-64B -64C	R 443 H.0/9.1 R 443 J.0/4.9	F, S 2 F F, S

KYLE LABORATORIES

Californic Testing Division

Prepared by _____ Date _____ Subject _____

QID No.	DESCRIPTION	EQUIPMENT NO.	LOCATION	TEST
133004	FC Valves/Fisher Flow Control (2.5")	CAC-FCV-2A -2B	R560 H.1/7.7 R558 H.5/6.6	F, S 2 F ₂ F, S 15
193001	Valve/Fisher Line from Heat Exch. 2.5" Globe Line	RHR-LCV-65A -65B	R481 7.9/K R475 L3/8.1	F, S 2 F ₂ F, S 15
236004	PC Valve/Fisher ECONTV PIC SONIC FLOW	RHR-PCV-51A -51B	R578 J/9.3 R575 H.8/9.3	F, S 2 F ₂ F, S 15
361103	Valve/BIF 18" HO BFLY	SGT-V-1A SGT-V-1B SGT-V-3A1 3A2 3B1 3B2 4A1 4A2 4B1 4B2 5A1 5A2 5B1 5B2	R583 H8/5.3 R583 J3/5.3 R576 H8/7.7 R576 J.0/7.7 R576 J3/6.8 R576 J3/7.4 R587 H8/7.1 R587 J.0/7.0 R585 J2/5.1 R585 J6/7.1 R587 H.6/7.0 R587 J/7.1 R587 J2/7 R585 J6/7	F, S 2 F ₂ 2 F ₂ 2.3 F, S
361104	Valve/BIF 30" BFLY	CEP-V-1A CEP-V-2A CSP-V-1 CSP-V-2	R558 J.4/5.4 R558 J.4/5.4 R508 H.5/7.6 R508 H.5/7.4	F, S 1 F ₂ F, S 2 F ₂ F, S 15 F, S

Prepared by _____ Date _____ Subject _____

QID No.	DESCRIPTION	EQUIPMENT NO.	LOCATION	TEST
361106	Valve / BIF 24" BFLY	CEP-V-3A -4A CSP-V-3 -4 -5 -6 -9	R495 H.5/5.4 R495 H.5/5.4 R481 H.6/7.6 R478 7.6/7.6 R475 H.7/8.3 R480 N.5/7.7 R490 H.9/5.1	F, S 4 F _L 1 S F, S
361110	Valve / BIF	SGT-V-2A -2B	R580 H.7/5.3 J3/5.3	F, S 2 F _L F, S 1 S

CYGNA
ATTACHMENT
 JOB NO. 82044
 FILE NO. 07.01.F
 SHEET NO. 7.1.28



Communications Report

Company:	CES	<input checked="" type="checkbox"/> Telecon	<input type="checkbox"/> Conference Report
Project:	WPPSS	Job No.	82046/CR-008
		Date:	6/11/82
Subject:	Qualification of Line Mounted Equip.		Time: a.m. Place: SDAO
Participants:	H. Reeser	of	CES, Richland
	W. Schlafer	of	CES, SDAO
		of	

Item	Comments	Req'd Action By
1.	The new work authorization had not yet been released. Use the Initial Analysis EQ-12-3000 number for the week-ending Friday 6/11/82.	
2.	Hal recommends that as a result of using our best engineering judgment in the qualification of line mounted equipment, it is more prudent to fail a few items first before presenting WPPSS with our concern for a more well defined position on line mounted equipment qualification. At that time, we can present a planned approach for additional analytical and/or in-situ testing to be conducted which will yield data needed for a more accurate definition of the dynamic input to line mounted equipment.	
3.	An examination of the preliminary horizontal OBE and SSE response spectra outside the containment building for a frequency of 8Hz, indicate that the g levels from Attachment 1 (of the Interim Dynamic Loads Criteria) to be used in the static analysis of line mounted equipment not affected by hydrodynamic loads, may already have a multiplicative factor incorporated in them. This factor may not yet still address the issue of a possible resonance condition of the line mounted equipment which would result in even higher g levels for use in analysis.	


CYGNA
ATTACHMENT
JOB NO. <u>82046</u>
FILE NO. <u>GT.DL.F</u>
SHEET NO. <u>7.1.29</u>



Communications Report

Company: CES	<input checked="" type="checkbox"/> Telecon	<input type="checkbox"/> Conference Report
Project: WPPSS Equipment Qualification	Job No. 82046/CR-005	Date: June 8, 1982
Subject: Response Spectra & WPPSS E.Q. Documents	Time: pm	Place: SDAO
Participants:	H. Reeser	of CES, Richland
	J. Forman	of Wyle (CES, Richland)
	W. Schlafer	of CES, SDAO

Item	Comments	Req'd Action By
1.	<p>Hal has asked Jim Forman to help Cygna obtain the following information from WPPSS or from similar data available within Wyle:</p> <ul style="list-style-type: none"> a) Separate SRV Response Spectra for use in fatigue stress analysis. b) Time histories used in deriving the SRV response spectra for use in determining the number of significant stress cycles and duration of an SRV loading. c) The number of SRV events. d) The number of significant stress cycles and duration of the hydrodynamic loads (AP/Chugging) associated with the LOCA event. 	
2.	<p>The large compilation of Response Spectra for OBE, SSE and combined hydrodynamic events recently received by the BAO, SDAO and the SFAO are to be considered preliminary. Hal will update and transmit an official copy of response spectra to be used for analysis/testing.</p>	
3.	<p>Hal is also sending the WPPSS</p> <ul style="list-style-type: none"> a) FSAR Section 3.10 and Appendices b) The 2/12/82 submittal to the NRC concerning Equipment qualification. 	





Communications Report

Company: CES	<input checked="" type="checkbox"/> Telecon	<input type="checkbox"/> Conference Report
Project: WPPSS Equipment Qualification	Job No. 82046/CR-004	Date: June 8, 1982
Subject: QID File Review	Time: am	Place: SDAO
Participants:	P. Guglielmino	of BAO
	W. Schlafer	of SDAO
		of

Item	Comments	Req'd Action By
1.	In the review of a QID file, if errors in other than seismic analysis are discovered which adversely affect the equipment's qualification, these too must be noted and corrected or justified.	
2.	If the error is such that the equipment can still be qualified, note the error and the fact it does not adversely affect qualification, but avoid the expense of altering that portion of the analysis.	
3.	Both Peter and myself feel that a better defensible position needs to be investigated for the loads used in the analysis of line mounted equipment.	

CYGNA
ATTACHMENT
 JOB NO. 82044
 FILE NO. OT.01.F
 SHEET NO. 7.1.31

Signed: W. Schlafer	Page 1	of 1
Distribution: Kammerzell, Read, Patel, Hsieh, Rajan, Abolhoda, Curry, Minichiello, Reeser		
PROJECT FILE		



Communications Report

Company: CES

Telecon

Conference Report

Project:

WPPSS Equipment Qualification

Job No. 82046/CR-003

Date: June 3, 1982

Subject:

Time: pm

Place:

Participants:


H. Reeser

of CES, Richland

W. Schlafer

of CES, San Diego

Item	Comments	Req'd Action By
1.	Hal questioned his immediate contact at WPPSS, Dennis Armstrong, about the number of SRV events and number of cycles. Their reply was "we don't know".	
2.	Hal has suggested that Cygna investigate these issues, formulate a position, and then get WPPSS concurrence. Since WPPSS has generated combined response spectra for seismic and SRV events, I suggested to Hal he obtain separate SRV response spectra and time histories from which they were derived. This will help in determining the length an SRV event and the number of significant cycles. The number of SRV events is more difficult to determine and possibly needs a more thorough understanding of the BWR's systems.	HGR
3.	Hal will be our contact in Richland to submit our Action Plan and cost estimates for approval.	



Signed:

W. Schlafer *WS*

Page

1

of

1

Distribution:

Kammerzell, Read, Patel, ~~Hsieh~~, Rajan, Abolhoda, Curry, Guglielmino,

1020 00

Minichiello, Reeser, PROJECT FILE
WS: ib



Communications Report

Company	CES	<input checked="" type="checkbox"/> Telecon	<input type="checkbox"/> Conference Report
Project	WNP-2 Equipment Qualification		Job No. 82044
Subject	Weld size at Valve Flange/Ear Interface		Date 4/28/83
			Time 2:00 p.m.
Participants	Don Searle	of	CES/RBO
	Rick Ricappito	of	BIF 401-885-1000
		of	

Item	Comments	Rec'd Action By
	<p>Requested and received information concerning the attachment of the rectangular shaped "ears" to the valve body flanges.</p> <p>Rick informed me that all of these items were affixed to the valve flange by means of welding.</p> <ul style="list-style-type: none"> a) 0.31" fillet weld three sides b) 0.31" "J"/Groove weld on side flush with flange face <p>Reference: BIF Order No: PN27234, PN27235 BIF Assembly Drawing: A-206767</p>	

CYGNA

ATTACHMENT

JOB NO. 82044

FILE NO. DT. 01.F

SHEET NO. 7.1-33

July 16, 1974

Conference Notes No. 258

RECEIVED
 RECEIVED
 JUL 23 1974
 JUN 17 1974
 CYGNA-RICHMOND

Subject: W.O. 2808
 Washington Public Power Supply System
 WPPSS Nuclear Project No. 2
 Contract No. 68
~~HVAC - Isolation Valves~~

Date: July 5, 1974

Place: B.I.F.
 Providence, Rhode Island

Purpose: ~~Review of B&R Comments on Seismic Calculations~~
 and General Review Meeting

Present: B.I.F.

- J.P. Cunningham - Product Engr-Butterfly Valves
- *T. Masse - Engr. Product Mgr. - Butterfly Valves
- *G.F. MacDonald - Director Nuclear Q.A.
- *T. Wolfe - Marketing Manager - Butterfly Valves

Burns and Roe

D. Sheikh
 J. V. Zalavadia

* Part Time

WPP NO. 2	K HALE	Robert 2								
	W VAUGHAN	3								
	OE TRAPP									

JJ Verderber
 J Hendrickson
 Fofatti
 HSechster
 J Rodsky
 J Roberts
 PPerry
 MHroncich
 DMurphy
 HReh
 CVesy (PT&O)
 RLuken
 RECamp
 JHagan
 HDoon
 RWoodward
 JBlas (2)
 HSybil
 JO'Donnell
 AWChamos
 MGoodman
 SFox
 JVZalavadia
 DSheikh
 BBedrosian
 RBaldwin
 EFerrari (6)
 MKahn
 pf
 db

Notes: 1. Documents to BIF

Burns and Roe Comments on Q.A. Manual-
 Burns and Roe letter BRBIF-68-74-011, dated
 March 19, 1974.

2. Seismic Calculations - B&R Comments

Burns and Roe pointed out the following items
 BIF agreed to revise their seismic calculations accordingly.

- a. Change the material ASTM A-176 & A-48, which are Cast Iron and not allowed per Contract Specification.
- b. Submit the proof that the valves will fail open or close as mentioned in the specification.
- c. Submit the calculations for the detail of seating torque value, used in design calculations
- d. Submit stress and fatigue analysis for the spring anchors in the cylinder.
- e. Consideration of relatively higher temperature when using ASTM materials.

pc
CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. 07.01.F
SHEET NO. 7.1.34

- f. ~~Submit proof that there would be no loss of function during and after the prescribed seismic disturbance as mentioned in paragraph 3.3 of the specification. The seismic calculations include stress analysis only. The analysis for strain/deformation is also required as a proof that there will be no loss of function.~~
- g. Submit analysis or proof that radiation will not adversely affect the yield point of the material.
- h. Submit analysis and design for 72" and 84" valves considering normal load with the combination of $\frac{1}{2}$ SSE stresses shall be maintained within the normal allowable working stress limit as mentioned in paragraph 3.3.1.1 of specification.

3. Mandatory Testing for Seismic Qualifications

~~Burns and Roe asked BIF to submit dynamic or shake table tests for motor, switches etc, as mentioned in 3.3.4 of the specification. BIF replied that they have already tested the same type of equipment for greater accelerations than Burns and Roe specified and that they will submit the test data for Burns and Roe review and approval.~~

4. Stardvne Model used in Seismic Calculations

~~BIF clarified satisfactorily Burns and Roe comments the Stardvne Model used for 84" and 72" valves.~~

CYGNA
ATTACHMEN
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.1</u>
SHEET NO. <u>7.1.35</u>

5. Closing Time

~~Burns and Roe asked for proof that the valves will open or close in specified time as mentioned in the specification. BIF replied that they cannot analytically prove this, but they will test prove at the time of leakage test in the presence of Burns and Roe inspector to meet the Contract Specification requirements.~~

6. Double Eccentricity of Cylinder

~~Burns and Roe pointed out that they should consider double eccentricity on the cylinder while designing trunnion pin, instead of the single eccentricity considered in 30" 24" valves. BIF agreed to look into the problem.~~

7. Natural Frequencies of 18", 24", and 30" Valves

Burns and Roe asked BIF to submit the natural fundamental frequency of 18", 24", and 30" valves. BIF replied that since this is beyond the scope of contract, they will inform Burns and Roe regarding additional cost for this work. Burns and Roe stated that after reviewing their quotation and after WPFSS's approval Burns and Roe will notify BIF if additional work is authorized. (BIF informed Mr. D. S. [unclear] on July 9, 1973 by telephone that the cost of

additional work will be \$300.00).

8. General-BIF Comments

BIF indicated as follows:

- a. If operation or accidental temperature is high, the rubber seal should be on valve disc, correctly specified by Burns and Roe, instead of valve body. Rubber seal if on valve body, is fixed by glue, which cannot resist high temperature. Rubber seal on valve disc is fixed in-between metal pieces.
- b. If water or any other fluid is supposed to flow in the pipe, the shaft in the valve should be vertical. The vertical shaft would mean C.G. of pressure due to fluid will be on the axis and hence much less driving force is required to operate the valves. But in case of air or steam it makes no difference.

9. Quality Assurance Manual

Burns and Roe stated that Burns and Roe comments on BIF Quality Assurance Manual was mailed to BIF on March 19, 1974 (BRBIF-68-74-011) and was classified "Not Approved". The response to these comments has not been received as of this date. BIF stated that the BIF Plant is on vacation for 2 weeks (July 1 thru July 12). Mr. MacDonald will start updating QA Manual on July 15 and he expects to complete by July 19, 1974. BIF will revise their Q.A. Manual and/or provide necessary supplements to the manual as per Burns and Roe comments. Burns and Roe comments were discussed. Mr. MacDonald will call Mr. Sheldon Paige of Burns and Roe on July 15, for the clarification of the following Burns and Roe comments:

- a. Corrective action
- b. Audit of Purchase Regs./P.O.'s/change orders
- c. Compliance to supplier Quality Control Program
- d. Compliance to Lower Tier Procurement
- e. Welding Process Sheet Form N-152 (BIF) and the forms of Contract Specification 17A-30 and 17A-31

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>07.01.F</u>
SHEET NO. <u>7.1.3L</u>

10. Inservice Inspection Requirements

Burns and Roe questioned regarding the requirements of "calibration blocks" in accordance with the draft of the 1974 Edition of ASME Section XI, Article I-3000 "Preparation for Calibration" for Inservice Inspection. BIF stated that the special calibration blocks are not required. They will submit detailed method of Inservice Inspection with Standard calibration blocks.

11. Item Owed to BIF by B&R

Decision on BIF quotation on calculations on natural frequencies of 18", 24" and 30" valves (Item No. 7).

12. Item Owed to B&R by BIE

- a. Submission of revised seismic calculations as per Item No.s 2, 3, and 6 above.
- b. Submission of revised Q:A. Manual (Item No. 9)
- c. Inservice Inspection Requirements (Item No. 10)

JJV/JVZ/dcw

Prepared by *Paul Smith*
J.V. Zalawadia

Submitted by *J. W. DeLoach*

cc: Mr. J. E. Woolsey - WPPSS -3
Mr. P. C. Otness - BPA -1

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OF.OI.F</u>
SHEET NO. <u>7.1.37</u>



QID# 361106

7.3 BIF Report

B I F A UNIT OF GENERAL SIGNAL
1600 DIVISION ROAD
WEST WARWICK, R.I. 02893

QUALIFICATION OF PRIMARY CONTAINMENT BUTTERFLY ISOLATION VALVES
UNDER LOCA CONDITION.

DYNAMIC TORQUE CALCULATION OF BUTTERFLY VALVE

PREPARED FOR:

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

VALVE SIZES 30", and 24"
WPPSS CONTRACT NO. 68
BIF ORDER NO.: PN27234 & PN27235
WPPSS IDENTIFICATION NO. CSP-V-1 & 2, and
CSP-V-3 & 4

Prepared by: Debendra K. Das *Debendra K. Das*
Date: Nov. 10, 1982
Checked by: Dezso Szilagyi *Dezso Szilagyi*
Date: Nov. 10, 1982

REPORT NO. TR-27234 And
TR-27235

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>A-1</u>

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1. Summary	1
2. Dynamic torque tables	2
3. References	6
4. Analytical Procedure and Flow Data	7
5. Analysis for 30 inch valve	
(I) a. Hand Computation of several test cases for air flow	25
b. Computer results and comparison with hand computation	28
(II) c. Hand computation of several test cases for steam flow	40
d. Computer results and comparison with hand computation	42
6. Analysis for 24 inch valve	
(III) e. Hand computation of several test cases for air flow	53
f. Computer results and comparison with hand computation	55
(IV) g. Hand computation of several test cases for steam flow	67
h. Computer results and comparison with hand computation	69
7. Appendix	80
a. WPPSS Calc.No. ME-02-83-08-0, Sheets 1 thru 9	
b. LOCA Temp. Curve	
c. LOCA Pressure Curve	
d. WPPSS Letter dated 10/22/82	
e. BIF Flow Loss Coefficient K_v plot	
f. BIF dynamic torque Coefficient C_T plot	

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>A-2</u>

SUMMARY

This report contains the dynamic torque analysis of two butterfly valves of sizes 30, and 24 inch. The analysis is performed for LOCA (loss of Coolant Accident) per WPPSS Specification, reference 1 on page six of this report. The analytical procedure and the assumptions are outlined in the section beginning on page seven. Dynamic torque calculations have been performed for two media, namely, air and saturated steam for various angles of opening of these valves.

The results of the analysis tabulated on page two through five of the report indicate that the dynamic torques developed under the specified flow conditions are less than the design torques used in the original Seismic and Stress analysis of these valves. Therefore the valves are safe against the action of dynamic torque in the event of a LOCA.

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>A-3</u>

SUMMARY OF RESULTS

Table - 1, 30 Inch Valve, airflow

Time s	Angle α deg.	Dynamic Torque in-lb
1.0	90 (Full open)	11020
1.5	78.75	23098
2.0	67.50	18138
2.5	56.25	14747
3.0	45.00	12428
3.5	33.75	10780
4.0	22.50	8014
4.5	11.25	3972
5.0	9.0 (Full closed)	0.0 *

T_{Net} = 22174 in-lb

* At full closed position the dynamic torque is zero and the net torque is due to seating and bearing friction.

NOTE: The design torque used in the Seismic analysis report No. TR-74-8 by McPherson Associates for this valve is 27800 in-lb. Therefore the design is safe.

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01-F</u>
SHEET NO. <u>A-4</u>

SUMMARY OF RESULTS

Table - 2, 30 Inch Valve Steam flow

Time s	Angle α deg.	Dynamic Torque in-lb
1.0	90 (Full open)	11032
1.5	78.75	23175
2.0	67.50	18142
2.5	56.25	14668
3.0	45.00	12424
3.5	33.75	10580
4.0	22.50	7809
4.5	11.25	3867
5.0	9.0 (Full closed)	0.0 *

T_{Net} = 22174 in-lb

* At full closed position the dynamic torque is zero and the net torque is due to seating and bearing friction.

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>A-5</u>

SUMMARY OF RESULTS

Table - 3, 24 Inch Valve; Air flow

Time s	Angle α deg.	Dynamic Torque in-lb
1.0	90 (Full open)	5525
1.5	78.75	11692
2.0	67.50	9095
2.5	56.25	7428
3.0	45.00	6239
3.5	33.75	5430
4.0	22.50	4043
4.5	11.25	2020
5.0	9.0 (Full closed)	0.0 *

T_{Net} = 13808 in-lb

* At full closed position the dynamic torque is zero and the net torque is due to seating and bearing friction.

Note: The design torque used in the Seismic analysis report No. TR-74-7 by McPherson Associate for this valve is 17000 in-lb. Therefore the design is safe.

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>A-6</u>

SUMMARY OF RESULTS

Table - 4, 24 Inch Valve, Steam flow

Time s	Angle α deg.	Dynamic Torque in-lb
1.0	90 (Full open)	5425
1.5	78.75	11394
2.0	67.50	8921
2.5	56.25	7213
3.0	45.00	6109
3.5	33.75	5202
4.0	22.50	3842
4.5	11.25	1902
5.0	9.0 (Full closed)	0.0 *

T_{Net} = 13808 in-lb

* At full closed position the dynamic torque is zero and the net torque is due to seating and bearing friction.

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01-F</u>
SHEET NO. <u>A-7</u>

REFERENCES


1. WPPSS Specification 2808-68, Calc. No. ME-02-83-08-0, Sheets 1 thru 9, dated 10/8/82.
 LOCA Temperature Curve Fig. 6.2-2.
 LOCA Pressure Curve Fig. 6.2-3.
2. ANSI/AWWA C504-80, AWWA Standard for Rubber-Seated Butterfly Valves. American Water Works Association, Colo.
3. Beard, C., Final Control Elements, Valves and Actuators, First Edition, Rimbach Publications, 1969.
4. Hutchison, J. W., ISA Handbook of Control Valves, 2nd Edition.
5. Torque and Sizing Calculation for BIF Butterfly Valves, No. D-214590, dated 1/9/75 for WPPSS Contract #68.
6. B I F Test Report for Dynamic Torque and Head Loss Tests of Cast Iron Streamline Disc versus Fabricated Flat Plate Disc dated May 13, 1974.
7. B I F Test Report #TR-0650-43, Hydrodynamic and Headloss Test of 12" - 150 Lb. Butterfly Valve with directly connected short radius elbow upstream, dated 2/24/82.
8. B I F Drawings: 30 inch Valve General Arrangement Drawing A-206763
 24 inch Valve General Arrangement Drawing A-206764

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>A-8</u>



QID# 361106

7.4 McPherson Associates Analysis



23.2401.0127

BIF A UNIT OF GENERAL SIGNAL
1600 DIVISION ROAD
WEST WARWICK, R.I. 02893

DESIGN AND SEISMIC ANALYSIS
OF
24" CYLINDER OPERATED BUTTERFLY VALVE
FOR
WASHINGTON PUBLIC POWER SUPPLY SYSTEM
AND
BURNS AND ROE

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.OLE</u>
SHEET NO. <u>B-1</u>

CUSTOMER P.O. CONTRACT 68

BIF SHOP ORDER NO'S PN27235-U-0708
PN27236-U-0808

BIF SERIAL NO'S PN27235-1 thru 4
PN27236-1 thru 3

REPORT NO. TR-74-7
PREPARED BY MCPHERSON ASSOCIATES, INC.

APPROVED BY: [Signature]

REAPPROVED: [Signature]

3/7/74

1/5/76 (REV 1)

DR FILE
NUMBER

68 00 0050

DESIGN AND
SEISMIC ANALYSIS
OF
24" CYLINDER OPERATED
BUTTERFLY VALVE
A-206765

22 February 1974

Prepared For:

BIF
A Unit of General Signal Corporation

Prepared By:

Thomas M. Riley
John R. Henry

BIF
A Unit of General Signal Corporation
Purchase Order No. 84908-63

McPherson Associates, Inc.
Report No. TR-74-7 - REV. 1 12/31/75

McPherson Associates, Inc.
400 Totten Pond Road
Waltham, Massachusetts 02154

CYGNA	
ATTACHMENT	
JOB NO.	R2044
FILE NO.	OT.01.F
SHEET NO.	B-2



400 TOTTEN POND ROAD • WALTHAM, MASSACHUSETTS 02154

DESIGN AND
SEISMIC ANALYSIS
OF
24" CYLINDER OPERATED
BUTTERFLY VALVE
A-206765

BIF
A Unit of General Signal Corporation:
Purchase Order No. 84908-63

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>B-3</u>

McPherson Associates, Inc.
Report No. TR-74-7 - REV. 1 12/31/75

FOR 24" VALVES

BIF Contract No.

68

BIF S.O. No.

N 27235-F
N 27236-F

Valve Tag No's

CSP-V-3
CSP-V-4
CEP-V-3A
CEP-V-4A
CSP-V-5
CSP-V-6

REVISION RECORD

NUS REPORT TR-74-7

REVISION 1

12/31/75

- Page 3 a) Mat'l was ASTM A-126 & A-48
 b) Allowable Stress Value corrected
- Page 5 a) Drive Lever was B-184005-6
 b) Clevis was D-146578
- Page 9 a) Mat'l was ASTM A-126, Class C
 b) Corrected yield stress allowable
 c) Deleted ASTM A-48
- Page 32 a) Ref. drawings were B-184005-6 & D-14578
- Pages 33, 35, 36 & 37
 a) Mat'l was ASTM A-126
 b) Corrected Stress Allowable

CYGNA

ATTACHMENT

JOB NO. 82044

FILE NO. OT.01.F

SHEET NO. B-4

NUCLEAR

Section 1.0
INTRODUCTION

The purpose of this report is to determine the structural adequacy of a 24" Butterfly Valve Assembly when subjected to seismic accelerations as described in Reference 1 and to insure the valve design is in accordance with Reference of this report.

The seismic plus operating analysis is performed in accordance with Washington Public Power Supply System Specification No. 2808-68, Reference 1, and all applicable information as described in Section 4.0 of this report.

CYGNA
ATTACHMENT
JOB NO. <u>R2044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>B-7</u>

NUCLEAR

Section 2.0
SUMMARY OF RESULTS

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>07.01.F</u>
SHEET NO. <u>B-8</u>

NUCLEAR

BY: JAE DATE: 2-21-74

SUBJECT: 24" S.F.V.

SHEET NO. 2.01 OF

CHKD. BY: JH DATE: 2-27-74

- SUMMARY -

JOB NO. _____

COMPONENT	PAGE	STRESS COMPARISON (PSI) & MATERIAL
TRUNNION PINS	19	$T = 1919 < .6 S_y = 11100$ (SA-276, 304)
CYL. OPERATOR DRIVE ROD	22	$T = 52113 < S_y = 90000$ (AISI-4140)
CYL. SUPPORT BRACKET	28	$T = 1319 < S_y = 36000$ (ASTM A-36)
CLEVIS	33	$T = 1233 < .6 S_y = 36000$ (ASTM A-395) ①
CLEVIS PIN	33	$T = 1136 < .6 S_y = 9900$ (SA-276, 304)
DRIVE LEVER	37	$T = 40449 < S_y = 45000$ (ASTM A-395)
VALVE BODY "EARS"	42	$T = 18761 < S_y = 22000$ (SIS 4140)
HARDWARE	45	$T = 12927 < S_y = 23333$ (SA-516)
SHAFT	50	$S.I. = 18387 < 1.8 S_m = 27150$ (SA-479)
DISC	51	$S.I. = 3871 < S_m = 15000$ (SA-516, G20)
TAPER PINS	53	$T = 10753 < .8 S_m = 12000$ (SA-276)
VALVE BODY	65	$S.I. = 17330 < 1.2 S_m = 19000$ (SA-516, G20)
GLAND FOLLOWER	67	THICKNESS CHECK ONLY
THRUST BEARING COVER	69	THICKNESS CHECK ONLY

CYGNA
ATTACHMENT
 JOB NO. R2044
 FILE NO. OT.01.F
 SHEET NO. B-9

NOT CLEAR

THE TERM "S.I." REFERS TO STRESS INTENSITY

1) N. H. C.
 A. S. S.
 T. S. S.

Section 3.0

CONCLUSIONS

McPherson Associates, Inc. concludes that all components for the 24" Butterfly Valve, as analyzed in this report, meet the requirements of all governing specifications for seismic and operating considerations as defined in References 1, and 3 of this report.

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>B-10</u>

NUCLEAR

TABLE OF CONTENTS

<u>Section No.</u>		<u>Page</u>
i	Table of Contents	i
ii	Certification	ii
1.0	Introduction	1
2.0	Summary of Results	2
3.0	Conclusions	4
4.0	References	5
5.0	Design Data	7
6.0	Analysis	10
6.1.	Cylinder Operator Assembly	14
6.2	Cylinder Support Bracket	23
6.3	Clevis Assembly and Drive Lever	31
6.4	Valve Body Support "Ears" and Associated Hardware	38
6.5	Shaft and Disc Assembly and Associated Hardware	46
6.6	Valve Sizing and Stress Analysis Considering Combined Operating and Seismic Conditions	55

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>B-5</u>

NUCLEAR

Certification

McPherson Associates, Inc. certifies that the 24" Butterfly Valve, A-206765, as shown on the customer drawings was analyzed in accordance with Washington Public Power Supply System Specification No. 2808-68 and to the best of our knowledge and belief, meets the requirements of Paragraphs 3.2, 3.3, and 3.5.2.4 of this document and Reference 3 of Section 4.0 of this report.

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.OI.F</u>
SHEET NO. <u>B-6</u>

John R. Henry
John R. Henry
Registered Professional Engineer
Mass. Registration No. 25929

NUCLEAR

Section 4.0

REFERENCES

1. Washington Public Power Supply System Specification No. 2808-68.
2. BIF Drawings

<u>Drawing No.</u>	<u>Revision</u>	<u>Description</u>
A-206765	B	24" Butterfly Valve-General Arrangements
A-900523	-	Body, Fabricated
A-900524	-	Body, Machining
A-900339	-	Disc, Fabricated
A-900340	-	Disc, Machined
A-208293	-	Cylinder Support Bracket
B-900521, B-900522	-	Operator Shafts
B-211830	-	Drive Lever
D-211837-1	-	Clevis
D-206661	-	Miller Cylinder

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>OT.01.F</u>
SHEET NO. <u>B-11</u>

3. Section III, Nuclear Power Plant Components, ASME Boiler and Pressure Vessel Code, 1971 with Addenda.
4. Virgil Moring Faires, Design of Machine Elements, 4th Edition, The MacMillan Co., N.Y., 1965.
5. Raymond J. Roark, Formulas for Stress and Strain, 4th Edition, McGraw Hill Book Co., 1965.
6. Laddish Catalog No. 55.
7. Grinnel, Piping and Engineering, 3rd Edition, 1971.
8. 1963 Supplement to Screw Thread Standards for Federal Services;
9. Baumeister & Marks, Standard Handbook for Mechanical Engineers, 7th Edition, McGraw Hill Book Company.

ent, Mechanical Engineers Handbook.

U.S.T.M. Standards - Part 2.

U.S.M. Metals Handbook.

Timoshenko and Goodier, Theory of Elasticity, 3rd Edition,
McGraw Hill Book Co., 1970.

Timothy and Smith, Advanced Mechanics of Materials,
2nd Edition, John Wiley & Son, Inc., 1966.

Machinery's Handbook, 17th Edition, The Industrial Press,
1964.

Section VIII, Pressure Vessels, Division 2 - Alternative
Codes, A.S.M.E. Boiler and Pressure Vessel Code, 1971.

McGraw Hill Publishing Co., Standard Mathematics
Tables, Twelfth Edition.

American National Standards Institute - Document B16.5
entitled "Steel Pipe Flanges and Flanged Fittings."

CYGNA

ATTACHMENT

JOB NO. 82044

FILE NO. OT.01.F

SHEET NO. B-12



Final Qualification Report

PROJECT: Equipment Seismic and Hydrodynamic Requalification
JOB NO: 82044
CALC NO: OS.01.F

CLIENT: Washington Public Power Supply System
QID NO: 361104




TITLE: Equipment Seismic and Hydrodynamic Requalification of
30" Cylinder Operated Butterfly Valves:
CSP-V-1 and 2
CEP-V-1A and 2A

PREPARED BY:	M.A. Scott <i>M.A. Scott</i>	6/15/83
		DATE
REVIEWED BY:	L.C. Fernandez <i>L.C. Fernandez</i>	6/15/83
		DATE
APPROVED BY:	F. Khanachet <i>F. Khanachet</i>	6/15/83
		DATE

SUPPLY SYSTEM: *RW Hickman* 6/15/83

REVISION: 1

REVISION STATUS LOG

Rev. No.	Date	Prepared by / Reviewed by	Approved by Cygna Energy Services	Approved by WPPSS	Description
0	2/16/83	R. Hsieh H. Abolhoda J. Rakowski L. Fernandez			Original Issue
1	6/15/83	M. Scott L. Fernandez			Revised to incorporate addition of shear plates

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

REQUALIFICATION CERTIFICATE

WNP- 2

QID 361104

COMPONENT NO: CSP-V-1, CSP-V-2, CEP-V-1A, and CEP-V-2A

COMPONENT DESCRIPTION: 30" Cylinder Operated Butterfly Valves

MANUFACTURER: BIF MODEL NO: A-206763

EQUIPMENT CLASSIFICATION: ACTIVE PASSIVE

SEISMIC QUALIFICATION REPORT REFERENCE:

Cygn Energy Services, "Equipment Seismic and Hydrodynamic Requalifica-
tion of 30" Cylinder Operated Butterfly Valves," File No. OS.01.F,
QID No. 361104, Revision 1, June, 1983.

~~REQUALIFICATION ACTION PLAN~~

REQUIRED ACTION: 1) Replace A-307 Ear Bolts with A-325 bolts.
2) Addition of shear plates, see sheets 4.3.30
to 4.3.48 for additional details.

THE ABOVE SEISMIC ~~QUALIFICATION~~ QUALIFICATION REPORTS HAVE BEEN REEVALUATED IN ACCORDANCE WITH THE CURRENT NRC SEISMIC ~~CRITERIA~~ CRITERIA:

- 1. IEEE STANDARDS 344 (1975)
- 2. USNRC REGULATORY GUIDES 1.92, 1.100
- 3. STANDARD REVIEW PLANS 3.9.2, 3.10, ~~4.3~~
- 4. NUREG-0588

This equipment is qualified as a assembly when the air cylinders are completely qualified addressed in QID #018001.

THE ABOVE COMPONENT HAS BEEN FOUND ACCEPTABLE FOR PERFORMING ITS INTENDED SAFETY RELATED FUNCTION WHEN SUBJECTED TO THE PLANT SPECIFIC VIBRATORY ~~LOADS~~ LOADS.

PREPARED BY	J.E. Rakowski <u>1</u> <i>md</i> 6/14/83	DATE	3/25/83
REVIEWED BY	<i>J. J. ...</i> 6/15/83	DATE	5/10/83
APPROVED BY	<i>RW Heckman</i> 6/15/83	DATE	



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

Qualification Summary of Equipment

QID# 361104

Ref. No.

- I. PLANT NAME: WNP-2 TYPE
- PHR _____
1. NSSS: GE 2. A/E: Burns & Roe BWR 5, Mark II
- II. COMPONENT NAME: 30" Cylinder Operated Butterfly V. COMPONENT NO. CSP-V-1 & 2
CEP-V-1A & 2A
1. SCOPE: NSSS BOP
2. MODEL NUMBER: A-206763 QUANTITY: 2
3. VENDOR: BIF
4. IF THE COMPONENT IS A CABINET OR PANEL, NAME AND MODEL NO. OF THE DEVICES INCLUDED:
N/A
5. PHYSICAL DESCRIPTION: a. APPEARANCE: Butterfly Valve with 10" Cyl Operator
b. DIMENSIONS: 30" Nominal Diameters
c. WEIGHT: 1208 - Valve Assy; 914 - Operator & Bracket
6. LOCATION: BUILDING: Reactor
ELEVATION: 508' (CSP) and 588' (CEP)
7. FIELD MOUNTING CONDITIONS: BOLT (NO. _____ SIZE _____)
 WELD (LENGTH _____)

8. a. SYSTEM IN WHICH LOCATED: Containment Supply Purge Systems (CSP)
Containment Exhaust Purge Systems (CEP)
b. FUNCTIONAL DESCRIPTION: Primary Containment isolation, prevention of
of the release of radioactive material to the environment.
c. IS THE EQUIPMENT REQUIRED FOR: HOT STANDBY COLD SHUTDOWN
 BOTH NEITHER
9. PERTINENT REFERENCE DESIGN SPECIFICATION: WPPSS Spec. 2808-68
- III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT: YES NO

Qualification Summary of Equipment (Continued)

QID# 361104

Ref. No.

IV. EQUIPMENT QUALIFICATION METHOD:

TEST ANALYSIS COMBINATION OF TEST & ANALYSIS

QUALIFICATION REPORT: Equipment Seismic and Hydrodynamic Requalification of 30" Cylinder Operated Butterfly Valve*

(NO., TITLE & DATE): File No. OS.01.F, June, 1983

COMPANY THAT PREPARED REPORT: Cygn Energy Services

COMPANY THAT REVIEWED REPORT: Washington Public Power Supply Systems

*Plus original valve analysis

1

V. VIBRATION INPUT:

1. LOADS CONSIDERED: a. SEISMIC ONLY
 b. HYDRODYNAMIC ONLY
 c. COMBINATION OF (a) AND (b)

2. METHOD OF COMBINING RRS: ABSOLUTE SUM SRSS OTHER (SPECIFY) _____

3. REQUIRED RESPONSE SPECTRA (ATTACH THE GRAPHS): Section 5.1 of QID 361104

4. DAMPING CORRESPONDING TO RSS: OBE _____ SSE 3%

5. REQUIRED ACCELERATION IN EACH DIRECTION: ZPA OTHER (SPECIFY) Section 5.5

OBE S/S = Attached F/B = _____ V = _____

SSE S/S = Attached F/B = _____ V = _____

6. WERE FATIGUE EFFECTS OR OTHER VIBRATION LOADS CONSIDERED?

YES NO

IF YES, DESCRIBE LOADS CONSIDERED AND HOW THEY WERE TREATED IN OVERALL QUALIFICATION PROGRAM:

The calculated stress ranges were compared to the
AISC allowables, as the structures analyzed were not
part of the pressure boundary.

*NOTE: IF MORE THAN ONE REPORT, COMPLETE ITEMS IV THROUGH VII FOR EACH REPORT

Qualification Summary of Equipment (Continued)

QID# 361104

Ref. No.

VI. IF QUALIFICATION BY TEST, THEN COMPLETE*: N/A

1. SINGLE FREQUENCY MULTI-FREQUENCY RANDOM

2. SINGLE AXIS MULTI-AXIS SINE BEAT _____

3. NO. OF QUALIFICATION TESTS: OBE _____ SSE _____ OTHER (SPECIFY) _____

4. FREQUENCY RANGE: _____

5. NATURAL FREQUENCIES IN EACH DIRECTION (SIDE/SIDE, FRONT/BACK, VERTICAL):

S/S = _____ F/B = _____ V = _____

6. METHOD OF DETERMINING NATURAL FREQUENCIES:

LAB TEST IN SITU TEST ANALYSIS

7. TRS ENVELOPING RRS USING MULTI-FREQUENCY TEST: YES (ATTACH TRS & RRS GRAPHS) NO

8. INPUT g-LEVEL TEST: OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. LABORATORY MOUNTING:

BOLT (NO. _____, SIZE _____) WELD (LENGTH _____) _____

10. FUNCTIONAL OPERABILITY VERIFIED: YES NO NOT APPLICABLE

11. TEST RESULTS INCLUDING MODIFICATIONS MADE:

12. OTHER TEST PERFORMED (SUCH AS AGING OR FRAGILITY TEST, INCLUDING RESULTS):

*NOTE: IF QUALIFICATION BY A COMBINATION OF TEST AND ANALYSIS, ALSO COMPLETE ITEM VII.

Qualification Summary of Equipment (Continued)

QID# 361104

Ref. No.

VII. IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. METHOD OF ANALYSIS:

- STATIC ANALYSIS EQUIVALENT STATIC ANALYSIS
 DYNAMIC ANALYSIS TIME-HISTORY RESPONSE SPECTRUM

2. NATURAL FREQUENCIES IN EACH DIRECTION (SIDE/SIDE, FRONT/BACK, VERTICAL):

S/S = 13.0 Hz F/B = 11.45 Hz V = >100 Hz

3. MODEL TYPE:

- 3D 2D 1D FINITE ELEMENT BEAM CLOSED FORM SOLUTION

4. COMPUTER CODES: _____

FREQUENCY RANGE AND NO. OF MODES CONSIDERED: _____

- HAND CALCULATIONS

5. METHOD OF COMBINING DYNAMIC RESPONSES: ABSOLUTE SUM SRSS OTHER (SPECIFY) _____

6. DAMPING: OBE _____ SSE _____ BASIS FOR THE DAMPING USED: N/A*

7. SUPPORT CONSIDERATIONS IN THE MODEL: pipe-mounted

8. CRITICAL STRUCTURAL ELEMENTS:

A. IDENTIFICATION	LOCATION	GOVERNING LOAD	SEISMIC STRESS	TOTAL STRESS	STRESS ALLOWABLE
		OR RESPONSE COMBINATION			
Operator Drive Rod	Cylinder on CSP-V-1	Fatigue Stress		86,826	90,000
		Stress Range		57,526	90,000
Ear Weld	Support Ear CSP-V-1	Fatigue Stress		26,554	28,000
		Stress Range			
B. MAX. CRITICAL DEFLECTION		LOCATION	MAXIMUM ALLOWABLE DEFLECTION TO ASSURE FUNCTIONAL OPERABILITY		
< 0.01"		Valve disk radial deflection	approx 1/8" radial clearance		

NOTE: Calculations based on accelerations for CSP-V-1 and 2 will provide an envelope for CEP-V-1A and 2A. See Table 1.1 of Section 4.3 for relative required accelerations for CSP and CEP valve operators.

*Based on calculation using Revised Burns and Roe Piping Analysis Accelerations, April, 1983.

Qualification Summary of Equipment (Continued)

QID# 361104

VIII. REFERENCES

1) BIF Drawings

	Drawing #	Rev#	Description
a	A-206763	F	General Arrangement
b	CEP-625-10		From Reactor Nozzle X-3 to SGT-FU-1A, 1B
c	CEP-625-11.12	H.	From Reactor Nozzle X-3 to SGT-FU-1A, 1B
d	C-26095		Model A-83B Cylinder
e	A-206767		Valve Assembly
f	DOC-D-220-0310-IR-66	O	Tube erection iso-metric
g	D-207110	F	Valve Data Sheet
h	M-144		General Arrangement plan mis level
k	CSP-807-3.4		Containment purge air supply system

References continued on page 2.6

Completed By

JERAKOWSKI

m/p

 Δ m/p 6/2/83

Date

3/25/83

Reviewed By

H. E. ...

L. ...

Date

5/16/83

THIS PAGE NOT USED.




Calculation Sheet

Project	WPPSS Mechanical Equipment Qualification	Prepared By	J.E. Rakowski	Date	3/25/83
Subject	30" Butterfly Valves	Checked By	L.C. Fernandez	Date	4/29/83
System	CSP and CEP	Job No.	82044	File No.	OS.01/F
Analysis No.	361104	Rev. No.	1	Sheet No.	2.6

Reference cont'n

- 2) Formulas for Natural Frequency and Mode Shapes,
Robert D. Blevins
Van Nostrand Reinhold Company
1979 Edition
- 3) BIF Report TR-27234 and TR-27235, "Dynamic Torque
Calculation of Butterfly Valve; Sizes 24 and 30 inch",
dated November 10, 1982.
- 4) Report TR-74-8 by McPherson Assoc., Inc., "Design &
Seismic Analysis 30" Cylinder operated Butterfly Valve".
(Rev. 1) 12/31/75.
- 5) WPPSS letter to Cygna Energy Services, GE-02-RWH-018,
12/17/82.
- 6) WPPSS, WNP-2 SRM Equipment List Summary Sheets dated
2/10/83.
- 7) Cygna Energy Services, Equipment Qualification Walkdown
Verification Form dated 7/14/82 and 7/19/82.
- 8) Cygna Energy Services, "Project Manual Design Criteria,"
DC-1, Rev. 1, 10/82.
- 9) Burns & Roe Revised Piping Analysis Loads
for CSP-V-1 and 2 (received 4/13/83) and CEP-V-1A and
1B (dated 11/15/82).
- 10) Communications Report, R. Ricappito of BIF and J. Rakowski
of CES, "BIF Valve Dimensions", 2/11/83
- 11) Cygna Energy Services, "Equipment Seismic and Hydrodynamic
Requalification Calculation No. OS.01.F", QID No. 361104,
Revision 1, May, 1983.





Calculation Sheet

Project: WPPSS, WNP-2 Seismic/Hydrodynamic Mechanical Equipment Requalification		Prepared By: L.C. Fernandez	Date: 4/29/83
Subject: 30" Butterfly Valves		Checked By: <i>[Signature]</i>	Date: 4/25/83
System: CEP and CSP		Job No: 82044	File No: OS.01.F
Analysis No: 361104	Re. No: 1	Sheet No: 2.7	

UPSET CONDITION G-LEVELS

EPN	N	V	E
CSP- V -1	0.76	1.36	0.88
CSP- V -2	0.66	1.33	0.79

FAULTED CONDITION G-LEVELS (REQUIRED) 6 AND 10 INCH AIR CYLINDER OPERATORS

EPN	HYDR LDS	ELEV 'R'	N	G'S V	E
CSP-V -1	Y	508.00	2.26	3.62	2.80
CSP- V -2	Y	508.00	1.44	3.54	1.90
CEP- V -1A	Y	588.00	1.93	2.23	1.85
CEP- V -2A	Y	588.00	0.96	2.11	1.16

From Revised Burns and Roe Piping Accelerations, see Section 5.5.





TABLE OF CONTENTS

QID# 361104

<u>SECTION</u>	<u>TITLE</u>	<u>NO OF PAGES</u>
1.0	Requalification Certificate	1
2.0	SQRT Forms	7
3.0	Table of Contents	2
4.0	Requalification Analysis	-
4.1	Conclusions	1
4.2	Summary of Results	5
4.3	Analysis	82
Pg. 4.3.1	Introduction	-
Pg. 4.3.8	Calculations	-
Pg. 4.3.53	References	-
5.0	Appendices	-
5.1	Response Spectra	4
5.2	Walkdown Sheets	6
5.3	Valve Local Coordinate Systems	1
5.4	SRM Sheets	4
5.5	Revised Burns & Roe Piping Analysis Accelerations	6
6.0	Drawings	8



TABLE OF CONTENTS

QID# 361104

CON'T

<u>SECTION</u>	<u>TITLE</u>	<u>NO OF PAGES</u>
7.0	Transmittals, Prior Calculations and Reports	-
7.1	Communication Reports	6
7.2	Original Requalification and SQRT Forms	7
7.3	BIF Report *	9
7.4	McPherson Associates Analysis *	78

*Note: Excerpts from report included in specified section. For complete report see Cygna Energy Services File No. OS.01.F, QID 361104, "Equipment Seismic and Hydrodynamic Requalification of 30" Cylinder Operated Butterfly Valves," Revision 1, June, 1983.

Revision 1



Calculation Cover Sheet

Project	Equipment Seismic and Hydrodynamic Requalification	Job No.	82044
		File No.	0S.01.F
Client	Washington Public Power Supply System	Calc. Set No.	1
		No. of Sheets	83
Subject	BIF 30" Cylinder Operated Butterfly Valves, QID# 361104 EPNS: CSP-V-1, 2 CEP-V-1A, 2A		

Statement of Problem

Seismic and Hydrodynamic Requalification of CSP-V-1, CSP-V-2, CEP-V-1A, CEP-V-2A to Burns and Roe Piping Analysis Loads.


Sources of Data

See References pages 4.3.53 and 54.

Sources of Formulae & References

See References pages 4.3.53 and 54.

Remarks The equipment requalification was performed based on calculations using Revised Burns and Roe Piping Analysis Accelerations, April, 1983. (See Section 5.5)

Originators	Checkers	Distribution	Revision No.
JE Rakowski	LC Fernandez	Supply System-2 Project File-1	1
H. Abolhoda	MA Scott		Supersedes Calculation Set No.
R. Hsieh	DE Searle		Revision 0, 7/23/82
			Approved By:  Date: 6/15/83



Calculation Sheet

Project	Prepared By	Date
Subject	Checked By	Date
System	Job No.	File No.
Analysis No.	Rev No.	Sheet No

CONTENTS

	Calculation Cover Sheet
4.1	Conclusions
4.2	Summary of Results
4.3	Analysis
4.3.1	Introduction
4.3.2	Calculations
4.4	References




Calculation Sheet

Project	Prepared By:	Date
Subject	Checked By:	Date
System	Job No.	File No.
Analysis No	Rev. No.	Sheet No

SECTION 4.1

CONCLUSIONS



FINAL
QUALIFICATION
REPORT

PROJECT: Equipment Seismic & Hydrodynamic Requalification

JOB NO.: 82044

CALC. NO.: 1P.01/F

CLIENT: Washington Public Power Supply System

QID NO.: 018001

TITLE: Equipment Seismic & Hydrodynamic Requalification

8", 10" and 12" Bore Air Cylinder Operator

EPN # CEP-A0-1A, 2A

REA-A0-1, 2

CEP-A0-3A, 4A

ROA-A0-1, 2

CSP-A0-1, 2

CSP-A0-3, 4, 5, 6, 9

PREPARED BY:

D. Kimer / J. E. Rakowski

12/3/82 / 2/19/83

REVIEWED BY:

Ronald P. Canessa / [Signature]

12-3-82 4/25/83

APPROVED BY:

[Signature]

12-8-82 5/20/83

SUPPLY SYSTEM RW Hickman

5/24/83

REVISION:

0

REVISION STATUS LOG

Rev. No.	Date	Prepared by	Reviewed by	Approved by Cygna Energy Services	Approved by WPPSS	Description
0	12/8/82	L.K. AER	RPC	JMF to P. Guglielmino		

1.0 REQUALIFICATION CERTIFICATION

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

REQUALIFICATION CERTIFICATE

WNP- 2

QID 018001

COMPONENT NO: CSP-AO-344

COMPONENT DESCRIPTION: 8" Bore Air Cylinder Operators

MANUFACTURER: Miller Fluid Power Corp. MODEL NO: A83

EQUIPMENT CLASSIFICATION: ACTIVE PASSIVE

SEISMIC QUALIFICATION REPORT REFERENCE:

Cygn Report 1P.01/F, QID 018001

WPPSS Seismic Qualification of 8" and 10" Bore Miller Air Operator.

ENVIRONMENTAL QUALIFICATION REPORT REFERENCE:

Remarks 1: Parts of the air operators such as the drive rod, trunnion pins, brackets and clevis were evaluated as part of the respective valve QID packages.

Remarks 2: These operators do not qualify until the operability demonstration described in Section 4.3.2 has been performed.

THE ABOVE SEISMIC AND ENVIRONMENTAL QUALIFICATION REPORTS HAVE BEEN REEVALUATED IN ACCORDANCE WITH THE CURRENT NRC SEISMIC AND ENVIRONMENTAL CRITERIA:

1. IEEE STANDARDS 344 (1975)
2. USNRC REGULATORY GUIDES 1.92, 1.100
3. STANDARD REVIEW PLANS 3.9.2, 3.10, 3.11
4. ~~XXXXXXXXXX~~

This certificate applies only to the operator which was evaluated as part of the valve assembly. Following completion of the valve requalification (QID 361106), the certification will be revised to address the entire assembly.

THE ABOVE COMPONENT HAS BEEN FOUND ACCEPTABLE FOR PERFORMING ITS INTENDED SAFETY RELATED FUNCTION WHEN SUBJECTED TO THE PLANT SPECIFIC VIBRATORY LOADS, subject to the above remarks.

PREPARED BY	<u>J. E. RAKOWSKI (SIGNED IN ABSENCE BY MCE)</u>	DATE	<u>4/27/83</u>
REVIEWED BY	<u>[Signature]</u>	DATE	<u>4/27/83</u>
APPROVED BY	<u>[Signature]</u>	DATE	<u>5/25/83</u>

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

REQUALIFICATION CERTIFICATE

WNP- 2

QID 018001

COMPONENT NO: CSP-AO-1 $\frac{1}{2}$ COMPONENT DESCRIPTION: 10" Bore Air Cylinder OperatorsMANUFACTURER: Miller Fluid Power Corp. MODEL NO: A83EQUIPMENT CLASSIFICATION: ACTIVE PASSIVE

SEISMIC QUALIFICATION REPORT REFERENCE:

Cygn Energy Services Report 1P.01/F, QID 018001WPSS Seismic Qualification of 8" and 10" Bore Miller
Air Operator.

ENVIRONMENTAL QUALIFICATION REPORT REFERENCE:

Remarks 1: Parts of the air operators such as the drive rod, trunnion
pins, brackets and clevis were evaluated as part of the
respective valve QID packages.Remarks 2: CSP-AO-1,2 are not qualified until the operability demon-
stration described in Section 4.3.2 has been performed.

THE ABOVE SEISMIC AND ~~ENVIRONMENTAL~~ QUALIFICATION REPORTS HAVE BEEN REEVALUATED IN ACCORDANCE WITH
THE CURRENT NRC SEISMIC AND ~~ENVIRONMENTAL~~ CRITERIA:

1. IEEE STANDARDS 344 (1975)
2. USNRC REGULATORY GUIDES 1.92, 1.100
3. STANDARD REVIEW PLANS 3.9.2, 3.10, 3.11
4. NUREG-0455

This certificate applies only to the operator which was evaluated as part of the valve assembly. Following completion of the valve requalification (QID 361104), the certification will be revised to address the entire assembly.

THE ABOVE COMPONENT HAS BEEN FOUND ACCEPTABLE FOR PERFORMING ITS INTENDED SAFETY RELATED FUNCTION WHEN SUBJECTED TO THE PLANT SPECIFIC VIBRATORY, ... LOADS, subject to the above remarks.

PREPARED BY <u>J. E. RAKOWSKI (SIGNED IN ABSENCE BY MJC)</u>	DATE <u>4/27/93</u>
REVIEWED BY <u>[Signature]</u>	DATE <u>4/27/93</u>
APPROVED BY <u>[Signature]</u>	DATE <u>5/13/93</u>

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

REQUALIFICATION CERTIFICATE

WNP- 2

QID 018001

COMPONENT NO: CSP-AO-5,6&9

COMPONENT DESCRIPTION: 8" Bore Air Cylinder Operators

MANUFACTURER: Miller Fluid Power Corp. MODEL NO: A83

EQUIPMENT CLASSIFICATION: ACTIVE PASSIVE

SEISMIC QUALIFICATION REPORT REFERENCE:

Cygn Report 1P.01/F, QID 018001

WPPSS Seismic Qualification of 8" and 10" Bore Miller
Air Operator.

ENVIRONMENTAL QUALIFICATION REPORT REFERENCE:

Remarks 1: Parts of the air operators such as the drive rod, trunnion
pins, brackets and clevis were evaluated as part of the
respective valve QID packages.

THE ABOVE SEISMIC AND ENVIRONMENTAL QUALIFICATION REPORTS HAVE BEEN REEVALUATED IN ACCORDANCE WITH
THE CURRENT NRC SEISMIC AND ENVIRONMENTAL CRITERIA:

- 1. IEEE STANDARDS 344 (1975)
- 2. USNRC REGULATORY GUIDES 1.92, 1.100
- 3. STANDARD REVIEW PLANS 3.9.2, 3.10, 3.11
- 4. ~~NUREG-0648~~

This certificate applies only to the operator which was evaluated as part of the valve assembly. Following completion of the valve requalification (QID 361106), the certification will be revised to address the entire assembly.

THE ABOVE COMPONENT HAS BEEN FOUND ACCEPTABLE FOR PERFORMING ITS INTENDED SAFETY RELATED FUNCTION WHEN SUBJECTED TO THE PLANT SPECIFIC VIBRATORY LOADS.

PREPARED BY	<u>J E RAKOWSKI (SIGNED IN ABSENTIA BY <i>[Signature]</i>)</u>	DATE	<u>4/27/83</u>
REVIEWED BY	<i>[Signature]</i>	DATE	<u>4/27/83</u>
APPROVED BY	<i>[Signature]</i>	DATE	<u>4/27/83</u>

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

REQUALIFICATION CERTIFICATE

WNP- 2

QID 018001

COMPONENT NO: CEP-AO-1A¹ 2ACOMPONENT DESCRIPTION: 10" Bore Air Cylinder OperatorsMANUFACTURER: Miller Fluid Power Corp. MODEL NO: A83 (2A), A83B (1A)EQUIPMENT CLASSIFICATION: ACTIVE PASSIVE

SEISMIC QUALIFICATION REPORT REFERENCE:

Cynga Report 1P.01/F, QID 018001WPPSS Seismic Qualification of 8" and 10" Bore Miller
Air Operator.

ENVIRONMENTAL QUALIFICATION REPORT REFERENCE:

Remarks: Parts of the air operators such as the drive rod, trunnion
pins, brackets and clevis were evaluated as part of the re-
spective valve QID packages.

THE ABOVE SEISMIC AND ~~ENVIRONMENTAL~~ QUALIFICATION REPORTS HAVE BEEN REEVALUATED IN ACCORDANCE WITH
THE CURRENT NRC SEISMIC AND ~~ENVIRONMENTAL~~ CRITERIA:

1. IEEE STANDARDS 344 (1975)
2. USNRC REGULATORY GUIDES 1.92, 1.100
3. STANDARD REVIEW PLANS 3.9-2, 3.10, ~~3.10-1~~
4. ~~USNRC REGULATORY GUIDES~~

This certificate applies only to the operator which was evaluated as part of the valve assembly. Following completion of the valve requalification (QID 361104), the certification will be revised to address the entire assembly.

THE ABOVE COMPONENT HAS BEEN FOUND ACCEPTABLE FOR PERFORMING ITS INTENDED SAFETY RELATED FUNCTION
WHEN SUBJECTED TO THE PLANT SPECIFIC VIBRATORY ~~AND~~ LOADS.

PREPARED BY <u>JE RAKOWSKI (SIGNED IN ABSENCE BY WNC)</u>	DATE <u>4/27/93</u>
REVIEWED BY <u>[Signature]</u>	DATE <u>4/27/93</u>
APPROVED BY <u>[Signature]</u>	DATE <u>4/27/93</u>

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

REQUALIFICATION CERTIFICATE

WNP- 2

QID 018001

COMPONENT NO: CEP-AO-3A & 4ACOMPONENT DESCRIPTION: 8" Bore Air Cylinder OperatorsMANUFACTURER: Miller Fluid Power Corp. MODEL NO: A83(4A), A83B(3A)EQUIPMENT CLASSIFICATION: ACTIVE PASSIVE

SEISMIC QUALIFICATION REPORT REFERENCE:

Cygn Report 1P.01/F, QID 018001WPPSS Seismic Qualification of 8" and 10" Bore Miller
Air Operator.

ENVIRONMENTAL QUALIFICATION REPORT REFERENCE:

Remarks: Parts of the air operators such as the drive rod, trunnion
pins, brackets and clevis were evaluated as part of the
respective valve QID packages.

THE ABOVE SEISMIC AND ~~ENVIRONMENTAL~~ QUALIFICATION REPORTS HAVE BEEN REEVALUATED IN ACCORDANCE WITH
THE CURRENT NRC SEISMIC AND ~~ENVIRONMENTAL~~ CRITERIA:

1. IEEE STANDARDS 344 (1975)
2. USNRC REGULATORY GUIDES 1.92, 1.100
3. STANDARD REVIEW PLANS 3.9-2, 3.10, 3.11
4. ~~NUREG-0001~~

This certificate applies only to the operator which was evaluated as part of the valve assembly. Following completion of the valve requalification (QID 361106), the certification will be revised to address the entire assembly.

THE ABOVE COMPONENT HAS BEEN FOUND ACCEPTABLE FOR PERFORMING ITS INTENDED SAFETY RELATED FUNCTION
WHEN SUBJECTED TO THE PLANT SPECIFIC VIBRATORY LOADS.

PREPARED BY <u>J. E. RAKOWSKI (SIGNED IN ABSENTIA BY MAREK)</u>	DATE <u>4/27/83</u>
REVIEWED BY <u>[Signature]</u>	DATE <u>4/27/83</u>
APPROVED BY <u>[Signature]</u>	DATE <u>5/12/83</u>

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

REQUALIFICATION CERTIFICATE

WNP- 2

QID 018001

COMPONENT NO: REA-AO-1 $\frac{1}{2}$, ROA-AO-1 $\frac{1}{2}$

COMPONENT DESCRIPTION: 12" Bore Air Cylinder Operators

MANUFACTURER: Miller Fluid Power Corp. MODEL NO: A83

EQUIPMENT CLASSIFICATION: ACTIVE PASSIVE

SEISMIC QUALIFICATION REPORT REFERENCE:

Cygn Report 1P.01/F, QID 018001

WPPSS Seismic Qualification of 8" and 10" Bore Miller

Air Operator.

ENVIRONMENTAL QUALIFICATION REPORT REFERENCE:

N/A

THE ABOVE SEISMIC AND ~~ENVIRONMENTAL~~ QUALIFICATION REPORTS HAVE BEEN REEVALUATED IN ACCORDANCE WITH THE CURRENT NRC SEISMIC AND ~~ENVIRONMENTAL~~ CRITERIA:

- 1. IEEE STANDARDS 344 (1975)
- 2. USNRC REGULATORY GUIDES 1.92, 1.100
- 3. STANDARD REVIEW PLANS 3.9.2, 3.10, ~~3.11~~
- 4. ~~STANDARD REVIEW PLAN 3.10.1~~

THE ABOVE COMPONENT HAS BEEN FOUND ACCEPTABLE FOR PERFORMING ITS INTENDED SAFETY RELATED FUNCTION WHEN SUBJECTED TO THE PLANT SPECIFIC VIBRATORY ~~AND~~ LOADS.

PREPARED BY	<u>J.E. RAKOWSKI (SIGNED IN ABSENCE BY WRO)</u>	DATE	<u>4/27/85</u>
REVIEWED BY	<u>[Signature]</u>	DATE	<u>4/27/85</u>
APPROVED BY	<u>[Signature]</u>	DATE	<u>4/27/85</u>

2.0 SQRT FORM(S) AND REFERENCES



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

Qualification Summary of Equipment

OID 018001

Ref. No.

I. PLANT NAME: WNP-2 TYPE _____

PWR _____

1. NSSS: GE 2. A/E: Burns & Roe BWR 5-Mark II
CEP-AO-3A, 4A

II. COMPONENT NAME: 8" Bore Air Cylinder COMPONENT NO. CSP-AO-3,4,5,6,9

1. SCOPE: NSSS BOP

2. MODEL NUMBER: A83B QUANTITY: 7

3. VENDOR: BIF

4. IF THE COMPONENT IS A CABINET OR PANEL, NAME AND MODEL NO. OF THE DEVICES INCLUDED:

N/A

5. PHYSICAL DESCRIPTION: a. APPEARANCE: Cylindrical 13

b. DIMENSIONS: 8" Dia. x 51.5" long (excludes the drive rod) 13

c. WEIGHT: 399 lbs. - cylinder, 277 lb. - bracket 13

6. LOCATION: BUILDING: Reactor Building 4

ELEVATION: 475' - 497' 4

7. FIELD MOUNTING CONDITIONS: BOLT (NO. _____ SIZE _____)

WELD (LENGTH _____)

8. a. SYSTEM IN WHICH LOCATED: CEP; Containment Exhaust Purge System 4
CSP; Containment Supply Purge System

b. FUNCTIONAL DESCRIPTION: Primary Containment Isolation and Prevention 4
of the release of radioactive material to the environment

c. IS THE EQUIPMENT REQUIRED FOR: HOT STANDBY COLD SHUTDOWN

BOTH NEITHER 4

9. PERTINENT REFERENCE DESIGN SPECIFICATION: 68

III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT: YES NO

(see walkdown)

Qualification Summary of Equipment (Continued)

QID 018001

Ref. No.

VI. IF QUALIFICATION BY TEST, THEN COMPLETE: N/A

1. SINGLE FREQUENCY MULTI-FREQUENCY RANDOM
2. SINGLE AXIS MULTI-AXIS SINE BEAT _____

3. NO. OF QUALIFICATION TESTS: OBE _____ SSE _____ OTHER (SPECIFY) _____

4. FREQUENCY RANGE: _____

5. NATURAL FREQUENCIES IN EACH DIRECTION (SIDE/SIDE, FRONT/BACK, VERTICAL):

S/S = _____ F/B = _____ V = _____

6. METHOD OF DETERMINING NATURAL FREQUENCIES:

- LAB TEST IN SITU TEST ANALYSIS

7. TRS ENVELOPING RRS USING MULTI-FREQUENCY TEST: YES (ATTACH TRS & RRS GRAPHS) NO

8. INPUT g-LEVEL TEST: OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. LABORATORY MOUNTING:

- BOLT (NO. _____, SIZE _____) WELD (LENGTH _____) _____

10. FUNCTIONAL OPERABILITY VERIFIED: YES NO NOT APPLICABLE

11. TEST RESULTS INCLUDING MODIFICATIONS MADE:

12. OTHER TEST PERFORMED (SUCH AS AGING OR FRAGILITY TEST, INCLUDING RESULTS):

*NOTE: IF QUALIFICATION BY A COMBINATION OF TEST AND ANALYSIS, ALSO COMPLETE ITEM VII.

FAULTED CONDITION G-LEVELS*
8 AND 10 INCH AIR CYLINDER OPERATORS

EPN	HYDR LDS	ELEV 'R'	N	G'S V	E	N***	V***	E***
CSP-A0-1	Y	508.00	4.40	6.51	4.89**	2.26	3.62	2.80
CSP-A0-2	Y	508.00	4.95	6.45	3.72**	1.44	3.54	1.90
CSP-A0-3	Y	481.00	5.72	3.82	7.45**	2.66	2.99	3.76
CSP-A0-4	Y	478.00	4.65	4.06	6.57**	2.96	3.17	4.19
CSP-A0-5	Y	475.00	9.35	5.75	7.72	2.96	3.44	5.42
CSP-A0-6	Y	480.00	9.35	5.57	1.46	11.39	3.33	5.85
CSP-A0-9	Y	490.00	2.57	1.73	2.67	NC	NC	NC
EP-A0-1	Y	588.00	1.27	1.77	1.23	NC	NC	NC
EP-A0-2	Y	588.00	0.78	1.77	1.02	NC	NC	NC
CEP-A0-3A	Y	495.00	13.89	1.66	1.04	4.57	1.26	0.86
CEP-A0-4A	Y	495.00	10.95	1.50	1.10	3.35	1.34	0.86

*Transmitted from the final piping analysis, see Section 5.5.

**These valves are required to fail-closed during a DBE, change Use Code to "1,3".

*** THESE ACCELERATIONS REPRESENT REVISED PIPING ANALYSIS
BURNER & ROE INC WOODBURY, TELECOPIED TRANSMITTAL P. SCHUENZEL
TO D. ARMSTRONG (WPPSS). SEE SEC. 5.5/QID D18001

Excerpted
MLC/1/2/8



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

Qualification Summary of Equipment

QID 018001

I. PLANT NAME: <u>WNP-2</u> TYPE _____	Ref. No.
1. NSSS: <u>GE</u> 2. A/E: <u>Burns & Roe</u> PWR _____ 5 - Mark II	
II. COMPONENT NAME: <u>10" Bore Air Cylinder</u> COMPONENT NO. <u>CSP-AO-1, 2</u> BMR CEP-AO-1A, 2A	4
1. SCOPE: <input type="checkbox"/> NSSS <input checked="" type="checkbox"/> BOP	
2. MODEL NUMBER: <u>A83B</u> QUANTITY: <u>4</u>	
3. VENDOR: <u>BIF</u>	
4. IF THE COMPONENT IS A CABINET OR PANEL, NAME AND MODEL NO. OF THE DEVICES INCLUDED: <u>N/A</u>	
5. PHYSICAL DESCRIPTION: a. APPEARANCE: <u>Cylindrical</u>	13
b. DIMENSIONS: <u>10" dia. x 64" long (excludes the drive rod)</u>	13
c. WEIGHT: <u>593 lbs. - cylinder, 321 lb. - bracket</u>	13
6. LOCATION: BUILDING: <u>Reactor Building</u>	4
ELEVATION: <u>508' to 560'</u>	4
7. FIELD MOUNTING CONDITIONS: <input checked="" type="checkbox"/> BOLT (NO. _____ SIZE _____) <input type="checkbox"/> WELD (LENGTH _____) <input type="checkbox"/> _____	
8. a. SYSTEM IN WHICH LOCATED: <u>CEP; Containment Exhaust Purge System</u>	4
CSP; Containment Supply Purge System	
b. FUNCTIONAL DESCRIPTION: <u>Primary Containment Isolation and Prevention of the release of radioactive material to the environment.</u>	4
c. IS THE EQUIPMENT REQUIRED FOR: <input type="checkbox"/> HOT STANDBY <input type="checkbox"/> COLD SHUTDOWN <input checked="" type="checkbox"/> BOTH <input type="checkbox"/> NEITHER	4
9. PERTINENT REFERENCE DESIGN SPECIFICATION: <u>68</u>	
III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT: <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO (See Walkdown)	

Qualification Summary of Equipment (Continued)

QID 018001

Ref. No.

EQUIPMENT QUALIFICATION METHOD:

TEST
 ANALYSIS
 COMBINATION OF TEST & ANALYSIS

4

QUALIFICATION REPORT: Requalification Analysis of QID 018001

(NO., TITLE & DATE): OP.01/F, February 1983

COMPANY THAT PREPARED REPORT: Cygna Energy Services

COMPANY THAT REVIEWED REPORT: Washington Public Power Supply System

V. VIBRATION INPUT:

1. LOADS CONSIDERED: a. SEISMIC ONLY
 b. HYDRODYNAMIC ONLY
 c. COMBINATION OF (a) AND (b)

4

2. METHOD OF COMBINING RRS: ABSOLUTE SUM SRSS OTHER (SPECIFY) _____

3. REQUIRED RESPONSE SPECTRA (ATTACH THE GRAPHS): Section 5.1

4. DAMPING CORRESPONDING TO RSS: OBE _____ SSE 2%

5. REQUIRED ACCELERATION IN EACH DIRECTION: ZPA OTHER (SPECIFY) Sec. 5.4

OBE S/S = Attached F/B = _____ V = _____

SSE S/S = Attached F/B = _____ V = _____

6. WERE FATIGUE EFFECTS OR OTHER VIBRATION LOADS CONSIDERED?

YES NO

13

IF YES, DESCRIBE LOADS CONSIDERED AND HOW THEY WERE TREATED IN OVERALL QUALIFICATION PROGRAM:

For those EPN's which are subjected to hydrodynamic loadings,

1

the fatigue analysis on critical locations will be performed

to comply with the requirements of AISC, Section 5, Appendix

B. Total number of hydrodynamic stress cycles is equal to

15560.0 cycles (10 x 6 (OBE/SSE) + 3 x 4500 (SRV) + 2000.0 cycles

(chugging).

*NOTE: IF MORE THAN ONE REPORT, COMPLETE ITEMS IV THROUGH VII FOR EACH REPORT

Qualification Summary of Equipment (Continued)

QID 018001

Ref. No.

VI. IF QUALIFICATION BY TEST, THEN COMPLETE*:

N/A

1. SINGLE FREQUENCY MULTI-FREQUENCY RANDOM
2. SINGLE AXIS MULTI-AXIS SINE BEAT _____

3. NO. OF QUALIFICATION TESTS: OBE _____ SSE _____ OTHER (SPECIFY) _____

4. FREQUENCY RANGE: _____

5. NATURAL FREQUENCIES IN EACH DIRECTION (SIDE/SIDE, FRONT/BACK, VERTICAL):

S/S = _____ F/B = _____ V = _____

6. METHOD OF DETERMINING NATURAL FREQUENCIES:

LAB TEST IN SITU TEST ANALYSIS

7. TRS ENVELOPING RRS USING MULTI-FREQUENCY TEST: YES (ATTACH TRS & RRS GRAPHS) NO

8. INPUT g-LEVEL TEST: OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. LABORATORY MOUNTING:

BOLT (NO. _____, SIZE _____) WELD (LENGTH _____) _____

10. FUNCTIONAL OPERABILITY VERIFIED: YES NO NOT APPLICABLE

11. TEST RESULTS INCLUDING MODIFICATIONS MADE:

12. OTHER TEST PERFORMED (SUCH AS AGING OR FRAGILITY TEST, INCLUDING RESULTS):

*NOTE: IF QUALIFICATION BY A COMBINATION OF TEST AND ANALYSIS, ALSO COMPLETE ITEM VII.

Qualification Summary of Equipment (Continued)

QID 018001

Ref. No.

IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. METHOD OF ANALYSIS:

- STATIC ANALYSIS EQUIVALENT STATIC ANALYSIS
 DYNAMIC ANALYSIS TIME-HISTORY RESPONSE SPECTRUM

13

2. NATURAL FREQUENCIES IN EACH DIRECTION (SIDE/SIDE, FRONT/BACK, VERTICAL):

s/s = 13.0 Hz F/B = 11.45 Hz v = 100 Hz

10

3. MODEL TYPE:

- 3D 2D 1D FINITE ELEMENT BEAM CLOSED FORM SOLUTION

4. COMPUTER CODES: None

FREQUENCY RANGE AND NO. OF MODES CONSIDERED: N/A

- HAND CALCULATIONS

13

5. METHOD OF COMBINING DYNAMIC RESPONSES: ABSOLUTE SUM SRSS OTHER (SPECIFY) _____

6. DAMPING: OBE _____ SSE _____ BASIS FOR THE DAMPING USED: N/A*

7. SUPPORT CONSIDERATIONS IN THE MODEL: Pipe-Mounted

10

8. CRITICAL STRUCTURAL ELEMENTS:

A. IDENTIFICATION	LOCATION	GOVERNING LOAD OR RESPONSE COMBINATION	SEISMIC STRESS (Range)	TOTAL STRESS	STRESS ALLOWABLE
Drive Rod	Operator CSP-V-1	Fatigue/Faulted	86824		90,000 PSI

11

B. MAX. CRITICAL DEFLECTION

LOCATION

MAXIMUM ALLOWABLE DEFLECTION TO ASSURE FUNCTIONAL OPERABILITY

Operability to be demonstrated by test for CSP-AO-1 & 2.

**Air Operator bushing stress > 200psi

* Final Response accelerations from piping analysis were used.

*
 FAULTED CONDITION G-LEVELS
 8 AND 10 INCH AIR CYLINDER OPERATORS

EPN	HYDR LDS	ELEV 'R'	N	G'S V	E	N ***	V ***	E ***
CSP-A0-1	Y	508.00	4.40	6.51	4.89 **	2.26	3.62	2.80
CSP-A0-2	Y	508.00	4.95	6.45	3.72 **	1.44	3.54	1.90
CSP-A0-3	Y	481.00	5.72	3.82	7.45 **	2.66	2.99	3.76
CSP-A0-4	Y	478.00	4.65	4.06	6.57 **	2.96	3.17	4.19
CSP-A0-5	Y	475.00	9.35	5.75	7.72	2.96	3.44	5.42
CSP-A0-6	Y	480.00	9.35	5.57	1.46	11.39	3.33	5.85
CSP-A0-9	Y	490.00	2.57	1.73	2.67	NC	NC	NC
CEP-A0-1	Y	588.00	1.27	1.77	1.23	NC	NC	NC
EP-A0-2	Y	588.00	0.78	1.77	1.02	NC	NC	NC
CEP-A0-3A	Y	495.00	13.89	1.66	1.04	4.57	1.26	0.86
CEP-A0-4A	Y	495.00	10.95	1.50	1.10	3.35	1.34	0.86

*Transmitted from the final piping analysis, see Section 5.5.

**These valves are required to fail-closed during a DBE, change Use Code to "1,3".

*** THESE ACCELERATIONS REPRESENT REVISED PIPING ANALYSIS
 BURNS & ROE INC WOODBURY, TELECOPIED TRANSMITTAL P. SCHUENZEL
 TO D. ARMSTRONG (WPPSS). SEE SEC. 5.5/QID 018001

E. S. P. 4/21/83
 M. D. 4/27/83



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

Qualification Summary of Equipment

QID 018001

Ref. No.

I. PLANT NAME:	WNP-2	TYPE	
	1. NSSS: GE	2. A/E: Burns & Roe	PWR 5 - Mark II
II. COMPONENT NAME:	12" Bore Air Cylinder	COMPONENT NO.	BWR REA-AO-1, 2 ROA-AO-1, 2
1. SCOPE:	<input type="checkbox"/> NSSS	<input checked="" type="checkbox"/> BOP	4
2. MODEL NUMBER:	A83B	QUANTITY:	4
3. VENDOR:	BIF		
4. IF THE COMPONENT IS A CABINET OR PANEL, NAME AND MODEL NO. OF THE DEVICES INCLUDED:	N/A		
5. PHYSICAL DESCRIPTION: a. APPEARANCE:	Cylindrical		
b. DIMENSIONS:	12" dia. x 46.83" long (excludes the drive rod)		
c. WEIGHT:	583 lbs. - cylinder, 586 lb. - bracket		
6. LOCATION: BUILDING:	Reactor Building		
ELEVATION:	578' to 597'		
7. FIELD MOUNTING CONDITIONS:	<input checked="" type="checkbox"/> BOLT (NO. _____ SIZE _____) <input type="checkbox"/> WELD (LENGTH _____) <input type="checkbox"/> _____		
8. a. SYSTEM IN WHICH LOCATED:	REA; Reactor Building Exhaust Air (HVAC) System ROA; Reactor Building Outside Air (HVAC) System		
b. FUNCTIONAL DESCRIPTION:	Reactor Building, Containment Atmosphere Control, and prevention of the release of radioactive material to the environment.		
c. IS THE EQUIPMENT REQUIRED FOR:	<input type="checkbox"/> HOT STANDBY <input type="checkbox"/> COLD SHUTDOWN <input checked="" type="checkbox"/> BOTH (REA) <input checked="" type="checkbox"/> NEITHER (ROA)		
9. PERTINENT REFERENCE DESIGN SPECIFICATION:	68		
III. IS EQUIPMENT AVAILABLE FOR INSPECTION IN THE PLANT:	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO (See Walkdown)		

Qualification Summary of Equipment (Continued)

QID 018001

Ref. No.

4

EQUIPMENT QUALIFICATION METHOD:

- TEST
 ANALYSIS
 COMBINATION OF TEST & ANALYSIS

QUALIFICATION REPORT: Requalification Analysis of QID 018001

(NO., TITLE & DATE): OP.01/F, February 1983

COMPANY THAT PREPARED REPORT: Cygn Energy Services

COMPANY THAT REVIEWED REPORT: Washington Public Power Supply System

V. VIBRATION INPUT:

1. LOADS CONSIDERED: a. SEISMIC ONLY
 b. HYDRODYNAMIC ONLY
 c. COMBINATOR OF (a) AND (b)

2. METHOD OF COMBINING RRS: ABSOLUTE SUM SRSS OTHER (SPECIFY) _____

3. REQUIRED RESPONSE SPECTRA (ATTACH THE GRAPHS): Section 5.1

4. DAMPING CORRESPONDING TO RSS: OBE _____ SSE 2%

5. REQUIRED ACCELERATION IN EACH DIRECTION: ZPA OTHER (SPECIFY) Sect. 5.

OBE S/S = 1.0 F/B = 1.0 v = 0.6

SSE S/S = 1.0 F/B = 1.0 v = 0.6

6. WERE FATIGUE EFFECTS OR OTHER VIBRATION LOADS CONSIDERED?

- YES NO

IF YES, DESCRIBE LOADS CONSIDERED AND HOW THEY WERE TREATED IN OVERALL QUALIFICATION PROGRAM:

For those EPN's which are subjected to hydrodynamic loadings, the fatigue analysis on critical locations will be performed to comply with the requirements of AISC, Section 5, Appendix B. Total number of hydrodynamic stress cycles is equal to 15560.0 cycles (10x6 (OBE/SSE) + 3x4500 (SRV) + 2000.0 cycles (chugging).

13

1

*NOTE: IF MORE THAN ONE REPORT, COMPLETE ITEMS IV THROUGH VII FOR EACH REPORT

Qualification Summary of Equipment (Continued) QID 018001

Ref. No.

VI. IF QUALIFICATION BY TEST, THEN COMPLETE*: N/A

 1. SINGLE FREQUENCY MULTI-FREQUENCY RANDOM

 2. SINGLE AXIS MULTI-AXIS SINE BEAT _____

3. NO. OF QUALIFICATION TESTS: OBE _____ SSE _____ OTHER (SPECIFY) _____

4. FREQUENCY RANGE: _____

5. NATURAL FREQUENCIES IN EACH DIRECTION (SIDE/SIDE, FRONT/BACK, VERTICAL):

S/S = _____ F/B = _____ V = _____

6. METHOD OF DETERMINING NATURAL FREQUENCIES:

 LAB TEST IN SITU TEST ANALYSIS

 7. TRS ENVELOPING RRS USING MULTI-FREQUENCY TEST: YES (ATTACH TRS & RRS GRAPHS) NO

8. INPUT g-LEVEL TEST: OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. LABORATORY MOUNTING:

 BOLT (NO. _____, SIZE _____) WELD (LENGTH _____) _____

 10. FUNCTIONAL OPERABILITY VERIFIED: YES NO NOT APPLICABLE

11. TEST RESULTS INCLUDING MODIFICATIONS MADE:

12. OTHER TEST PERFORMED (SUCH AS AGING OR FRAGILITY TEST, INCLUDING RESULTS):

*NOTE: IF QUALIFICATION BY A COMBINATION OF TEST AND ANALYSIS, ALSO COMPLETE ITEM VII.

Qualification Summary of Equipment (Continued)

QID 018001

Ref. No.

IF QUALIFICATION BY ANALYSIS, THEN COMPLETE:

1. METHOD OF ANALYSIS:

- STATIC ANALYSIS EQUIVALENT STATIC ANALYSIS
 DYNAMIC ANALYSIS TIME-HISTORY RESPONSE SPECTRUM

13

2. NATURAL FREQUENCIES IN EACH DIRECTION (SIDE/SIDE, FRONT/BACK, VERTICAL):

S/S = 10.81 F/B = 52.0 v = 100

3. MODEL TYPE:

- 3D 2D 1D FINITE ELEMENT BEAM CLOSED FORM SOLUTION

4. COMPUTER CODES: None

FREQUENCY RANGE AND NO. OF MODES CONSIDERED: N/A

HAND CALCULATIONS

5. METHOD OF COMBINING DYNAMIC RESPONSES: ABSOLUTE SUM SRSS OTHER (SPECIFY) _____

13

6. DAMPING: OBE _____ SSE _____ BASIS FOR THE DAMPING USED: N/A*

7. SUPPORT CONSIDERATIONS IN THE MODEL: Pipe-Mounted

8. CRITICAL STRUCTURAL ELEMENTS:

A. IDENTIFICATION	LOCATION	GOVERNING LOAD OR RESPONSE COMBINATION	SEISMIC STRESS	TOTAL STRESS	STRESS ALLOWABLE
Tie Rods		Operating		1368]psi	20000 psi
Drive Rods	threaded end	faulted		31,172 psi	86,400 psi

13

B. MAX. CRITICAL DEFLECTION

LOCATION

MAXIMUM ALLOWABLE DEFLECTION TO ASSURE FUNCTIONAL OPERABILITY

* Final response accelerations from piping analysis were used.

3.0 TABLE OF CONTENTS

TABLE OF CONTENTS

QID 018001

<u>SECTION</u>	<u>TITLE</u>	
1.0	Requalification Certificate	6
2.0	SQRT Form(s) and References	16
3.0	Table of Contents	1
4.0	Calculations - Cygna Requalification Analysis	
4.1	Conclusions	1
4.2	Summary of Results	6
4.3	Analysis	43
4.4	References	1
5.0	Appendixes to Requalification Analyses	
5.1	Response Spectra	6
5.2	Walkdown Sheets	23
5.3	Summary Sheets	16
5.4	Load Comparative sheets for REA and ROA Air Cylinders	
5.5	Burns & Roe telex final piping G-levels	7
6.0	Drawings used for Requalification	
7.0	Prior Calculations and Transmittals used for Requalification	

SECTION 4.0

REQUALIFICATION ANALYSIS



Calculation Cover Sheet

QID 018001

Project

Job No. 82044

Equipment Seismic/Hydrodynamic Requalification

File No. OP.01/F

Client

Calc. Set No. 1

Washington Public Power Supply System

No. of Sheets 51

Subject

Dynamic Qualification of 8, 10 and 12 inch Bore Air Cylinder Operators.

Statement of Problem

The equipment qualification was performed based on calculations using the air operator response g-levels transmitted by the A/E, current to 12/31/82.

Sources of Data


References, Section 4.4

Sources of Formulae & References

Cygna Design Criteria DC-1, Rev. 0

Remarks

None

Originators	Checkers	Distribution	Revision No.
L. Kaner	R. Casassa		0
J. Foley	D. Searle		Supersedes Calculation Set No.
J. Rakowski			Approved By:  Date: 5/20/83



Calculation Sheet

QID 018001

Project	Prepared By:	Date
Subject	Checked By:	Date
System	Job No.	File No.
Analysis No.	Rev. No.	Sheet No.

CONTENTS

	Pgs
Calculation Cover Sheet	
4.1 Conclusions	1
4.2 Summary of Results	6
4.3 Requalification Analysis	
4.3.1 Introduction	1
4.3.2 Cylinder Operability	3
4.3.3 Analysis	39
4.4 References	1
APPENDIX A, B, C	8



Calculation Sheet

Project	Prepared By:	Date
Subject	Checked By:	Date
System	Job No.	File No.
Analysis No.	Rev. No.	Sheet No.

SECTION 4.1

CONCLUSIONS



Calculation Sheet

Project	Prepared By:	Date
WPPSS Equip. Seismic/Hydrodynamic Requal.	J. E. Rakowski	4/22/83
Subject	Checked By:	Date
Requalification	D. Searle	4/25/83
System	Job No.	File No.
BIF Air Operators	82044	1P.01/F
Analysis No.	Rev. No.	Sheet No.
018001.	0	018001

CONCLUSIONS

This QID demonstrates seismic and hydrodynamic qualification of the 8, 10 and 12 inch bore diameter cylinder operators identified in Section 4.2.

Summary Table 4.2.2 presents these comparisons and shows requirements for the bolting material in the 8 and 10 inch cylinders.

1. Cylinders CSP-AO-1,2,3 & 4 must be qualified for an active function and require a representative operability demonstration as described in Section 4.3.2 of this report.

This should be performed using the values of air operator loads in QID 361104 and 361106.

QID packages 361101 and 361102 document qualification of the valves associated with the 12 inch air cylinder in this report for the seismic loads which they experience. No fatigue analysis is required for these cylinders because no hydrodynamic vibration is experienced. These cylinders were shown to qualify with A307 bracket bolting for the actual response g-levels calculated in the piping analysis.

This qualification package will be complete when a satisfactory operability test is performed and documented herein. It has been concluded in this report that the standard A307 "earbolts" should be replaced with A325 material type bolts on the 8" and 10" air cylinders only.



Calculation Sheet

Project	Prepared By:	Date
WPPSS Equip. Seismic/Hydrodynamic Requal	J. E. Rakowski	4/22/83
Subject	Checked By:	Date
Requalification		
System	Job No.	File No.
BIF Air Operators	82044	1P.01/F
Analysis No.	Rev. No.	Sheet No.
018001	0	018001

SECTION 4.2

SUMMARY OF RESULTS



Calculation Sheet

Project	Prepared By:	Date
WPPSS Equipment Seismic/Hydro. Requal.	J.E. Rakowski	4/22/83
Subject	Checked By:	Date
Requalification	<i>D.E. Seank</i>	4/25/83
System	Job No.	File No.
BIF Air Operators	82044	1P.01/F
Analysis No.	Rev. No.	Sheet No.
018001	0	018001 - 4.2.1.

4.2 SUMMARY OF RESULTS

Summary tables in this section present calculated stresses in comparison to allowables for the 8, 10 and 12 inch air cylinder operators. Trunnion pin, drive rod and bracket bolt calculated stresses for the 8 and 10 inch air cylinders were taken from QID 361106 and 361104, respectively. These calculations were performed on the valve/operator assembly using the SRSS method and the actual piping response g-levels to eliminate unnecessary conservatism in the higher-stressed components. The air operator components addressed in this report are not highly stressed and were analyzed using simpler techniques with generally higher envelope loads having greater margin. See Section 4.3.1 for more information.

The following summary tables note corresponding g-levels and operator components.



Calculation Sheet

Project: WPPSS Equip. Seismic/Hydrodynamic Requal. Prepared By: J.E. Rakowski Date: 4/22/83
Subject: Requalification Checked By: *A.E. Jenke* Date: 4/22/83
System: BIF Air Operators Job No.: 82044 File No.: 1P.01/F
Analysis No.: 018001 Rev. No.: 0 Sheet No.: 018001 - 4.2.2

TABLE 4.2.1


AIR CYLINDER REQUIRED G-LEVELS

SIZE	EPN	ELEVATION	REQ'D G'S - GLOBAL*		
			X(N)	Y(VERT)	Z(E)
8	CSP-AO-3	481	2.66	2.99	3.76
8	CSP-AO-4	478	2.96	3.17	4.19
8	CSP-AO-5	475	2.96	3.44	5.42
8	CSP-AO-6	480	11.39	3.33	5.85
8	CSP-AO-9	490	2.57	1.73	2.67
8	CEP-AO-3A	497	4.57	1.26	0.86
8	CEP-AO-4A	497	3.35	1.34	0.86
10	CSP-AO-1	500	2.26	3.62	2.80
10	CSP-AO-2	500	1.44	3.54	1.90
10	CEP-AO-1A	500	1.93	2.23	1.85
10	CEP-AO-2A	500	0.96	2.11	1.16
12	REA-AO-1	597	1.00	0.60	1.00
12	REA-AO-2	597	1.00	0.60	1.00
12	ROA-AO-1	578	1.00	0.60	1.00
12	ROA-AO-2	578	1.00	0.60	1.00

* Refer to final piping G-levels in Section 5.5 and QID 361104 and 361106.

NOTE: ALL STRESSES LISTED IN PSI

SUMMARY TABLE 4.2.2
EPN'S QUALIFIED TO REQUIRED PIPING RESPONSE G'S **



Calculation Sheet

Project: WPPSS - EQUIPMENT REPAIR / HYDRO REPAIR
 Subject: BIF VALUES w/ MILLER OPERATORS
 System: 8" 10' 12" AIR CYLINDERS
 Analysis No. RID: D/A001
 Rev. No. 0
 Sheet No. 016001-4.2.3
 Prepared By: P. J. Smith
 Checked By: [Signature]
 Job No. 82044
 File No. 1A.01/E
 Date 4/25/83
 Date 4/27/85

FAULTED		STRESS TYPE	VALVE EPN'S	CSP-3	CSP-4	CSP-5	CSP-6	CEP-3A	CEP-4A	CSP1	CSP2	
TR PINS	SA 276	SHEAR	4108 ^{MAX}	(ALLOW 11840)								
DR ROD	A-4140	NORMAL	31629	33019	40634	33433	7462	7462	44732	30082		
SUMMARY		(NORMAL ALLOWABLE)	86400									
EAR BOLTS	A-325	TENSILE	16845	18393	20848	50883	23525	23525	12150	8796		
		SHEAR	14670	15475	19482	17564	4538	4538	9500	7540		
SUMMARY		SHEAR ALLOWABLE	26250									
		NORMAL ALLOWABLE	66000									
FATIGUE RESULTS		STRESS TYPE	VALVE EPN'S	CSP-3	CSP-4	CSP-5	CSP-6	CEP-3A	CEP-4A	CSP1	CSP2	
TR PINS	SA-276	SHEAR	8216 ^{MAX}									
DR ROD	A-4140	NORMAL	46172	48952	65826	46866	13280	13280	86824	57526		
SUMMARY		(NORMAL ALLOWABLE)	90000									

* CSP-AD-9 ENVELOPED BY CSP-AD-4 BY WIDE MARGIN
 * CEP-AD-1A, 2A QUALIFIED BY CEP-AD-4A.
 ** SEE TABLE 4.2.1

1006 00



Calculation Sheet

Project	WPPSS Equip. Seismic/Hydrodynamic Requal.	Prepared By:	J.E. Rakowski	Date	4/22/83
Subject	Requalification	Checked By:	A. E. Shank	Date	4/25/83
System	BIF Air Operators	Job No.	82044	File No.	1P.01/F
Analysis No.	018001	Rev. No.	0	Sheet No.	018001 - 4.2.4

TABLE 4.2.2
(continued)

Remaining 8" Bore Air Operator Components $g_h=14$ $g_v=6$:

Cylinder:

$$SI_{\max} = 12,056 \text{ psi} < 18,000 \text{ psi} \quad \therefore \text{O.K.}$$

Tie Rods:

$$f_t = 6099 \text{ psi} < 20,000 \text{ psi} \quad \therefore \text{O.K.}$$

Support Bracket (Bearing):

$$F_p = 2299 \text{ psi} < 32400 \text{ psi} \quad \therefore \text{O.K.}$$

Total Stress:

$$= 7492 \text{ psi} < 21,600 \text{ psi} \quad \therefore \text{O.K.}$$

Shear Stress:

$$691 \text{ psi} < 14,400 \text{ psi} \quad \therefore \text{O.K.}$$

Weld:

$$f = 789 \text{ psi} < 21,000 \text{ psi} \quad \therefore \text{O.K.}$$

Fatigue:

$$f_r = 1579 \text{ psi} < 45,000 \text{ psi} \quad \therefore \text{O.K.}$$

Remaining 10" Bore Air Operator Components $g_h=6$ $g_v=5$:

Cylinder:

$$SI_{\max} = 9293 \text{ psi} \quad 18,000 \quad \therefore \text{O.K.}$$

Tie Rods:

$$f_t = 6614 \text{ psi} \quad 10,000 \text{ psi} \quad \therefore \text{O.K.}$$

Support Bracket (Bearing):

$$f_p = 2287 \text{ psi} \quad 32,400 \text{ psi} \quad \therefore \text{O.K.}$$



Calculation Sheet

Project	Prepared By:	Date
WPPSS Equip. Seismic/Hydrodynamic Requal.	J.E. Rakowski	4/22/83
Subject	Checked By:	Date
Requalification	D.E. Shank	4/25/83
System	Job No.	File No.
BIF Air Operators	82044	1P.01/F
Analysis No.	Rev. No.	Sheet No.
018001	0	018001-4.2.S

TABLE 4.2.2
(continued)

Total Stress:
= 4830 psi 21,600 psi O.K.

SUMMARY OF RESULTS

Shear Stress: $\tau = 346 \text{ psi} < 14,400 \text{ psi} \text{ O.K.}$
 Weld: $f = 832 \text{ psi} < 21,000 \text{ psi} \text{ O.K.}$
 Fatigue: N/A (Allowable stress range = 45 ksi for welds).

12" Bore Air Operators Components

Cylinder: $SI_{\max} = 3439 \text{ psi} < 18,000 \text{ psi} \text{ O.K.}$
 Tie Rods: $f_t = 13681 \text{ psi} < 20,000 \text{ psi} \text{ O.K.}$
 Support Bracket:(Bearing): $f_p = 1775 \text{ psi} < 32,400 \text{ psi} \text{ O.K.}$
 Total Stress: $\sigma = 4267 \text{ psi} < 21,600 \text{ psi} \text{ O.K.}$
 Shear Stress: $\tau = 283 \text{ psi} < 14,400 \text{ psi} \text{ O.K.}$
 Weld: $f = 3445 \text{ psi} < 21,000 \text{ psi} \text{ O.K.}$
 Drive Rod (Tensile): $\sigma = 31,172 \text{ psi} < 86,400 \text{ psi} \text{ O.K.}$
 Trunnion Pins (Shear): $\tau = 2,515 \text{ psi} < 11,840 \text{ psi} \text{ O.K.}$

Support Bracket Bolts (A307): $g_h = g_v = 1.54:$ (1.55)
 Tensile: 12,598 psi < 30,000 psi O.K.
 Shear: 6,339 psi < 15,000 psi O.K.



Calculation Sheet

Project	WPPSS EQ	Prepared By:	J.E. Rakowski	Date	4/22/83
Subject	24" Butterfly Valves	Checked By:	A.E. Shank	Date	4/22/83
System	CSP & CEP	Job No.	82044	File No.	OT.01/F
Analysis No.	018001	Rev. No.	0	Sheet No.	018001 - 4.2.6

SUMMARY TABLE 1.3 ALLOWABLE STRESSES

Since operability is required, the stresses for the faulted condition will be kept in the elastic range. The table below is based on AISC criteria and the yield stresses at temperature (340°F) from PG. 9 of REF. 4 for conservatism.

MATERIAL	YIELD STRS (PSI)	LEVEL A & B		LEVEL D	
		.6 Fy	.4 Fy	1.6 x .6 Fy = 0.96 Fy	1.6 x .4 Fy = 0.64 Fy
		BENDING ALLOW.	SHEAR ALLOW.	BENDING ALLOW.	SHEAR ALLOW.
AISI - 4140 HEAT TREATED	90,000	54,000	36,000	86,400	57,600
SA-276 , GR 304	18,500	11,100	7,400	17,760	11,840
ASTM A-295-60-45-15	45,000	27,000	18,000	43,200	28,800
SA-307	23,300	13,980	9,320	22,370	14,900
AISI - 1018 (MIN YIELD)	35,000	21,000	14,000	33,600	22,400
SA-193, GR 83, 304SS	31,000	18,600	12,400	29,760	19,840
SA-479, 304SS	22,650	13,590	9,060	21,744	14,500
SA-516, GR 60	28,000	16,800	11,200	26,880	17,920

* BRACKET BOLT ALLOWABLES TAKEN FROM AISC, 8TH ED., SEC. I.5.2.2



Calculation Sheet

Project	Prepared By:	Date
WPPSS Equip. Seismic/Hydrodynamic Requal	J.E. Rakowski	4/22/83
Subject	Checked By:	Date
Requalification		
System	Job No.	File No.
BIF Air Operators	82044	1P.01/F
Analysis No.	Rev. No.	Sheet No.
018001	0	018001

Section 4.3

REQUALIFICATION ANALYSIS



Calculation Sheet

Project	WPPSS Equip. Seismic/Hydrodynamic Requal.	Prepared By:	J. E. Rakowski	Date	4/22/83
Subject	Requalification	Checked By:	<i>D. Exum</i>	Date	4/22/83
System	BIF Air Operators	Job No.	82044	File No.	1P.01/F
Analysis No.	018001	Rev. No.	0	Sheet No.	018001 4.3.1:1

4.3.1 INTRODUCTION

The analyses herein address specific parts of the 8, 10 and 12 inch diameter Miller Air Products air cylinder operators identified in Section 1.0 of this QID. The remaining structural components of the operators were addressed in the associated* valve dynamic qualification packages. Refer to Table 4.3.1.

The analyses in this QID were performed with enveloping g-levels. Table 4.2.1 summarizes the required g-levels from the piping analysis. The air operator mass-stiffness model incorporated in the piping analysis to calculate response g-levels on the more severely loaded 8 and 10 inch operators is given in Appendix A of this calculation.

4.3.2 CYLINDER OPERABILITY

The cylinders designated as EPN CSP-AO-1,2,3,4 must operate during an DBE from open to fail-closed. While seating the valve disk during a DBE, the air cylinders must have sufficient capacity to overcome the seating torque of the valve plus the frictional forces in the bushing and cylinder. The following table compares the required seating torque forces and minimum cylinder spring preloads given in QID 361106 and 361104 for the 8 and 10 inch cylinders.


size	Required Seating Force	Spring Preload	Residual Capacity To Overcome Friction
8"	1150 lb.	1500 lb.	350 lb.
10"	1847 lb.	2900 lb.	1053 lb.

* QID's 361106, 361104 and (361101 & 361102) for the 8, 10 and 12 inch operators respectively.



<h1 style="text-align: center;">Calculation Sheet</h1>		Prepared By:	Date
		J.M. Foley	1/4/83
Project <u>WPPSS</u>		Checked By:	Date
		<i>H. Stark</i>	4/22/83
Subject <u>Air Operator ReQual</u>		Job No.	File No.
System <u>BIF Air Operators</u>		82044	IP.01/F
Analysis No. <u>018001</u> Rev. No. _____		Sheet No. <u>018001-4.3.2.1</u>	

TABLE 4.3.1
AIR OPERATOR QUALIFICATION



ITEM #	DESCRIPTION	REPORT	AREAS ANALYZED
1	Main Shaft	Valve	Bending, Shear, Keyway bearing.
2	Drive Lever	Valve	Tension, Bending, Bearing, Punch Shear, Keyway Bearing
3	Clevis	Valve	Tension, Bearing, Punch Shear
4	Clevis Pin	Valve	Shear.
5	Drive Rod*	Valve	Tension, Bending
6	Trunnion Pins*	Valve	Shear
7	Air Cylinder	Operator	Tension (applied), Pressure (with tie rods)
8	Bushings	Operator	Operability



Calculation Sheet		Prepared By: <i>J.M. Foley</i>	Date <i>1/4/83</i>
		Checked By: <i>A. Stark</i>	Date <i>7/22/83</i>
Project <i>WPPSS</i>	Subject <i>Air Operator ReQual.</i>	Job No. <i>82044</i>	File No. <i>1P.01/F</i>
System <i>BIF Air Operator</i>	Analysis No. <i>018001</i>	Rev. No. <i>0</i>	Sheet No. <i>018001-4.3.2</i>

TABLE 4.3.1 CONTINUED

ITEM #	DESCRIPTION	REPORT	AREAS ANALYZED
9	Support Bracket	Operator	Bearing, Bending, Shear, Weld Shear
10	Support Ears.	Valve	Tension, Bending, Shear
11	Support Bracket* Bolts	Valve	Tension, Shear

* Included herein for the 12-inch operator.



Calculation Sheet

Project	WPPSS Equip. Seismic/Hydrodynamic Requal.	Prepared By:	J.E. Rakowski	Date	4/22/83
Subject	Requalification	Checked By:	A.E. Jank	Date	4/22/83
System	BIF Air Operators	Job No.	82044	File No.	1P.01/F
Analysis No.	018001	Rev. No.	0	Sheet No.	018001 - 4.3.2.3

4.3.2 CYLINDER OPERABILITY (CON'D)

Ability of the spring to fully close the valve depends on the coefficient of friction between the sliding surfaces of the cylinder, namely the drive rod and bushing, and the piston and cylinder.

Although upper limit bushing pressures due to load reaction were given by Miller Air Products for consideration of shaft wear, (Section 7.0, Ref. 5a and 5b) this alone is not a sufficient criterion because piston friction in the cylinder is not accounted for.

Therefore, it is recommended that one 8" air operator (CSP-AO-3 or 4) be fieldtested to verify operability since this size has approximately only 25 percent the residual capacity of a 10 inch operator. Dynamic plus static bushing pressures for these operators are calculated in QID's 361106 and 361104 and these may be used as a guide to specify the simulated test g-level on the end of the air cylinder by consideration of the bushing reaction equation in Appendix B of this calculation. The test load should be applied in the direction which tends to rotate the cylinder about the trunnion pin axis. Bushing pressures for both the 8 and 10 inch operators must be considered in comparison to the relative residual capacity of the 8 and 10 inch cylinders so that both sizes are covered by this test.

4.3.3 ANALYSIS

4.3.3.1 12 inch operator assembly frequency*.


* Similar calculation for the 8 and 10 inch assemblies are given in QID 361106 and 361104.



Calculation Sheet		Prepared By:	Date
Project <u>WPPSS Seismic</u>		<u>L. Kumar</u>	<u>11/30/82</u>
Subject <u>Requalification</u>		Checked By:	Date
System <u>PIF Air Operator</u>		<u>R.P. Ganesha</u>	<u>12/7/82</u>
Analysis No. <u>019001</u> Rev. No. <u>0</u>		Job No.	File No.
		<u>82044</u>	<u>1P.01/F</u>
		Sheet No. <u>018001-4.33.1</u>	

4.3.3.1 12" OPERATOR ASSEMBLY FREQUENCY

CALCULATE THE NATURAL FREQUENCY OF THE 12" CYLINDER OPERATOR DUE TO THE BENDING STIFFNESS OF THE DRIVE ROD AND THE CYLINDER OPERATOR.



$$F_c = 500 \# \left(\frac{10.01}{24.63} \right) = 203.2 \#$$

$$F_D = 203.2 \# \left(\frac{3.5}{11.22} \right) = 63.4 \#$$

TO OVERCOME THE SEATING TORQUE:

$$\text{SEATING TORQUE} = \frac{17000 \text{ IN} \#}{11.5 \text{ IN}} = 1478 \# \text{ (PER REF. 4 p18)}$$

$$F_{A'} = 500 \# \left(\frac{1478 \#}{69.38} \right) = 10557 \#$$


$$\text{ACCELERATION} = \frac{F_{A'}}{W_{\text{ASSEMBLY}}} = \frac{10557 \#}{399 \#} = 26.5$$




Calculation Sheet		Prepared By:	Date
		L. Kamen	11/30/82
		Checked By:	Date
		R. Plaster	12/7/82
Project	WPPSS Seismic	Job No.	File No.
Subject	Requalification	82044	1P.01/F
System	BIF Air Operators	Sheet No.	
Analysis No.	818001	Rev. No.	0
		018001 - 4.3.3.2	

Calculation of f_n :

$$f_n = \frac{PL^3}{3EI} = \frac{500 \# (10.01^3)}{3(29 \times 10^6)(229.2)} = .000025"$$



ROTATION AT "B" DUE TO M_0 OF M/I DIAGRAM



$$M_0 = 500(10.01) = 5005 \text{ in}\#$$


$$\frac{5005}{229.2} = 21.84$$

$$\frac{2770}{229.2} = 12.09$$

$$\frac{2770}{0.79} = 3506.3$$

$$W_1 = 3506.3 \left(\frac{13.6}{2} \right) = 23843$$

$$W_2 = \left(\frac{21.84 + 12.09}{2} \right) (11) = 196.6$$



AREA 1
 $CG_{AREA 1} = \frac{1}{3}(13.63) = 4.54 \text{ in}$

AREA 2

RECTANGLE:
 $CG_R = \frac{1}{2}(11) = 5.5$
 $A_R = (11)(12.09) = 133$

TRIANGLE:
 $CG_T = \frac{2}{3}(11) = 7.33$
 $A_T = \frac{1}{2}(11)(21.84 - 12.09) = 53.63$

$$CG_{AREA 2} = \frac{(CG_R)(A_R) + (CG_T)(A_T)}{A_R + A_T}$$

$$= \frac{(5.5)(133) + (7.33)(53.63)}{133 + 53.63}$$

$$= 6.03$$

~~11~~ $11 - 6.03 = 4.97$



Calculation Sheet		Prepared By:	Date
Project <u>WPPSS Seismic</u>		<u>L. K...</u>	<u>11/30/82</u>
Subject <u>Requalification</u>		Checked By:	Date
System <u>BIF Air Operators</u>		<u>R. Casanova</u>	<u>12/7/82</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No. <u>92044</u>	File No. <u>1P.01/F</u>
		Sheet No. <u>018001-4.3.3.3</u>	

JE R...
A. Seale 4/22/83

$$R_B = 23843 \left(\frac{9.09}{24.63} \right) + 186.6 \left(\frac{17.89}{24.63} \right) =$$

$$R_B = 8749.5 + 271.1 = 8935$$

$$\Theta_B = \frac{8935}{29 \times 10^6} = .000308 \text{ rad}$$

DEFLECTION @ POINT "A"

δ'_A DUE TO Θ_B

$$\delta'_A = .000308 (10.01) = .003083 \text{ in}$$

$$\text{TOTAL } \delta_A = .000025 + .003083 = .003108''$$

$$K = \frac{P}{\delta} = \frac{500}{.003108} = 160871 \text{ #/in}$$

$$f_N = \frac{1}{2\pi} \sqrt{\frac{160871 (386.4)}{583}} = \underline{\underline{51.97 \text{ Hz}}}$$

f_N PARALLEL TO TRUNNION PINS AND DRIVE ROD:

IN REFERENCE TO QID 361104 & 361106, THE CYLINDER ASSY IS STIFF PARALLEL TO THE DRIVE ROD. USE THE FLEXIBLE 8" CYLINDER FREQUENCY FOR THE MODE PARALLEL TO THE TRUNNION PINS.



Calculation Sheet		Prepared By:	Date
Project <u>WPPSS-SEISMIC</u>		<u>L. Kamm</u>	<u>11/20/02</u>
Subject <u>REQUALIFICATION</u>		Checked By:	Date
System <u>BIF AIR OPERATOR</u>		<u>R. P. ...</u>	<u>12/7/02</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No.	File No.
		<u>82044</u>	<u>1P.01/F</u>
		Sheet No.	
		<u>018001-4.3.3.4</u>	

JE RAKOWSKI BY AKR
A. Shank 4/22/03

4.3.3.2 ANALYSIS OF THE 8" OPERATOR

CYLINDER

USING WEIGHT AND C.G. FOR CYLINDER & ROD FROM QID 361106.

C.G. OF CYLINDER FROM SHAFT = 43 IN

$$W = 399 \#$$

$$OD = 8.45" \quad ID = 7.97" \quad t = 0.24" IN$$

$$A = \frac{\pi (8.45^2 - 7.97^2)}{4} = 6.19 \text{ IN}^2$$


$$I = \frac{\pi (8.45^4 - 7.97^4)}{64} = 52.2 \text{ IN}^4$$

MOMENT ARM = DISTANCE FROM TRUNION TO C.G.

$$\text{MOMENT ARM} = 51.5" - (13.5 + 23.54) = 14.46"$$

$$M_{\text{TRUNION}} = (\text{MOMENT ARM})(\text{WEIGHT})(g)$$

$$= (14.46)(399)(14) = .80.773.6 \text{ \#}$$



Calculation Sheet		Prepared By:	Date
Project <u>WPPSS - SEISMIC</u>		<u>L Komer</u>	<u>11/30/92</u>
Subject <u>REQUALIFICATION</u>		Checked By:	Date
System <u>BIF AIR OPERATORS</u>		<u>R. Passaro</u>	<u>12/7/92</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No.	File No.
		<u>82044</u>	<u>1P.01/F</u>
		Sheet No.	
		<u>018001-4.3.3.5</u>	

J.F. Rakowski ^{BY}
A. Stark 4/22/83

8" ANALYSIS (CONT)

BENDING STRESSES ($x ; z$)

$$\sigma_{x,z} = \frac{My}{I} = \frac{80773.6 \left(\frac{8.45}{2}\right)}{52.2} = 6538 \text{ PSI}$$

AXIAL STRESSES (y)

$$\sigma_y = \frac{W(g)}{A} = \frac{399(7)}{6.19} = 452 \text{ psi}$$

STRESSES FROM PRESSURE

AXIAL: $\sigma_{\text{AXIAL}} = \frac{Pr}{2t} = \frac{150(7.97)}{2(.24)} = 2491 \text{ psi}$

HOOP: $\sigma_{\text{HOOP}} = \frac{Pr}{t} = \frac{150(7.97)}{.24} = 4981 \text{ psi}$

RADIAL: $\sigma_{\text{RADIAL}} = \frac{-150}{2} = -75 \text{ psi}$

SHEAR STRESS

$$\tau = \frac{Wg}{A} = \frac{399(14)}{6.19} = 902 \text{ psi}$$



Calculation Sheet		Prepared By:	Date
Project <u>WPPSS - SEISMIC</u>		<u>L. Kauer</u>	<u>11/30/02</u>
Subject <u>REQUALIFICATION</u>		Checked By:	Date
System <u>BIF AIR OPERATORS</u>		<u>R. Plasencia</u>	<u>12/7/02</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No.	File No.
		<u>82044</u>	<u>1P.01/F</u>
		Sheet No.	
		<u>018001-4.3.3.6</u>	

JE Rakowski ^{PH} mjd
A. Skarke 4/22/03

8" ANALYSIS (CONT)

DETERMINATION OF PRINCIPAL STRESSES

STRESS	X	Z	Y	OPER	SRSS	OPER + SRSS	OPER - SRSS
σ (psi)	6538	6538	452	2491	925.7	11,748	-6766
τ (psi)	902	902	-	-	1275	1275	-1275

PRINCIPAL STRESSES :

$$\sigma_{1,2} = \frac{\sigma_A + \sigma_{\text{oper}}}{2} \pm \sqrt{\left(\frac{\sigma_A - \sigma_{\text{oper}}}{2}\right)^2 + \tau^2}$$

OPER + SRSS : $\sigma_1 = 11,981$ psi $\sigma_2 = 4748$ psi

OPER - SRSS : $\sigma_1 = 4225$ psi $\sigma_2 = -7795$ psi

STRESS INTENSITIES : $\sigma_3 = \sigma_{\text{residual}} = -75$ psi

$\sigma_1 - \sigma_2$ OP + SRSS OP - SRSS
 7233 12,020

$\sigma_2 - \sigma_3$ 4823 -7720

$\sigma_3 - \sigma_1$ -12,056 -4300



Calculation Sheet		Prepared By:	Date
Project <u>WPPSS-SEISMIC</u>		<u>L. Kanner</u>	<u>11/20/82</u>
Subject <u>REQUALIFICATION</u>		Checked By:	Date
System <u>BIE AIR OPERATORS</u>		<u>R. Plassera</u>	<u>12/7/82</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No.	File No.
		<u>82044</u>	<u>1P.01/F</u>
		Sheet No.	
		<u>018001-4.3.3.7</u>	

J. E. Przewski ^{BY} mjd
A. J. Janku 4/22/83

8" ANALYSIS (CONT)

$$SI_{mx} = 12,056 \text{ psi}$$

- CYLINDER MATERIAL IS A519 STEEL.
- ∴ USE $S_u = 30,000 \text{ psi}$ (WHICH IS MINIMUM YIELD)
- ∴ ALLOWABLE = $.6 S_u = 18,000 \text{ psi}$

$$\therefore SI_{mx} = 12,056 < 18,000 \text{ psi}$$

∴ CYLINDER IS ACCEPTABLE

TIE RODS:

$$\text{LOAD} = (\text{INSIDE AREA}) \times (\text{PRESSURE})$$

$$= \frac{\pi (7.97)^2}{4} (150) = 7483 \text{ lb}$$

$$\text{LOAD PER BOLT} = \frac{7483}{4} = 1871 \text{ lb}$$

$$\text{TIE ROD DIAMETER} = 5/8 \text{"}$$

$$A_{\text{ROD}} = \frac{\pi d^2}{4} = \frac{\pi (5/8)^2}{4} = .31 \text{ in}^2$$

$$\sigma_{\text{ROD}} = \frac{1871}{.31} = 6035 \text{ psi} < 20 \text{ ksi (ASSUME A307 TIE ROD)}$$

∴ TIE RODS ARE ADEQUATE




Calculation Sheet		Prepared By: <i>L. Korman</i>	Date <i>11/30/81</i>
		Checked By: <i>R. Plescia</i>	Date <i>12/7/82</i>
Project	<i>WPPSS - SEISMIC</i>	Job No. <i>82044</i>	File No. <i>1P.01/F</i>
Subject	<i>REQUALIFICATION</i>	Sheet No. <i>018001-4.3.3.8</i>	
System	<i>BIF AIR OPERATOR</i>		
Analysis No.	<i>018001</i>	Rev. No.	<i>0</i>

J.E. Rakowski
A. Searle 4/22/83

8" ANALYSIS (CONT)

OPERATOR SUPPORT BRACKET



FORCES @ TRUNION PIN.

OVERTURNING

$$M = gWL = 5.0 (399) (51.5 - (13.5 + 23.54))$$

$$M = 80773.6 \text{ lb-in}$$

$$\text{depth} = 13.25 + \frac{2(.5)}{2} = 13.75 \text{ (REF DWG A-208293)}$$

$$F_1 = \frac{80773.6}{13.75} = 5874 \text{ lb}$$

VERTICAL

$$F_2 = g(W_{\text{TOTAL}}) \quad W_{\text{TOTAL}} = W_{\text{CYLINDER}}$$

$$W_{\text{CYLINDER}} = 399 \text{ lb}$$

$$F_2 = \frac{(.1)(399)}{2} = 19.95 \text{ lb/GIO OF PIN}$$




Calculation Sheet

Prepared By: <u>L. Korman</u>		Date: <u>11/20/82</u>
Checked By: <u>R.P. Casarosa</u>		Date: <u>12/7/82</u>
Project: <u>WPPSS - SEISMIC</u>	Job No.: <u>82044</u>	File No.: <u>1P-01/F</u>
Subject: <u>REQUALIFICATION</u>	Sheet No.: <u>018001-4.3.3.9</u>	
System: <u>BIF AIR OPERATORS</u>	Analysis No.: <u>018001</u> Rev. No.: <u>0</u>	

J. E. RAJKOWSKI BY
A. J. ... 4/22/83

8" ANALYSIS (CONT)



FORCE DUE TO CLEVIS RESTRAINT (Z-DIRECTION)

$$F_B = F_A + F_C$$

$$F_A = \text{WT OF CYLINDER} = 399$$

$$L_A F_A = F_C L_C \quad \therefore F_C = \frac{F_A L_C}{L_C}$$

$$F_C = \frac{399(14.46)}{(25.0)} = 231 \#$$

$$F_B = (231 + 399)/2 = 315 \# / \text{PER END OF PIN}$$

FORCE DUE TO CLEVIS RESTRAINT (Y-DIRECTION)

$$\frac{F_D}{3.5} = \frac{F_C}{11.22}$$

$$F_D = \frac{231}{11.22} (3.5) = 72.1 \#$$

$$F_D = 36.0 \# / \text{PER END OF PIN}$$



<h1 style="text-align: center;">Calculation Sheet</h1>		Prepared By:	Date
		<i>L. Kamen</i>	<i>11/30/82</i>
Project <u>WPPSS-SEISMIC</u> Subject <u>REQUALIFICATION</u> System <u>BIF AIR OPERATOR</u>		Checked By:	Date
		<i>R. P. ...</i>	<i>12/7/82</i>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No.	File No.
		<u>82044</u>	<u>1P.01/F</u>
		Sheet No.	
		<u>018001-4.3.3.10</u>	

J. Rakowski
H. ... 4/22/83

8" ANALYSIS (CONT)

$F_0 =$ SEATING TORQUE = 601 (QID 36106, CYGNA CALC'S.)

$$\begin{aligned} \text{TOTAL LOAD} &= F_D + \sqrt{F_1^2 + F_2^2 + F_8^2 + F_0^2} \\ &= 601 + \sqrt{5874^2 + 1396^2 + 315^2 + 36^2} = 6046 \# \end{aligned}$$

BEARING ON SUPPORT @ TRUNION PIN

BEARING AREA = $A_B = LD$

WHERE L = THE THICKNESS OF PLATE
D = DIAMETER OF PIN

$L = 1.5"$ $D = 1.75"$ (REF DWG A208293)

$A_B = 1.5(1.75) = 2.63 \text{ in}^2$

$\sigma_{\text{BEARING}} = \frac{F}{A_B} = \frac{6046}{2.63} = 2299 \text{ psi}$

ASSUME A-36 MATERIAL ALLOWABLE = , 9 $S_u = 32.4 \text{ ksi}$

$\therefore \sigma_{\text{BEARING}} = 2299 \text{ psi} < 32.4 \text{ ksi} \therefore \text{OK}$




Calculation Sheet		Prepared By:	Date
Project <u>WPPSS - SEISMIC</u>		<u>L. Korman</u>	<u>11/20/82</u>
Subject <u>REQUALIFICATION</u>		Checked By:	Date
System <u>BIF AIR OPERATOR</u>		<u>R. Korman</u>	<u>12/7/82</u>
Analysis No. <u>013001</u> Rev. No. <u>0</u>		Job No. <u>82044</u>	File No. <u>1P.01/F</u>
		Sheet No. <u>013001-4.3.3.11</u>	

JE PAKOWSKI
A. Korman 4/22/83

8" ANALYSIS (CONT)


CHECK BRACKET FOR BENDING



SECTION PROPERTIES

FROM P.29 OF REF 4

$$L = 13.5" \quad L_{max} = 22.0" \quad W = 13.25"$$



THICKNESS = .5"

(WEB DOES NOT EXIST @ MINIMUM SECTION)

$$\bar{y} = \frac{13.5(.5)(.25) + (13.5 - 1.62)(.5)(14)}{13.5(.5) + (13.5 - 1.62)(.5)}$$

$$\bar{y} = 6.69" \text{ FROM BOTTOM}$$

$$I = \frac{13.5(.5)^3}{12} + \frac{(13.5 - 1.62)(.5)^3}{12} + 13.5(.5)(6.69 - .25)^2 + (13.5 - 1.62)(.5)(14 - 6.69)^2$$

$$I = 597.6 \text{ IN}^4$$



Calculation Sheet		Prepared By:	Date
Project <u>WPPSS - SEISMIC</u>		<u>L. [unclear]</u>	<u>11/30/82</u>
Subject <u>REQUALIFICATION</u>		Checked By:	Date
System <u>BIF AIR OPERATOR</u>		<u>R. [unclear]</u>	<u>12/7/82</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No.	File No.
		<u>82044</u>	<u>IP.01/F</u>
		Sheet No.	
		<u>018001-4.33.12</u>	

JERAKOWSKI ST m&D
A. [unclear] 4/22/83

8" ANALYSIS (CONT)

BENDING STRESS:

$$M = [227(28.5 - 5) + 399(43 - 5)] 14.0 = 286950. \text{ "}$$

$$\sigma_B = \frac{[286950(14 - 6.69)]}{597.6} = 351.0 \text{ PSI}$$

AXIAL STRESS

$$A_{T_{\min}} = (13.5 - 1.62)(.5) = 5.94 \text{ in}^2$$

$$F_{\text{AXIAL}} = F_{\text{OVERTURNING}} + F_{\text{VERTICAL}}^* + F_{\text{SEATING}}^*$$

$$F_{\text{AXIAL}} = \frac{286950}{13.25} + 1396 + 601 = 23654 \text{ "}$$

$$\sigma_A = \frac{23,654}{5.94} = 3982 \text{ PSI}$$

* PREVIOUSLY CALCULATED



Calculation Sheet		Prepared By:	Date
Project <u>WPPSS - SEISMIC</u>		<u>L. Kinn</u>	<u>11/30/82</u>
Subject <u>REQUALIFICATION</u>		Checked By:	Date
System <u>BIF AIR OPERATOR</u>		<u>R. P. ...</u>	<u>12/7/82</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No.	File No.
		<u>82044</u>	<u>1P.01/F</u>
		Sheet No.	
		<u>018001-1.3.3.13</u>	

JE RAKOWSKI ^{BY}
H. ... 4/22/83

8" ANALYSIS (CONT)

SHEAR STRESS

$$V = 14.0 (W_{\text{CYLINDER}} + W_{\text{BECKET}})$$
$$= 14.0 (227 + 399) = 8764$$

$$\text{AREA} = 5.94 + 13.5(.5) = 12.69$$

$$\tau = \frac{3130}{12.96} = 691 \therefore \text{psi}$$

COMBINING AXIAL & BENDING STRESSES:

$$\sigma_{\text{TOTAL}} = 3510 + 3982 = 7492 \text{ psi}$$

$$\text{ALLOWABLE BENDING} = .6 S_u = 21,600 \text{ psi}$$

$$\sigma_{\text{TOTAL}} < .6 S_u \therefore \text{OK}$$

$$\text{ALLOWABLE SHEAR} = .4 S_u = 14,400 \text{ psi}$$

$$\tau < .4 S_u \therefore \text{OK}$$



<h2 style="text-align: center;">Calculation Sheet</h2>		Prepared By:	Date
		<i>L. Kann</i>	<i>11/30/92</i>
Project <u>WPPSS - SEISMIC</u>		Checked By:	Date
Subject <u>REQUALIFICATION</u>		<i>R. Lassman</i>	<i>12/5/92</i>
System <u>BIF AIR OPERATOR</u>		Job No.	File No.
Analysis No. <u>018001</u> Rev. No. <u>0</u>		<u>82044</u>	<u>IP.01/F</u>
		Sheet No.	
		<u>018001-4.3.3.14</u>	

JE RAKOWSKI
A. Clark 4/22/83

8^o ANALYSIS (CONT)

CHECK WELDS OF BRACKET

LOAD ON WELD = 6046 # *

AREA OF WELD = $2(.707)(.31) = .44 \text{ IN}^2/\text{IN}$

LENGTH OF WELD = 17.5" (NEGLECTING 6" SCH 40 STEEL PIPE)

∴ TOTAL AREA = $17.5(.44) = 7.66 \text{ IN}^2$

$\sigma = \frac{6046}{7.66} = 789 \text{ PSI} < 21,000 \text{ PSI} \therefore \text{OK}$
(8TH ED.)

FATIGUE ON WELDS (PER AISC SECTION 5 APPENDIX B)

ASSUME LOADING CONDITION 1 - *CYCLES = 20,000-100,000 (B)
FOR A BUILT-UP SECTION, USE CATEGORY B. (B2)

∴ FOR THE ALLOWABLE RANGE OF STRESSES : $F_{SC} = 45 \text{ ksi}$

STRESS RANGE = $2(6046) = 12,092$ *

$\sigma = \frac{12,092}{7.66} = 1579 \text{ PSI} < 45,000 \text{ PSI} \therefore \text{OK}$

∴ OPERATOR SUPPORT BRACKET IS
ACCEPTABLE

* PREVIOUSLY CALCULATED



Calculation Sheet		Prepared By:	M. Kuntz	Date:	11/15/82
		Checked By:	R. P. ...	Date:	12/7/82
Project	WPPSS - SEISMIC	Job No.	82044	File No.	1P.01/F
Subject	REQUALIFICATION	Sheet No.	018001-43.3.15		
System	BIF AIR OPERATOR				
Analysis No.	018001	Rev. No.	0		

J. Rakowski ^{BY}
A. Shank 4/22/83

4.3.3.3 ANALYSIS OF THE 10" OPERATOR

CYLINDER

USING WEIGHT AND C.G. FOR CYLINDER AND ROD FROM QID 361106.

C.G. OF CYLINDER FROM SHAFT = 59.5 IN

WEIGHT = 593 #

O.D. = 10.425 IN

I.D. = 9.960 IN

t = 0.233 IN

$$A = \frac{\pi (10.425^2 - 9.96^2)}{4} = 7.44 \text{ IN}^2$$

$$I = \frac{\pi (10.425^4 - 9.96^4)}{64} = 96.73 \text{ IN}^4$$

MOMENT ARM = DIST. FROM TRUNNION TO C.G.

MOMENT ARM = 64" - (13.25" + 29.25") = 21.5 IN


$$M_{@TRUNNION} = (\text{MOMENT ARM})(\text{WEIGHT})(g) \\ = (21.5)(593)(6) = 76497.0 \text{ in-lb}$$

BENDING STRESSES (X AND Z)

$$\sigma_{x,z} = \frac{M_y}{I} = \frac{76497 \left(\frac{10.425}{2} \right)}{96.73} = 4122.20 \text{ psi}$$

AXIAL STRESSES (Y)

$$\sigma_y = \frac{W(g)}{A} = \frac{593(6)}{7.44} = 478.23 \text{ psi}$$



<h2 style="text-align: center;">Calculation Sheet</h2>		Prepared By:	Date
		M. Kuntz	11/15/82
Project		Checked By:	Date
WPPSS - SEISMIC		R. Plazana	12/6/82
Subject		Job No.	File No.
REQUALIFICATION		32044	1P.01/F
System		Sheet No.	
BIF AIR OPERATOR		018001-4.3.3.16	
Analysis No. 018001		Rev. No. 0	

STRESSES FROM PRESSURE

JE Rakowski, P.E.
A. Sank 4/22/83

$$\text{AXIAL: } \sigma_{\text{AXIAL}} = \frac{P_r}{2t} = \frac{150(9.96)}{2(.233)} = 3206 \text{ psi}$$

$$\text{HOOP: } \sigma_{\text{HOOP}} = \frac{P_r}{t} = \frac{150(9.96)}{(.233)} = 6412 \text{ psi}$$

$$\text{RADIAL: } \sigma_{\text{RADIAL}} = -\frac{150}{2} = -75 \text{ psi}$$

SHEAR STRESS

$$\tau = \frac{Wq}{A} = \frac{593(6)}{7.44} = 478.23 \text{ psi}$$

DETERMINATION OF PRINCIPAL STRESSES

STRESS	X	Z	Y	OPER	SRSS	OPER + SRSS	OPER - SRSS
σ (psi)	4122	4122	478	3206	5849	9055	-2643
τ (psi)	478	478	-	-	676	676	-676

PRINCIPAL STRESSES :

$$\sigma_{1,2} = \frac{\sigma_{\text{AXIAL}} + \sigma_{\text{HOOP}}}{2} \pm \sqrt{\left(\frac{\sigma_{\text{AXIAL}} - \sigma_{\text{HOOP}}}{2}\right)^2 + \tau^2}$$

OPER + SRSS: $\sigma_1 = 9218 \text{ psi}$ $\sigma_2 = 6249 \text{ psi}$

OPER - SRSS: $\sigma_1 = 6462 \text{ psi}$ $\sigma_2 = -2693 \text{ psi}$

STRESS INTENSITIES: $\sigma_3 = \sigma_{\text{RADIAL}} = -75 \text{ psi}$

OP + SRSS OP - SRSS

$\sigma_1 - \sigma_2$ 2969 psi 9155 psi

$\sigma_2 - \sigma_3$ 6324 psi -2768 psi

$\sigma_3 - \sigma_1$ -9293 psi -6537 psi



Calculation Sheet

Prepared By:

M. Kuntz

Date

11/17/82

Checked By:

R. K. Jensen

Date

12/5/82

Project WPPSS-SEISHICSubject REQUALIFICATIONSystem BIF AIR OPERATOR

Job No.

82044

File No.

1P.01/F

Sheet No.

018001-4.3.3.17

Analysis No. 018001 Rev. No. 0

$$SI_{MAX} = 9293 \text{ psi}$$

JERAKOWSKI ^{BY} mod
A. Seale 4/22/83

ASSUME CYLINDER MATERIAL IS A-36 STEEL

$$\therefore \text{ALLOWABLE} = .65S_u = 21600 \text{ psi}$$

$$\therefore SI_{MAX} = 9293 < 21600 \text{ psi}$$

\therefore CYLINDER IS ACCEPTABLE

TIE RODS:

$$\begin{aligned} \text{LOAD} &= (\text{INSIDE AREA}) \times (\text{PRESSURE}) \\ &= \frac{\pi (9.96)^2}{4} (150) = 11687 \# \end{aligned}$$

$$\text{LOAD PER BOLT} = \frac{11687}{4} = 2922 \#$$

$$\text{TIE ROD DIAMETER} = \frac{3}{4}''$$

$$A_{ROD} = \frac{\pi d^2}{4} = \frac{\pi (3/4)^2}{4} = .442 \text{ IN}^2$$

$$\begin{aligned} \sigma_{/ROD} &= \frac{2922}{.442} = 6614 \text{ psi} < 20 \text{ ksi} \\ &(\text{ASSUME A307 THREADED ROD}) \end{aligned}$$


\therefore TIE RODS ARE ADEQUATE



Calculation Sheet

Project <u>WPPSS - SEISMIC</u>		Prepared By: <u>M. Kuntz</u>	Date <u>11/17/82</u>
Subject <u>REQUALIFICATION</u>		Checked By: <u>R.P. [unclear]</u>	Date <u>12/7/82</u>
System <u>BIF AIR OPERATOR</u>		Job No. <u>82044</u>	File No. <u>IP.01/F</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Sheet No. <u>018001-4.3.3.18</u>	

JE RAKOWSKI BY [Signature]
A. Shank 4/22/83



(REF DRAWING
C-26095)
(ref. 2).

FORCE DUE TO CLEVIS RESTRAINT (Z-DIR.)

$$F_B = F_A + F_C$$

$$F_A = \text{WEIGHT OF CYLINDER} = 593 \#$$

$$L_a F_a = F_c L_c \quad \therefore F_c = \frac{F_a L_a}{L_c}$$

$$F_c = \frac{593 (21.25)}{(27.125)} = 464.6 \#$$

$$F_B = \frac{(464.6 + 593)}{2} = 528.8 \# / \text{END OF PIN}$$

FORCE DUE TO CLEVIS RESTRAINT (Y-DIR)

$$\frac{F_D}{1.375} = \frac{F_C}{11.67}$$

$$F_D = \frac{464.6}{11.67} (1.375) = 54.74 \#$$

$$F_D = 27.34 \# / \text{END OF PIN}$$




<h1 style="text-align: center;">Calculation Sheet</h1>		Prepared By:	Date
		M. Kuntz	11/17/82
Project <u>WPPSS-SEISMIC</u> Subject <u>REQUALIFICATION</u> System <u>BIF AIR OPERATOR</u>		Checked By:	Date
		<i>R. Plescia</i>	12/7/82
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No.	File No.
		82044	1P.01F
		Sheet No.	
		018001-4.3.3.19	

JE RAKOUSKI

A. Shank 4/22/83

OPERATOR SUPPORT BRACKET



W = 593 #

FORCES AT TRUNNION PIN

OVERTURNING

$$M = gWL = (6.0)(593)(64 - (13.50 + 29.25))$$

$$= 75607.5 \text{ in.-lb}$$

$$d = 13.88 + \frac{2(5/8)}{2} = 14.51 \text{ IN (REF. DWG # A-208195)}$$

(ref. 6)

$$F_1 = \frac{75607.5}{14.51} = 5211 \#$$


VERTICAL

$$F_2 = g(W_{\text{TOTAL}})$$

$$W_{\text{TOTAL}} = W_{\text{CYLINDER}}$$

$$W_{\text{CYLINDER}} = 593 \#$$

$$F_2 = \frac{(6)(593)}{2} = 1779 \# / \text{END OF PIN}$$



<h2 style="text-align: center;">Calculation Sheet</h2>		Prepared By:	Date
		M. Kuntz	11/17/82
Project <u>WPPSS - SEISMIC</u> Subject <u>REQUALIFICATION</u> System <u>BIF AIR OPERATOR</u>		Checked By:	Date
		R. L. ...	12/7/82
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No. <u>82044</u>	File No. <u>1P.01/F</u>
		Sheet No. <u>018001-4.3.3.20</u>	

J. Rakowski *A. Mark* 4/22/83

$F_D = \text{SEATING TORQUE} = 964 \#$ (BIF REPORT p18)
(ref. 4)

$$\begin{aligned}
 \text{TOTAL LOAD} &= F_D + \sqrt{F_1^2 + F_2^2 + F_B^2 + F_D^2} \\
 &= 964 + \sqrt{5211^2 + 1779^2 + 529^2 + 27^2} \\
 &= 964 + 5531 \\
 &= 6496
 \end{aligned}$$

BEARING ON SUPPORT @ TRUNNION PIN

BEARING AREA = $A_B - LD$

WHERE: L = THICKNESS OF THE PLATE
D = DIAMETER OF THE PIN

$L = 15/8"$ $D = 1.75"$ (REF. DWG. A208195)
 $A_B = (15/8" \times 1.75") = 2.84 \text{ in}^2$ (DWG C-26095)

$$\sigma_{\text{BEARING}} = \frac{F}{A_B} = \frac{6496}{2.84} = 2287 \text{ psi}$$

ASSUME A-36 MATERIAL
 ALLOWABLE = $.95S_u = 32.4 \text{ ksi}$

$\therefore \sigma_{\text{BEARING}} = 2287 \text{ psi} < 32.4 \text{ ksi} \therefore \text{ok}$




Calculation Sheet

Project <u>WPPSS-SEISMIC</u>		Prepared By: <u>M. Kuntz</u>	Date: <u>11/17/82</u>
Subject <u>REQUALIFICATION</u>		Checked By: <u>R. P. ...</u>	Date: <u>12/7/82</u>
System <u>BIF AIR OPERATOR</u>		Job No. <u>82044</u>	File No. <u>1P.01/F</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Sheet No. <u>018001-4.3.3.21</u>	

J. B. Rakowski
A. Mark 4/22/83

CHECK BRACKET FOR BENDING




SECTION PROPERTIES (REF 6 w/PROCEDURE FROM REF 4 p 29)

$$2(.94) = 1.88 \quad \phi_{\text{HOLE}} = .94$$

$$L = 13.5 \quad L_{\text{MAX}} = 23.25 \quad W = 13.88$$

$$\text{THICKNESS} = .625$$

(WEB DOES NOT EXIST @ MIN. SECTION)



$$\bar{y} = \frac{.31(13.5)(.625) + (13.5 - 1.88)(.625)(.625 + 13.88 + .31)}{.625(13.5) + (13.5 - 1.88)(.625)}$$

$$= \frac{2.62 + 107.59}{8.44 + 7.26} = 7.02$$

$$I = \frac{13.5(.625)^2}{12} + \frac{(13.5 - 1.88)(.625)^2}{12} + 13.5(.625)(7.02)^2$$

$$+ (13.5 - 1.88)(.625)(.31 + (13.88 - 7.02))^2 = 780.0 \text{ in}^4$$

$$M = (6) [(59.5 - 5.25)(593) + (28.5 - 5.25)(312)] = 236546 \text{ # in}$$

$$\sigma_B = \frac{236546 \left(\frac{13.88}{2} \right)}{786.4} = 2068 \text{ PSI}$$



Calculation Sheet		Prepared By:	Date
		M. Kuntz	11/19/82
Project <u>WPPSS - SEISMIC</u>		Checked By:	Date
		R.P. Casaca	12/7/82
Subject <u>REQUALIFICATION</u>	Job No.	File No.	
System <u>BIF AIR OPERATOR</u>	82044	IP.01/F	
Analysis No. <u>018001</u>	Rev. No. <u>0</u>	Sheet No.	
		018001-4.3.3.22	

AXIAL STRESS

JERAKOWSKI BY *md*
D. Mark 4/22/83

$$A_{TMIN} = (13.5 - 1.88)(.625) = 7.26 \text{ in}^2$$

$$F_{AXIAL} = F_{OVERTURNING} + F_{VERTICAL}^* + F_{SEATING}^*$$

$$= \frac{236546}{13.88} + 1779 + 964 = 19785 \#$$

$$\sigma_A = \frac{19785}{7.26} = 2725 \text{ psi}$$

$$\sigma_A + \sigma_B = 2725 + 2088 = 4813 \text{ psi}$$

SHEAR STRESS

$$V = 6.0 (W_{CYL.} + W_{BRACKET}) \\ = 6.0 (593 + 312) = 5430 \#$$

$$AREA = 7.26 + 13.5(.625) = 15.7 \text{ in}^2$$

$$\tau = \frac{5430}{15.7} = 346 \text{ psi}$$

ALLOWABLES

$$\text{BENDING: } .6 S_u = 21,600 \text{ psi}$$

$$\text{SHEAR: } .4 S_u = 14,400 \text{ psi}$$

* PREVIOUSLY CALCULATED



Calculation Sheet		Prepared By:	Date
Project <u>WPPSS - SEISMIC</u>		<u>M. Kuntz</u>	<u>11/19/82</u>
Subject <u>REQUALIFICATION</u>		Checked By:	Date
System <u>BIF AIR OPERATOR</u>		<u>R. Karam</u>	<u>12/7/82</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No. <u>82044</u>	File No. <u>IP.01/F</u>
		Sheet No. <u>018001-4.3.3.23</u>	

JE RAKOWSKI BY MDX A. Jank 4/22/83

∴ SINCE $\sigma_{TOTAL} = 4813 < .6 S_u = 21,600 \text{ psi}$
 $\tau = 346 < .4 S_u = 14,400 \text{ psi}$

THE BRACKET IS ACCEPTABLE

CHECK WELDS OF GUSSET

LOAD ON WELD = 6496 #

AREA OF WELD = $2(.707)(.31) = .44 \text{ in}^2/\text{IN}$

LENGTH OF WELD = 17.75' (NEGLECTING PIPE)

∴ TOTAL AREA = $(17.75)(.44) = 7.81 \text{ in}^2$

$\sigma = \frac{6496}{7.81} = 832. \text{ psi} < 21,600 \text{ psi}$

WELD IS ACCEPTABLE

WELD FATIGUE ANALYSIS

SIMILAR TO THE 8" AIR OPERATOR,
THE WELD STRESS IS LOW SUCH THAT THE
STRESS RANGE IS FAR BELOW THE
RANGE GIVEN BY AISC, 8TH EDITION,
SECTION 5, APPENDIX B



Calculation Sheet		Prepared By:	Date
		L. Kamen	11/30/82
		Checked By:	Date
		R. P. L. [unclear]	12/17/82
Project	WPPSS - SEISMIC	Job No.	File No.
Subject	REQUALIFICATION	82044	1P.01/F
System	BIF AIR OPERATOR	Sheet No.	
Analysis No.	018001	Rev. No.	0
		018001-4.33.24	

JERAKOWSKI ^{PT} and A. J. [unclear] 4/22/83

4.3.3.4 ANALYSIS OF THE 12" OPERATOR

CYLINDER:

ASSUME: OD = 12.625" (DUE TO LACK OF INFORMATION) ID = 12.0" t = .31"

$$A = \frac{\pi(12.625^2 - 12.0^2)}{4} = 12.09 \text{ IN}^2$$

$$I = \frac{\pi(12.625^4 - 12.0^4)}{64} = 229.2 \text{ IN}^4$$

WEIGHT OF CYLINDER: (REF 3)

CYLINDER:

$$12.09 (.283)(47.88) = 163.8 \text{ #}$$

BLOCKS:

$$2.5 (12.75)^2 (.28)(2) = 227.6 \text{ #}$$

BARS:

$$2(3)(1.25)(47.88)(.28) = 100.55 \text{ #}$$

PISTON:

$$\frac{\pi(2)^2}{4} (46.88 + 4.5 + 4.375)(.283) = 49.6 \text{ #}$$

TIE RODS

$$\frac{\pi(1)^2}{4} (4)(46.88)(.283) = 41.7 \text{ #}$$

TOTAL WEIGHT = 583 #



Calculation Sheet		Prepared By:	Date
Project <u>WPPSS-SEISMIC</u>		<u>L. Komer</u>	<u>11/22/82</u>
Subject <u>REQUALIFICATION</u>		Checked By:	Date
System <u>BIF AIR OPERATOR</u>		<u>R. P. ...</u>	<u>12/7/82</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No. <u>B2044</u>	File No. <u>1P.01F</u>
		Sheet No. <u>018001-4.3.3.25</u>	

JERACOWSKI
D. ... 4/22/83

12" ANALYSIS (CONT)

CYLINDER (CONT)

MOMENT ARM = DISTANCE FROM TRUNION TO C.G.

$$\text{MOMENT ARM} = 46.88 - (21.38 + (15.5 - 4.5)) = 14.5''$$

$$M_{\text{TRUNION}} = (14.5)(583)(5) = 42268''^*$$

BENDING STRESSES (X & Z)

$$\sigma_{x,z} = \frac{My}{I} = \frac{42268 \cdot \left(\frac{12.625}{2}\right)}{229} = 1165.1 \text{ psi}$$

AXIAL STRESSES (Y)

$$\sigma_y = \frac{W(g)}{A} = \frac{583(4)}{12.09} = 193 \text{ psi}$$

STRESSES FROM PRESSURE

AXIAL: $\sigma_{\text{AXIAL}} = \frac{pr}{2t} = \frac{150(6)}{2(.31)} = 1452 \text{ psi}$

HOOP: $\sigma_{\text{HOOP}} = \frac{pr}{t} = \frac{150(6)}{.31} = 2903 \text{ psi}$

RADIAL: $\sigma_{\text{RADIAL}} = \frac{-150}{2} = -75 \text{ psi}$

SHEAR STRESS

$$\tau = \frac{Wg}{A} = \frac{583(5)}{12.09} = 241 \text{ psi}^+$$



Calculation Sheet		Prepared By: <i>L. Komen</i>	Date <i>11/30/92</i>
		Checked By: <i>R.P. [unclear]</i>	Date <i>12/7/92</i>
Project <i>WPPSS - SEISMIC</i>	Job No. <i>82044</i>	File No. <i>1P.01/F</i>	
Subject <i>REQUALIFICATION</i>	Sheet No. <i>018001-4.33.26</i>		
System <i>BIF AIR OPERATOR</i>	Analysis No. <i>018001</i> Rev. No. <i>0</i>		

JE RAKOWSKI BY *[Signature]*
A. Shank 4/22/83

12" ANALYSIS (CONT)

DETERMINATION OF PRINCIPAL STRESSES

STRESS	X	Z	Y	OPER	SRSS	OPER + SRSS	OPER - SRSS
σ_{psi}	1165	1165	193	1452	1659	3111	-207
τ_{psi}	241	241	-	-	341	341	-341

$\sigma_{hoop} = 2903$ $\sigma_3 = \sigma_r = -75$

PRINCIPAL STRESSES:

$$\sigma_{1,2} = \left(\frac{\sigma_{axial} + \sigma_{hoop}}{2} \right) \pm \sqrt{\left(\frac{\sigma_{axial} - \sigma_{hoop}}{2} \right)^2 + \tau^2}$$

OPER + SRSS: $\sigma_1 = 3364$ psi $\sigma_2 = 2650$ psi

OPER - SRSS: $\sigma_1 = 2940$ psi $\sigma_2 = -244$ psi

STRESS INTENSITIES:

	<u>OPER + SRSS:</u>	<u>OPER - SRSS:</u>
$\sigma_1 - \sigma_2$	714	3184
$\sigma_2 - \sigma_3$	2725	-169
$\sigma_3 - \sigma_1$	-3439	-3015



Calculation Sheet		Prepared By:	Date
Project <u>WPPSS-SEISMIC</u>		<u>L. Kamen</u>	<u>11/30/82</u>
Subject <u>REQUALIFICATION</u>		Checked By:	Date
System <u>RIF AIR OPERATOR</u>		<u>R. P. L...</u>	<u>12/7/82</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No. <u>82044</u>	File No. <u>1P.01/F</u>
		Sheet No. <u>018001-4.3.3.27</u>	

JE RAKOWSKI BY
D. Shank 4/22/83

12" ANALYSIS (CONT)

$$SI_{max} = 3439 \text{ psi}$$

CYLINDER MATERIAL IS ASSUMED TO BE THE SAME AS 8" OR 10" A519 STEEL

$$\therefore \text{ALLOWABLE} = 18,000 \text{ psi}$$

$$\therefore SI_{max} = 3439 < 18,000 \text{ psi}$$

\therefore CYLINDER IS ACCEPTABLE

TIE RODS:

$$\text{LOAD} = (\text{INSIDE AREA}) \times (\text{PRESSURE})$$

$$= \frac{\pi (12)^2}{4} (150) = 16965 \text{ \#}$$

$$\text{LOAD PER BOLT} = \frac{16965}{4} = 4241 \text{ \#}$$

TIE ROD DIAMETER - ASSUME $\frac{5}{8}$ "

$$A_{rod} = \frac{\pi d^2}{4} = \frac{\pi (\frac{5}{8})^2}{4} = .31 \text{ IN}^2$$

$$\sigma_{rod} = \frac{4241}{.31} = 13681 \text{ psi} < 20 \text{ ksi} \quad (\text{ASSUME A307 TENSILE 1200})$$

\therefore TIE RODS ARE ADEQUATE



Calculation Sheet

Prepared By:

L. Kamen

Date

11/30/82

Checked By:

R.P. Carasco

Date

12/7/82

Project WPPSS - SEISMICSubject REQUALIFICATIONSystem BIF AIR OPERATORAnalysis No. 018001 Rev. No. 0

Job No.

82044

File No.

1P.01/F


Sheet No.

018001-4.3.3.28

JE PRKOWSKI ^{BY}
A. Stark 4/22/83

12" ANALYSIS (CONT)

OPERATOR SUPPORT BRACKET



BRACKET WT :

TOP ; BOTTOM PL :

$$22(62)(.5)(2) = 1364 \text{ IN}^3$$

$$\text{GUSSET: } 16(14)(.5)(2) = 224 \text{ IN}^3$$

BAR @ TRUNION :

$$3(.75)(12)(4) = 108 \text{ IN}^3$$

10" SCH. 30 PIPE:

$$16(10.07)(2) = 322 \text{ IN}^3$$

$$\text{PL: } (3)(3)(.5)(8) = 36 \text{ IN}^3$$

$$(7)(7)(.75) = 37.0 \text{ IN}^3$$

$$V_{\text{TOTAL}} = 2091$$

$$W_{\text{TOTAL}} = 2091(.28) = 586 \text{ #}$$



Calculation Sheet		Prepared By:	Date
Project <u>WDPSS - SEISMIC</u>		<u>L. Kane</u>	<u>11/30/82</u>
Subject <u>REQUALIFICATION</u>		Checked By:	Date
System <u>BIF AIR OPERATOR</u>		<u>R. L. ...</u>	<u>12/7/82</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No. <u>82044</u>	File No. <u>1P.01/F</u>
		Sheet No. <u>018001-4.3.3.29</u>	

JERACOWSKI, BY
A. Stark 4/22/83

12" ANALYSIS (CONT)

FORCES @ TRUNION PIN

OVERTURNING

$$M = gWL = 5.0 (583) (46.88 - (15.5 + 21.375))$$

$$M = 29165 \text{ " #}$$

$$\text{depth} = 16 \text{ "}$$

$$F_1 = \frac{29165 \text{ " #}}{16 \text{ "}} = 1823 \text{ #}$$

VERTICAL

$$F_2 = g (W_{CYL})$$


$$F_2 = \frac{4 (583)}{2} = 1166 \text{ #}$$



<h2 style="text-align: center;">Calculation Sheet</h2>		Prepared By: <i>L Kama</i>	Date <i>11/30/82</i>
		Checked By: <i>R Placencia</i>	Date <i>12/7/82</i>
Project <i>WPPSS - SEISMIC</i>	Job No. <i>32044</i>	File No. <i>1P.01/F</i>	
Subject <i>REQUALIFICATION</i>	Sheet No. <i>018001 - 4.3.3.30</i>		
System <i>BIF AIR OPERATOR</i>	Analysis No. <i>018001</i>	Rev. No. <i>0</i>	

JE RAKOWSKI BY SMma
A. Smith 4/22/83

12" ANALYSIS (CONT)



FORCE DUE TO CLEVIS RESTRAINT (Z-DIRECTION)

$$F_B = F_A + F_C$$

$$F_A = \text{g-load of CYLINDER} = 583 \cdot (g_v + 1) = 583 \cdot 4 = 2332$$

$$L_c F_A = F_C L_c \quad \therefore F_C = \frac{F_A L_c}{L_c}$$

$$F_C = \frac{2332 (10.01)}{24.625} = 948 \#$$

$$F_B = \frac{(2332 + 948)}{2} = 1640 \quad \# \text{ / END OF PIN}$$

FORCE DUE TO CLEVIS RESTRAINT (Y-DIRECTION)

$$F_C = 948$$

$$F_D = F_C \left(\frac{3.5}{11.22} \right) = 948 (.31) = 294 \cdot \#$$

$$F_D / \text{END OF PIN} = \frac{294}{2} = 147 \cdot \#$$



Calculation Sheet		Prepared By:	Date
Project <u>WPPSS - SEISMIC</u>		<u>L. Kama</u>	<u>11/30/82</u>
Subject <u>REQUALIFICATION</u>		Checked By:	Date
System <u>RIF AIR OPERATOR</u>		<u>R. Plasencia</u>	<u>12/7/82</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No.	File No.
		<u>82044</u>	<u>IP.01/F</u>
		Sheet No. <u>018001-4.3.3.31</u>	

JE RAKOWSKI BY
A. Smith 4/22/83

12" ANALYSIS (CONT)

$$F_0 = \text{SEATING TORQUE} = 739"$$

$$F_{\text{Total}} = F_D + \sqrt{F_1^2 + F_2^2 + F_C^2 + F_0^2}$$

$$F_{\text{Total}} = 1739 + \sqrt{1823^2 + 1166^2 + 1640^2 + 147^2} = 4669$$

BEARING ON SUPPORT @ TRUNION PIN

$$\text{BEARING AREA} = A_B = LD$$

WHERE L = THICKNESS OF PLATE
D = DIAMETER OF PIN

$$L = 1.5" \quad D = 1.75" \quad (\text{REF 3 \& 7})$$

$$A_B = 1.5(1.75) = 2.63$$

$$\sigma_{\text{BEARING}} = \frac{F}{A_B} = \frac{4669}{2.63} = 1775 \text{ PSI}$$

ASSUME A-36 MATERIAL: ALLOWABLE = $\frac{1}{2} S_u = 32.4 \text{ KSI}$

$$\sigma_{\text{BEARING}} = 1775 \text{ PSI} < 32.4 \text{ KSI} \therefore \text{OK}$$




Calculation Sheet		Prepared By: <i>L. Kama</i>	Date 11/30/82	
		Checked By: <i>R. L. ...</i>	Date 12/7/82	
Project	V) PPS - SEISMIC		Job No. 82044	File No. 1P.01/F
Subject	REQUALIFICATION		Sheet No.	
System	BIF AIR OPERATOR		018001-4.3.3.32	
Analysis No.	018001	Rev. No.	D	

JE RAKOWSKI
A. Shank 4/22/83


12" ANALYSIS (CONT)

CHECK BRACKET FOR BENDING



SECTION PROPERTIES: (REF 7)

$$L = 22" \quad W = 16" \quad \text{THICKNESS OF } t = .5"$$



$$\bar{y} = \frac{22(.5)(.25) + (22-2.75)(.5)(16.75)}{22(.5) + (22-2.75)(.5)} = 7.95" \text{ FROM BOTTOM}$$

$$I = \frac{22(.5)^3}{12} + \frac{(22-2.75)(.5)^3}{12} + 22(.5)(7.95-.25)^2$$
$$+ (22-2.75)(.5)(17.-7.95)^2$$

$$I = 1441 \text{ IN}^4$$

* SEE NEXT PAGE



Calculation Sheet		Prepared By:	Date
Project <u>WPPSS - SEISMIC</u>		<u>L. Kamen</u>	<u>11/30/82</u>
Subject <u>REQUALIFICATION</u>		Checked By:	Date
System <u>BIF AIR OPERATOR</u>		<u>R. Plazza</u>	<u>12/1/82</u>
Analysis No. <u>018001</u>	Rev. No. <u>0</u>	Job No. <u>82044</u>	File No. <u>1P.01/F</u>
		Sheet No. <u>018001-4.3.3.33</u>	

JE RAKOWSKI ^{BT}
A. D. 4/22/83

12" ANALYSIS (CONT)

C.G. OF BRACKET

$$\bar{Y}_{\text{SHARP}} = \frac{31(22)(.5)(\frac{31}{2})(2) + 16(14)(.5)(31-15) + 2(3)(.75)(12)(30.05)}{31(22)(.5)(2) + 16(14)(.5) + 2(3)(.75)(12)}$$

$$\frac{+(10.07)(16)(31-5) + (3)(3)(.5)(13)(2) + (3)(3)(.25)(2)(23.5)}{(10.07)(16) + (3)(3)(.5)(2) + (3)(3)(.25)(2)}$$

$$\frac{+ \frac{(7)(7)(.75)}{2} (1.75)}{\frac{7(7)(.75)}{2}} = 17.73''$$

BENDING STRESS:

$$M = (5) [586(17.73-13) + 583(38.51-13) + 30.73(586) + 51.51(593)]$$

$$M = 328411.4''$$

$$\sigma_B = \frac{328411(17.735)}{1441} = 2063 \text{ psi}$$



Calculation Sheet		Prepared By:	Date
Project <u>WPPSS - SEISMIC</u>		<u>L. Kamen</u>	<u>11/30/82</u>
Subject <u>REQUALIFICATION</u>		Checked By:	Date
System <u>BIF AIR OPERATOR</u>		<u>RP [signature]</u>	<u>12/7/82</u>
Analysis No. <u>018001</u> Rev. No. <u>0</u>		Job No.	File No.
		<u>82044</u>	<u>IP. 01/F</u>
		Sheet No.	
		<u>018001-4.3.3.34</u>	

JERAKOWSKI ^{EST} ~~MD~~
Axle 4/22/83

12" ANALYSIS (CONT)

AXIAL STRESS

$$A_{T_{min}} = (22 - 2.75)(.5) = 9.63 \text{ in}^2$$

$$F_{AXIAL} = \frac{328411}{17} + 1166 + 739 = 21223.3$$

$$\sigma_A = \frac{21223.3}{9.63} = 2204 \text{ psi}$$

COMBINE AXIAL & BENDING

$$\sigma_{TOTAL} = 2204 + 2063 = 4267 \text{ psi}$$

shear STRESS

$$V = 5.0 (W_{CYL} + W_{CRACKER})$$
$$= 5.0 (586 + 583) = 5845$$

$$AREA = 22(.5) + 9.63 = 20.63$$

$$\tau = \frac{5845}{20.63} = 283.3 \text{ psi}$$

ALLOWABLES:

$$BENDING : .6 S_u = 21,600 \text{ psi}$$

$$SHEAR : .4 S_u = 14,400 \text{ psi}$$



Calculation Sheet		Prepared By: <i>L. Korman</i>	Date <i>11/30/82</i>
Project	<i>WIPPSS-SEISMIC</i>	Checked By: <i>R. P. Carraway</i>	Date <i>12/7/82</i>
Subject	<i>REQUALIFICATION</i>	Job No. <i>82044</i>	File No. <i>1P.01/F</i>
System	<i>BIF AIR OPERATOR</i>	Sheet No. <i>018001-4.33.35</i>	
Analysis No.	<i>018001</i>	Rev. No.	<i>0</i>

JE RACOWSKI BY
A. Shank 4/22/83

12" ANALYSIS (CONT)

∴ SINCE $\sigma_{TOTAL} = 4267 < .6S_u = 21,600$
 $\tau = 340 < 14,700 \text{ PSI}$

THE BRACKET IS ACCEPTABLE

CHECK WELDS OF GUSSET :

LOAD ON WELD : 21223.3^*

AREA OF WELD = $2(.707)(.31) = .44 \text{ IN}^2$

LENGTH OF WELD = $14''$

∴ TOTAL AREA = $14(.44) = 6.16 \text{ IN}^2$

$\tau = \frac{21223.3}{6.16} = 3445 \text{ PSI} < 21000 \text{ PSI}$


∴ OK



Calculation Sheet

Project	WPPSS Equipment Seismic/Hydrodynamic Requal.	Prepared By:	J.E. Rakowski	Date	4/22/83
Subject	Requalification	Checked By:	<i>[Signature]</i>	Date	5/14/83
System	BIF Air Operators	Job No.	82044	File No.	1P.01/F
Analysis No.	018001	Rev. No.	0	Sheet No.	018001-4.3.3.36

12" ANALYSIS (CONT'D)



USE 8" ϕ 10" CYLINDER DRIVE ROD CROSS SECTIONAL AREA FOR CONSERVATISM

$$F_c = \frac{LCG}{L_{ROD}} * \bar{W}_{AO} * g_1 = \frac{10.01}{25} * 583(3+1) = 934$$

$$M_B = 7.125 * F_c = 6655 \text{ lb} \cdot \#$$

MAT'L:
AISI-4140

$$\left(\frac{M_B}{I_B} \right)_{8" \text{ CYL}} = 6655 * \frac{.6478}{.1383} = 31,172 \text{ PSI} < 86,400 \text{ PSI} \text{ OK}$$

(SHEAR NOT GOVERNING PER 8" ϕ 10" A/S. ANALYSES)

DRIVE ROD FATIGUE:

$$2 * 31,172 = 62,344 \text{ PSI} < 90,000 \text{ PSI STRESS RANGE, CATEGORY A.}$$

TRUNNION PINS

$$M_1 = \bar{W}_{AO} * g_3 * LCG = 583 * 5 * 10.01 = 29,179 \text{ lb} \cdot \#$$



Calculation Sheet

Project WPPSS Equip. Seismic/Hydrodynamic Requal.	Prepared By: J.E. Rakowski	Date 4/22/83
Subject Requalification	Checked By: <i>[Signature]</i>	Date 5/14/83
System BIF Air Operators	Job No. 82044	File No. 1P.01/F
Analysis No. 018001	Rev. No. 0	Sheet No. 018001-4.3.3.37

$$F_{23} = \frac{M_1}{x} = \frac{29,179}{12.95 \text{ (for 8" Ao)}} = 2289$$

$$F_{11} = \frac{(L_{RAD} + L_{CG})}{L_{RAD}} \frac{\bar{W}_{AO}}{2} g_1 = \frac{(25+10.01)}{25} * \frac{583}{2} * (4) = 1637 \#$$

$$F_{22} = \frac{\bar{W}_{AO}}{2} g_2 = \frac{583}{2} * 5 = 1458 \#$$

$$\left. \begin{aligned} F_{ST2} &= 739 \text{ lb. (on one transmission pin)} \\ F_{WEIGHT} &= \frac{583}{2} = 292 \text{ lb. (on one transmission pin)} \end{aligned} \right\} = 1030 \text{ lb}$$

$$\sigma = \frac{1}{.75 * 2.41 \text{ in}^2} \left\{ \left[(F_{23} + F_{22})^2 + F_{11}^2 \right]^{\frac{1}{2}} + F_{FIXED} \right\}$$

$$\sigma = \frac{1}{.75 * 2.41} \left\{ \left[(2289 + 1458)^2 + 1637^2 \right]^{\frac{1}{2}} + 1030 \right\} = 2515 \text{ PSI} < 11,840 \text{ PSI}$$


(OK)

SUPPORT BRACKET BOLTS: USE $G_H = G_V = 1.54g$ FOR BOLTS ONLY

$$\text{BOLT TENSION} = \sigma_T = \frac{M_{FB}}{4L_1 A_b} + \frac{M_{AX}}{4L_2 A_b} + \frac{F_{SS}}{4A_b}$$

USE 8" A/O DIMENSIONS FOR CONSERVATISM

$$A_b (3/4" \text{ bolt}) = .334 \text{ in}^2$$





Calculation Sheet

Project	WPPSS Equipment Seismic/Hydrodynamic Requal.	Prepared By:	J.E. Rakowski	Date	4/22/83
Subject	Requalification	Checked By:	<i>[Signature]</i>	Date	5/10/93
System	BIF Air Operators	Job No.	82044	File No.	1P.01/F
Analysis No.	018001	Rev. No.	0	Sheet No.	018001-4.3.3.38

$$M_{FB} = 583 \# (28.5 + 10.01)(1.54) + 586 (17.73)(1.54)$$


$$(W_{BR} = 586 \#, \text{SEE Pg. 28})$$

$$M_{FB} = 50,575 \text{ in}\#$$

$$M_{AX} = (583 + 586)(8)(g_H)$$

$$M_{AX} = 14,402 \text{ in}\#$$

$$F_{SS} = (583 + 586)(g_H) = 1169 \times 1.54 = 1800 \#$$



$$\sigma_T \text{ Bolts} = \frac{50,575}{4(5)(.334)} + \frac{14,402}{4(3.75)(.334)} + \frac{1800}{4(.334)} = \frac{12,598 \text{ PSI}}{< 30,000 \text{ OK}}$$

$$\sigma_T \text{ BOLTS} = \text{BOLT SHEAR: } \sigma = \left[S_{FB}^2 + S_{AX}^2 \right]^{\frac{1}{2}} \text{ (FOR A307) (S * 1.5)}$$

FROM PAGE 34:

$$F_C = \frac{\sum M_{SHAFT}}{4R} \text{ where } R = 13"$$

$$M_{SHAFT} = M_{FB} + M_{AX} = 64,977$$

$$F_C = \frac{64977}{4(13)} = 1250 \#$$



Calculation Sheet

Project WPPSS Equip. Seismic/Hydrodynamic Requal.	Prepared By: J.E. Rakowski	Date 4/22/83
Subject Requalification	Checked By:	Date
System RTF Air Operators	Job No. 82044	File No. 1P.01/F
Analysis No. 018001	Rev. No. 0	Sheet No. 018001-4.3.3.39

HORIZONTAL BOLT SHEAR DUE TO HORIZONTAL INERTIA:

$$S_{IH} = \frac{(\bar{w}_{AO} + \bar{w}_{BR}) * g_H}{4A_b}$$

$$S_{IH} = \frac{1169 * 1.54}{4(.334)} = 1347 \text{ PSI}$$

VERTICAL + DEADWEIGHT BOLT STRESS:

$$S_{IV} = \frac{1169(1+1.54)}{4A_b} = 2222 \text{ PSI}$$

$$\text{TOTAL: } (S_{IH}^2 + S_{IV}^2)^{\frac{1}{2}} = 2598 \text{ PSI}$$

ADD SHEAR STRESS DUE TO TORQUE (= $\sum M_{FB} + M_{AX}$)

$$\tau_{\text{TOTAL}} = 2598 + \frac{1250}{.334} = 6339 \text{ PSI}$$

6339 PSI < 15,000 PSI PER AISC, SEC 1.5.2.2, A307 MAT'L. (1.5*S)

NOTE : NO FATIGUE ANALYSIS FOR 12" A/O BECAUSE NO HYDRODYNAMIC LOAD CYCLING EXPERIENCED.



Calculation Sheet		Prepared By:	Date
Project	WPPSS-Seismic	<i>L. Kamen</i>	<i>12/9/82</i>
Subject	Requalification	Checked By:	Date
System	<i>BIF Air Operators</i>	<i>R. Plasencia</i>	<i>12-8-82</i>
Analysis No.	<i>018001</i>	Job No. 82044	File No.
Rev. No.	<i>0</i>		<i>IP.01/F</i>
		Sheet No.	<i>018001-4.4.1</i>

4.4 REFERENCES

1. 8" Cylinder, Dwg. No. C-26096, Flick-Reedy Corp.
2. 10" Cylinder, Dwg. No. C-26045, Flick-Reedy Corp.
3. 12" Cylinder, Dwg. No. C-26093, Flick-Reedy Corp.
4. BIF Report TR-74-7, Rev. 1, Dated 1/5/76.
5. Cylinder Support Bracket, 8" x 15" Cylinder Operator., Dwg. No. A-208293.
6. Cylinder Support Bracket, 10" x 15" Cylinder Operator, Dwg. No. A-208195.
7. Cylinder Support Bracket, 12" x 15" Center Trunion Mtd. Miller Cylinders. Dwg. # A-208274.
8. Manual of Steel Construction, AISC, 8th Ed.
9. Cygna Calculation, 82044, QID 361106, Dated 12/7/82, Rev. 2.
10. Cygna Calculation, 82044, QID 361104, Dated 7/23/82, Rev. 0.

QID 018001

APPENDIX A

SUMMARY OF A/O MODEL
USED IN PIPING ANALYSIS




Calculation Sheet


Project	WPPSS EG	Prepared By:	J. E. R. [Signature]	Date	1/3/83
Subject	BIF VALVE / ACTUATOR MODEL SUMMARY	Checked By:	H. E. [Signature]	Date	3/24/83
System	CSP	Job No.	82044	File No.	OT.01/F
Analysis No.	361104 + 106	Rev. No.	0	Sheet No.	A 1/3

SUMMARY

A) MODEL CONFIGURATION



B) ACTUAL STRUCTURE



STRUCTURAL MEMBER DIRECTIONS

- ① +X
- ② -Y
- ③ -Z
- ④ +X
- ⑤ YZ-PLANE
- ⑥ +X
- ⑦ +Y
- ⑧ +Y
- ⑨ -Y



Calculation Sheet

Project	WPPSS	Prepared By:	J. E. Kotsmold	Date	1/3/83
Subject	BIF VALVE/ACTUATOR MODEL	Checked By:	A. E. Seale	Date	3/24/83
System	CSP	Job No.	82044	File No.	OT.01/F
Analysis No.	3611046 361106	Rev. No.	0	Sheet No.	A 2/3

① VALVE EARS

8" CYL (24" VALVE)

$$\begin{aligned}
 A_x &= A_y = A_z = 15 \text{ IN}^2 \\
 I_{xx} &= 106 \text{ IN}^4 \\
 I_{yy} &= 11.2 \text{ IN}^4 \\
 I_{zz} &= 31.2 \text{ IN}^4 \\
 C_y &= 5.60 \\
 C_z &= 3.75 \\
 E &= 28 \times 10^6 \text{ PSI} \quad F_s = 11.6 \times 10^6 \text{ PSI} \\
 l &= 7.125 \text{ IN}
 \end{aligned}$$



$$\begin{aligned}
 &21 \\
 &657 \\
 &21.4 \\
 &63 \\
 &5.25 \\
 &4.75 \\
 &\checkmark \\
 &4.85 \text{ IN}
 \end{aligned}$$

② BRACKET

(Pint $e=0$ & odd 277# 15" down) 321#

$$\begin{aligned}
 A_x &= A_y = A_z = 6.84 \text{ IN}^2 & 8.5 \\
 I_{xx} &= 102 \text{ IN}^4 & 255 \\
 I_{yy} &= 1000 \text{ IN}^4 & 1000 \text{ IN}^4 \\
 I_{zz} &= 2.16 \text{ IN}^4 & 4.22 \text{ IN}^4 \\
 C_x &= .25 \text{ IN} & .313 \\
 C_z &= 6.84 \text{ IN} & 8.5 \\
 E &= 28 \times 10^6 \text{ PSI} \quad F_s = 11.6 \times 10^6 \text{ PSI} & \checkmark \\
 l &= 28.5 \text{ IN} \text{ (15" down to CG)}
 \end{aligned}$$

③ & ④ BRACKET OFFSETS $L_3 = 8.8 \text{ IN}$ $L_4 = 6.875 \text{ IN}$
 8.5 IN 8.0 IN

③ MASSLESS, RIGID LINK, 8.8" LONG (8.5)

④ " " , 6.875" " (8.0)

(END RELEASE FOR ROTATION
 θ_{xx} ON ④)



Calculation Sheet

Project	W P P S S EQ	Prepared By:	J. E. [Signature]	Date	11/3/83
Subject	BIF VALVE/ACTIVATOR MODEL SUMMARY	Checked By:	A. E. [Signature]	Date	3/24/83
System	CSP	Job No.	82044	File No.	OT.01/F
Analysis No.	361106+361104	Rev. No.	0	Sheet No.	A 3/3

⑤ SHAFT OFFSET

RIGID LINK 14.48" LONG (14.30)
AT 52.6° ↑ AS SHOWN

⑥ SHAFT

$$\begin{aligned}
 A_x = A_y = A_z &= 3.98 \text{ IN}^2 && 4.91 \\
 I_{xx} &= 2.52 \text{ IN}^4 && 3.04 \\
 I_{yy} &= 4 \text{ " } && 5.75 \\
 I_{zz} &= 1.26 \text{ " } && 1.92 \\
 C_y &= 1.125 && 1.25 \\
 C_z &= 1.125 && 1.25 \\
 E &= 29 \times 10^6 \text{ PSI } E_s = 11.6 \times 10^6 \text{ PSI} \\
 l &= 14 \text{ in.} && 12.85 \text{ " }
 \end{aligned}$$

⑦ DRIVE ROD

$$\begin{aligned}
 A_x = 2.41 \quad A_y = 2.41 \quad A_z &= 2.41 \text{ IN}^2 && 2.41 \text{ IN}^2 \\
 I_{xx} = I_{zz} &= .46 \text{ IN}^4 && .46 \text{ IN}^4 \\
 I_{yy} &= .92 \text{ IN}^4 && .92 \text{ IN}^4 \\
 C_x = C_z &= .875 \text{ IN} && .875 \text{ IN} \\
 \text{HIGH STREN. } \star E &= 30 \times 10^6 \text{ PSI } E_s = 12 \times 10^6 \text{ PSI}
 \end{aligned}$$

⑧ & ⑨ CYLINDER

(PUT P=0 & ADD 399# AT END.) → 593#

$$\begin{aligned}
 L_8 &= 13.5 \text{ " } && 13.5 \text{ " } \\
 L_9 &= 14.0 \text{ " } && 19 \text{ " } \\
 I_{yy} &= 74 \text{ IN}^4 && 180 \text{ IN}^4 \\
 I_{xx} = I_{zz} &= 52 \text{ IN}^4 && 127 \text{ IN}^4 \\
 A_x = A_y = A_z &= 50 \text{ IN}^2 && 78 \text{ IN}^2 \\
 C_x = C_z &= 4 \text{ " } && 5 \text{ IN}
 \end{aligned}$$



Calculation Sheet

Project	Prepared By:	Date
Subject	Checked By:	Date
System	Job No.	File No.
Analysis No.	Rev. No.	Sheet No.

APPENDIX B & C

AIR CYLINDER BUSHING PRESSURE EQUATIONS




Calculation Sheet

Project	WPPSS EQ	Prepared By:	J. P. [Signature]	Date	2/18/83
Subject	AIR CYLINDER BUSHING PRESSURE	Checked By:	A. E. [Signature]	Date	3/22/83
System	CEP, CSP	Job No.	82044	File No.	OP.01/F
Analysis No.	018001	Rev. No.	6	Sheet No.	APPENDIX B - PG. 1/3

ANALYSIS FOR A/O BUSHING SIDE LOAD PRESSURE

$$\text{BUSHING PRESSURE} = \frac{\text{BUSHING FORCE}}{\text{AREA}}$$

BUSHING FORCE CALCULATED FROM F_c (AT CLEVIS)



$$P = F_c \frac{(L_{DR} + d)}{dA}$$

REF — FOR BOTH 8" & 10" A/O, $A_{10} = 2.075 \text{ in}^2$.

WORST CASE IS FOR VALVE-OPEN, WHERE L_{DR} IS MAXIMUM & d IS MINIMUM, 15" STROKE IN EACH CASE.

8"	10"
$L_{DR}(\text{OPEN}) = 40 - 13.5 = 26.5$	$= L_{DR}(\text{OPEN}) 8" \& 10"$
$d: \text{CYL. LEN.} = 51.5"$	$= 64"$

ASSUME PISTON CENTER IS 6" FROM END WHEN ON CLOSED STOP, $51.5 - 6 = 45.5"$ $64 - 6 = 58"$

$\therefore d = 45.5 - 15 = 30.5"$	$58 - 15 = 43"$
------------------------------------	-----------------



Calculation Sheet

Project	WPPSS EQ	Prepared By:	J. E. Paluszki	Date	2/18/83
Subject	AIR CYLINDER BUSHING PRESSURE	Checked By:	A. E. Stark	Date	3/22/83
System	CEP, CSP	Job No.	82044	File No.	OP.01/F
Analysis No.	018001	Rev. No.	0	Sheet No.	APPENDIX B, PG. 2/3

FOR CYLINDER DRIVE ROD IN OPEN POSITION:

	8"	10"
L _{ROD OPEN}	40"	40"
L _{CG OPEN}	10.96"	16.25"
L _{DR}	26.5"	26.5"
d _o	30.5"	43"
A _{Bushing}	2.075"	2.075 in ²

$$F_{c|o} = \frac{L_{CG|OPEN} \times W_{AO} \times g_1}{L_{ROD|OPEN}}$$

$$P_{BUSHING} = \frac{F_{c|o} (L_{DR} + d)}{d \times A_{Bushing}}$$

THESE EQUATIONS AND PARAMETERS WERE INCORPORATED INTO THE COMPUTER PROGRAMS FOR CALCULATION OF VALVE AND AIR OPERATOR COMPONENT STRESSES IN QID 361106 & 361104.


BUSHING PRESSURE AS CALCULATED BY THE SRSS METHOD IN THE PROGRAMS CAN BE USED TO BACK-CALCULATE AN IN-SITU LOAD F_e TO TEST FOR CYLINDER OPERABILITY. SEE NEXT PAGE.

(CONTINUED)



Calculation Sheet

Project	WPPS EQ	Prepared By:	J E Rodowski	Date	2/19/83
Subject	AIR CYLINDER BUSHING PRESSURE	Checked By:	H. E. ...	Date	3/22/83
System	CSP, CEP	Job No.	82044	File No.	OP.01/F
Analysis No.	018001	Rev. No.	0	Sheet No.	APPENDIX B, PG. 3/3



$L = 51.5''$ for 8" A0
 $= 64''$ for 10" A0
 REF: BIF XMITTAL 11/9/82, SEC. 7.0

$$F_c = \frac{L_{CG} |_0}{L_{ROD} |_0} \bar{W}_{A0} * g_1 = P_{BUSHING} * A_{BUSHING} * \frac{d |_0}{l = 57''}$$

(8") Cylinder Open - Position Parameters are used because in situ tests are to be performed, if necessary, on CSP-V-3 & 4, from the open position to fail-closed. (SEE 4.3.1). Bushing pressure was calculated in QID 36106 & 36104 with open-position parameters because this is where pressures are greatest in stroke.

From 36106:

$$\begin{aligned}
 L_{CG} |_0 &= 10.96'' \\
 L_{ROD} |_0 &= 40'' \\
 d |_0 &= 30.5'' \\
 W_{A0} &= 399 \# \\
 A_{BUSH} &= 2.075 \text{ in}^2
 \end{aligned}$$

TEST FORCE:

$$\therefore F_{\text{end of cyl}} (51.5 - 13.5) = 40 F_c$$

$$\begin{aligned}
 F_e &= \frac{40}{(51.5 - 13.5)} * P_B * A_B * \frac{d |_0}{l = 57} \\
 &= 1.05 * P_B * 2.075 * \frac{30.5}{57}
 \end{aligned}$$

FOR TESTING:

★ USE ONLY THE DYNAMIC COMP. OF P_B IN 36106. $F_e = 1.17 P_B$ (#'s) ★




Calculation Sheet

Project	WPPSS - EQUIPMENT QUALIFICATION	Prepared By:	Honkshank	Date	4/25/83
Subject	AIR CYLINDER BUSHING PRESSURE	Checked By:		Date	
System	CSP, CEP, ROA, REA	Job No.	82044	File No.	0P01/F
Analysis No.	81D 018001	Rev. No.	0	Sheet No.	APPENDIX C, Pg 1/2

EXTRAPOLATING APPENDIX B APPROACH AND APPLYING TO 12" AIR CYLINDER PARAMETERS

12" CYLINDER	
L_{ROD} RETRACTED	24"
L_{CG} RETRACTED	10.01"
L_{DR}	14"
d_{DR}	41"
$A_{BUSHING}$	$2.373 \cdot 2$
$L_{CYLINDER LENGTH}$	47"

REF DWG C-26093
A-206759



CALCULATION IS FOR THE ROD RETRACTED CONDITION

* ASSUME PISTON CENTER IS 6" FROM END WHEN ON CLOSED STOP

$$d_{R} = 47 - 6 = 41"$$

TEST FORCE:

$$F_{e(CND)} (47 - 11) = F_{e(RET)} (25)$$

$$K_{A0} = 583 \#$$

$$g_1 = 1.54 \text{ (LOAD COMPAR. SECS)}$$

$$F_{e(RET)} = \frac{L_{CG(RET)} \times W_{A0} \times g_1}{L_{ROD(RET)}} \rightarrow P_{BUSH} = \frac{F_{e(RET)} (L_{DR} + d_R)}{A_{BUSH} \times d_R}$$

$$F_{e(END)} = \left(\frac{25}{36} \right) P_B (2.373)(41) \left(\frac{1}{14+41} \right) \quad F_{e(RET)} = \left(\frac{7.25}{24} \right) (583)(1.54)$$

$$F_{e(END)} = 1.23 P_B$$

$$F_{e(RET)} = 271.22 \#$$

$$P_{BUSH} = \frac{(271.22)(14+41)}{(41)(2.373)}$$

$$P_{BUSH} = 153.32 \text{ PSI} < 200 \text{ PSI}$$

(MILLER'S EXTENDED USE ALLOW STRESS)

(SEE TELECON

SECTION 7.0)



Calculation Sheet

Project	WPPSS - EQUIPMENT QUALIFICATION	Prepared By:	Don Seale	Date	4/25/83
Subject	AIR CYLINDER BUSHING PRESSURE	Checked By:		Date	
System	ROA & REA	Job No.	82044	File No.	1P.01.F
Analysis No.	018001	Rev. No.	0	Sheet No.	APPENDIX C 2/2

CONSIDER ROD EXTENDED CONDITION OF CYLINDER
12" CYLINDER (ROD EXTENDED)

$L_{ROD/EXTEND}$	36" (ASSUME 5 1/2" CLOSIS)
$L_{CG/EXTEND}$	7.13
L_{DR}	$36 - 11 = 25$
d/E^*	$(41 - 15) = 26$
A_{BUSH}	2.373 in^2
L_{CL}	47"

* ASSUME PISTON CENTER IS 6" FROM END WHEN RETRACTED

$$F_{C(EXTEND)} = \frac{L_{CG(EXT)} \times W_{AOK} g_i}{L_{ROD(EXT)}} = \frac{7.13}{36} (583)(1.54)$$

$$F_{C(EXTEND)} = 177.82 \#$$

$$P_{PUSH} = \frac{F_{C(EXT)} (L_{DR} + d_E)}{A_{BUSH} (d_E)}$$
$$= \frac{178(25 + 26)}{2.373(26)}$$

$$P_{PUSH} = 147 \text{ PSI} < 200 \text{ PSI}$$


∴ OPERABILITY TEST NOT REQUIRED FOR 12" OPERATOR

5.0 - CONTENTS

- 5.1 Response Spectra
- 5.2 Walkdown Sheets
- 5.3 SRM Sheets
- 5.4 Load Comparative Sheets
- 5.5 Revised B&R Inc. Piping Analysis Accelerations


5.1 - RESPONSE SPECTRA

NO 82045 DID 001




HPPSS, HANFORD NO.2, REACTOR BUILDING, MODEL NO. 2 REV. 1
SSE (DBE) FLOOR SPECTRUM - HORIZONTAL
MASS NO.2, EL. 605'-10.5", DAMPING=0.02

NO 82045 DID 001




CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. 1P.01.F
SHEET NO. 5/12

WPPSS, HANFORD NO. 2, REACTOR BUILDING, MODEL NO. 2 REV. 1
SSE (DBE) FLOOR SPECTRUM - COMBINED VERTICAL
MASS NO. 2, EL. 605'-10.5", DAMPING=0.02



WPPSS REACTOR BLDG. SRSS OF SRV SSE AP/CHUG.
 MASS NO. 186 EL. 541 FT. VERT. TRANSLATION
 CONTAINMENT VESSEL DAMPING= .005, .01, .02, .04




WPPSS REACTOR BLDG. SRSS OF SRV SSE AP/CHUC.


MASS NO. 187 EL. 558 FT. HORIZ. TRANSLATION

CONTAINMENT VESSEL

DAMPING= .005, .01, .02, .04



WPPSS REACTOR BLDG. SRSS OF SRV SSE AP/CHUG.
 MASS NO. 182 EL. 500 FT. VERT. TRANSLATION
 CONTAINMENT VESSEL DAMPING= .005, .01, .02, .04



WPPSS REACTOR BLDG. SRSS OF SRV SSE AP/CHUG.

MASS. NO. 182 EL. 500 FT. HORIZ. TRANSLATION

CONTAINMENT VESSEL

DAMPING= .005, .01, .02, .04

5.2 Walkdown Sheets



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM



EPN# CSP-V-1

QID# 361104

BLDG R

FLOOR EL 501

COORDS M.5/7.6

MFR BIF

COMPONENT EL 508

DSCRPT 30" BFLY

MOD# A206763

SERIAL# _____

MAT'L _____

PSI @ _____ °F

LBS _____ SIZE _____

ASME CLASS _____

YOKE ORIENTATION

⊥ TO AXIS OF PIPE ()

// TO AXIS OF PIPE ()

YOKE LENGTH _____
(FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS _____


BOLT TYPE _____ BOLT Ø _____

WELD TYPE & SIZE _____

PIPE MOUNTED YES () NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()

FULL (6WAY) ANCHOR BETWEEN COMPONENT & PRI CONT YES () NO ()



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

CYGNA
ATTACHMENT
JOB NO. 82644
FILE NO. 1P.01.F
SHEET NO. 5.2.1

OPERATOR EPN _____ MANUFACTURER _____

MODEL NO _____ SERIAL NO _____

TYPE _____ SIZE _____ ORDER NO _____

MOTOR EPN _____ MANUFACTURER _____

MODEL NO _____ SERIAL NO _____

ID NO _____ INS CLASS _____ 1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: Definition (N/F = Not Found)

Component not installed as of 7/19/82


△ VISUAL INSPECTION PERFORMED 12/22/82; IT WAS NOTED VALVE NOT INSTALLED. SEE SHEET 2 OF 2.

PREPARED BY Doug True DATE 7/19/82 REVIEWED BY William Cunha DATE 7/19/82

(SIGNATURE) (SIGNATURE)


△ Doug True 1/5/83

William Cunha




Calculation Sheet


Project	<u>WNP #2</u>	Prepared By:	<u>Jim Seale</u>	Date	<u>12/22/82</u>
Subject	<u>EQUIP. QUALIFICATION</u>	Checked By:	<u>E. Robinson</u>	Date	<u>1/4/83</u>
System		Job No.	<u>82044</u>	File No.	
Analysis No.	<u>QID 361104</u>	Rev. No.		Sheet No.	<u>2 OF 2</u>



CSP-V-1,2 (TOP VIEW)



PLAN VIEW (B-B)



SECTION VIEW A-A

$\theta \approx 7^\circ$ — CSP-V-1
 $\theta \approx 6^\circ$ — CSP-V-2

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>IP.O/F</u>
SHEET NO. <u>5.2.2</u>

FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION, ONLY)



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM



EPN# CSF-V-2

QID# 361104

COORDS M.5/7.4

DSCRIP 30" BFLY

MAT'L _____

LBS _____ SIZE _____

ASME CLASS _____

BLDG R

FLOOR EL 501

MFR BIF

COMPONENT EL 508

MOD# A-206763

SERIAL# _____

PSI @ _____ °F

YOKE ORIENTATION

L TO AXIS OF PIPE ()

// TO AXIS OF PIPE ()

YOKE LENGTH _____
(FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS _____


BOLT TYPE _____ BOLT Ø _____

WELD TYPE & SIZE _____


PIPE MOUNTED YES () NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()

FULL (6WAY) ANCHOR BETWEEN COMPONENT & PRI CONT YES () NO ()



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. 12.01.F
SHEET NO. 5.2.3

OPERATOR EPN _____ MANUFACTURER _____

MODEL NO _____ SERIAL NO _____

TYPE _____ SIZE _____ ORDER NO _____

MOTOR EPN _____ MANUFACTURER _____

MODEL NO _____ SERIAL NO _____

ID NO _____ INS CLASS _____ 1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: Definition (N/F = Not Found) Limit Switch
VISUAL INSPECTION PERFORMED 12/22/82 + IT WAS NOTED VALVE INSTALLED SEE SHEET 2 OF 2
Note: Not installed as of 7/19/82

PREPARED BY Doug True (SIGNATURE) DATE 7/19/82 REVIEWED BY William Cunha (SIGNATURE) DATE 7/19/82


Doug True
L. J. ... 1/5/83

WILLIAM CUNHA




Calculation Sheet


Project	KNP #2	Prepared By:	Jim Seale	Date	12/22/82
Subject	EQUIP. QUALIFICATION	Checked By:	J E Robinson	Date	1/4/83
System		Job No.	82044	File No.	
Analysis No.	QID#361104	Rev. No.		Sheet No.	2 OF 2



CSP-V-1,2 (TOP VIEW)



PLAN VIEW (B-B)



$\theta \approx 7^\circ$ — CSP-V-1
 $\theta \approx 6^\circ$ — CSP-V-2
 SECTION VIEW A-A

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. I.P.O.I.F
SHEET NO. 5.2.4

FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION, ONLY)

EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM



EPN# CSP-V-3

QID# 361106

BLDG R

FLOOR EL 501.47

COORDS M.1/7.6

MFR BTF 0657

COMPONENT EL 481

DSCRPT 24" BFLY
Cont Isol Valve

MOD# DWG A20764

SERIAL# N27235-1

MAT'L SA-516-GR-70

150 PSI @ 275 °F

LBS N/F SIZE 24"

ASME CLASS N/F

YOKE ORIENTATION

⊥ TO AXIS OF PIPE (✓)

// TO AXIS OF PIPE (✓)

YOKE LENGTH 0'-4 1/2"
(FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS N/A

BOLT TYPE N/A BOLT Ø N/A


WELD TYPE & SIZE N/A

PIPE MOUNTED YES (✓) NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO (✓)

IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES () NO () N/F

DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO () N/F



GLOBAL CO-ORDINATE SYSTEM

CYGNA
ATTACHMENT
 JOB NO. 82044
 FILE NO. 1.P.O.I.F
 SHEET NO. 512.5

SECT OF PIPE NOT INSTALLED
SEE COMMENT #1

VALVE STEM ORIENTATION

OPERATOR EPN COVERED W/ PLASTK

MANUFACTURER _____

MODEL NO _____

SERIAL NO _____

TYPE _____ SIZE _____

ORDER NO _____

MOTOR EPN N/A NOT MOTOR OPERATED

MANUFACTURER _____

MODEL NO _____

SERIAL NO _____

ID NO _____ INS CLASS _____

1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: Definition (N/F = Not Found)

* CSP-LMS-3

1. LENGTH OF PIPE HAS NOT BEEN INSTALLED FROM
VALVE TO CONTAINMENT.

PREPARED BY William Cunha (SIGNATURE)

DATE 7/21/07

REVIEWED BY Doug True (SIGNATURE)

DATE 7/21/07


William Cunha
A. Searle 15163

Doug True




Calculation Sheet

Project	WNP#2	Prepared By:	Don Clark	Date	12/22/82
Subject	EQUIP. QUALIFICATION	Checked By:	J. E. R. Albrecht	Date	1/4/83
System	CEP/CSP	Job No.	82044	File No.	
Analysis No.	QID#361106	Rev. No.		Sheet No.	



PLAN CSP-V-3,4 (TYP VIEW)



SECTION A-A

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. 1P.01.F
SHEET NO. 5.2.6

CSP-V-3 - 0 ~ 7°
 CSP-V-4 - 0 ~ 6°

FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION ONLY)

EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM



EPN# CSP-V-4
QID# 361106
COORDS 7.6 / 19.6
DSCR# 24" BFLY
CONT. ISOL VALVE
MAT'L SA-516-GR-70
LBS N/F SIZE 24"
ASME CLASS N/F

BLDG R FLOOR EL 47'
MFR BIF COMPONENT EL 47'
MOD# DWS 125744 0657 SERIAL# 272-35-2
150 PSI @ 275 °F


YOKE ORIENTATION

⊥ TO AXIS OF PIPE (✓)
// TO AXIS OF PIPE (✓)
YOKE LENGTH 0' - 4 1/2"
(FLANGE TO FLANGE)


MOUNTING CONDITION

NO OF BOLTS N/A
BOLT TYPE N/A BOLT Ø N/A
WELD TYPE & SIZE N/A
PIPE MOUNTED YES (✓) NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO (✓)
IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES () NO () N/F
DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO () N/F



GLOBAL CO-ORDINATE SYSTEM



SECT OF PIPE NOT INSTALLED
SEE COMMENT #1
VALVE STEM ORIENTATION

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. 1P.01.F
SHEET NO. 5.2.7

OPERATOR EPN COVERED W/ PLASTIC MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
TYPE _____ SIZE _____ ORDER NO _____

MOTOR EPN N/A NOT MOTOR OPERATED MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
ID NO _____ INS CLASS _____ 1-PHASE () 3-PHASE () AC _____ DC _____


COMMENTS: Definition (N/F = Not Found)
1. LENGTH OF PIPE HAS NOT BEEN INSTALLED FROM VALVE TO CONTAINMENT.

PREPARED BY William C. ... DATE 7/21/12 REVIEWED BY Doug True DATE 7/21/12
(SIGNATURE) (SIGNATURE)
William C. ... 115113
Doug True




Calculation Sheet

Project	WNP#2	Prepared By:	Don Clark	Date	12/22/82
Subject	EQUIP. QUALIFICATION	Checked By:	ER Alworth	Date	1/4/83
System	CEP/CSP	Job No.	82044	File No.	
Analysis No.	QID#361106	Rev. No.		Sheet No.	



PLAN CSP-V-3,4 (TYP VIEW)



SECTION A-A

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. 1201R
SHEET NO. 528

CSP-V-3 - $\theta \sim 7^\circ$
 CSP-V-4 - $\theta \sim 6^\circ$

FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION ONLY)

EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM



EPN# CSP-V-5

QID# 361106

BLDG R

FLOOR EL 471

COORDS M.7 | P.3

MFR GIF

COMPONENT EL 475

DSCRIP 24" BFLY

MOD# DWG A20765

SERIAL# 27236-1

MAT'L _____

_____ PSI @ _____ °F

LBS _____ SIZE _____

ASME CLASS _____

YOKE ORIENTATION

L TO AXIS OF PIPE ()

// TO AXIS OF PIPE ()

YOKE LENGTH _____

(FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS _____

BOLT TYPE _____ BOLT Ø _____


WELD TYPE & SIZE _____

PIPE MOUNTED YES () NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()

IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES () NO ()

DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO ()



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

CYGNA

ATTACHMENT

JOB NO. 82044

FILE NO. IP.01/E

SHEET NO. 5.29

OPERATOR EPN _____ MANUFACTURER _____

MODEL NO _____ SERIAL NO _____

TYPE _____ SIZE _____ ORDER NO _____

MOTOR EPN _____ MANUFACTURER _____

MODEL NO _____ SERIAL NO _____

ID NO _____ INS CLASS _____ 1-PHASE () 3-PHASE () AC _____ DC _____

Δ VISUAL INSPECTION MADE 2/22/82 IT WAS NOTED VALVE INSTALLED SEE SHEET 20PZ

COMMENTS: Definition (N/F = Not Found)

Valve not installed as of 7/21/82

PREPARED BY William Cunha DATE 7/21/82 REVIEWED BY Doug True DATE 7/21/82

(SIGNATURE) (SIGNATURE)

William Cunha


Δ A. Shank 1/5/83

Doug True




Calculation Sheet

Project	WIND #2	Prepared By:	Alan Clark	Date	12/22/82
Subject	EQUIP. QUALIFICATION	Checked By:	E. R. ...	Date	1/4/83
System		Job No.	82044	File No.	
Analysis No.	DID # 361106	Rev. No.		Sheet No.	2 OF 2



CSP-V-5




CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. I.P.O.I.F.
SHEET NO. 5.2.10

AIR OPERATOR

PARALLEL PROJECT
~ 8°
24" CSP(1)-1

PLAN VIEW

FIELD SKETCH (FOR THE PURPOSE OF SHOWING OPERATOR ORIENTATION ONLY.)



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

EPN# CSP-V-6
QID# 361106
COORDS N.5 / 7.7
DSCRIP 24" BFLY
MAT'L _____
LBS _____ SIZE _____
ASME CLASS _____

BLDG R FLOOR EL 471
MFR BIF COMPONENT EL 480
MOD# A-206765 SERIAL# _____
PSI @ _____ °F


YOKE ORIENTATION

TO AXIS OF PIPE ()
 // TO AXIS OF PIPE ()
YOKE LENGTH _____
(FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS _____
BOLT TYPE _____ BOLT Ø _____
WELD TYPE & SIZE _____
PIPE MOUNTED YES () NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()
IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES () NO ()
DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO ()



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

CYGNA
ATTACHMENT
JOB NO. 820
FILE NO. 1P.01.F
SHEET NO. 5.2.11

OPERATOR EPN _____ MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
TYPE _____ SIZE _____ ORDER NO _____

MOTOR EPN _____ MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
ID NO _____ INS CLASS _____ 1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: Definition (N/F = Not Found)

X CSP-LMS-6 1. Not installed as of 7/21/82


VISUAL INSPECTION MADE 12/22/82 & IT WAS NOTED VALVE INSTALLED SEE SHEET 20FZ
PREPARED BY William Cunha DATE 7/21/82 REVIEWED BY Doug True DATE 7/21/82
(SIGNATURE) (SIGNATURE)

WILLIAM CUNHA 11/5/83 Doug True




Calculation Sheet

Project	WNP#2	Prepared By:	Jim Shank	Date	12/22/82
Subject	EQUIP. QUALIFICATION	Checked By:	E. Robinson	Date	1/4/83
System	CEP/CES	Job No.	82044	File No.	
Analysis No.	QID# 361106	Rev. No.		Sheet No.	2 OF 2



PLAN VIEW CSA-V-6



SECTION A-A

CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>1P.O.I.E.</u>
SHEET NO. <u>5.2.12</u>

FIELD SKETCH (FOR THE PURPOSE OF DEPICTING OPERATOR ORIENTATION, ONLY)

EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM



EPN# CSP-V-9
QID# 361106
COORDS M9/S.1
DSCR# 24" BFLY
MAT'L _____
LBS _____ SIZE _____
ASME CLASS _____

BLDG R FLOOR EL 471
MFR BIF COMPONENT EL 490
MOD# A20765 SERIAL# _____
_____ PSI @ _____ °F


YOKE ORIENTATION

| TO AXIS OF PIPE ()
// TO AXIS OF PIPE ()
YOKE LENGTH _____
(FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS _____
BOLT TYPE _____ BOLT Ø _____
WELD TYPE & SIZE _____
PIPE MOUNTED YES () NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()
IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES () NO ()
DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO ()



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

CYGNA
ATTACHMENT
JOB NO. 82024
FILE NO. IPDIF
SHEET NO. 5.2.13

OPERATOR EPN _____	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
TYPE _____ SIZE _____	ORDER NO _____
MOTOR EPN _____	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
ID NO _____	INS CLASS _____
	1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: Definition (N/F = Not Found)
Note: not installed as of 7/21/82

PREPARED BY William Cunha DATE 7/21/82 REVIEWED BY Doug True DATE 7/21/82
(SIGNATURE) (SIGNATURE)
WILLIAM CUNHA Doug True



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

EPN# CEP-V-1A

QID# 361104

BLDG R

FLOOR EL 548

COORDS J4/5.4

MFR BIF

COMPONENT EL 558

DSCRIP 30" Butterfly

MOD# A-206763

SERIAL# 27234-3

MAT'L SA-516-GR70

45 PSI @ 340 °F

LBS N/A SIZE 30"

ASME CLASS 2

YOKE ORIENTATION

TO AXIS OF PIPE ()

// TO AXIS OF PIPE () N/A

YOKE LENGTH N/A
(FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS N/A

BOLT TYPE N/A BOLT Ø N/A


WELD TYPE & SIZE N/A

PIPE MOUNTED YES () NO () bolted flanges


PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()

IS COMP BETWEEN CONT & 1ST ANC. (FULL 6 WAY ANC) YES () NO ()

DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO ()



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. 1201.F
SHEET NO. 5.2.14

OPERATOR EPN N/A MANUFACTURER _____

MODEL NO _____ SERIAL NO _____

TYPE _____ SIZE _____ ORDER NO _____

MOTOR EPN N/A MANUFACTURER _____


MODEL NO _____ SERIAL NO _____

ID NO _____ INS CLASS _____ 1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: 2 Limit Switches Found
Model: 1707100
EA74080100

EPN's: not known
Manufacturer: Nanco Controls

PREPARED BY Doug Ince DATE 7/14/82 REVIEWED BY William Cunha DATE 7/14/82
(SIGNATURE) (SIGNATURE)
David Tarr WILLIAM CUNHA



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

EPN# CEP-V-2A
QID# 361104
COORDS 5.4/5.4
DSCRIP 30" Butterfly
MAT'L SA-516-GR 70
LBS N/A SIZE 30"
ASME CLASS 2

BLDG R FLOOR EL 548
MFR BIF COMPONENT EL 558
MOD# 0657 SERIAL# 27234-4
45 PSI @ 340 °F


YOKE ORIENTATION

| TO AXIS OF PIPE ()
// TO AXIS OF PIPE () N/A
YOKE LENGTH N/A
(FLANGE TO FLANGE)


MOUNTING CONDITION

NO OF BOLTS N/A
BOLT TYPE N/A BOLT Ø N/A
WELD TYPE & SIZE N/A
PIPE MOUNTED YES () NO () bolted flanges

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()
IS COMP BETWEEN CONT & 1ST ANC. (FULL 6 WAY ANC) YES () NO ()
DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO ()



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

CYGIA
ATTACHMENT
JOB NO. 82044
FILE NO. 7R01E
SHEET NO. 52/5

OPERATOR EPN <u>N/A</u>	MANUFACTURER _____
MODEL NO <u>N/A</u>	SERIAL NO _____
TYPE _____ SIZE _____	ORDER NO _____
MOTOR EPN <u>N/A</u>	MANUFACTURER _____
MODEL NO _____	SERIAL NO _____
ID NO _____ INS CLASS _____	1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: 2 Limit Switches found Manufactures: Nanco Controls
Model #: 1703100 EPN: CEP-LMS-2A
: EA 74080100
PREPARED BY Dave Doyel DATE 7/14/82 REVIEWED BY William C. ... DATE 7/14/82
(SIGNATURE) (SIGNATURE)



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

EPN# CEP-V-3A
QID# 311106
COORDS H.5/5.4
DSCRIP 24. BLFY SUPP Chamber Exhaust
MAT'L SA-516 GR-N/F
LBS N/F SIZE 2 1/2"
ASME CLASS N/F

BLDG R FLOOR EL 471
MFR BIF COMPONENT EL 495
MOD# DWG A-20174 SERIAL# N27235-3
150 PSI @ 275 °F


YOKE ORIENTATION

⊥ TO AXIS OF PIPE (✓)
// TO AXIS OF PIPE (✓)
YOKE LENGTH 0' - 4 1/2"
(FLANGE TO FLANGE)


MOUNTING CONDITION

NO OF BOLTS N/A
BOLT TYPE N/A BOLT Ø N/A
WELD TYPE & SIZE N/A
PIPE MOUNTED YES (✓) NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO (✓)
IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES (✓) NO ()
DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO (✓)



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

CYGNA
ATTACHMENT
JOB NO. 82084
FILE NO. IP.01.F
SHEET NO. 5.2.16

OPERATOR EPN N/A MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
TYPE _____ SIZE _____ ORDER NO _____

MOTOR EPN N/A MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
ID NO _____ INS CLASS _____ 1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: Definition (N/F = Not Found)

* CEP-LMS-3A
Δ SEE SHEET 2 OF 2 FOR OPERATOR ORIENTATION

PREPARED BY William C. ... DATE 7/21/82 REVIEWED BY Doug True DATE 7/21/82
(SIGNATURE) (SIGNATURE)

WILLIAM C. ...
Δ by search 1/5/83
Doug True





Calculation Sheet


Project	WPPS MECH. E.Q.	Prepared By:	J. E. Rodriguez	Date	12/18/82
Subject	BIF VALVE & AO	Checked By:	M. E. Seank	Date	12/20/82
System	CSP/CEP	Job No.	82044	File No.	
Analysis No.		Rev. No.		Sheet No.	2/2

WALK DOWN
 VALVE & OPERATOR ORIENTATIONS
 CEP - V - 3A & 4A




CEP - V - 3A :



CYGNA
ATTACHMENT
JOB NO. <u>82044</u>
FILE NO. <u>1P.01.F</u>
SHEET NO. <u>5.2.17</u>



CEP - V - 4A :



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM



EPN# CEP-V-4A
QID# 361106
COORDS H.5/S.4
DSCRPT 24" BFLY
MAT'L SA-516 GR -1/8
LBS N/F SIZE 24"
ASME CLASS N/F

BLDG R FLOOR EL 471
MFR BIF COMPONENT EL 495
MOD# ~~DWB A 206764~~ 0657 SERIAL# N 27235-4
150 PSI @ 275 °F


YOKE ORIENTATION

⊥ TO AXIS OF PIPE (✓)
 // TO AXIS OF PIPE (✓)
YOKE LENGTH 0'-4 1/2"
(FLANGE TO FLANGE)


MOUNTING CONDITION

NO OF BOLTS N/A
BOLT TYPE N/A BOLT Ø N/A
WELD TYPE & SIZE N/A
PIPE MOUNTED YES (✓) NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO (✓)
IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES (✓) NO ()
DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO (✓)



GLOBAL CO-ORDINATE SYSTEM



VALVE STEM ORIENTATION

CYGNA
ATTACHMENT
JOB NO. 32044
FILE NO. 1P.01.R
SHEET NO. 52.18

OPERATOR EPN N/A MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
TYPE _____ SIZE _____ ORDER NO _____

MOTOR EPN N/A MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
ID NO _____ INS CLASS _____ 1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: Definition (N/F = Not Found)

* CEP-LMS-4A not found
▲ SEE SHEET 2 OF 2 FOR OPERATOR ORIENTATION

PREPARED BY William Amador DATE 7/1/82 REVIEWED BY Doug True DATE 7/21/82
(SIGNATURE) (SIGNATURE)

William Amador 7/1/82 Doug True 7/21/82
William Amador 7/1/82 Doug True






Calculation Sheet

Project	WPPS MECH. E.Q.	Prepared By:	J. E. Radkowski	Date	12/18/82
Subject	BIF VALVE & AO	Checked By:	M. E. Seank	Date	12/20/82
System	CSP / CEP	Job No.	82044	File No.	
Analysis No		Rev. No.		Sheet No.	2/2





WALK DOWN
 VALVE & OPERATOR ORIENTATIONS
 CEP - V - 3A & 4A

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. 1P.01F
SHEET NO. 5.2.19

CEP - V - 3A:



CEP - V - 4A:



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM



EPN# REA-V-1
QID# 361102
COORDS H.2/6.2
DSCRPT 72" BFLY
MAT'L SA-516-GR60
LBS N/F SIZE N/F
ASME CLASS N/F

BLDG R FLOOR EL 572
MFR BIF COMPONENT EL 597
MOD# DWG A206760 SERIAL# 27230-1
1 PSI @ 110 °F



YOKE ORIENTATION

L TO AXIS OF PIPE ()
// TO AXIS OF PIPE ()
YOKE LENGTH 0'-7"
(FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS N/A
BOLT TYPE N/A BOLT Ø N/A
WELD TYPE & SIZE N/A
PIPE MOUNTED YES () NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()
IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES () NO ()
DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO ()



CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. 1.P.011F
SHEET NO. 5.2.20

GLOBAL CO-ORDINATE SYSTEM

VALVE STEM ORIENTATION

OPERATOR EPN N/A MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
TYPE _____ SIZE _____ ORDER NO _____

MOTOR EPN N/A MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
ID NO _____ INS CLASS _____ 1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: Definition (N/F = Not Found)

* REA-LMS-1 not accessible / no staging.
1. not motor operated

PREPARED BY Doug True DATE 7/21/12 REVIEWED BY William Cunha DATE 7/21/12
(SIGNATURE) (SIGNATURE)
Doug True William Cunha

EQUIPMENT QUALIFICATION WALKDOWN VERIFICATION FORM



EPN# REA-V-2
QID# 361102
COORDS H.4/6.2
DSCRIP 72" BFLY
MAT'L SA-516-GR60
LBS N/F SIZE 72"
ASME CLASS N/F

BLDG R FLOOR EL 572
MFR BIF COMPONENT EL 597
MOD# ~~2006 A-206760~~ 0657 SERIAL# N27230-2
PSI @ 110 °F



YOKE ORIENTATION

L TO AXIS OF PIPE (✓)
// TO AXIS OF PIPE (✓)
YOKE LENGTH 0'-7"
(FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS N/A
BOLT TYPE N/A BOLT Ø N/A
WELD TYPE & SIZE N/A
PIPE MOUNTED YES (✓) NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO (✓)
IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES () NO (✓)
DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES (✓) NO ()



CYGNA ATTACHMENT
JOB NO. 82
FILE NO. 1P01F
SHEET NO. S.2.21

GLOBAL CO-ORDINATE SYSTEM

VALVE STEM ORIENTATION

OPERATOR EPN N/A MANUFACTURER
MODEL NO SERIAL NO
TYPE SIZE ORDER NO
MOTOR EPN N/A MANUFACTURER
MODEL NO SERIAL NO
ID NO INS CLASS 1-PHASE () 3-PHASE () AC DC

COMMENTS: Definition (N/F = Not Found)

* REA-LMS-2 not accessible; no staging
note: not motor operated

PREPARED BY Doug True DATE 7/21/12 REVIEWED BY William Cunha DATE 7/21/12
(SIGNATURE) (SIGNATURE)
Doug True WILLIAM CUNHA



EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM

EPN# ROA-V-1

QID# 361101

BLDG R

FLOOR EL 572

COORDS N. 7/5.7 N1/6.2

MFR BIF

COMPONENT EL 578

DSCRPT 84" R Bldg Isol Valve

MOD# 0657

SERIAL# 27229-1

MAT'L SA-576 GR-60

1 PSI @ 105 °F

LBS N/A SIZE 84"

ASME CLASS N/A


YOKE ORIENTATION

L TO AXIS OF PIPE
// TO AXIS OF PIPE
YOKE LENGTH 0'-7 1/2"
(FLANGE TO FLANGE)

MOUNTING CONDITION

NO OF BOLTS N/A
BOLT TYPE N/A BOLT Ø N/A
WELD TYPE & SIZE N/A
PIPE MOUNTED YES NO

PERMANENT OBSTRUCTION (WITHIN 2") YES NO
IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES NO
DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES NO



CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. IP.01/F
SHEET NO. 5.2.22

GLOBAL CO-ORDINATE SYSTEM

VALVE STEM ORIENTATION

OPERATOR EPN N/A MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
TYPE _____ SIZE _____ ORDER NO _____


MOTOR EPN N/A MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
ID NO _____ INS CLASS _____ 1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: Definition (N/F = Not Found)

note: coordinates were incorrect

PREPARED BY William Amick DATE 7/21/92 REVIEWED BY Doug True DATE 7/21/92
(SIGNATURE) (SIGNATURE)
William Amick Doug True

EQUIPMENT QUALIFICATION
WALKDOWN VERIFICATION FORM



EPN# ROA-V-2
QID# 361101
COORDS H. 7/5.0
DSCRIP 84" R Bldg Isol Valve
MAT'L SA 516 GR-60
LBS N/F SIZE 84"
ASME CLASS N/F

BLDG R FLOOR EL 572
MFR BIF COMPONENT EL 578
MOD# 0657 SERIAL# 27229-2
1 PSI @ 105 °F



YOKE ORIENTATION

MOUNTING CONDITION

L TO AXIS OF PIPE ()
// TO AXIS OF PIPE ()
YOKE LENGTH 0'-7 1/2"
(FLANGE TO FLANGE)

NO OF BOLTS N/A
BOLT TYPE N/A BOLT Ø N/A
WELD TYPE & SIZE N/A
PIPE MOUNTED YES () NO ()

PERMANENT OBSTRUCTION (WITHIN 2") YES () NO ()
IS COMP BETWEEN CONT & 1ST ANC (FULL 6 WAY ANC) YES () NO ()
DO MULTIPLE SUPPORTS EXIST BETWEEN CONT & COMP YES () NO ()



CYGNA
ATTACHMENT
JOB NO. 82011
FILE NO. IPC
SHEET NO. S.2.23

GLOBAL CO-ORDINATE SYSTEM

VALVE STEM ORIENTATION

OPERATOR EPN N/A MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
TYPE _____ SIZE _____ ORDER NO _____

MOTOR EPN N/A MANUFACTURER _____
MODEL NO _____ SERIAL NO _____
ID NO _____ INS CLASS _____ 1-PHASE () 3-PHASE () AC _____ DC _____

COMMENTS: Definition (N/F = Not Found)
note: coordinates were incorrect

PREPARED BY William Cunha DATE 7/21/02 REVIEWED BY Doug True DATE 7/21/02
(SIGNATURE) (SIGNATURE)
WILLIAM CUNHA Doug True

5.3 SRM Sheets

function FIN

-SRM MASTER EQUIPMENT LIST-

EPN
2-CSP-A0-1

COMPOSITE EPN
2-CSP-V-1+

CONTRACT 68 MFG M322 MODEL A83B SERIAL NUMBER

DESCRIPTION
AIR OPERATOR FOR CSP-V-1

LEVEL 2 EC A USE 1 3 HOURS 4320 SAFETY FUNCTION B1,F ACCURACY

A/E DRAWING M543 AE ZONE D5 BLDG R ELEV 508 DETAIL N. 0/7.7 ZONE R43 ROOM

HL Y	SEIS. TEST	QUAL ANL	F/O	C	ENV. AGING	QUAL DBE	C	QUAL SEIS	STATUS ENV	TM	FREQ	QID
		<u>01</u>		<u>9</u>				<u>C</u> <u>A</u>		<u>P</u>	<u>07</u>	<u>018001</u>

MESSAGE

CYGNA	
PROJECT	<u>WIPASS-WNP2</u>
TITLE	<u>SRM LIST</u>
PREPARED BY:	<u>H. X. Lane</u>
DATE	<u>4/22/83</u>
CHECKED BY:	<u>[Signature]</u>
DATE	<u>5/19/83</u>
JOB NO.	<u>62044</u>
FILE NO.	<u>1.P.01/E</u>
SHEET NO.	<u>5.3.1</u>

function FIN

user number 43

-SRM MASTER EQUIPMENT LIST-

date/time 02/10/83 09:11

EPN
2-CSP-A0-2

COMPOSITE EPN
2-CSP-V-2+

CONTRACT
38

MFG
M322

MODEL
A83B

SERIAL NUMBER

DESCRIPTION
AIR OPERATOR FOR CSP-V-2

LEVEL	EC	USE	HOURS	SAFETY FUNCTION	ACCURACY
<u>2</u>	<u>A</u>	<u>2 3</u>	<u>4320</u>	<u>B1, F</u>	

A/E DRAWING	AE ZONE	BLDG	ELEV	DETAIL	ZONE	ROOM
<u>M543</u>	<u>D6</u>	<u>R</u>	<u>508</u>	<u>7.7/N.0</u>		

SEIS. TEST	QUAL ANL	F/O	ENV. AGING	QUAL DBE	C	QUAL SEIS	STATUS ENV	TM	FREQ	QID
<u>HL</u>	<u>01</u>		<u>C</u>			<u>C</u>		<u>P</u>	<u>07</u>	<u>018001</u>

MESSAGE

CYGNA	
PROJECT	<u>WAPSS-WNP2</u>
TITLE	<u>SRM LIST</u>
PREPARED BY	<u>A. Slank</u>
DATE	<u>4/22/83</u>
CHECKED BY:	<u>[Signature]</u>
DATE	<u>5/17/83</u>
JOB NO.	<u>82044</u>
FILE NO.	<u>1P.01.F</u>
SHEET NO.	<u>3.3.2</u>

function FIN

user number 43

date/time 02/10/83 09:11

-SRM MASTER EQUIPMENT LIST-

EPN
2-CSP-AD-3

COMPOSITE EPN
2-CSP-V-3+

CONTRACT
68

MFG
M322

A83B

MODEL

SERIAL NUMBER
73354165

DESCRIPTION
AIR OPERATOR FOR CSP-V-3

LEVEL	EC	USE	HOURS	SAFETY FUNCTION	ACCURACY
<u>2</u>	<u>A</u>	<u>2 3</u>	<u>4320</u>	<u>B1, F</u>	

A/E DRAWING	AE ZONE	BLDG	ELEV	DETAIL	ZONE	ROOM
<u>M543</u>	<u>D5</u>	<u>R</u>	<u>481</u>	<u>M. 6/7. 6</u>	<u>R33</u>	

HL	SEIS. TEST	QUAL ANL	F/O	C	ENV. AGING	QUAL DBE	C	QUAL SEIS	STATUS ENV	TM	FREQ	QID
<u>Y</u>		<u>01</u>		<u>9</u>				<u>C</u>		<u>P</u>	<u>10</u>	<u>018001</u>

MESSAGE

CYGNA	
PROJECT	<u>WAPSS-WIND</u>
TITLE	<u>SRM LIST</u>
PREPARED BY	<u>A. Stark</u>
DATE	<u>4/22/83</u>
CHECKED BY:	<u>[Signature]</u>
DATE	<u>5/19/83</u>
JOB NO.	<u>82044</u>
FILE NO.	<u>1P.01/F</u>
SHEET NO.	<u>5.3.3</u>

function FIN

user number 43

date/time 02/10/83 09:12

-SRM MASTER EQUIPMENT LIST-

EPN
2-CSP-A0-4

COMPOSITE EPN
2-CSP-V-4+

CONTRACT
68

MFG
M322

MODEL
A83B

SERIAL NUMBER
73354165

DESCRIPTION
AIR OPERATOR FOR CSP-V-4

LEVEL	EC	USE	HOURS	SAFETY FUNCTION	ACCURACY
<u>2</u>	<u>A</u>	<u>2 3</u>	<u>4320</u>	<u>B1,F</u>	

A/E DRAWING	AE ZONE	BLDG	ELEV	DETAIL	ZONE	ROOM
<u>M543</u>	<u>C5</u>	<u>R</u>	<u>478</u>	<u>M. 6/7.6</u>	<u>R33</u>	

SEIS. TEST	QUAL ANL	F/D	ENV. AGING	QUAL DBE	C	QUAL SEIS	STATUS ENV	TM	FREQ	QID
<u>HL</u> <u>Y</u> MESSAGE	<u>01</u>		<u>C</u> <u>9</u>			<u>C</u> <u>A</u>		<u>P</u>	<u>10</u>	<u>018001</u>

CYGNA

PROJECT WPA55-WNA2

TITLE JRM LIST

PREPARED BY: [Signature]

DATE 4/22/83

CHECKED BY: [Signature]

DATE 5/12/83

JOB NO. 82044

FILE NO. 1P.01/E

SHEET NO. 5.34

function FIN

user number '43

-SRM MASTER EQUIPMENT LIST-

date/time 02/10/83 09:12

EPN
2-CSP-A0-5

COMPOSITE EPN
2-CSP-V-5+

CONTRACT
68

MFG
M322

MODEL
AB3B

SERIAL NUMBER
R75508823

DESCRIPTION
AIR OPERATOR FOR CSP-V-5

LEVEL	EC	USE	HOURS	SAFETY FUNCTION	ACCURACY
<u>2</u>	<u>A</u>	<u>2 3</u>	<u>4320</u>	<u>B1,F</u>	

A/E DRAWING	AE ZONE	BLDG	ELEV	DETAIL	ZONE	ROOM
<u>M543</u>	<u>C5</u>	<u>R</u>	<u>475</u>	<u>M. 7/8. 3</u>	<u>R33</u>	

SEIS. TEST	QUAL ANL	F/D	ENV. AGING	QUAL DBE	C	QUAL SEIS	STATUS ENV	TM	FREQ	QID
<u>HL</u>	<u>01</u>		<u>C</u>			<u>C</u>		<u>P</u>	<u>10</u>	<u>018001</u>
<u>y</u>			<u>9</u>			<u>A</u>				

MESSAGE

CYGNA	
PROJECT	<u>WPASS WNP2</u>
TITLE	<u>SRM LIST</u>
PREPARED BY:	<u>D. Xerke</u>
DATE	<u>4/23/83</u>
CHECKED BY:	<u>[Signature]</u>
DATE	<u>5/19/85</u>
JOB NO.	<u>820dd</u>
FILE NO.	<u>1P.01/E</u>
SHEET NO.	<u>5.3.5</u>

user number 43
function FIN

-SRM MASTER EQUIPMENT LIST-

date/time 02/10/83 09:1

EPN
2-CSP-A0-6

COMPOSITE EPN
2-CSP-V-6+

CONTRACT 68 MFG M322 MODEL A83B SERIAL NUMBER _____

DESCRIPTION
AIR OPERATOR FOR CSP-V-6

LEVEL 2 EC A USE 2 3 HOURS 4320 SAFETY FUNCTION B1,F ACCURACY _____

A/E DRAWING M543 AE ZONE B14 BLDG R ELEV 480 DETAIL N. 5/7.7 ZONE R31 ROOM _____

SEIS. QUAL ENV. QUAL QUAL STATUS TM FREQ GID
TEST ANL F/O C AGING DBE C SEIS ENV
HL ~ Y 01 — C 9 — — — C A — P 10 018001
MESSAGE

CYGNA
PROJECT WPASS-WNA2
TITLE SRM LIST
PREPARED BY: A. Stark
DATE 4/22/83
CHECKED BY: [Signature]
DATE 5/13/83
JOB NO. 82044
FILE NO. IP01/E
SHEET NO. 5.3.6

function FIN

user number 43

-SRM MASTER EQUIPMENT LIST-

date/time 02/10/83 09:1:

EPN
2-CSP-A0-9

COMPOSITE EPN
2-CSP-V-9+

CONTRACT 68 MFG M322 MODEL A83B SERIAL NUMBER

DESCRIPTION
AIR OPERATOR FOR CSP-V-9

LEVEL 2 EC A USE 2 3 HOURS 4320 SAFETY FUNCTION B1, F ACCURACY

A/E DRAWING M543 AE ZONE C6 BLDG R ELEV 490 DETAIL M. 9/5.1 ZONE ROOM

HL	SEIS. TEST	QUAL ANL	F/O	ENV. AGING	QUAL DBE	C	QUAL SEIS	STATUS ENV	TM	FREQ	GID
<u>HL</u>		<u>01</u>		<u>C</u>			<u>C</u>		<u>P</u>	<u>10</u>	<u>018001</u>

MESSAGE

CYGNA	
PROJECT	<u>WPPSS-WN/De</u>
TITLE	<u>SRM LIST</u>
PREPARED BY:	<u>A. Shank</u>
DATE	<u>4/22/83</u>
CHECKED BY:	<u>[Signature]</u>
DATE	<u>5/17/83</u>
JOB NO.	<u>82044</u>
FILE NO.	<u>1P.01/E</u>
SHEET NO.	<u>S.3.7</u>

function FIN

-SRM MASTER EQUIPMENT LIST-

EPN
2-CEP-A0-1A

COMPOSITE EPN
2-CEP-V-1A+

CONTRACT 88 MFG M322 MODEL A63B SERIAL NUMBER _____

DESCRIPTION
AIR OPERATOR FOR CEP-V-1A

LEVEL 2 EC A USE 2 3 HOURS 1.0 SAFETY FUNCTION B1.F ACCURACY _____

A/E DRAWING M543 AE ZONE J13 BLDG R ELEV 560 DETAIL J.4/5.4 ZONE R62 ROOM _____

SEIS. GUAL ENV. GUAL GUAL STATUS TM FREQ GID
HL TEST ANL F/O C AGING DBE C SEIS ENV
Y 01 ? ? ? ? ? A ? P 07 018001

MESSAGE

CYGNA	
PROJECT	<u>WPPSS-WNP2</u>
TITLE	<u>SRM LIST</u>
PREPARED BY:	<u>A. Shank</u>
DATE	<u>4/22/83</u>
CHECKED BY:	<u>[Signature]</u>
DATE	<u>5/19/83</u>
JOB NO.	<u>82644</u>
FILE NO.	<u>1P.01/E</u>
SHEET NO.	<u>53.8</u>

function FIN

-SRM MASTER EQUIPMENT LIST-

EPN
2-CEP-AQ-2A

COMPOSITE EPN
2-CEP-V-2A+

CONTRACT
2

MFG
M322

A83B

MODEL

SERIAL NUMBER

73354164

DESCRIPTION
AIR OPERATOR FOR CEP-V-2A

LEVEL	EC	USE	HOURS	SAFETY FUNCTION	ACCURACY
<u>2</u>	<u>A</u>	<u>2 3</u>	<u>1.0</u>	<u>B1,F</u>	

A/E DRAWING	AE ZONE	BLDG	ELEV	DETAIL	ZONE	ROOM
<u>M543</u>	<u>J13</u>	<u>R</u>	<u>558</u>	<u>J. 4/5. 4</u>	<u>R62</u>	

SEIS. QUAL	ENV. QUAL	GUAL STATUS	TM	FREQ	GID
HL TEST ANL F/O C	AGING DBE C	SEIS ENV			
<u>Y</u>	<u>01</u>	<u>9</u>	<u>2</u>	<u>07</u>	<u>018001</u>

MESSAGE

CYGNA	
PROJECT	<u>WPPS-WNP2</u>
TITLE	<u>SRM LIST</u>
PREPARED BY:	<u>A. Stanley</u>
DATE	<u>4/22/83</u>
CHECKED BY:	<u>[Signature]</u>
DATE	<u>5/9/83</u>
JOB NO.	<u>82044</u>
FILE NO.	<u>1P.01/E</u>
SHEET NO.	<u>5.3.9</u>

user number 43

date/time 02/10/83 09:14

function FIN

-SRM MASTER EQUIPMENT LIST-

EPN
2-CEP-A0-3A

COMPOSITE EPN
2-CEP-V-3A+

CONTRACT
3

MFG
M322

A83B

MODEL

SERIAL NUMBER

73354165

DESCRIPTION
AIR OPERATOR FOR CEP-V-3A

LEVEL	EC	USE	HOURS	SAFETY FUNCTION		ACCURACY						
<u>2</u>	<u>A</u>	<u>2 3</u>	<u>1.0</u>	<u>B1, F</u>								
A/E DRAWING		AE ZONE	BLDG	ELEV	DETAIL	ZONE	ROOM					
<u>M543</u>		<u>C14</u>	<u>R</u>	<u>497</u>	<u>H. 5/5.4</u>	<u>R32</u>						
HL	TEST	ANL	F/O	C	AGING	DBE	C	SEIS	STATUS	TM	FREQ	GID
<u>Y</u>		<u>01</u>		<u>2</u>				<u>A</u>	<u>-</u>	<u>P</u>	<u>10</u>	<u>018001</u>

MESSAGE

CYGNA	
PROJECT	<u>WAPSS-WIND</u>
TITLE	<u>SRM LIST</u>
PREPARED BY	<u>A. Stark</u>
DATE	<u>4/22/83</u>
CHECKED BY:	<u>[Signature]</u>
DATE	<u>5/13/85</u>
JOB NO.	<u>82044</u>
FILE NO.	<u>IP.01/E</u>
SHEET NO.	<u>5.3.10</u>

function FIN

user number 43

-SRM MASTER EQUIPMENT LIST-

date/time 02/10/83 09:14

EPN
2-CEP-AD-4A

COMPOSITE EPN
2-CEP-V-4A+

TRACT
68

MFG
M322

A83B

MODEL

SERIAL NUMBER

73354165

DESCRIPTION

AIR OPERATOR FOR CEP-V-4A

LEVEL	EC	USE	HOURS	SAFETY FUNCTION	ACCURACY
<u>2</u>	<u>A</u>	<u>2 3</u>	<u>1.0</u>	<u>B1, F</u>	

A/E DRAWING	AE ZONE	BLDG	ELEV	DETAIL	ZONE	ROOM
<u>M543</u>	<u>C14</u>	<u>R</u>	<u>497</u>	<u>H. 5/5. 4</u>	<u>R32</u>	

HL	TEST	SEIS. ANL	QUAL F/D	C	ENV. AGING	QUAL DBE	C	QUAL SEIS	STATUS ENV	TM	FREQ	GID
<u>Y</u>		<u>01</u>						<u>A</u>		<u>P</u>	<u>10</u>	<u>018001</u>

MESSAGE

CYGNA	
PROJECT	<u>WAPSS-WAP2</u>
TITLE	<u>SRM LIST</u>
PREPARED BY	<u>A. X. [Signature]</u>
DATE	<u>4/22/83</u>
CHECKED BY	<u>[Signature]</u>
DATE	<u>5/12/83</u>
JOB NO.	<u>02044</u>
FILE NO.	<u>IP.01F</u>
SHEET NO.	<u>5.3.11</u>

2-ROA-V-1 EPN

2-ROA-V-1+ COMPOSITE EPN

CONTRACT
68

MFG
B250

0657

MODEL

SERIAL NUMBER

7229-1

DESCRIPTION
84.0" R BLDG ISO VALVE

LEVEL	EC	USE	HOURS	SAFETY FUNCTION	ACCURACY
<u>2</u>	<u>A</u>	<u>1 0</u>	<u>4320</u>	<u>B2, D</u>	

A/E DRAWING	AE ZONE	BLDG	ELEV	DETAIL	ZONE	ROOM
<u>M545</u>	<u>F3</u>	<u>R</u>	<u>578</u>	<u>N. 7/5. 7</u>	<u>R73</u>	

HL	TEST	SEIS. ANL	QUAL F/D	C	ENV. AGING	QUAL DBE	C	QUAL SEIS	STATUS ENV	TM	FREQ	QID
<u>N</u>		<u>02</u>		<u>0</u>				<u>A</u>		<u>P</u>	<u>14</u>	<u>361101</u>

MESSAGE

CYGNA	
PROJECT	<u>K/PPSS-W/DZ</u>
TITLE	<u>SRM LIST</u>
PREPARED BY:	<u>[Signature]</u>
DATE	<u>4/25/83</u>
CHECKED BY:	<u>[Signature]</u>
DATE	<u>5/19/83</u>
JOB NO.	<u>82644</u>
FILE NO.	<u>1.P.01.F</u>
SHEET NO.	<u>5.3.12</u>

function FIN

-SRM MASTER EQUIPMENT LIST-

2-ROA-V-2 EPN

COMPOSITE EPN
2-ROA-V-2+

CONTRACT 68 MFG B250 MODEL 0657 SERIAL NUMBER 7229-2

DESCRIPTION
84.0" R BLDG ISO VALVE

LEVEL	EC	USE.	HOURS	SAFETY FUNCTION		ACCURACY		
<u>2</u>	<u>A</u>	<u>1 0</u>	<u>4320</u>	<u>B2, D</u>				
A/E DRAWING		AE ZONE	BLDG	ELEV	DETAIL	ZONE	ROOM	
<u>M545</u>		<u>F3</u>	<u>R</u>	<u>578</u>	<u>N. 7/5. 0</u>	<u>R73</u>		
HL	SEIS. QUAL		ENV. QUAL	QUAL	STATUS	TM	FREQ	QID
<u>N</u>	<u>TEST</u>	<u>ANL</u> <u>F/O</u>	<u>C</u> <u>AGING</u> <u>DBE</u> <u>C</u>	<u>SEIS</u>	<u>ENV</u>	<u>P</u>	<u>14</u>	<u>361101</u>

MESSAGE

CYGNA	
PROJECT	<u>WPPSS-WNPA</u>
TITLE	<u>SRM LIST</u>
PREPARED BY:	<u>[Signature]</u>
DATE	<u>4/25/83</u>
CHECKED BY:	<u>[Signature]</u>
DATE	<u>5/19/83</u>
JOB NO.	<u>82044</u>
FILE NO.	<u>P.O.I.E</u>
SHEET NO.	<u>5.3.13</u>

function FIN user number 43

date/time 04/22/83 14:47

-SRM MASTER EQUIPMENT LIST-

2-REA-V-2 EPN 2-REA-V-2+ COMPOSITE EPN

CONTRACT _____ MFG B250 MODEL DWG A-206760 SERIAL NUMBER -27230-2

DESCRIPTION
72.0" BFLY R BLD ISO

LEVEL	EC	USE	HOURS	SAFETY FUNCTION		ACCURACY	
<u>2</u>	<u>A</u>	<u>1 3</u>	<u>4320</u>	<u>B2.F</u>			
A/E DRAWING		AE ZONE	BLDG	ELEV	DETAIL	ZONE	ROOM
<u>M545</u>		<u>J3</u>	<u>R</u>	<u>597</u>	<u>H. 4/6.2</u>	<u>R71</u>	
SEIS. QUAL	ENV. QUAL	QUAL	STATUS	TM	FREQ	QID	
HL TEST ANL F/D C	AGING DBE C		SEIS ENV				
-	-	-	<u>A</u>	<u>P</u>		<u>361102</u>	

MESSAGE

CYGNA	
PROJECT	<u>WPPSS-WNA2</u>
TITLE	<u>JRM LIST</u>
PREPARED BY:	<u>[Signature]</u>
DATE	_____
CHECKED BY:	<u>[Signature]</u>
DATE	<u>5/19/83</u>
JOB NO.	<u>82044</u>
FILE NO.	<u>1P.01/P</u>
SHEET NO.	<u>5.3.14</u>

04/06/83

BURNS & ROE INC
 WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 WNP-2 SAFETY RELATED MECHANICAL EQUIPMENT LIST
 DWG E553-2, REV 5

PAGE 532

SORTED BY EQUIP. NO.

DATA DATE 04/06/83

EQUIPMENT NO. EQUIPMENT DESCRIPTION	COMPOSITE NO.	DRAWING NO. PLANT LOCATION	MFG CODE	MFG MODEL NO CONTRACT	LV EQUIP. CLASS	SAFETY FUNCTION HOURS	USE
REA-A0-8+ SPENT FUEL POOL PUMP ROOM		M545 F10			1 J		10
REA-A0-V1 AIR OPER FOR VALVE REA-V-1	REA-V-1+	M545 J3 R 597 H.2/6.2	M322	A83B	2 B2,F	4320	13
REA-A0-V2 AIR OPER FOR VALVE REA-V-2	REA-V-2+	M545 J3 R 597 H.4/6.2	M322	A83B	2 B2,F	4320	13
REA-FN-1A REACTOR BUILDING EXHAUST FAN	REA-FN-1A+	M545 J5 R 572 H.2/4.2	J127	54-26 1/2-1770 2-22A	2 *		33
REA-FN-1A+ REACTOR BUILDING EXHAUST FAN		M545 J5 R 592 H.2/4.2			1 *		33
REA-FN-1B REACTOR BUILDING EXHAUST FAN	REA-FN-1B+	M545 J5 R 572 H.2/4.2	J127	54-26 1/2-1770 2-22A	2 *		33
REA-FN-1B+ REACTOR BUILDING EXHAUST FAN		M545 J5 R 585 H.2/4.2			1 *		33
REA-SR-27 SAMPLE RACK FOR REA-RE-1S		M544 F2			2 B2,F		20
REA-SR-37 FLOW CONT. RACK FOR ELEV. DISCH. PT		M544 F3					
REA-V-1 72.0" BFLY R BLD ISO	REA-V-1+	M545 J3 R 572 H.2/6.2		B250			
REA-V-1+ RX BLDG EXH VLV DISCH COMPOSITE		M545 J3 R 597 H.2/6.2					
REA-V-2 72.0" BFLY R BLD ISO	REA-V-2+	M545 J3 R 572 H.4/6.2		B250			
REA-V-2+ RX BLDG EXH VLV DISCH COMPOSITE		M545 J3 R 597 H.4/6.2					
RFW-V-10A 24" CHECK RFW TO RPV (INSIDE PC)		M529 012 C 512 15 D AZ R36		A391			
RFW-V-10B 24" CHECK RFW TO RPV (INSIDE PC)		M529 06 C 512 345 D AZ R36		A391			

CYGNIA

PROJECT: WPPSS-KIN2
 TITLE: SRM LIST
 PREPARED BY: *Abn/Alak*
 DATE: 4/25/83
 CHECKED BY: *[Signature]*
 DATE: 5/17/83
 JOB NO.: 82044
 FILE NO.: 1P61E
 SHEET NO.: S.3.15

REA-A0-V1
REA-A0-V2

04/06/83

BURNS & ROE INC
 WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 WMP-2 SAFETY RELATED MECHANICAL EQUIPMENT LIST
 DWG E553-2 REV 5

PAGE 570

DATA DATE 04/06/83

SORTED BY EQUIP. NO.

EQUIPMENT NO. EQUIPMENT DESCRIPTION	COMPOSITE NO.	DRAWING NO. PLANT LOCATION	MFG CODE	MFG MODEL NO CONTRACT	LV. EQUIP. CLASS	SAFETY FUNCTION HOURS	USE
ROA-AD-15+ ANA RM 1A AUTO DAMPER		M545 G13 R 563 M.8/4.8			1 J A	10	
ROA-AD-17 ANA RM 1B AUTO DAMPER	ROA-AD-17+	M545 G14 R 548 M.8/4.2	M139	331-2782 2-216	2 J A	4320	10
ROA-AD-17+ ANA RM 1B AUTO DAMPER		M545 G14 R 563 M.8/4.2			1 J A	10	
ROA-AD-19 SPENT FUEL POOL PUMP ROOM	ROA-AD-19+	M545 FB R 548 L.0/4.0	P014	630-N-31408 216	2 J A	4320	10
ROA-AD-19+ SPENT FUEL POOL PUMP ROOM		M545 FB R 548 L.0/4.0			1 J A	10	
ROA-AO-AD10 AIR OPERATOR FOR ROA-AD-10	ROA-AD-10+	M545 E14 R 542 M.5/3.9			2 J A	4320	10
ROA-AO-AD11 MCC ROOM II AUTO DAMPER	ROA-AD-11+	M545 E0 R 542 M.7/8.1			2 J A	4320	10
ROA-AO-AD12 DC MCC ROOM AUTO DAMPER	ROA-AD-12+	M545 C7 R 480 J.0/8.3					
ROA-AO-AD13 RECGMB MCC RMI AUTO DAMPER	ROA-AD-13+	M545 G14 R 591 M.5/6.0					
ROA-AO-AD14 RECOHB MCC RM II AUTO DAMPER	ROA-AD-14+	M545 G13 R 591 M.9/7.4					
ROA-AO-AD15 ANA RM 1A AUTO DAMPER	ROA-AD-15+	M545 G12 R 563 M.8/4.8					
ROA-AO-AD17 ANA RM 1B AUTO DAMPER	ROA-AD-17+	M545 G14 R 563 M.8/4.2					
ROA-AO-V1 R BLDG ISO VALVE	ROA-V-1+	M545 F3 R 572 D.0/4.0	M322				
ROA-AO-V2 R BLDG ISO VALVE	ROA-V-2+	M545 F3 R 572 D.0/4.0	M322				
ROA-FN-1A SUPPLY FAN	ROA-FN-1A+	M545 G7 R 572 N2/4.0	B515				

CYGNIA	
PROJECT	WAPSS-KINPZ
TITLE	SEM LIST
PREPARED BY:	Tom Shank
DATE	4/25/83
CHECKED BY:	[Signature]
DATE	5/17/83
JOB NO.	82044
FILE NO.	1201E
SHEET NO.	5.3/6

ROA-AO-V1
 ROA-AO-V2

QID 018001

5.4 Load Comparative Sheets
for
REA and ROA Air Cylinders

NIP 7/21/82 Cygnus 11D
CODE

10/7/82 SRM List

DESIGN CODE:

GROUP:

PIPELINE DESIGN:


BUILDING R

ELEVATION 567

HL N Cygnus 11D

USE 13

EC A



- ASME III CLASS 1 = A
- ASME III CLASS 2 = B
- ASME III CLASS 3 = C
- B 31.1 = D

1. BURNS & ROE-(HOME)
2. GENERAL ELECTRIC-NSSS
3. BURNS & ROE-(SITE)
4. GE. - IS + E

INTERIM QUALIFICATION:

COMMENTS:

LOADS - INTERIM CRITERIA

LOADS - QUALIFYING ANALYSIS

	X'SS	y	Z'FB	SRSS
VALVE				
OPERATOR				

	X'SS	y	Z'FB	SRSS
VALVE				
OPERATOR				

VALVE
OPERATOR

FAIL
PASS

FINAL QUALIFICATION:

COMMENTS:

LOADS - FINAL PIPING ANALYSIS

	X'Horiz	y'Horiz	Z'VERT	SRSS
VALVE	1.0	1.0	0.6	1.54
OPERATOR				

VALVE
OPERATOR

FAIL
PASS

ASSEMBLY GEOMETRY:

COMMENTS:

	WALKDOWN	QUALIFYING ANALYSIS	PIPING ANALYSIS
VALVE BODY WEIGHT	---		
YOKE: LENGTH			
FREQUENCY	---		
STIFFNESS	---		
OPERATOR WEIGHT	---		

ASSEMBLY

FAIL
PASS

PERFORMED BY: _____

DATE _____

CHECKED BY: _____

DATE _____

VALVE QUALIFICATION DATA.

VALVE EPN: REA-V-1

QID: 361102

N/P 7/1/82 Cygnus WD

10/7/82 SRM List


DESIGN CODE:

ASME III CLASS 1	= A	<input type="checkbox"/>
ASME III CLASS 2	= B	<input type="checkbox"/>
ASME III CLASS 3	= C	<input type="checkbox"/>
B 31.1	= D	<input type="checkbox"/>

PIPELINE DESIGN:

1. BURNS & ROE (HOME)	<input type="checkbox"/>
2. GENERAL ELECTRIC-NSSS	<input type="checkbox"/>
3. BURNS & ROE (SITE)	<input type="checkbox"/>
4. GE. - IS & E	<input type="checkbox"/>

BUILDING 2
ELEVATION 567
HL N Cygnus WD
USE 13
EC A



INTERIM QUALIFICATION:

COMMENTS:

LOADS - INTERIM CRITERIA

	χ_{SS}	γ	\bar{z}_{FB}	SRSS
VALVE				
OPERATOR				

LOADS - QUALIFYING ANALYSIS

	χ_{SS}	γ	\bar{z}_{FB}	SRSS
VALVE				
OPERATOR				

VALVE
OPERATOR

FAIL	PASS
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>

FINAL QUALIFICATION:

COMMENTS:

LOADS - FINAL PIPING ANALYSIS

	χ_{HORIZ}	γ_{HORIZ}	\bar{z}_{VERT}	SRSS
VALVE	1.0	1.0	0.6	1.54
OPERATOR				

VALVE
OPERATOR

FAIL	PASS
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>

ASSEMBLY GEOMETRY:

COMMENTS:

	WALKDOWN	QUALIFYING ANALYSIS	PIPING ANALYSIS
VALVE BODY WEIGHT	---		
YOKE: LENGTH			1
FREQUENCY	---		
STIFFNESS	---		
OPERATOR WEIGHT	---		

ASSEMBLY

FAIL	PASS
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>

PERFORMED BY: _____ DATE _____ CHECKED BY: _____ DATE _____

VALVE QUALIFICATION DATA: VALVE EPN: EA-V-2 QID: 3002

N/F 7/21/82 Cygnar WD

10/1/82 SRM LIST

DESIGN CODE:

ASME III CLASS 1 = A
 ASME III CLASS 2 = B
 ASME III CLASS 3 = C
 B31.1 = D

GROUP:

PIPELINE DESIGN:

1. BURNS & ROE-(HOME)
 2. GENERAL ELECTRIC-NSSS
 3. BURNS & ROE-(SITE)
 4. GE. - IS & E


BUILDING R

ELEVATION 578

HL N Cygnar WD

USE 10

EC A



INTERIM QUALIFICATION:

COMMENTS:

LOADS - INTERIM CRITERIA

LOADS - QUALIFYING ANALYSIS

	X'SS	y	Z'FB	SRSS
VALVE				
OPERATOR				

	X'SS	y	Z'FB	SRSS
VALVE				
OPERATOR				

VALVE
OPERATOR

FAIL
PASS

FINAL QUALIFICATION:

COMMENTS:

LOADS - FINAL PIPING ANALYSIS

	X HORIZ	y HORIZ	Z VERT	SRSS
VALVE	1.0	1.0	0.6	1.54
OPERATOR				

VALVE
OPERATOR

FAIL
PASS

ASSEMBLY GEOMETRY:

COMMENTS:

	WALKDOWN	QUALIFYING ANALYSIS	PIPING ANALYSIS
VALVE BODY WEIGHT	---		
YOKE: LENGTH			
FREQUENCY	---		
STIFFNESS	---		
OPERATOR WEIGHT	---		

ASSEMBLY

FAIL
PASS

PERFORMED BY: _____

DATE _____

CHECKED BY: _____

DATE _____

VALVE QUALIFICATION DATA

VALVE EPN: ROA-V-1

QID: 361101

N/F 7/21/82 Cygna WD
CODE 11

10/7/82 SRM: LST R

DESIGN CODE:

GROUP:

PIPELINE DESIGN:


BUILDING:

ELEVATION 578

HL N Cygna WD

USE 10

EC A



- ASME III CLASS 1 = A
- ASME III CLASS 2 = B
- ASME III CLASS 3 = C
- B 31.1 = D

- 1. BURNS & ROE - (HOME)
- 2. GENERAL ELECTRIC - NSSS
- 3. BURNS & ROE - (SITE)
- 4. GE. - IS & E

INTERIM QUALIFICATION:

COMMENTS:

LOADS - INTERIM CRITERIA

LOADS - QUALIFYING ANALYSIS

	X'SS	Y	Z'FB	SRSS
VALVE				
OPERATOR				

	X'SS	Y	Z'FB	SRSS
VALVE				
OPERATOR				

VALVE
OPERATOR

FAIL	PASS

FINAL QUALIFICATION:

COMMENTS:

LOADS - FINAL PIPING ANALYSIS

	X HORIZ	Y HORIZ	Z VERT	SRSS
VALVE	1.0	1.0	0.6	1.54
OPERATOR				

VALVE
OPERATOR

FAIL	PASS

ASSEMBLY GEOMETRY:

COMMENTS:

	WALKDOWN	QUALIFYING ANALYSIS	PIPING ANALYSIS
VALVE BODY WEIGHT	---		
YOKE: LENGTH			
FREQUENCY	---		
STIFFNESS	---		
OPERATOR WEIGHT	---		

ASSEMBLY

FAIL	PASS

PERFORMED BY: _____

DATE _____

CHECKED BY: _____

DATE _____

VALVE QUALIFICATION DATA:

VALVE EPN: A-V-2

QID: 301

VALVE #	ACCELERATIONS	
	VERTICAL	HORIZONTAL
REA-V-1	0.6g	1.0g
REA-V-2	0.6g	1.0g
ROA-V-1	0.6g	1.0g
ROA-V-2	0.6g	1.0g
CAC-V-1A	0.6g	1.0g
CAC-V-1B	0.6g	1.0g
CAC-V-2A	0.6g	1.0g
CAC-V-2B	0.6g	1.0g
CAC-V-3A	0.6g	1.0g
CAC-V-3B	0.6g	1.0g
CAC-FCV-5A	0.6g	1.0g
CAC-FCV-5B	0.6g	1.0g
CAC-FCV-6A	0.6g	1.0g
CAC-FCV-6B	0.6g	1.0g
CAC-TCV-4A	0.6g	1.0g
CAC-TCV-4B	0.6g	1.0g
CAC-RV-63A	0.6g	1.0g
CAC-RV-63B	0.6g	1.0g
CAC-RV-65A	0.6g	1.0g
CAC-RV-65B	0.6g	1.0g

$$SRSS = \sqrt{0.6^2 + 1.0^2 + 1.0^2} = 1.54$$

5.5 REVISED B&R INC. PIPING
ANALYSIS ACCELERATIONS

D. Armstrong
(X-6834)

APR 13 1993

P. Schuenzel 516-677-~~2430~~
Burns & Roe 2493
Woodbury

Preliminary Valve accelerations for
Valves CSP-V-1, 2, 3, 4, 5. Please
forward the modified flexible valve model
(one that has been checked) to be included
in our documentation.

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. IP01E
SHEET NO. 551

CSP-V-1 Valve Qualification

B&R File No. Dig. 68-00-008

Operation I.D. No.

B&R M200 Iso No. 172

Anchor Group: 125

CYGNA

ATTACHMENT

JOB NO. 82044

FILE NO. 1P01/E

SHEET NO. S.S.2

PRELIMINARY

VALVE ACCELERATIONS

Location	Nodal Pt. No.	Mass Wt. (lb.)	Condition	Accelerations (g)			Comments
				X	Y	Z	
Valve Operator (Bracket)	25	321	Upset	0.65	1.27	0.65	
			Emergency	0.88	1.58	1.87	
			Faulted	1.31	2.66	2.13	
Valve Operator (Bracket)	33	573	Upset	0.76	1.36	0.88	
			Emergency	2.07	2.93	2.62	
			Faulted	2.21	3.62	2.80	

Checked by: [Signature] Date: [Date]
 Prepared by: [Signature] Date: [Date]
 Title: 15-bolt Qualification of Ring Calculation

CSP-V-4 Valve Qualification

B&R File No. Dwg. 68-00-0009

Operation I.D. No.

B&R M200 Iso. No. 172

Anchor Group 125

PRELIMINARY

VALVE ACCELERATIONS

CYGNA

ATTACHMENT

JOB NO. 62044

FILE NO. 1P.DIE

SHEET NO. 515.3

Location	Nodal Pt. No.	Mass Wt. (lb.)	Condition	Accelerations (g)			Comments
				X	Y	Z	
Valve Operator (Bracket)	103	277	Upset	0.95	1.40	0.85	
			Emergency	2.80	1.97	1.71	
			Faulted	2.96	2.91	1.99	
Valve Chamber	111	399	Upset	1.44	1.38	1.50	
			Emergency	1.60	1.78	4.07	
			Faulted	1.87	3.17	4.19	

Checked
Status As-Built Verification of Piping Calculations

CSP-V-3 Valve Qualification

B&R File No. DWG 68-00-0009 Operation I.D. No.

B&R M200 Iso. No. 172 Anchor Group 125

CYGNA
ATTACHMENT
JOB NO. 82064
FILE NO. 1P.01/E
SHEET NO. S.5.4

PRELIMINARY

VALVE ACCELERATIONS

Approved
Checked
Status Is-Built Verification of Piping Calculation

Location	Nodal Pt. No.	Mass Wt. (lb)	Condition	Accelerations (g)			Comments
				X	Y	Z	
Valve Operator (Bracket)	86	277	Upset	0.72	1.32	0.70	
			Emergency	2.48	1.73	1.14	
			Faulted	2.66	2.76	1.53	
Valve Operator (Bracket)	95	299	Upset	1.23	1.60	0.96	
			Emergency	1.80	2.09	1.62	
			Faulted	2.27	2.97	2.11	

CSP-V-5 Valve Qualification

B.P.R. File No. DW 68-00-0019

Operation I.D. No.

B.P.R. M200 Iso. No. 172

Anchor Group 125

PRELIMINARY

VALVE ACCELERATIONS

GYGNA

ATTACHMENT

JOB NO. 82044

FILE NO. P.0113

SHEET NO. 5.5.6

Station As-Built Verification of Piping Calculation

Location	Nodal Pt. No.	Mass Wt. (lb)	Condition	Accelerations (g)			Comments
				X	Y	Z	
			Upset	0.95	1.31	1.71	
Valve Operator (Bracket)	128	277	Emergency	2.80	1.82	5.32	
			Faulted	2.96	2.81	5.42	
			Upset	0.97	1.40	1.60	
Valve Operator	127	395	Emergency	1.29	3.69	2.34	
			Faulted	1.42	3.74	2.55	

CSP-V-2 Valve Qualification

B&R File No. DWG 68-00-0008 Operation I.D. No.

B&R M200 Iso No. 172 Anchor Group 125

CYGNA

ATTACHMENT

JOB NO. B2044

FILE NO. 1P.01/E

SHEET NO. S.5.5

PRELIMINARY
VALVE ACCELERATIONS

Location	Nodal Pt. No.	Mass Wt. (lb.)	Condition	Accelerations (g)			Comments
				X	Y	Z	
Valve Operator (Bracket)	8	321	Upset	0.61	1.27	0.64	
			Emergency	0.81	1.51	1.56	
			Faulted	1.26	2.62	1.86	
Valve Operator	17	573	Upset	0.66	1.33	0.79	
			Emergency	1.06	2.82	1.61	
			Faulted	1.74	3.74	1.90	

Status Is-Built Verification of Pipe Calculations

CSP-V-6	BRAK	74	277	11.39	1.78	.75
	CYL	71	399	2.55	3.33	5.85

CEP-V-3A	BODY BRAK	21	847	3.10	1.25	0.9
	OPRK	24	626	4.57	1.26	.86

CEP-V-4A	BODY	31	847	3.71	1.33	0.89
	OPRK	34	626	3.35	1.34	0.86

CYGNA
ATTACHMENT
JOB NO. 82044
FILE NO. 1P.01F
SHEET NO. 5.5.7

1948-1949

1948-1949

1948-1949

6.0 DRAWINGS USED FOR REQUALIFICATION

Contents

1. BIF Drawing A-208293, Cylinder Support Bracket for 8 x 15 Cylinder Operator, 24" Valve.
2. BIF Drawing A208195, Cylinder Support Bracket for 10 x 15 Cylinder Operator, 30" Valve.
3. BIF Drawing A-208274, Cylinder Support Bracket for 12 x 15 Cylinder Operator, 30" Valve.
4. Flick - Reedy Corp. Drawing C-26095, Certified Dimension for Model A83B Cylinder, 10" Bore, 57 5/8" Stroke.
5. Flick - Reedy Corp. Drawing C-26096, Certified Dimension for Model A83B Cylinder, 8" Bore, 46 3/8" Stroke.
6. Flick - Reedy Corp. Drawing C-26093, Certified Dimension for Model A83B Cylinder, 12" Bore, 40" Stroke.
7. BIF Drawing A206759, General Arrangement of (2), 12"x15" Cylinders - Spring loaded, 84" (valve).
8. BIF Drawing A206760, General Arrangement of (2), 12"x15" Cylinders - Spring loaded 72" (valve).
9. Miller Fluid Power Drawings 7505, 7505 A-D, Series 8, SRE Air Cylinder Cross Section - (General Arrangements Showing Seals).

7.0 PRIOR CALCULATIONS AND TRANSMITTALS
USED FOR REQUALIFICATION

CONTENTS

1. Telecopy from R. Ricapitto, BIE Corp. to P. Guglielmino, CES/BAO, (Miller A/O Dimensional Data), 2 pages.

2. Telecon, O. Konstantinow of Miller and R. Hsieh of CES/SDAO, QID #018001 and 018009, (A/O Dimensional Data), 2 Pages.

3. Telecon, R. Ricoppito, BIE and R. Hsieh, CES/SDAO, QID #018001 and 018009, (A/O Design Criteria and Parameter Data), 2 Pages.

4. Telecon, D. Pflam, Coil Specialty Co. and R. Hsieh, CES/SDAO, QID 018001 and 018009, (A/O Design Criteria), 1 Page.

5. Telecons John Martin of Miller Air Products and J.E. Rakowski of Cygna Energy Services.

a) 12/23/82, Air Cylinder Side Load Criteria and Bushing Areas.

b) 1/5/83, Air Cylinder Side Load Criteria and Bushing Reaction Design Equation.

c) 2/10/83, Bushing Material and Clearances.

[Handwritten notes and scribbles]

[Handwritten notes and scribbles]

[Handwritten notes and scribbles]

TECH
GUGLIEMINO
BOSTON

CENTER OF GRAVITY

LA JOLLA
CA.

WPPSS CYG NA ENERGY N27233 THRU N27236
EXTRAPOLATION

1) 6" dia x 10" STROKE Miller Cyl. S.O.# N27233 GA# A206762
18" B/V SGT-Y-2A & 2B SPRING TO OPEN

$$\text{Rod Retracted} = \frac{12.75(100)}{25.00} = 51\% \quad / \quad \text{Rod Extended} = \frac{13.32(100)}{25.00} = 53.5\%$$

2) 10" dia x 15" STROKE Miller Cyl. S.O.# N27234 GA# A206763
30" B/V CSP-Y-1, 2, 1A, & 2A SPRING TO CLOSE

$$\text{Rod Retracted} = \frac{29.25(100)}{64.00} = 45.7\% \quad / \quad \text{Rod Extended} = \frac{34.5(100)}{64.00} = 53.9\%$$

THEREFORE: SINCE ALL UNITS ARE OF SIMILAR GENERAL CONSTRUCTION, THE CENTER OF GRAVITY CAN BE ASSUMED TO BE PROPORTIONAL, HENCE ITEMS # 3 below

3. 8" dia x 15" STROKE Miller Cyl. S.O.# N27236 GA# A206765
24" B/V CSP-Y-5, -6, & -9 SPRING TO OPEN

$$\begin{aligned} \text{C.G. Rod Retracted} &= 51\% (51.5) = 26.27 \text{ in.} \\ \text{(PROPORTIONAL TO \#1 ABOVE)} & \\ \text{C.G. Rod Extended} &= 53.5\% (51.5) = 27.64 \text{ in.} \end{aligned} \quad \left. \begin{array}{l} \text{NEW} \\ \text{C.G.'S} \end{array} \right\}$$

24" B/V CSP-Y-3, -4, -3A, & -4A Fail Close
SPRING TO CLOSE
S.O.# N27235 GA# A206764

$$\begin{aligned} \text{C.G. Rod Retracted} &= 45.7\% (51.5) = 23.54 \text{ in.} \\ \text{(PROPORTIONAL TO \#2 ABOVE)} & \\ \text{C.G. Rod Extended} &= 53.9\% (51.5) = 27.76 \text{ in.} \end{aligned} \quad \left. \begin{array}{l} \text{NEW} \\ \text{C.G.'S} \end{array} \right\}$$

NOTE: BIF Seismic Report

TR-74-7 NOT ADVERSELY
AFFECTED. ORIGINAL C.G.'S

BIF - Richard Riquie
11/9/82


REPRESENT WORST CASE CONDITIONS.

MILLER CYLINDERS C.G.'s SHOWN WITH RODS RETRACTED

* ALL CYLINDER ACTUATORS SHOWN HERE WITH VALVE IN CLOSED POSITION

1-617-542-7821
 TO: CYGNA ENERGY
 BOSTON PETER GUGLIEMINO

CAL. RAY HSIEH
 1-714-755-0165



FROM: B.I.F. RICHARD RICAPITO
 Richard Ricapito 11/18/82



Subject: 11007
Project: 11007

Communications Report

Company: Telecon Conference Report

Project: 11007 Job No.:

Subject: QID #018001 and 018009 (Air Cylinder Operator) Date: 9/1/77

Participants:

_____ of _____
_____ of _____
_____ of _____

Item	Comments	Req'd Action By
7.	<p>Basically, the assembly of the internal components of an air-spring cylinder are: a preloaded compressed spring with a concentrate spring stop tube (welded to the end cap plate) on one end of the piston. And with a series of concentrate rings on the other end of the piston (between the piston and the end plate) to keep the spring in compression. The piston is made from iron and is threaded into the drive rod or piston rod. The piston is able to take the thrust from the air pressure.</p> <p>In case the drive rod is moved in the direction which causes the piston to bear on the end plate (through the concentrate rings) and asserts a thrust on this end plate, the threads on the piston will experience the same magnitude of this thrust. A sketch of the air-spring cylinder operator is as below:</p>	

Signed: _____ Page: 2 of 2

Distribution:



11000
11008R

Communications Report

Company: CES

Telecon

Conference Report

Project:

Washington Public Power Supply System

Job No. 82044

Date: 10/8/82

Subject:

QID #018001 and 018009

Time: 8:25 A.M.

Place: SDAO

Participants:

Rick Ricapitto of BIF

Raymond Hsieh of CES/SDAO

Item	Comments	Req'd Action By
1.	<p>Dwg. #C-26096 drawn by Flick-Reedy Corporation (Miller Fluid Power Div.) indicated that both the "fail closed" (CSP-V-3,4 and CEP-V-3A & 4A), and the "fail open" design (CSP-V-5, 6) have the same spring preload (1,500 #) and the final load (3,000 #). (Note that CSP-V-9 (fail open) was not mentioned in C-26096). It was pointed out in QID #361106 that the "fail open" operator assembly does not have enough air pressure to close the butterfly valve if the spring final load is equal to 3,000#.</p> <p>Rick went through the BIF record and confirmed that the information contained in Dwg. #C-26096 is incorrect. There should be two types of spring, one for the "fail close" design which has a spring preload of 1,500# and final load of 3,000#; the other type of spring is for the "fail open" design which has a spring preload of 350# and a spring final load of 1,850#. For the fail open design with a 70.psig air pressure and a piston area of 50.3 in.²; a pressure force of 3,521# could be exerted on the piston. This is sufficient to overcome both the spring final load (1,850#) and the seating torque force of 1,478#. Rick also pointed out that all the valves and its air cylinder operators have been tested for the operability (to open and close). From this Telecon it can be concluded that the valves, EPN #CSP-V-5,6,9 (the fail open design) which WPPSS already received, are properly designed except the record of the spring forces (inside the air cylinder) are not shown correctly. Rick indicated he will send me the required information to clear up the spring forces problem.</p>	
2.	<p>Rick will also send me the support brackets of the 6", 8" and 10" bore air cylinders.</p>	

Signed:

R. Hsieh

Page

1

of

2

Distribution:



Communications Report

Company: Telecon Conference Report

Project: _____ Job No. _____

_____ Date: _____

Subject: _____ Time: _____

QID #018001 and 018009 _____ Place: _____

Participants: _____ of _____

_____ of _____

_____ of _____

Item	Comments	Req'd Action By
3.	<p>Rick and I discussed the locations of the CG of the 6", 8" and 10" bore air cylinders (for both the "fail closed" and "fail open" designs). We concluded that the CG locations of the 6" bore air cylinder (fail open design, Dwg. # A-206762) and the 10" bore air cylinder (fail closed design, Dwg. #A-206763) are probably correct (can't find the calcs). However, for the 8" bore air cylinder, Dwg. #A-206764 (fail closed design) and Dwg. #A-206765 (fail open design), both have the identical CG location on the cylinders.</p> <p>There are possibly two mistakes about the CG location on the 8" bore air cylinder. First, the "fail closed" and "fail open" designs could not have the same CG location because the spring and the spring stop tube are located on the opposite end of the cylinder of the two designs. Note that the spring and the spring stop tube are located at the opposite end of the air inlet, and the two designs have a different location of the air inlet (at the opposite end).</p> <p>Second, the CG of the 6" and 10" bore cylinders are both located near the center of the air cylinder. However, the 8" bore air cylinder has its CG located about 9" off the center of the cylinder toward the far end (away from the support bracket). Rick will search for the calculations of the CG locations of the air cylinders. If he failed to find those calculations, he promised to send me a letter stating that the CG location of the 8" bore air cylinder have both the "fail open and fail closed designs and can be assumed to have the same proportion as that of the corresponding 6" bore cylinder (fail open design) and the 10" bore cylinder (fail closed design), respectively.</p>	
4.	<p>The time needed to close or open the butterfly valve is approximately two seconds (estimated).</p>	

Signed: _____ Page: 2 of 2

Distribution: _____



10000
0001

Communications Report

Company:	Telecon	<input type="checkbox"/> Conference Report
Project:	Washington Public Power Supply System	Job No. 82044
Subject:	QID #018001, 018009 (Air Cylinder Operator)	Date: 10/6/82
Participants:	Dave Pflam of Coil Specialty Co.	Time: 10:50 A.M.
	Raymond Hsieh of CES/SDAO	Place: SDAO

Item	Comments	Req'd Action By
1.	<p>Dave explained to me that the spring manufacturer uses the following rules in designing the springs:</p> <p>a. For low cycle spring design:</p> $\sigma_{max} = 0.45 F_u$ <p>(F_u = ultimate tensile strength of material)</p> <p>b. For high cycle spring design:</p> $\sigma_{max} = 0.3 \text{ to } 0.35 F_u$ <p>Dave indicated if he were designing these springs of the air cylinder for WPPSS ten years ago, he will use these same rules.</p>	
2.	The most common used material for the spring which "Coil Specialty" provides to Miller Fluid Power is AISI 5160H which has an F_u of 196 ksi.	
3.	The bar diameter for the 10", 8" and 6" bore air cylinder are: 1", 7/8" and 3/4" respectively.	
4.	Dave mentioned he doesn't know the fatigue life information of the spring. He said that it is very unusual to hear that springs failed in low stress cycles (less than 20,000 cycles) when designed to the rules mentioned in (1) above.	

Signed: R. Hsieh Page 1 of 1

Distribution:



COMMUNICATIONS
NO. 6

Communications Report

Company: CYGNA Telecon Conference Report

Project: _____ Job No: _____

Date: _____

Subject: WPPSS - EQ Time: 12/23/82 // 1/3/83

MILLER AIR OPERATORS 361106 361104 0800 Place: _____

Participants: J. R. Robinson of CES

John Martin 800-323-2520 of MILLER

of _____

Item	Comments	Req'd Action By
<p>NOTE: Cyl bushing is a std. cylinder - does not rotate!</p>	<p>John Martin's + Perfection / Application. Enginon thru Miller's Perfection Product. Air cylinders can take up to 200 PSI "side load" in harsh conditions and up to 400 PSI for harsh / dynamic conditions.</p> <p>Example Sheet size Area</p> <p>DIA = 1 3/8 8 cyl. bry area = 1.451 (1.48)</p> <p>2 3/4 10 2.075 2.41</p> <p>2 3/4 12 2.373 3.24</p> <p>2 3/4 14 2.942 3.58</p> <p>EX (7) 2.373 (2075)</p> <p>200 PSI \rightarrow 2.373 IN² \Rightarrow 84 lb (?) (474 ?)</p> <p>400 PSI @ 1 3/4 (2075) \Rightarrow 830 lb</p>	
	<p>NOT SAME</p>	



Communications Report

Company: CES Telecon Conference Report

Project: _____ Job No. _____

W PPS EQ Date: 1/5/83

Subject: _____ Time: 8:15 AM

MILLER AIR OPERATORS (D-018001) Place: RGHD

Participants: JOHN MARTIN / 800-323-2520 of MILLER

JIM RAICOWSKI of CES


Item	Comments	Req'd Action By
------	----------	-----------------

① JOHN CONFIRMED SENDING A DRAWING SHOWING MILLER CYLINDERS WITH BUSHING. DESIGN DEPICTS CURRENT DESIGN WHICH MAY DIFFER FROM THE BIF VINTAGE, BUT BUSHING DESIGN IS SAME.

② BUSHING DESIGN EQUATION:

$$\text{BEARING PRESSURE} = \frac{\text{Weight (side load)} \times \text{Lever Length}}{d \text{ (big mid pt} \rightarrow \text{Piston mid pt.)} \times \text{BEARING AREA}}$$

③ Bushing Design is for:
 (A) 200 PSI MAX IN DYNAMIC CONDITION, I.E. DRIVE ROD MOVING AXIALLY
 (B) 400 PSI MAX WITH DRIVE ROD IN STATIC CONDITION (SPRING-HELD, NO ACTUATION)



$$F = PA \times d = W \times \text{lvr. len.}$$
 (DOESN'T FIT; SHOULD BE)

$$F = PA \times d = W(d + \text{lvr. len.})$$

Signed: J E Robinson Date: 1/5/83 Page: _____

Distribution: _____



Communications Report

Company: CES Telecon Conference Report

Project: _____ Job No: _____

Date: 2/10/83

Subject: _____ Time: 10: AM

Place: RBO

Participants: John Maitre of Miller Air Products
Jim Rakowski of CES/RBO

Item	Comments	Req'd Action By
Q	What is lushing / luff clearance and lushing material in air cylinder operators supplied to BFA.	
A	Brushing metal probably nodular iron. Typical clearance based on piston tolerance of $+0$ / $-.001$ with the lushing bars held to even closer tolerances.	

Signed: _____ Page _____ of _____

Distribution: _____

Communications Report

Company Telecon Conference Report
 Project WPPSS Equipment Seismic/Hydrodynamic Regualification Job No. 820443
 Date: 12/13/82
 Subject ~~018003, 018004, 018009, 018013, 361020, 361729, 361740, 361901~~ Time: 1:00
 Place: Richland
 Participants W. Hardy of CES, RBO
 L. Fernandez of CES, RBO

Item	Comments	Req'd Action By
1	<p>RBO has original verification packages for the above referenced files which specify incomplete status. These shall be organized into complete package format and filed in the RBO QID binders. The completed packages are forthcoming from the Area Offices in the form of Revision 1. These Revision 1 regualification packages will supersede Revision 0 in RBO QID files.</p> <p>It is noted that none of these incomplete packages (Revision 0) have been submitted to the SS.</p>	WH

