

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8310120267      DOC. DATE: 83/10/03      NOTARIZED: NO      DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe      05000397  
 AUTH. NAME      AUTHOR AFFILIATION  
 SORENSON, G.C.      Washington Public Power Supply System  
 RECIP. NAME      RECIPIENT AFFILIATION  
 SCHWENCER, A.      Licensing Branch 2

SUBJECT: Requests that spent fuel storage pool monitors not be made  
 requirement in Tech Specs based on recent exemption granted  
 for License SNM-1890. Storage in spent fuel storage area  
 exempt, predicated on design of storage facility.

DISTRIBUTION CODE: B001S      COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

## NOTES:

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
NRR/DL/ADL		1	0	NRR LB2 BC		1	
NRR LB2 LA		1	0	AULUCK, R.	01	1	
INTERNAL: ELD/HDS2		1	0	IE FILE		1	
IE/DEPER/EPB	36	3	3	IE/DEPER/IRB	35	1	
IE/DEQA/QAB	21	1	1	NRR/DE/AEAB		1	
NRR/DE/CEB	11	1	1	NRR/DE/EHEB		1	
NRR/DE/eqB	13	2	2	NRR/DE/GB	28	2	
NRR/DE/MEB	18	1	1	NRR/DE/MTEB	17	1	
NRR/DE/SAB	24	1	1	NRR/DE/SGEB	25	1	
NRR/DHFS/HFEB	40	1	1	NRR/DHFS/LQB	32	1	
NRR/DHFS/PSRB		1	1	NRR/DL/SSPB		1	
NRR/DSI/AEB	26	1	1	NRR/DSI/ASB		1	
NRR/DSI/CPB	10	1	1	NRR/DSI/CSB	09	1	
NRR/DSI/ICSB	16	1	1	NRR/DSI/METB	12	1	
NRR/DSI/PSB	19	1	1	NRR/DSI/RAB	22	1	
NRR/DSI/RSB	23	1	1	REG FILE	04	1	
RGN5		3		RM/DDAMI/MIB		1	
EXTERNAL: ACRS	41	6	6	BNL (AMDTS ONLY)		1	
DMB/DSS (AMDTS)		1	1	FEMA-REP DIV	39	1	
LPDR	03	1	1	NRC PDR	02	1	
NSIC	05	1	1	NTIS		1	

TOTAL NUMBER OF COPIES REQUIRED: LTTR 53 ENCL 46



## Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

October 3, 1983  
G02-83-881

Docket No. 50-397

Director of Nuclear Reactor Regulation  
Attention: Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Schwencer:

Subject: NUCLEAR PROJECT NO. 2  
CRITICALITY DETECTORS IN SPENT FUEL STORAGE AREA

References: 10CFR70.24 and WNP-2 Technical Specification LCO 3.3.7.1

The Supply System requests an exception to the interpretation that the requirements of 10CFR70.24 for nuclear fuel stored in the spent fuel storage area requires a spent fuel pit criticality monitor.

The spent fuel storage area has 22 feet of water shielding normally covering the spent fuel. A point kernel shielding calculation conservatively estimates that a setpoint of  $5 \times 10^{-3}$  Mr/hr would be required at the pool surface to detect a criticality with the sensitivity requirements of 10CFR70.24(a)(1). 70.24 also states that the section is not intended to require underwater monitoring when special nuclear material is handled or stored beneath water shielding.

The spent fuel storage area is a high density rack design with fixed poison surrounding each fuel location. A spent fuel rack fully loaded with fresh fuel at a 3.25 weight percent maintains Keff  $< .95$  at the conservative moderator temperature of 68°F, giving assurance that an inadvertent criticality in the spent fuel storage area would not occur.

8310120267 831003  
PDR ADDCK 05000397  
P PDR

Boo /  
1/0

A. Schwencer

Page Two

October 3, 1983

CRITICALITY DETECTORS IN SPENT FUEL STORAGE AREA

A request for an exemption to 10CFR70.24 was granted for the Supply System's Special Nuclear Materials License, (SNM-1890). Storage in the spent fuel storage area was exempt, predicated on the design of the spent fuel storage facility.

The Supply System is therefore requesting that spent fuel storage pool monitors not be made a requirement of Limiting Condition for Operation 3.3.7.1 in the WNP-2 technical specifications.

Very truly yours,



G. C. Sorensen, Acting Manager,  
Nuclear Safety and Regulatory Programs

RJT/tmh

cc: R Auluck - NRC  
WS Chin - BPA  
A Toth - NRC Site  
D Hoffman - NRC

