

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

MAY

ACCESSION NBR: 8403270141 DOC. DATE: 84/03/22 NOTARIZED: NO DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397  
 AUTH. NAME: SORENSEN, G.C. AUTHOR AFFILIATION: Washington Public Power Supply System  
 RECIP. NAME: SCHWENCER, A. RECIPIENT AFFILIATION: Licensing Branch 2

SUBJECT: Discusses updated status of Licensing Condition (16) re emergency response capability. Transient Data Acquisition Sys & Graphics Display Sys computers now functional.

DISTRIBUTION CODE: A003S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: OR/Licensing Submittal: Suppl 1 to NUREG-0737 (Generic Ltr 82-33)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	NRR LB2 BC	7		
INTERNAL:	IE/DEPER/EPB	3	NRR PAULSON, W	1
	NRR/DHFS/HFEB	5	NRR/DHFS/PSRB	1
	NRR/DL/ORAB	1	NRR/DL/ORB5	5
	NRR/DSI/CPB	1	NRR/DSI/ICSB	1
	NRR/DSI/METB	1	NRR/DSI/RAB	1
	NRR/DSI/RSB	1	REG FILES	1
	RGNS	1		
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1	NTIS	1



## Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

March 22, 1984  
G02-84-159

8403270141 840322  
PDR ADDCK 05000397  
F PDR

Docket No. 50-397

Director of Nuclear Reactor Regulation  
Attention: Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Schwencer:

Subject: NUCLEAR PLANT NO. 2  
FACILITY OPERATING LICENSE NPF-21,  
LICENSING CONDITION (16), EMERGENCY  
RESPONSE CAPABILITY

- References:
- 1) Letter, G02-84-60, G. C. Sorensen (SS) to A. Schwencer (NRC), "Status of Emergency Preparedness License Requirements for Operation in Excess of Five Percent", dated February 3, 1984
  - 2) Letter, G02-84-154, G. C. Sorensen (SS) to A. Schwencer (NRC), "Status of Emergency Preparedness License Requirements for Operation in Excess of Five Percent", dated March 19, 1984
  - 3) Letter, G02-84-153, G. C. Sorensen (SS) to A. Schwencer (NRC), "Licensing Condition (16)", dated March 19, 1984

Reference 1 provided the status of several license conditions related to Emergency Preparedness: (16) requirement 5, (24) and (25).

- o Condition (25), Offsite Emergency Preparedness - completed per Reference 1.
- o Condition (24), Emergency Planning Program - completed per Reference 2.
- o Condition (16) requirement 5, Emergency Response Facilities (ERF) - reported complete contingent upon completion of condition (16) requirement 2, item A7.15, Inoperative Transient Data Acquisition System (TDAS) and Graphics Display System (GDS) computer systems which was reported complete per Reference 3.

The TDAS and GDS computers are now functional. In order to declare the TSC and EOF functional, NUREG-0737, Supplement 1, requires certain Reg. Guide 1.97 variables to be available in the EOF and TSC. The primary method of

A003  
110



Handwritten scribbles at the top right corner.

Faint, illegible text or markings in the upper right quadrant.

Faint, illegible text or markings in the lower right quadrant.

Faint, illegible markings at the bottom left corner.

Faint, illegible markings at the bottom right corner.

A. Schwencer

Page Two

March 22, 1984

LICENSING CONDITION (16), EMERGENCY RESPONSE CAPABILITY

assuring availability of these variables is the TDAS. However, some of the Reg. Guide 1.97 input to the TDAS have not yet been calibrated and accepted and are not available on the TDAS. Under this condition and future occasions when the TDAS is inoperative, alternate methods will be used to assure availability of the Reg. Guide 1.97 variables. Alternate methods available include standard plant phones, a dedicated phone, radio communications and Nefax capability. With the use of alternate methods for assuring the availability of the Reg. Guide 1.97 variables in the TSC and EOF, these facilities can be declared functional and licensing condition (16), requirement 5 complete.

Should you have any further questions, please contact Mr. P. L. Powell, Manager, WNP-2 Licensing.

Very truly yours,

*Carl Van Hoff for GCS*

G. C. Sorensen, Manager  
Regulatory Programs

PLP/tmh

cc: R Auluck - NRC  
WS Chin - BPA  
AD Toth - NRC Site



Handwritten scribbles or marks in the top right corner.

0.00 00 1

0.00 1