

MAY 11 1984

Docket No. 50-397

8405210490 840511
PDR ADCK 05000397
Q PDR

Mr. G. C. Sorensen, Manager
Regulatory Programs
Washington Public Power Supply System
P. O. Box 968
3000 George Washington Way
Richland, Washington 99352

Dear Mr. Sorensen:

SUBJECT: WNP-2, Inservice Inspection Program

Reference: Letter, G02-82-156, G. C. Sorensen to A. Schwencer, " WNP-2. Use of Portions of Later Addenda of ASME Section XI Examination of Class 2 Systems," dated March 20, 1984

The reference letter requested that the Commission evaluate and approve a plant-specific alternative inspection program for the selection and examination of class 2 piping which consists of using paragraphs IWC-1220, IWC-1221, IWC-1222 and Table IWC-2500, Examination Category C-F, from the 1983 Edition of Section XI of the ASME Code including Addenda through Winter 1983. These requirements will be used in lieu of the mandatory requirements which according to 10CFR50.55a are ASME Section XI 1980 Edition, with Addenda through Winter 1980. For emergency core cooling and residual heat removal system, 1974 Edition including Addenda through Summer 1975.

The staff has reviewed your request and compared your proposed alternative inspection program with the requirements of the regulations. The staff has determined that your alternative inspection program would result in more inservice volumetric examinations and thus your program for the selection and examination of Class 2 piping, as described in the referenced letter is acceptable.

Sincerely,

A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

cc: See next page

DL:LB#2/PM
Rauluck:bdm
5/10/84

DL:LB#2/BC
ASchwencer
5/11/84

Distribution:
Document Control
NRC PDR
Local PDR
NSIC
LB#2 Reading
E. Hylton, LA

R. Auluck
OELD, Attorney
ACRS (16)
E. Jordan
N. Grace
Region V



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 11, 1984

Docket No. 50-397

Mr. G. C. Sorensen, Manager
Regulatory Programs
Washington Public Power Supply System
P. O. Box 968
3000 George Washington Way
Richland, Washington 99352

Dear Mr. Sorensen:

SUBJECT: WNP-2, Inservice Inspection Program

Reference: Letter, 602-82-156, G. C. Sorensen to A. Schwencer, "WNP-2. Use of Portions of Later Addenda of ASME Section XI Examination of Class 2 Systems," dated March 20, 1984

The reference letter requested that the Commission evaluate and approve a plant-specific alternative inspection program for the selection and examination of class 2 piping which consists of using paragraphs IWC-1220, IWC-1221, IWC-1222 and Table IWC-2500, Examination Category C-F, from the 1983 Edition of Section XI of the ASME Code including Addenda through Winter 1983. These requirements will be used in lieu of the mandatory requirements which according to 10CFR50.55a are ASME Section XI 1980 Edition, with Addenda through Winter 1980. For emergency core cooling and residual heat removal system, 1974 Edition including Addenda through Summer 1975.

The staff has reviewed your request and compared your proposed alternative inspection program with the requirements of the regulations. The staff has determined that your alternative inspection program would result in more inservice volumetric examinations and thus your program for the selection and examination of Class 2 piping, as described in the referenced letter is acceptable.

Sincerely,

A handwritten signature in cursive script, appearing to read "A. Schwencer".

A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

cc: See next page



1-2-3-4-5-6-7-8-9-10-11-12-13-14-15-16-17-18-19-20-21-22-23-24-25-26-27-28-29-30-31-32-33-34-35-36-37-38-39-40-41-42-43-44-45-46-47-48-49-50-51-52-53-54-55-56-57-58-59-60-61-62-63-64-65-66-67-68-69-70-71-72-73-74-75-76-77-78-79-80-81-82-83-84-85-86-87-88-89-90-91-92-93-94-95-96-97-98-99-100

WNP-2

Mr. G. C. Sorensen, Manager
Regulatory Programs
Washington Public Power Supply System
P. O. Box 968
3000 George Washington Way
Richland, Washington 99352

cc: Nicholas Reynolds, Esquire
Bishop, Cook, Liberman, Purcell & Reynolds
1200 Seventeenth Street, N. W.
Washington, D. C. 20036

Mr. G. E. Doupe, Esquire.
Washington Public Power Supply System
P. O. Box 968
3000 George Washington Way
Richland, Washington 99352

Nicholas Lewis, Chairman
Energy Facility Site Evaluation Council
Mail Stop PY-11
Olympia, Washington 98504

P. L. Powell, Licensing Manager
Washington Public Power Supply System
P. O. Box 968
Richland, Washington 99352

Mr. W. G. Conn, Sr. N/M Group Supervisor
Burns and Roe, Incorporated
601 Williams Boulevard
Richland, Washington 99352

R. B. Glasscock, Director
Licensing and Assurance
Washington Public Power Supply System
P. O. Box 968, MD 650
Richland, Washington 99352

Mr. J. D. Martin
WNP-2 Plant Manager
Washington Public Power Supply System
P. O. Box 968
Richland, Washington 99352