



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

DOCKET NO. '50-397

WPPSS NUCLEAR PROJECT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

License No. NPF-21
Amendment No. 10

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Washington Public Power Supply System (the Supply System, also the licensee) dated March 14, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application as amended, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulation set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, Facility Operating License No. NPF-21 is amended to revise the Technical Specifications as indicated in the attachment to this amendment and paragraph 2.C.(2) of the Facility Operating License is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 10, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

8507010201 850612
PDR ADCK 05000397
P PDR

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Walter R. Butler, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure:
Changes to the Technical
Specifications

Date of Issuance: JUN 12 1985

ATTACHMENT TO LICENSE AMENDMENT NO. 10
FACILITY OPERATING LICENSE NO. NPF-21
DOCKET NO. 50-397

Replace the following page of the Appendix "A" Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

REMOVE

3/4 4-11

INSERT

3/4 4-11



TABLE 3.4.3.2-1

REACTOR COOLANT SYSTEM PRESSURE ISOLATION VALVES

<u>VALVE NUMBER</u>	<u>SYSTEM</u>
HPCS-V-4	HPCS
HPCS-V-5	HPCS
LPCS-V-5	LPCS
LPCS-V-6	LPCS
*RCIC-V-66	RCIC
*RCIC-V-13	RCIC
RHR-V-8	RHR
RHR-V-9/209	RHR
*RHR-V-23	RHR
RHR-V-41A, B, C	RHR
RHR-V-42A, B, C	RHR
RHR-V-50A/123A, 50B/123B	RHR
RHR-V-53A, B	RHR

TABLE 3.4.3.2-2

REACTOR COOLANT SYSTEM INTERFACE VALVES
LEAKAGE PRESSURE MONITORS

<u>INSTRUMENT NUMBER</u>	<u>FUNCTION</u>	<u>ALARM SETPOINT (psig)</u>
HPCS-PIS-3 (E22-N003)	HPCS Pump Suction Pressure High	≤ 80
LPCS-PIS-5 (E21-N005)	LPCS Pump Discharge Pressure High	≤ 442
RCIC-PS-21 (E51-N021)	RCIC Pump Suction Pressure High	≤ 91
RHR-PIS-22A, B, C (E12-N022)	RHR Pump Discharge Pressure to RPV High	≤ 475
RHR-PS-18 (E12-N018)	RHR Pump Shutdown Cooling Suction Pressure High	≤ 168

*The 18 month leakage test for these valves is deferred until the first refueling outage.