



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

DOCKET NO. 50-397

WPPSS NUCLEAR PROJECT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE



License No. NPF-21
Amendment No. 13

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Washington Public Power Supply System (the Supply System, also the licensee) dated February 27, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application as amended, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, Facility Operating License No. NPF-21 is amended to revise the Technical Specifications as indicated in the attachments to this amendment and paragraph 2.C.(2) of Facility Operating License NPF-21 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 13, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

8507100417 850625
PDR ADDCK 05000397
P PDR



3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Walter R. Butler

Walter R. Butler, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure:
Changes to Technical Specifications

Date of Issuance: JUN 25 1985



ATTACHMENT TO LICENSE AMENDMENT NO. 13
FACILITY OPERATING LICENSE NO. NPF-21
DOCKET NO. 50-397

Replace the following pages of the Appendix "A" Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

REMOVE

3/4 3-28
3/4 3-32
3/4 3-36

INSERT

3/4 3-28
3/4 3-32
3/4 3-36



TABLE 3.3.3-1 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>		<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM(a)</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>ACTION</u>	
C. <u>DIVISION 3 TRIP SYSTEM</u>					
1. <u>HPCS SYSTEM</u>					
a. Reactor Vessel Water Level - Low, Low, Level 2		2(b)	1, 2, 3, 4*, 5*	30	
b. Drywell Pressure - High		2(b)	1, 2, 3	30	
c. Reactor Vessel Water Level-High, Level 8		2(c)	1, 2, 3, 4*, 5*	32	
d. Condensate Storage Tanks Level-Low		2(d)	1, 2, 3, 4*, 5*	36	
e. Suppression Pool Water Level-High		2(d)	1, 2, 3, 4*, 5*	36	
f. HPCS System Flow Rate-Low (Minimum Flow)		1	1, 2, 3, 4*, 5*	31	
g. Manual Initiation		1/division	1, 2, 3, 4*, 5*	34	
	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>ACTION</u>
D. <u>LOSS OF POWER</u>					
1. 4.16 kV Emergency Bus Under-voltage (Loss of Voltage)	2/bus	1/bus	2/bus	1, 2, 3, 4**, 5**	37
2. 4.16 kV Emergency Bus Under-voltage (Degraded Voltage)	3/bus	2/bus	2/bus	1, 2, 3, 4**, 5**	38

TABLE NOTATIONS

- (a) A channel may be placed in an inoperable status for up to 2 hours during periods of required surveillance without placing the trip system in the tripped condition provided at least one other OPERABLE channel in the same trip system is monitoring that parameter.
- (b) Also activates the associated division diesel generator.
- (c) Provides signal to close HPCS pump discharge valve only on 2-out-of-2 logic.
- (d) Provides signal to HPCS pump suction valves only.
- * When the system is required to be OPERABLE per Specification 3.5.2 or 3.5.3.
- ** Required when ESF equipment is required to be OPERABLE.
- # Not required to be OPERABLE when reactor steam dome pressure is less than or equal to 128 psig.



TABLE 3.3.3-2 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
C. <u>DIVISION 3 TRIP SYSTEM</u>		
1. <u>HPCS SYSTEM</u>		
a. Reactor Vessel Water Level - Low Low, Level 2	> -50 inches*	> -57 inches
b. Drywell Pressure - High	< 1.65 psig	< 1.85 psig
c. Reactor Vessel Water Level - High, Level 8	< 54.5 inches*	< 56.0 inches
d. Condensate Storage Tank Level - Low	> 448 ft 3 in. elevation	> 448 ft 0 in. elevation
e. Suppression Pool Water Level - High	< 466 ft 8 in. elevation	< 466 ft 10 in. elevation
f. HPCS System Flow Rate - Low (Minimum Flow)	> 1250 gpm	> 1200 gpm
g. Manual Initiation	N.A.	N.A.
D. <u>LOSS OF POWER</u>		
1. 4.16 kV Emergency Bus Undervoltage Loss of Voltage ##	a. 4.16 kV Basis - 2870 ± 86 volts b. 120 V Basis - 82 ± 2.5 volts	2870 ± 172 volts 82 ± 5 volts
a. Divisions 1 and 2	a. 4.16 kV Basis - 3016 ± 90 volts	3016 ± 180 volts
b. Division 3	b. 120 V Basis - 87 ± 2.5 volts	87 ± 5 volts
2. 4.16 kV Emergency Bus Undervoltage Degraded Voltage (Divisions 1, 2, and 3)	a. 4.16 kV Basis - 3632 ± 108 volts b. 120 V Basis - 104.0 ± 3.0 volts c. 8 ± 0.04 sec time delay	3632 ± 216 volts 103.8 ± 6.0 volts 8 ± 0.8 sec time delay

TABLE NOTATIONS

*See Bases Figure B 3/4 3-1.

##These are inverse time delay voltage relays or instantaneous voltage relays with a time delay. The voltages shown are the maximum that will not result in a trip. Lower voltage conditions will result in decreased trip times.



TABLE 4.3.3.1-1 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
C. <u>DIVISION 3 TRIP SYSTEM</u>				
1. <u>HPCS SYSTEM</u>				
a. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3, 4*, 5*
b. Drywell Pressure-High	N.A.	M	R	1, 2, 3
c. Reactor Vessel Water Level-High, Level 8	S	M	R	1, 2, 3, 4*, 5*
d. Condensate Storage Tank Level - Low	N.A.	M	R	1, 2, 3, 4*, 5*
e. Suppression Pool Water Level - High	N.A.	M	R	1, 2, 3, 4*, 5*
f. HPCS System Flow Rate-Low (Minimum Flow)	N.A.	M	R	1, 2, 3, 4*, 5*
g. Manual Initiation	N.A.	R	N.A.	1, 2, 3, 4*, 5*
D. <u>LOSS OF POWER</u>				
1. 4.16 kV Emergency Bus Undervoltage (Loss of Voltage)	N.A.	N.A.	R	1, 2, 3, 4**, 5**
2. 4.16 kV Emergency Bus Undervoltage (Degraded Voltage)	N.A.	M	R	1, 2, 3, 4**, 5**

TABLE NOTATIONS

#Not required to be OPERABLE when reactor steam dome pressure is less than or equal to 128 psig.

*When the system is required to be OPERABLE per Specification 3.5.2.

**Required when ESF equipment is required to be OPERABLE.

