

TABLE 3.6.3-1 (Continued)
PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>VALVE GROUP(a)</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>
a. <u>Automatic Isolation Valves (Continued)</u>		
Reactor Core Isolation Cooling		
RCIC-V-8	8	13 (j)
RCIC-V-63	8	16 (j)
RCIC-V-64	12	H.A.
RCIC-V-76	8	22
Low Pressure Core Spray		
LPCS-V-12	10	180
High Pressure Core Spray		
HPCS-V-23	11	180
b. <u>Excess Flow Check Valves(e)</u>		
Containment Atmosphere		
PI-EFC-X29d		H.A.
PI-EFC-X29f		
PI-EFC-X30a		
PI-EFC-X30f		
PI-EFC-X42d		
PI-EFC-X61c		
PI-EFC-X62b		
PI-EFC-X69d		
PI-EFC-X72b		
PI-EFC-X73c		
PI-EFC-X86		
PI-EFC-X67		
PI-EFC-X82b		
PI-EFC-84a		
PI-EFC-X86A		
PI-EFC-X86B		
PI-EFC-X87A		
PI-EFC-X87B		
PI-EFC-X119		

UNRECORDED COPY
 10:15

PI-EFC-X78a
PI-EFC-X42c

8602240274 860218
PDR ADCK 05000397
P PDR

TABLE 3.6.3-1 (Continued)
PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>VALVE GROUP(a)</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>
b. <u>Excess Flow Check Valves (e) (Continued)</u>		
Reactor Pressure Vessel		N.A.
PI-EFC-X8		
PI-EFC-X12A,B,C		
PI-EFC-X18A,B,C,D		
PI-EFC-X37e,f		
PI-EFC-X38a,b,c,d,e,f		
PI-EFC-X39a,b,d,e		
PI-EFC-X40c,d		
PI-EFC-X41c,d		
PI-EFC-X42a,b		
PI-EFC-X44Aa,Ab,Ac,Ad,Ae,Af,Ag,Ah,Aj, Ak,Al,Am		
PI-EFC-X44Ba,Bb,Bc,Bd,Be,Bf,Bg,Bh,Bj, Bk,Bl,Bm		
PI-EFC-X61a,b		
PI-EFC-X62c,d		
PI-EFC-X66		
PI-EFC-X67		
PI-EFC-X69a,b,e		
PI-EFC-X70a,b,c,d,e,f		
PI-EFC-X71a,b,c,d,e,f		
PI-EFC-X72a		
PI-EFC-X73a		
PI-EFC-X74a,b,e,f		
PI-EFC-X75a,b,c,d,e,f		
PI-EFC-X78b,c,f		
PI-EFC-X79a,b		
PI-EFC-X82b		
PI-EFC-X84a		
PI-EFC-X106		
PI-EFC-X107		
PI-EFC-X108		
PI-EFC-X109		
PI-EFC-X110		

RECEIVED
APR 14 1963