


8603040452 860226
PDR ADOCK 05000397
PDR

XN-NF-86-01
Rev. 1
Issue Date 2/25/86

WNP-2 CYCLE 2 RELOAD ANALYSIS

Prepared by:


J.E. Krajicek, Senior Engineer
BWR Safety Analysis

Concur:

 2/11/86
G.N. Ward, Manager
Reload Licensing


Approve:

 2/11/86
G.J. Busselman, Manager
Fuel Design


Approve:

 2/12/86
T.W. Patten, Manager
Neutronics and Fuel Management

Approve:

 2/13/86
H.E. Williamson, Manager
Licensing and Safety Engineering

Approve:

 2/13/86
G.L. Ritter, Manager
Fuel Engineering and Technical Services

m/n

EXXON NUCLEAR COMPANY, INC.

NUCLEAR REGULATORY COMMISSION DISCLAIMER

IMPORTANT NOTICE REGARDING CONTENTS AND USE OF THIS DOCUMENT

PLEASE READ CAREFULLY

This technical report was derived through research and development programs sponsored by Exxon Nuclear Company, Inc. It is being submitted by Exxon Nuclear to the USNRC as part of a technical contribution to facilitate safety analyses by licensees of the USNRC which utilize Exxon Nuclear-fabricated reload fuel or other technical services provided by Exxon Nuclear for light water power reactors and it is true and correct to the best of Exxon Nuclear's knowledge, information, and belief. The information contained herein may be used by the USNRC in its review of this report, and by licensees or applicants before the USNRC which are customers of Exxon Nuclear in their demonstration of compliance with the USNRC's regulations.

Without derogating from the foregoing, neither Exxon Nuclear nor any person acting on its behalf:

- A. Makes any warranty, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this document, or that the use of any information, apparatus, method, or process disclosed in this document will not infringe privately owned rights; or
- B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, method, or process disclosed in this document.

TABLE OF CONTENTS

<u>Section</u>		<u>Page</u>
1.0	INTRODUCTION.....	1
2.0	FUEL MECHANICAL DESIGN ANALYSIS.....	2
3.0	THERMAL HYDRAULIC DESIGN ANALYSIS.....	3
3.1	Design Criteria.....	3
3.1.3	Fuel Centerline Temperature.....	3
3.2	Hydraulic Characterization.....	3
3.2.5	Bypass Flow.....	3
3.3	MCPR Fuel Cladding Integrity Safety Limit.....	3
3.3.1	Coolant Thermodynamic Condition.....	3
3.3.2	Design Basis Radial Power Distribution.....	3
3.3.3	Design Basis Local Power Distribution.....	3
4.0	NUCLEAR DESIGN ANALYSIS.....	4
4.1	Fuel Bundle Nuclear Design Analysis.....	4
4.2	Core Nuclear Design Analysis.....	4
4.2.1	Core Configuration.....	4
4.2.2	Core Reactivity Characteristics.....	4
4.2.3	Stability Analysis.....	5
4.2.4	Core Hydrodynamic Stability.....	5
5.0	ANTICIPATED OPERATIONAL OCCURRENCES.....	5
5.1	Analysis of Plant Transients at Rated Conditions.....	5
5.2	Analyses for Reduced Flow Operation.....	6
5.3	ASME Overpressurization Analysis.....	6
5.4	Control Rod Withdrawal Error.....	6





TABLE OF CONTENTS

<u>Section</u>		<u>Page</u>
5.5	Fuel Loading Error.....	6
5.6	Determination of Thermal Margins.....	7
6.0	POSTULATED ACCIDENTS	7
6.1	Loss-of-Coolant Accident.....	7
6.1.1	Break Location Spectrum.....	8
6.1.2	Break Size Spectrum.....	8
6.1.3	MAPLHGR Analyses for ENC XN-1 8x8 Fuel.....	8
6.2	Control Rod Drop Accident.....	8
7.0	TECHNICAL SPECIFICATIONS.....	9
7.1	Limiting Safety System Settings.....	9
7.1.1	MCPR Fuel Cladding Integrity Safety Limit.....	9
7.1.2	Steam Dome Pressure Safety Limit.....	9
7.2	Limiting Conditions for Operation.....	9
7.2.1	Average Planar Linear Heat Generation Rate Limits for ENC XN-1 8x8 Fuel.....	9
7.2.2	Minimum Critical Power Ratio.....	9
7.2.3	Surveillance Requirements.....	10
7.2.3.1	Scram Insertion Time Surveillance.....	10
7.2.3.2	Stability Surveillance.....	10
7.2.3.3	Mechanical Design LHGR Surveillance.....	11
9.0	ADDITIONAL REFERENCES.....	22
<u>APPENDICES</u>		
A.	SEISMIC-LOCA EVALUATION.....	A-1
B.	SINGLE LOOP OPERATION.....	B-1




LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
4.1	Neutronic Design Values.....	12
A.1	Comparison of Physical and Geometric Characteristics for ENC and GE 8x8 Assemblies.....	A-2

LIST OF FIGURES

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3.1	Radial Power Histogram for 1/4 Core Safety Limit Model.....	14
3.2	WNP-2 Cycle 2 Safety Limit Local Power Factors (ENC Fuel).....	15
4.1	WNP-2 Cycle 2 (XN-1) Enriched Zone Enrichment Distribution.....	16
4.2	WNP-2 Cycle 2 Reference Loading Pattern by Fuel Type.....	17
4.3	Decay Ratio vs. Reactor Power for WNP-2 Cycle 2.....	18
5.1	WNP-2 Cycle 2 Control Rod Withdrawal Analysis Initial Control Rod Pattern.....	19
5.2	Reduced Flow MCPR Operating Limit.....	20
7.1	Linear Heat Generation Rate (LHGR) Limit versus Average Planar Exposure Exxon 8x8 Fuel.....	21



WNP-2 CYCLE 2 RELOAD ANALYSIS


Design and Safety Analyses

1.0 INTRODUCTION

This report provides the results of the analyses performed by Exxon Nuclear Company (ENC) in support of the Cycle 2 reload for the Supply System Nuclear Project Number 2 (WNP-2). WNP-2 is scheduled to commence Cycle 2 operation in June 1986. This report is intended to be used in conjunction with ENC topical report XN-NF-80-19(A), Volume 4, "Application of the ENC Methodology to BWR Reloads," which describes the analyses performed in support of this reload, identifies the methodology used for those analyses, and provides a generic reference list. Section numbers in this report are the same as corresponding section numbers in XN-NF-80-19(A), Volume 4. Appendix A of this report presents a seismic-LOCA evaluation of ENC 8x8 fuel, and Appendix B addresses single loop operation.

The WNP-2 Cycle 2 core will comprise a total of 764 fuel assemblies, including 132 unirradiated ENC XN-1 8x8 assemblies, and 632 previously irradiated 8x8 assemblies fabricated by General Electric (GE). The reference core configuration is described in Section 4.2.

As a result of a change in energy requirements since the Cycle 2 analysis commenced, the number of unirradiated ENC assemblies to be actually loaded in Cycle 2 is to be lower than the 196 8x8 assemblies quoted in the System Transient Analysis Report (Reference 9.3). The control rod withdrawal error (CRWE) event was evaluated for the appropriate core loading of 132 ENC 8x8 assemblies and found to be the



most limiting transient. Since the core loading used in the system transient analysis approximates the actual core loading, it is expected that the results presented herein are representative to the Cycle 2 reactor core. Thus, the review of this current document by the U.S. NRC can begin and proceed as there are expected to be minor changes, if any, needed in this documentation after the reanalysis of the system transients with the final loading pattern.


The design and safety analyses reported in this document were based on the design and operational assumptions in effect for WNP-2 during the previous operating cycle except the analyses were expanded to encompass increased core flow up to 106%.

2.0 FUEL MECHANICAL DESIGN ANALYSIS

Applicable Fuel Design Report: Reference 9.1 and 9.6

Qualification analyses provided in the two references are both applicable to the WNP-2 XN-1 fuel.

The expected power history for the fuel to be irradiated during Cycle 2 of WNP-2 is bounded by the assumed power history in the fuel mechanical design analyses. ENC analyses have confirmed that centerline melting and 1% uniform total clad strain will not be exceeded during all anticipated operational occurrences. Furthermore, the centerline melt criteria are more restrictive than the 1% uniform total clad strain criteria. In addition the internal rod pressure in the ENC fuel was conservatively calculated to be below system pressure for Cycle 2 exposures using this assumed power history.



3.0 THERMAL HYDRAULIC DESIGN ANALYSIS**3.1 DESIGN CRITERIA****3.1.3 Fuel Centerline Temperature**

Exposure at Minimum Margin Point	5000 MWD/MTM
Centerline Temperature at 120% Power	4065°F
Melting Point of Fuel	5000°F
Margin to Centerline Melting	935°F

3.2 HYDRAULIC CHARACTERIZATION**3.2.5 Bypass Flow**

Calculated Bypass Flow Fraction	11.6%
---------------------------------	-------

3.3 MCPR FUEL CLADDING INTEGRITY SAFETY LIMIT**3.3.1 Coolant Thermodynamic Condition**

Core Power	3754 MWt
Core Inlet Enthalpy	527.7 BTU/lbm
Steam Dome Pressure	1031 psia
Feedwater Temperature	420°F

3.3.2 Design Basis Radial Power Distribution

See Figure 3.1

3.3.3 Design Basis Local Power Distribution

See Figure 3.2




4.0 NUCLEAR DESIGN ANALYSIS

4.1 FUEL BUNDLE NUCLEAR DESIGN ANALYSIS

Assembly Average Enrichment	2.72 w/o U-235
Radial Enrichment Distribution	Figure 4.1
Axial Enrichment Distribution	Uniform 2.89 w/o U-235 with 6 inch top and bottom natural uranium blankets
Burnable Poisons	Figure 4.1
Non-Fueled Rods	Figure 4.1
Neutronic Design Parameters	Table 4.1

4.2 CORE NUCLEAR DESIGN ANALYSIS

4.2.1	Core Configuration	Figure 4.2
	Core Exposure at EOC1 (MWD/MTM)	8,161
	Core Exposure at BOC2 (MWD/MTM)	7,424
	Core Exposure at EOC2 (MWD/MTM)	13,528
4.2.2	Core Reactivity Characteristics	
	BOC Cold K-effective, All Rods Out	1.1062
	BOC Cold K-effective, Strongest Rod Out	0.9689
	Reactivity Defect/R-Value, % delta k/k	1.43
	Standby Liquid Control System (SBLC)	
	Reactivity, 660 PPM Boron, K-effective	0.9595



4.2.3 Stability Analysis

Reactor Core Stability

Figure 4.3

Maximum Decay Ratio Value
100% Flow Control Line

0.45

4.2.4 Core Hydrodynamic Stability

WNP-2 has adopted a detect and suppress approach to assuring hydrodynamic stability during plant operation. Because of differences in the relative pressure drop characteristics of the upper and lower tie plate designs between the ENC XN-1 fuel and G.E. 8x8R fuel, the ENC fuel is slightly more stable than the G.E. fuel. The detect and suppress operating requirements in the Technical Specifications implemented during Cycle 1 are to continue in Cycle 2 to provide assurance of stable core operation for Cycle 2.

The stability analysis results shown in Figure 4.3 are included only to be informative, and stability analyses are not necessary to support the detect and suppress plant operational approach to hydrodynamic stability.


5.0 ANTICIPATED OPERATIONAL OCCURRENCES

Applicable Transient Analysis Report

Reference 9.2

5.1 ANALYSIS OF PLANT TRANSIENTS AT RATED CONDITIONS Reference 9.3

Limiting Transient(s): Load Rejection Without Bypass (LRWB)
Feedwater Controller Failure (FWCF)
Loss of Feedwater Heating (LFWH)



<u>Transient*</u>	<u>Maximum Heat Flux</u>	<u>Maximum Power</u>	<u>Maximum Pressure</u>	<u>Delta-CPR</u>
LRWB	116%	320%	1170 psig	0.18
FWCF	109%	147%	1158 psig	0.08
LFWH	123%	126%	1069 psig	0.16

5.2 ANALYSES FOR REDUCED FLOW OPERATION

Reference 9.3

Limiting Transient: Recirculation Flow Increase

5.3 ASME OVERPRESSURIZATION ANALYSIS

Reference 9.3

Limiting Event	MSIV Closure
Worst Single Failure	MSIV Position Scram Trip
Maximum Pressure	1317 psig
Maximum Steam Dome Pressure	1288 psig

5.4 CONTROL ROD WITHDRAWAL ERROR

Initial Control Rod Pattern for CRWE Analysis Figure 5.1


<u>Rod Block Setting</u>	<u>Distance Withdrawn (ft)</u>	<u>ENC Delta-CPR</u>	<u>GE Delta-CPR</u>
106%**	4.0	0.21	0.22
107%	4.5	0.23	0.24
108%	5.0	0.24	0.26

5.5 FUEL LOADING ERROR

Delta CPR 0.11

* All transients are based on measured plant scram insertion data, see Section 7.2.3.1.

** Rod Block Setting (RBS) of 106% for Cycle 2.



5.6 DETERMINATION OF THERMAL MARGINS

Summary of Thermal Margin Requirements

<u>Event</u>	<u>Delta-CPR</u>	<u>MCPR Limit</u>	<u>Model</u>
LRWB	0.18 [*]	1.24	COTRANSA
FWCF	0.08	1.14	COTRANSA
LFWH	0.16	1.22	PTSBWR3
CRWE	0.22	1.28 ^{**}	XTGBWR

MCPR Operating Limits at Rated Conditions

<u>Fuel Type</u>	<u>MCPR Limit (106% RBS)</u>
ENC XN-1 8x8	1.27
GE P8x8R	1.28

MCPR Operating Limits at Off-Rated Conditions

Figure 5.2

Reduced Flow MCPR Limit


Reference 9.3

6.0. POSTULATED ACCIDENTS

6.1 Loss-of-Coolant Accident

* 0.18 at 104% power/100% flow and 0.19 at 104% power/106% flow.

** 1.27 for ENC fuel, 1.28 for GE fuel.




- 6.1.1 Break Location Spectrum Reference 9.4
- 6.1.2 Break Size Spectrum Reference 9.4
- 6.1.3 MAPLHGR Analyses Reference 9.5

Limiting Break: Split Break in the Recirculation Suction
Piping With an Area Equal to Sixty
Percent of the Double-Ended Cross-
Sectional Pipe Area

<u>Bundle Average Exposure (MWD/MTM)</u>	<u>MAPLHGR (kw/ft)</u>	<u>Peak Clad Temperature, °F</u>	<u>Peak Local MWR, %</u>
0	13.0	1765	0.49
5,000	13.0	1766	0.48
10,000	13.0	1765	0.47
15,000	13.0	1772	0.47
20,000	13.0	1788	0.54
25,000	11.3	1699	0.34
30,000	9.4	1521	0.17
35,000	7.9	1397	0.10

- 6.2 Control Rod Drop Accident Reference 9.7

Dropped Control Rod Worth, mK	6.6
Doppler Coefficient dK/KdT, 1/°F	-9.5×10^{-6}
Effective Delayed Neutron Fraction	0.0050
Four-Bundle Local Peaking Factor	1.26
Maximum Deposited Fuel Rod Enthalpy (cal/gm)	98.



7.0 TECHNICAL SPECIFICATIONS

7.1 Limiting Safety System Settings

7.1.1 MCPR Fuel Cladding Integrity Safety Limit

MCPR Safety Limit	1.06
-------------------	------

7.1.2 Steam Dome Pressure Safety Limit

Pressure Safety Limit	1345 psig
-----------------------	-----------

7.2 Limiting Conditions for Operation

7.2.1 Average Planar Linear Heat Generation
Rate Limits for ENC XN-1 8x8 Fuel

<u>Bundle Average Exposure (MWD/MTM)</u>	<u>MAPLHGR (Kw/ft)</u>
0	13.0
5,000	13.0
10,000	13.0
15,000	13.0
20,000	13.0
25,000	11.3
30,000	9.4
35,000	7.9

7.2.2 Minimum Critical Power Ratio


Rated Conditions MCPR Limits (100% to 106% flow)

<u>Fuel Type</u>	<u>Limit</u>
ENC XN-1 8x8	1.27
GE P8x8R	1.28

Off-Rated Conditions MCPR Limit

Reduced Flow MCPR Limit

Figure 5.2



7.2.3 Surveillance Requirements

7.2.3.1 Scram Insertion Time Surveillance

The ENC reload safety analyses were performed using the control rod insertion times shown below which are based on plant data. In the event that plant surveillance shows these scram insertion times may be exceeded, the plant thermal margin limits are to default to the values which correspond to the technical specification control rod scram times.


<u>Position Inserted From Fully Withdrawn</u>	<u>Average Rod Time in Seconds* as Defined in Footnote</u>
Notch 45	0.404
Notch 39	0.660
Notch 25	1.504
Notch 5	2.624

The limiting transient using technical specification control rod scram times is the generator load rejection without bypass. The MCPR for both ENC and GE fuel during Cycle 2 is 1.32 using the technical specification control rod speeds. The use of technical specification control rod insertion times on all of the core transients investigated has been shown to have no effect on the definition of the limiting transient, but only to change the magnitude of the delta CPR. This is discussed in reference 9.2.

7.2.3.2 Stability Surveillance

Detect and Suppress Procedures in accordance with the surveillance requirements implemented in the Technical Specifications during Cycle 1 are applicable during Cycle 2.

* Slowest measured average control rod insertion time to specified notches for each group of four control rods arranged in a 2x2 array.



7.2.3.3 Mechanical Design LHGR Surveillance

The mechanical design linear heat generation rate (LHGR) limit versus average planar exposure for ENC 8x8 reload fuel is shown in Figure 7.1. This figure was developed from information contained in reference 9.1, and the region of permissible operation is shown.




Table 4.1 Neutronic Design Values

Fuel Pellet

Fuel Material	UO ₂ Sintered Pellets
Density, g/cc	10.36
% of T.D.	94.5
Diameter	
Enriched Fuel	0.4055
Natural Fuel	0.4045

Fuel Rod

Fuel Length, inches	150
Cladding Material	Zircaloy-2
Clad I.D., inches	0.414
Clad O.D., inches	0.484

Fuel Assembly

Number of Fuel Rods	62
Number of Inert Water Rods	2
Fuel Rod Enrichments	Figure 4.1
Fuel Rod Pitch, inches	0.641
Fuel Assembly Loading, KgU	176.0





Table 4.1 Neutronic Design Values (Cont.)

Core Data

Number of fuel assemblies	764
Rated thermal power, MW	3323
Rated core flow, Mlbm/hr	108.5
Core inlet subcooling, BTU/lbm	19.0
Reactor Pressure, psia	1019.0
Channel thickness, inch	0.100
Fuel assembly pitch, inch	6.00
Water gap thickness (symmetric), inch	0.522

Control Rod Data

Absorber material	B4C
Total blade span, inch	9.75
Total blade support span, inch	1.58
Blade thickness, inch	0.260
Blade face-to-face internal dimension, inch	0.200
Absorber rods per blade	76
Absorber rod outside diameter, inch	0.188
Absorber rod inside diameter, inch	0.138
Absorber density, % of theoretical	70.0



WNP-2 CYCLE 2 DESIGN BASIS RADIAL POWER





Figure 3.1 Radial Power Histogram For 1/4 Core Safety Limit Model




LL 0.91	L 0.95	ML 1.02	M 1.06	M 1.06	ML 1.02	L 0.95	LL 0.91
L 0.95	ML 0.97	H 1.08	ML* 0.87	H 1.04	H 1.07	M 1.04	L 0.95
ML 1.02	H 1.08	H 1.01	H 1.00	H 0.98	H 1.00	ML* 0.90	ML 1.02
M 1.06	ML* 0.87	H 1.00	W 0.00	M 0.90	H 0.98	H 1.04	M 1.06
M 1.06	H 1.04	H 0.98	M 0.90	W 0.00	H 0.99	M 0.93	M 1.05
ML 1.02	H 1.07	H 1.00	H 0.98	H 0.99	H 1.00	H 1.07	M 1.08
L 0.95	M 1.04	ML* 0.90	H 1.04	M 0.93	H 1.07	ML* 0.96	ML 1.07
LL 0.91	L 0.95	ML 1.02	M 1.06	M 1.05	M 1.08	ML 1.07	L 1.03

Figure 3.2

WNP-2 Cycle 2 Safety Limit
Local Power Factors (ENC Fuel)

XN-CH-0524




```

*****
*
*
* : LL : L : ML : M : M : ML : L : LL :
* :   :   :   :   :   :   :   :   :   :
*
* : L : ML : H : ML* : H : H : M : L :
* :   :   :   :   :   :   :   :   :
*
* : ML : H : H : H : H : H : ML* : ML :
* :   :   :   :   :   :   :   :   :
*
* : M : ML* : H : W : M : H : H : M :
* :   :   :   :   :   :   :   :   :
*
* : M : H : H : M : W : H : M : M :
* :   :   :   :   :   :   :   :   :
*
* : ML : H : H : H : H : H : H : M :
* :   :   :   :   :   :   :   :   :
*
* : L : M : ML* : H : M : H : ML* : ML :
* :   :   :   :   :   :   :   :   :
*
* : LL : L : ML : M : M : M : ML : L :
* :   :   :   :   :   :   :   :   :
    
```

LL RODS (3) --- 1.50 W/O U235
 L RODS (7) --- 2.00 W/O U235
 ML RODS (9) --- 2.57 W/O U235
 M RODS (16) --- 2.94 W/O U235
 H RODS (22) --- 3.54 W/O U235
 ML* RODS (5) --- 2.57 W/O U235 + 2.00 W/O GD203
 W RODS (2) --- INERT WATER ROD


Figure 4.1 WNP-2 Cycle 2 (XN-1) Enriched Zone Enrichment Distribution



A	B	B	B	B	B	B	B	B	B	B	B	B	B	A
B	C	A	C	B	C	A	C	B	C	B	C	B	B	A
B	A	B	B	A	A	B	B	A	B	A	B	B	B	A
B	C	B	C	A	C	B	C	A	C	B	C	B	B	A
B	B	A	A	B	B	A	A	B	B	A	B	B	B	A
B	C	A	C	B	C	A	C	B	C	B	C	B	B	A
B	A	B	B	A	A	B	B	A	B	B	B	B	B	A
B	C	B	C	A	C	B	C	B	C	B	C	B	A	
B	B	A	A	B	B	A	B	B	B	B	B	B	A	
B	C	B	C	B	C	B	C	B	C	B	A	A		
B	B	A	B	A	B	B	B	B	B	A				
B	C	B	C	B	C	B	C	B	A					
B	B	B	B	B	B	B	B	A	A					
B	B	B	B	B	B	B	A							
A	A	A	A	A	A	A								

<u>Fuel Type</u>	<u>Number of Assemblies</u>	<u>Description</u>
A	200	GE 8x8 Type II 1.76 w/o U-235
B	432	GE 8x8 Type III 2.19 w/o U-235
C	132	XN-1 8x8 2.72 w/o U-235

Figure 4.2 WNP-2 Cycle 2 Reference Loading Pattern by Fuel Type
(One Quarter of Symmetrical Core Loading)






Figure 4.3 Decay Ratio vs. Reactor Power for WNP-2 Cycle 2




	02	06	10	14	18	22	26	30	34	38	42	46	50	54	58	
59					--	--	--	--	--	--						59
55				--	--	00	--	36	--	00	--	--				55
51			--	--	--	--	--	--	--	--	--	--	--			51
47		--	--	00	--	00	--	00	--	00	--	00	--	--		47
43	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	43
39	--	00	--	00	--	10	--	12	--	10	--	00	--	00	--	39
35	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	35
31	--	36	--	00	--	12	--	00*	--	12	--	00	--	36	--	31
27	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	27
23	--	00	--	00	--	10	--	12	--	10	--	00	--	00	--	23
19	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	19
15		--	--	00	--	00	--	00	--	00	--	00	--	--		15
11			--	--	--	--	--	--	--	--	--	--	--	--		11
07				--	--	00	--	36	--	00	--	--				07
03					--	--	--	--	--	--	--	--				03
	02	06	10	14	18	22	26	30	34	38	42	46	50	54	58	

* Control Rod Being Withdrawn
 Rod Position in Notches Withdrawn
 Full in = 00
 Full out = --

Figure 5.1 WNP-2 Cycle 2 Control Rod Withdrawal Analysis
 Initial Control Rod Pattern






20

XN-NF-86-01
Rev. 1

Figure 5.2 Reduced Flow MCPR Operating Limit








Figure 7.1

**LINEAR HEAT GENERATION RATE (LHGR) LIMIT
VERSUS AVERAGE PLANAR EXPOSURE
EXXON 8X8 FUEL**



9.0 ADDITIONAL REFERENCES

- 9.1 S.F. Gaines, "Generic Mechanical Design for Exxon Nuclear Jet Pump BWR Reload Fuel," XN-NF-81-21(A), Revision 1, Exxon Nuclear Co., Inc., Richland, WA 99352 (January 1982).
- 9.2 R.H. Kelley, "Exxon Nuclear Plant Transient Methodology for Boiling Water Reactors," XN-NF-79-71(P), Revision 2, Exxon Nuclear Co., Inc., Richland, WA 99352 (November 1981).
- 9.3 J.E. Krajicek, "WNP-2 Cycle 2 Plant Transient Analysis," XN-NF-85-143, Revision 1, Exxon Nuclear Co., Inc., Richland, WA 99352 (February, 1985).
- 9.4 J.E. Krajicek, "LOCA Break Spectrum for a BWR 5," XN-NF-85-138(P), Exxon Nuclear Co., Inc., Richland, WA 99352 (December 1985).
- 9.5 D.J. Braun, "WNP-2 LOCA-ECCS Analysis, MAPLHGR Results," XN-NF-85-139, Exxon Nuclear Co., Inc., Richland, WA 99352 (December 1984).
- 9.6 M.H. Smith, "Generic Mechanical Design for Exxon Nuclear Jet Pump BWR Reload Fuel," XN-NF-81-21, Revision 1, Supplement 1, Exxon Nuclear Co., Inc., Richland, WA 99352 (March 1985).
- 9.7 "Exxon Nuclear Methodology for Boiling Water Reactors-Neutronics Methods for Design and Analysis." XN-NF-80-19(A), Volume 1 and Supplements, Exxon Nuclear Co., Inc., Richland, WA 99352 (May 1980).



APPENDIX A

SEISMIC-LOCA EVALUATION

The structural response of the ENC XN-1 8x8 fuel is the same as the structural response of the GE P8x8R fuel it replaces in the WNP-2 core. Therefore, the seismic-LOCA structural response evaluation performed in support of the initial core remains applicable and continues to provide assurance that control blade insertion will not be inhibited following the occurrence of the design basis seismic-LOCA event.

The physical and geometric properties of the ENC XN-1 8x8 and the GE P8x8R fuel types which are important to the dynamic response of the fuel are summarized in Table A1. The close agreement between the important parameters for the two fuel types indicates that the structural response would be very similar for both fuel types.

Similarity in the natural frequencies of the two fuel types is further assured by the stiffness of the fuel assembly channel box. Both fuel types use an equivalent fuel assembly channel box, and the channel box dominates the overall dynamic response of the incore fuel. ENC calculations show that more than 97% of the stiffness of a fuel assembly is attributable to the stiffness of the channel box. For this reason, the dynamic structural response of the reload core is essentially that of the initial core, and the original seismic-LOCA analysis remains applicable. Deformation of the channel to the point that control blade insertion is inhibited is not predicted to occur.




Table A.1 Comparison of Physical and Geometric Characteristics
for ENC and GE 8x8 Assemblies

<u>Property</u>	<u>Fuel Type</u>	
	<u>ENC</u>	<u>GE</u>
Fuel Rod Pitch, inch	.641	.640
Number of Spacers	7	7
Assembly Weight, lbs	589	600
Assembly Length, inch	176.05	176.16
Fuel Rod Diameter, inch	.484	.483
Cladding Thickness, inch	.035	.032



APPENDIX B

SINGLE LOOP OPERATION
(SLO)

The NSSS supplier, General Electric (GE), has provided analyses which demonstrate the safety of plant operation with a single recirculation loop out of service for an extended period of time. These analyses restrict the overall operation of the plant to lower bundle power levels and lower nodal power levels than are allowed when both recirculation systems are in operation. The physical interdependence between core power and recirculation flow rate inherently limits the core to less than rated power. Because the ENC fuel was designed to be compatible with the coresident fuel in thermal hydraulic, nuclear, and mechanical design performance, and because the ENC methodology has given results which are consistent with those of the previous analyses for normal two-loop operation, the analyses performed by GE for single loop operation are also applicable to single loop operation with fuel and analyses provided by ENC.

With a single recirculation loop in operation, the GE analyses supported continued operation with an increase of 0.01 in the MCPR safety limit. Because of the similarity between the ENC XN-1 8x8 fuel type and the other fuel types making up the remainder of the core, and because of the similarity in the magnitude of the uncertainties which determine the MCPR safety limit, this small increase in the safety limit value is also appropriate for operation with ENC fuel and analyses. For Cycle 2 operation with both recirculation loops in operation, the MCPR safety limit is 1.06, which is the same value as was used for the previous cycle. For Cycle 2 operation with a



single recirculation loop in service, the MCPR safety limit is 1.07, which is also the same value as was used for the previous cycle.

The consequences of core-wide transients at the reduced power and flow conditions necessitated by single loop operation are bounded by the consequences of these events at rated conditions. The additional conservatism imposed by the reduced flow MCPR operating limits specified in the main body of this report assures that the MCPR safety limit will not be violated during anticipated operational occurrences with a single recirculation loop in service. No modification to the delta-CPR defining the rated conditions MCPR operating limit is required, and the reduced flow MCPR limit curve remains conservatively applicable during single loop operation. Because the reduced flow MCPR limit curves are based on equipment performance which physically cannot happen during single loop operation, the added conservatism present in the curves compensates for the penalties associated with increased uncertainties in the MCPR safety limit and control rod drive performance. The reduced flow MCPR limit curves are applicable without modification during single loop operation.

The stability characteristics of the Cycle 2 core are equivalent to or better than those of the previous cycle core. Reactor operation within the monitoring which assured adequate stability using the detect and suppress approach for the previous cycle will continue to assure adequate stability for Cycle 2.

To support operation of WNP-2 with a core composed of GE P8x8R and ENC 8x8 fuel with a single recirculation pump operating, ENC recommends the conservative use of GE fuel MAPLHGR limits for the similar GE P8x8R fuel design with a multiplier of 0.84 applied for single loop operation. The basis for this recommendation is as follows:



The phenomena which require the reduction in MAPLHGR limits are a result of operation of the WNP-2 system with a single active recirculation loop, and are equally applicable to both GE and ENC fuel designs; and

The analytical methods used by GE have yielded conservative MAPLHGR limits relative to the MAPLHGR limits obtained using the approved ENC analytical methods.

Therefore, applying the more conservative GE MAPLHGR limits to ENC fuel provides a limit which assures conformance with the criteria of 10 CFR 50.46.



XN-NF-86-01
Rev. 1
ISSUE DATE 2/25/86

WNP-2 CYCLE 2 RELOAD ANALYSIS

Distribution

J.C. Chandler
R.E. Collingham
S.E. Jensen
T.H. Keheley
J.E. Krajicek
T.L. Krysinski
J.L. Maryott
J.N. Morgan
T.W. Patten
A. Reparaz
G.L. Ritter
B.T. Stiles
G.N. Ward
H.E. Williamson

J.B. Edgar/WPPSS (32)

Document Control (5)

