

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8606090390 DDC DATE: 86/06/03 NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 SORENSEN, G. C. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION
 ADENSAM, E. G. BWR Project Directorate 3

SUBJECT: Informs that air dryers installed in diesel engine air starting sys, satisfying License Condition 2. C. (20).

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	BWR ADTS		1	0	BWR EB		1
	BWR EICSB		2	2	BWR FOB		1
	BWR PD3 LA		1	0	BWR PD3 PD 01		5
	BRADFUTE, J		1		BWR PSB		1
	BWR RSB		1				
INTERNAL:	ACRS	09	6	0	ADM/LFMB		1
	ELD/HDS2		1	0	NRR/DRAFT/TSCB		1
	NRR/ORAS		1	0	<u>REG FILE</u>	04.	1
	RGN5		1				
EXTERNAL:	24X		1		EG&G BRUSKE, S		1
	LPDR	03	1		NRC PDR	02	1
	NSIC	05	1				

TOTAL NUMBER OF COPIES REQUIRED: LTTR 31 ENCL 0



Faint, illegible text in the upper left quadrant.

Faint, illegible text in the upper middle section.

Faint, illegible text in the lower left quadrant.

Faint, illegible text in the lower middle section.

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

8606090390 860603
PDR ADDCK 05000397
PDR

June 3, 1986
G02-86-471

Docket No. 50-397

Director of Nuclear Reactor Regulation
Attn: Ms. E. G. Adensam, Project Director
BWR Project Directorate No. 3
Division of BWR Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensam:

Subject: NUCLEAR PLANT NO. 2
OPERATING LICENSE NPF-21, SATISFACTION
OF LICENSE CONDITION 2.C.(20)

The subject License Condition requires the Supply System install air dryers in the diesel engine air starting system prior to startup following the first refueling outage. Accordingly, the air dryers have been installed and declared operable.

The Supply System considers License Condition 2.C.(20), Emergency Diesel Engine Starting System to be satisfied. Should you have any questions in this matter, please contact Mr. P. L. Powell, Manager, WNP-2 Licensing.

Very truly yours,


G. C. Sorensen, Manager
Regulatory Programs

SIS/bk

cc: JO Bradfute - NRC
JB Martin - NRC RV
E Revell - BPA
NS Reynolds - BLCP&R
NRC Site Inspector

A001
1/6