



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

DOCKET NO. 50-397

WPPSS NUCLEAR PROJECT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 32
License No. NPF-21

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Washington Public Power Supply System (the Supply System, also the licensee), dated August 12, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the enclosure to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-21 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 32, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

8611180181 861106
PDR ADOCK 05000397
P PDR

1944



3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Elinor G. Adensam, Director
BWR Project Directorate No. 3
Division of BWR Licensing

Enclosure:
Changes to the Technical
Specifications

Date of Issuance: November 6, 1986

AMENDMENT NO. 32 TO FACILITY OPERATING LICENSE NO. NPF-21
WPPSS NUCLEAR PROJECT NO. 2

DISTRIBUTION:

Docket No. 50-397

NRC PDR
Local PDR
PRC System
NSIC
BWD-3 r/f
JBradfute (2)
EHylton (1)
EAdensam
Attorney, OELD
CMiles
RDiggs
JPartlow
EJordan
BGrimes
LHarmon
TBarnhart (4)
EButcher

ENCLOSURE TO LICENSE AMENDMENT NO. 32

FACILITY OPERATING LICENSE NO. NPF-21

DOCKET NO. 50-397

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain a vertical line indicating the area of change.

REMOVE

3/4 3-92
3/4 3-93
3/4 11-17

INSERT

3/4 3-92
3/4 3-93
3/4 11-17



TABLE 3.3.7.12-1 (Continued)

TABLE NOTATIONS

*At all times.

**During main condenser offgas treatment system operation.

#Radwaste Building Ventilation Exhaust fan. There are 3 fans; WEA-FN-1A, WEA-FN-1B and WEA-FN-1C.

ACTION STATEMENTS

- ACTION 110 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue for up to 30 days provided that grab samples are taken at least once per 8 hours and analyzed for noble gas gamma emitters within 24 hours.
- ACTION 111 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, operation of main condenser offgas treatment system may continue for up to 30 days provided that grab samples are collected at least once per 4 hours and analyzed within the following 4 hours. If the recombiner temperature remains constant and THERMAL POWER has not changed, the grab sample collection frequency may be changed to 8 hours.
- ACTION 112 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue for up to 30 days provided that within 4 hours after the channel has been declared inoperable samples are continuously collected with auxiliary sampling equipment as required in Table 4.11-2.
- ACTION 113 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue for up to 30 days provided that the flow rate is estimated at least once per 4 hours.
- ACTION 114 - With the number of channels operable less than required by the Minimum Channels OPERABLE requirement, gases from the main condenser offgas treatment system may be released to the environment for up to 72 hours provided:
- a. The offgas treatment system is not bypassed, and
 - b. The offgas post-treatment monitor used in a pretreatment function shall be OPERABLE.*
- ACTION 115 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway shall be terminated.

*With the offgas post-treatment monitor in a pretreatment function unavailable or inoperable, install a temporary replacement ionization chamber for the pretreatment monitor or be in HOT STANDBY within the following 12 hours.

TABLE 4.3.7.12-1

RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>SOURCE CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE IS REQUIRED</u>
1. Main Condenser Offgas Post-Treatment Radiation Monitor					
a. Gross gamma detector alarm and automatic isolation of the offgas system outlet and drain valves	D	D	R(2)	Q(1)	**
2. Main Condenser Offgas Pre-Treatment Radiation Monitor					
a. Gamma sensitive ion chamber located upstream of holdup line	D	M	R(2)	Q(1)	**
3. Main Plant Release Monitor					
a. Noble Gas Activity Monitor					
1) Low Range	D	M	R(2)	Q(1)	*
2) Intermediate Range	D	M	R(2)	Q(7)	*
b. Iodine Sampler	W	N.A.	N.A.	N.A.	*
c. Particulate Sampler	W	N.A.	N.A.	N.A.	*
d. Effluent System Flow Rate Monitor	D	N.A.	R	Q	*
e. Sampler Flow Rate Monitor	D	N.A.	R	Q	*
4. Turbine Building Ventilation Exhaust Monitor					
a. Noble Gas Activity Monitor					
1) Low Range	D	M	R(2)	Q(1)	*
2) Intermediate Range	D	M	R(2)	Q(7)	*
b. Iodine Sampler	W	N.A.	N.A.	N.A.	*
c. Particulate Sampler	W	N.A.	N.A.	N.A.	*
d. Effluent System Flow Rate Monitor	D	N.A.	R	Q	*
e. Sampler Flow Rate Monitor	D	N.A.	R	Q	*

RADIOACTIVE EFFLUENTS

MAIN CONDENSER

LIMITING CONDITION FOR OPERATION

3.11.2.7 The gross radioactivity rate (beta and/or gamma) of the noble gases measured at the main condenser air ejector shall be limited to less than or equal to 332 millicuries/second after 30 minutes decay.

APPLICABILITY: During main condenser offgas treatment system operation as specified in Section 3.3.7.12.

ACTION:

With the gross radioactivity rate of the specified noble gases at the motive steam jet condenser discharge exceeding 332 millicuries/second, restore the gross radioactivity rate to within its limit within 72 hours or be in at least HOT STANDBY within the next 12 hours.

SURVEILLANCE REQUIREMENTS

4.11.2.7.1 The radioactivity rate of noble gases at the main condenser air ejector shall be monitored in accordance with Specification 3.3.7.12.

4.11.2.7.2 The gross radioactivity rate (beta and/or gamma) of the specified noble gases from the main condenser air ejector shall be determined to be within the limits of Specification 3.11.2.7 at the following frequencies by performing an isotopic analysis of a representative sample of gases taken at the discharge (prior to dilution and/or discharge) of the main condenser air ejector:

- a. At least once per 31 days.
- b. Within 4 hours following an increase, as indicated by the condenser air ejector noble gas activity monitor, of greater than 50%, after factoring out increases due to changes in THERMAL POWER level, in the nominal steady-state fission gas release from the primary coolant.

