	1				1
TITLE	SHEET	DATE/REV.	TITLE	SHEET	DATE/REV.
5.0 Quality		}	Floor Drain Radioactive	М 539	32A
Assurance			Containment	11 339	32A
Program	5-1	0	Cooling&Purge	M 543	21
		<del> </del>	Containment	11 0 10	
		У	Atmos. Control	M 554	14
6.0 Flow			Containment		
Diagrams Control	6-1	0	Instru. Air	M 556	13A
Service Air	M 510*	34	Main Steam	M 567	70
Diesel Oil &	H 310"	34	Leakage Cont.	M 557	7A
Misc. Systems	M 512	13A	Liquid Sam.	M 607 sh.	2 5
Reactor Core			Liquid Same	17 007 311.	<u></u>
Iso. Cooling	M 519	21			1
Low Pressure					
Core Spray	M 520	18			
High Pressure					
Core Spray	М 520	18			
Residual Heat	u 501	0.5			
Removal Standby Liq.	M 521	25	-		
Control	м 522	9			
Reactor Water	IT JEE		-		
Cleanup	M 523	32D			
Standby Service	9	020			
Water	M 524	22D			
Reactor Closed					
Cooling	M 525	21 D			
Fuel Pool	u 506	200			
Cooling Control Rod	M 526	28C			<del></del>
Drive	м 528	20			স্
01146	720				
Main Steam	М 529	25A	1		
Reactor					
Feedwater	M 529	25A			
Reactor Recirc					
Cooling	M 530	23A			
Equip. Drain Radioactive	M 537	27			
Radioactive	11 337	27			
			<del> </del>		
					<del></del>
Burns & Roe Flow Diagram Number					
The state of the stage and trained.					

•

December 11, 1985

Docket No.: 50-397

Mr. G. C. Sorensen, Manager Regulatory Programs Washington Public Power Supply System P.O. Box 968 3000 George Washington Way Richland, Washington 99352 DISTRIBUTION
Docket File
Local PDR
NSIC
EHylton
OELD, Attorney
JPartlow
EJordan
Service List

NRC PDR
PRC System
BWR PD #3 RF
JBradfute
ACRS(16)
BGrimes

Dear Mr. Sorensen:

Subject: License Condition 2.C. (6) Ultimate Heat Sink

References: (1) Facility Operating License NPF-21 - WPPSS Nuclear Project No. 2, dated December 20, 1983

(2) Letter GO-85-649, Sorensen (SS) to Butler (NRC), dated September 27, 1985

The Operating License granted to the Supply System, Reference (1), included a condition for operation, 2.C.(6), that required the Supply System to "...perform operational testing of the ultimate heat sink spray ponds to verify analyzed parameters of drift loss, seepage and operational capacity." Those tests were conducted during the summer of 1985, and formally reported to the NRC in an attachment to a letter, Reference (2).

The staff has reviewed this report on spray pond drift loss, etc. transmitted with the referenced letter. The staff agrees with the procedures used for measuring water losses and concludes that the range of windspeeds encountered is adequate for verification of the relationship used in the analysis. The measurements showed that a safety margin of about 20% exists between the data and the safety analysis values and increases with increasing windspeed. We conclude that the original analysis performed by WPPSS in 1979 was conservative in regard to calculation of drift losses.

Based on this review, the staff approves the Supply System's results and conclusions. This approval completes the action which fully satisfies the license condition 2.C.(6), Ultimate Heat Sink.


Sincerely,

Elinor Adensam, Director BWR Project Directorate #3 Division of BWR Licensing

cc: See next page

BWR:PD#3 LA:BWR PD#3 JBradfute:mn EH#/#60n 12/3/85 12/3/85 PWR-A: PMG RBallard 12/06/85

BWR:DE N BLiaw 12/04/85 D:BWR:PD#3 EAdensam



Mr. G. C. Sorensen, Manager Washington Public Power Supply System WPPSS Nuclear Project No. 2 (WNP-2)

CC:
Nicholas S. Reynolds, Esq.
Bishop, Liberman, Cook,
Purcell & Reynolds
1200 Seventeenth Street, N.W.
Washington, D.C. 20036

Mr. G. E. Doupe, Esquire
Washington Public Power Supply System
P. O. Box 968
3000 George Washington Way
Richland, Washington 99532

Mr. Curtis Eschels, Chairman Energy Facility Site Evaluation Council Mail Stop PY-11 Olympia, Washington 98504

P. L. Powell, Licensing Manager Washington Public Power Supply System P. O. Box 968, MD 956B Richland, Washington 99352

Mr. W. G. Conn
Burns and Roe, Incorporated
c/o Washington Public Power Supply
System
P. O. Box 968, MD 994E
Richland, Washington 99352

R. B. Glasscock, Director Licensing and Assurance Washington Public Power Supply System P. O. Box 968, MD 280 Richland, Washington 99352

Mr. C. M. Powers WNP-2 Plant Manager Washington Public Power Supply System P. O. Box MD 927M Richland, Washington 99352 Regional Administrator, Region V U.S. Nuclear Regulatory Commission 1450 Maria Lane, Suite 210 Walnut Creek, California 94596

