

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8905180307      DOC. DATE: 89/05/18      NOTARIZED: NO      DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe      05000397  
 AUTH. NAME      AUTHOR AFFILIATION  
 SORENSEN, G.C.      Washington Public Power Supply System  
 RECIP. NAME      RECIPIENT AFFILIATION  
                                  Document Control Branch (Document Control Desk)

SUBJECT: Undated ltr providing clarifications re proposed ATWS recirculating pump trip design, per 890418 telcon.

DISTRIBUTION CODE: A055D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 2  
 TITLE: OR/Licensing Submittal: Salem ATWS Events GL-83-28

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD5 LA		1	0		PD5 PD		3	3
	SAMWORTH, R		1	1					
INTERNAL:	ACRS		6	6		NRR LASHER, D		1	1
	NRR/DEST/ESB 8D		1	1		NRR/DEST/ICSB 7		1	1
	NRR/DEST/PSB 8D		1	0		NRR/DLPQ/QAB 10		1	0
	NRR/DOEA/GCB 11		1	0		NUDOCS-ABSTRACT		1	1
	OC/LFMB		1	0		OGC/HDS2		1	0
	<u>REG FILE</u> 01		1	1		RES/DSIR/EIB		1	1
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 25 ENCL 19

*m/184 gh*

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S



---

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

---

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

---

Docket No. 50-397

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

Gentlemen:

Subject:           **NUCLEAR PLANT NO. 2  
OPERATING LICENSE NPF-21  
PROVISIONS FOR ATWS RECIRCULATING  
PUMP TRIP (ADDITIONAL INFORMATION)**

Reference:        1) Letter, G02-89-055, GC Sorensen (SS) to NRC,  
                          same subject, dated April 5, 1989

                      2) Letter, G02-89-015, GC Sorensen (SS) to NRC  
                          "Compliance with ATWS Rule 10CFR 50.62 Relating  
                          to RPT System", dated February 6, 1989


In Reference 1) the Supply System requested that the NRR Staff provide the Supply System with any concerns they might have with the conceptual RPT logic trip design previously submitted (Reference 2). The Supply System requested the NRR respond no later than April 21, 1989. On April 18, 1989 a conference call was held between Hulbert Li, Jerry Mauck, and Bob Samworth of the NRR, and Larry Aeschliman, Bob Green, Gordon Brastad and Scott Mulkey of the Supply System. The purpose of the conference call was to discuss any concerns the Staff had regarding the proposed subject design.

As a result of the above conference call, the Supply System provides the following clarifications:

8905180307 890518  
PDR ADDCK 05000397  
P PNU



A055  
/



Page Two

PROVISIONS FOR ATNS RECIRCULATING PUMP TRIP (ADDITIONAL INFORMATION)

1. The Supply System will install a permanent testing feature that will allow testing, while at power, of the relay logic up to and including the last relay prior to the trip coil.
2. Indication of testing will be provided to the Control Room Operators.
3. The Supply System will submit the appropriate Technical Specification change (no later than March 1, 1990).

It is the Supply System's understanding that the NRR staff has no other specific concerns regarding the WNP-2 RPT proposed design at this time. The Supply System intends to proceed immediately on that basis.

Very truly yours,



G. C. Sorensen, Manager  
Regulatory Programs (MD 280)

HLA/bk

cc: JB Martin - NRC RV  
NS Reynolds - BCP&R  
RB Samworth - NRC  
DL Williams - BPA/399  
NRC Site Inspector - 901A

May 18, 1989

DISTRIBUTION  
Docket File  
PDR  
LPDR  
PD 5  
JLee

DOCKET NO(S). 50-397

Mr. G. C. Sorensen, Manager  
Regulatory Programs  
Washington Public Power Supply System  
Post Office Box 968  
Richland, Washington 99352

SUBJECT: WASHINGTON PUBLIC POWER SUPPLY SYSTEM - NUCLEAR PROJECT NO. 2

The following documents concerning our review of the subject facility are transmitted for your information.

- Notice of Receipt of Application, dated \_\_\_\_\_.
- Draft/Final Environmental Statement, dated \_\_\_\_\_.
- Notice of Availability of Draft/Final Environmental Statement, dated \_\_\_\_\_.
- Safety Evaluation Report, or Supplement No. \_\_\_\_\_ dated \_\_\_\_\_.
- Environmental Assessment and Finding of No Significant Impact, dated \_\_\_\_\_.
- Notice of Consideration of Issuance of Facility Operating License or Amendment to Facility Operating License, dated \_\_\_\_\_.
- Bi-Weekly Notice; Applications and Amendments to Operating Licenses Involving No Significant Hazards Considerations, dated 5/3/89 [see page(s)] 18962-18963.
- Exemption, dated \_\_\_\_\_.
- Construction Permit No. CPPR-\_\_\_\_\_, Amendment No. \_\_\_\_\_ dated \_\_\_\_\_.
- Facility Operating License No. \_\_\_\_\_, Amendment No. \_\_\_\_\_ dated \_\_\_\_\_.
- Order Extending Construction Completion Date, dated \_\_\_\_\_.
- Monthly Operating Report for \_\_\_\_\_ transmitted by letter dated \_\_\_\_\_.
- Annual/Semi-Annual Report- \_\_\_\_\_  
\_\_\_\_\_ transmitted by letter dated \_\_\_\_\_.

Office of Nuclear Reactor Regulation

Enclosures:  
As stated

cc: See next page

*m/af  
gn*

OFFICE	DRP/PD5						
SURNAME	JLee						
DATE	5/18/89						

