

CONTROLLED COPY

TABLE 3.8.4.2-1

PRIMARY CONTAINMENT PENETRATION CONDUCTOR
OVERCURRENT PROTECTIVE DEVICES

<u>EQUIPMENT</u>	<u>PRIMARY PROTECTION</u>	<u>BACKUP PROTECTION</u>		
a. <u>6900V Circuit Breakers</u>				
RRC-P-1A	E-CB-RRR (Relay)	E-CB-S5 (Relay) E-CB-N2/5 (Relay)		
RRC-P-1B	E-CB-RRB (Relay)	E-CB-S6 (Relay) E-CB-N2/6 (Relay)		
b. <u>480VAC Fused Disconnects</u>				
MS-V-16	MC-8B-A	Fused	MC-8B	125ACB
RWCU-V-1	MC-8B-A	Fused	MC-8B	125ACB
RHR-V-9	MC-8B-A	Fused	MC-8B	125ACB
RCIC-V-63	MC-8B-A	Fused	MC-8B	125ACB
RCC-V-40	MC-8B-A	Fused	MC-8B	125ACB
RHR-V-123B	MC-8B-A	Fused	MC-8B	125ACB
RCIC-V-76	MC-8B-A	Fused	MC-8B	125ACB
RHR-V-123A	MC-8B-A	Fused	MC-8B	125ACB

125ACB
125ACB
125ACB
125ACB
125ACB
125ACB
125ACB
125ACB
125ACB

*Change all
to state
Fused*

8908180333 890814
PDR ADOCK 05000397
PDC