

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

August 14, 1989
G02-89-137

Docket No. 50-397

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

Gentlemen:

Subject: NUCLEAR PLANT NO. 2
LICENSE NO. NPF-21, REQUEST FOR AMENDMENT TO TECHNICAL
SPECIFICATION TABLE 3.8.4.2-1 PRIMARY CONTAINMENT
PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE RELAY DEVICES
CONFIRMATION OF CNSRB APPROVAL

Reference: Letter, G02-89-136, GD Bouchey to NRC,
same subject, dated August 13, 1989

In the reference we stated that Supply System Corporate Nuclear Safety Review Board (CNSRB) review and approval of the subject Technical Specification change request would be confirmed by August 14, 1989.

This letter is to inform you that this CNSRB review and approval has been accomplished.

The reference stated that a 100 Ampere fuse would be used to replace MCC 8B-A. After additional Engineering review, the fuse size has been changed from 100 to 90 Ampere. This is to provide additional margin in the protection of the containment penetration. The 90 Ampere fuse will still provide the required coordination with the downstream MCC feeder fuses and has been verified to be sufficiently large to carry all the required loads on the MCC.

Very truly yours,



G. D. Bouchey, Director
Licensing & Assurance

AGH/bk

cc: J. B. Martin - NRC RV
N. S. Reynolds - BCP&R
R. B. Samworth - NRC
D. L. Williams - BPA/399
C. Eschels - EFSEC
NRC Site Inspector - 901A

8908180334 890814
PDR ADOCK 05000397
P PDC

STATE OF WASHINGTON)
COUNTY OF BENTON)

Subject: REQUEST FOR AMENDMENT TO
TECHNICAL SPECIFICATION TABLE
3.8.4.2-1 PRIMARY CONTAINMENT
PENETRATION CONDUCTOR OVERCURRENT
PROTECTIVE RELAY DEVICES
CONFIRMATION OF CNSRB APPROVAL

I, G. D. Bouchey, being duly sworn, subscribe to and say that I am the Director, Licensing & Assurance, for the WASHINGTON PUBLIC POWER SUPPLY SYSTEM, the applicant herein; that I have full authority to execute this oath; that I have reviewed the foregoing; and that to the best of my knowledge, information, and belief the statements made in it are true.

DATE August 14, 1989


G. D. Bouchey
G. D. Bouchey, Director
Licensing & Assurance

On this day personally appeared before me G. D. Bouchey, to me known to be the individual who executed the foregoing instrument, and acknowledged that he signed the same as his free act and deed for the uses and purposes herein mentioned.

GIVEN under my hand and seal this 14th day of August 1989.

Reese A. Robinson
Notary Public in and for the
STATE OF WASHINGTON

Residing at Richland, WA
My commission expires 7/14/91



100-100000-100000

