



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

DOCKET NO. 50-397

NUCLEAR PROJECT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 72  
License No. NPF-21

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
  - A. The application for amendment filed by the Washington Public Power Supply System (the licensee), dated August 13, 1989, and supplemental letter dated August 14, 1989, comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8908280159 890816  
PDR ADOCK 05000397  
P PNU




2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. NPF-21 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 72, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
George W. Knighton, Director  
Project Directorate V  
Division of Reactor Projects - III,  
IV, V and Special Projects

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: August 16, 1989



ENCLOSURE TO LICENSE AMENDMENT NO. 72

FACILITY OPERATING LICENSE NO. NPF-21

DOCKET NO. 50-397

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains a vertical line indicating the areas of change. Also to be replaced is the following overleaf page.

AMENDMENT PAGE

3/4 8-23

OVERLEAF PAGE

3/4 8-24



TABLE 3.8.4.2-1

PRIMARY CONTAINMENT PENETRATION CONDUCTOR  
OVERCURRENT PROTECTIVE DEVICES

<u>EQUIPMENT</u>	<u>PRIMARY PROTECTION</u>	<u>BACKUP PROTECTION</u>
<u>a. 6900V Circuit Breakers</u>		
RRC-P-1A	E-CB-RRA (Relay)	E-CB-S5 (Relay) E-CB-N2/5 (Relay)
RRC-P-1B	E-CB-RRB (Relay)	E-CB-S6 (Relay) E-CB-N2/6 (Relay)
<u>b. 480VAC Fused Disconnects</u>		
MS-V-16	MC-8B-A Fused	MC-8B Fused
RWCU-V-1	MC-8B-A Fused	MC-8B Fused
RHR-V-9	MC-8B-A Fused	MC-8B Fused
RCIC-V-63	MC-8B-A Fused	MC-8B Fused
RCC-V-40	MC-8B-A Fused	MC-8B Fused
RHR-V-123B	MC-8B-A Fused	MC-8B Fused
RCIC-V-76	MC-8B-A Fused	MC-8B Fused
RHR-V-123A	MC-8B-A Fused	MC-8B Fused

