## ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

DOC.DATE: 90/04/05 NOTARIZED: YES DOCKET # ACCESSION NBR:9004200247 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397 AUTHOR AFFILIATION AUTH. NAME Washington Public Power Supply System RECIPIENT AFFILIATION SORENSEN, G.C. RECIP. NAME Document Control Branch (Document Control Desk) SUBJECT: Application for amend to License NPF-21, reviseing Tech Spec figure 3.4.6.1. ENCL DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR SIZE: TITLE: OR Submittal: General Distribution NOTES: RECIPIENT COPIES RECIPIENT COPIES LTTR ENCL ID CODE/NAME LTTR ENCL ID CODE/NAME 1 1 PD5 LA 1 1 DD2, DD 5 5 SAMWORTH, R NRR/DET/ECMB 9H INTERNAL: ACRS 6 6 NRR/DOEA/OTSB11 NRR/DST 8E2 1 .1 1 1 NRR/DST/SELB 8D 1 1 NRR/DST/SICB 7E 1 1 NRR/DST/SRXB 8E 1 NUDOCS-ABSTRACT 1 0 OC/LFMB OGC/HDS2 REG-PILE RES/DSIR/EIB 1

NRC PDR

NOTE TO ALL "RIDS" RECIPIENTS:

EXTERNAL: LPDR

NSIC

PLEASE HELP US TO REDUCE WASTEI CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 27 ENCL 25

1

A Leit

R

D

D

S

R

## WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

April 5, 1990 G02-90-071

4

Docket No. 50-397

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, D.C. 20555

Gentlemen:

Subject:

NUCLEAR PLANT NO. 2, OPERATING LICENSE NPF-21 REQUEST FOR AMENDMENT TO TECHNICAL SPECIFICATION PRESSURE/TEMPERATURE LIMITS - SECTION 3.4.6.1, SUPPLEMENTAL INFORMATION

References: 1) Letter, GO2-89-201, GC Sorensen (SS) to NRC, same subject, dated October 27, 1989

2) Generic Letter 88-11, "NRC Position on Radiation Embrittlement of Reactor Vessel Materials and its Impact on Plant Operations", dated July 12, 1988

Reference 1 submitted the subject technical specification in response to the reference 2 generic letter. In subsequent conversations between Messrs R. Samworth and J. Tsao (NRC) and P. Powell, D. Bosi and T. Erwin (Supply System) it was recognized that the reactor pressure vessel temperature limit curves provided by Reference 1 as Figure 3.4.6.1 did not encompass the conservatisms contemplated by the Staff. Accordingly, the attached pressure/temperature limits curve is submitted as replacement to that provided in Reference 1.

The Supply System's initial submittal of the reactor pressure vessel temperature limit curves was completed in strict compliance with Appendix G of the ASME Code, NUREG 0800, Regulatory Guide 1.99 Rev. 2, and WRC Bulletin 175. The attached revised curves incorporate further conservatism involving through-wall temperature corrections as suggested by the Staff. The normal startup/shutdown fluid temperatures conservatively follow the steam saturation line controlled by the turbine bypass valves above 130 psig. In sum, a high level of conservatism is imposed at WNP-2 when both operational guidelines and the technical specification limits, as specified by the revised pressure/temperature limit curves, are considered.

9004200247 900405 PDR ADOCK 05000397 PDR ADOCK 05000397

A001

Page Two
REQUEST FOR AMEND TO TS PRESSURE/TEMPERATURE
LIMITS - SECTION 3.4.6.1, SUPPLEMENTAL INFORMATION

The Supply System has reviewed the No Significant Hazards and Environmental Assessment Exclusion discussions provided in reference 1 and concluded that these discussions bound the conservative changes represented in the attached curve.

This supplemental information has been reviewed and approved by the WNP-2 Plant Operations Committee (POC) and the Supply System Corporate Nuclear Safety Review Board (CNSRB). In accordance with 10CFR 50.91, the State of Washington has been provided a copy of this letter.

As stated in Reference 1 the generic letter requires implementation within two plant outages of the effective date of Revision 2 to Regulatory Guide 1.99 (May 1988). Accordingly, for WNP-2 this change should be effective no later than commencement of initial heat up at the end of the WNP-2 1990 refueling outage tentatively scheduled for May 31, 1990.

Very truly yours,

alan Hose ben

G. C. Sorensen, Manager Regulatory Programs

PLP/bk Attachments

cc:

JB Martin - NRC RV
NS Reynolds - BCP&R
RB Samworth - NRC
DL Williams - BPA/399
NRC Site Inspector - 901A

STATE OF WASHINGTON
COUNTY OF BENTON

Subject: Request for Amend. to TS Pressure/ Temperature Limits - Sec. 3.4.6.1

I, A. G. HOSLER, being duly sworn, subscribe to and say that I am the Manager, WNP-2 Licensing, for the WASHINGTON PUBLIC POWER SUPPLY SYSTEM, the applicant herein; that I have full authority to execute this oath; that I have reviewed the foregoing; and that to the best of my knowledge, information and belief the statements made in it are true.

DATE April 5, 1990

A. G. HOSLER, Manager WNP-2 Licensing

On this day personally appeared before me A. G. HOSLER to me known to be the individual who executed the foregoing instrument and acknowledged that he signed the same as his free act and deed for the uses and purposes herein mentioned.

GIVEN under my hand and seal this 5th day of 000, 1990.

Notary Public in and for the

State of Washington

Residing at Konnowick Wa