

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9102250013 DOC. DATE: 91/01/31 NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 HUTCHISON, L.B. Washington Public Power Supply System
 BAKER, J.W. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Jan 1991 for Washington Nuclear
 Plant Unit 2.W/910205 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	PD5	LA	3	3		PD5	PD	1	1
	ENG,	P.L.	1	1					
INTERNAL:	ACRS		10	10		AEOD/DOA		1	1
	AEOD/DSP/TPAB		1	1		IRM TECH ADV		2	2
	NRR/DLPO/LPER10		1	1		NRR/DOEA/OEAB		1	1
	REG FILE 01		1	1		RGN5		1	1
EXTERNAL:	EG&G BRYCE, J.H		1	1		NRC PDR		1	1
	NSIC		1	1					

*Cont NO
118478*

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 26 ENCL 26

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

GO2-9-021

Docket No. 50-397

February 5, 1991

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Subject: **NUCLEAR PLANT NO. 2**
 MONTHLY OPERATING REPORT
 JANUARY 1991

Transmitted herewith is the Monthly Operating Report for January 1991 as required by our Technical Specifications 6.9.1.6.

Very truly yours,

J.W. Baker

J.W. Baker
WNP-2 Plant Manager
(MD 927M)

JWB:LBH:bap

Enclosure

cc: Mr. J.B. Martin, NRC Region V
 Mr. C. Sorensen, NRC Resident Inspector (901A)
 Ms. Dottie Sherman, ANI, Farmington CT
 Mr. J.T. Wheelock, INPO
 Mr. W.H. Lovelace, NRC, Washington D.C.

9102250013 910131
PDR ADOCK 05000397
R PDR



*Cont No
118478
IE24*

OPERATING DATA REPORT
WNP-2

01-Feb-91

1. DOCKET: 50-397
2. REPORTING PERIOD: Jan-91 OUTAGE + ON-LINE HOURS 744
3. UTILITY CONTACT: LEONARD HUTCHISON (509) 377-2486
4. LICENSED THERMAL POWER (MWt): 3323
5. NAMEPLATE RATING (GROSS MWe): 1200.9
6. DESIGN ELECTRICAL RATING (NET MWe): 1100
7. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): 1140
8. MAXIMUM DEPENDABLE CAPACITY (NET MWe): 1095

9. IF CHANGES OCCUR ABOVE SINCE LAST REPORT, GIVE REASONS:
None.

10. POWER TO WHICH RESTRICTED, IF ANY (NET MWe): _____

11. REASONS FOR RESTRICTIONS, IF ANY: None.

	MONTH	YEAR	CUMULATIVE
12. REPORT PERIOD HOURS	744	744	53768.2
13. HOURS REACTOR CRITICAL	744.0	744.0	39728.2
14. RX RESERVE SHTDWN HRS	0.0	0.0	340.4
15. HRS GENERATOR ON LINE	744.0	744.0	38346.8
16. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	381.7
17. GROSS THERMAL ENERGY (MWH)	2450660	2450660	108799685
18. GROSS ELECTRICAL ENERGY (MWH)	825840	825840	36227480
19. NET ELECTRICAL ENERGY (MWH)	797521	797521	34825691
20. UNIT SERVICE FACTOR	100.0%	100.0%	71.3%
21. UNIT AVAILABILITY FACTOR	100.0%	100.0%	72.0%
22. UNIT CAPACITY FACTOR (MDC NET)	97.9%	97.9%	59.2%
23. UNIT CAPACITY FACTOR (DER NET)	97.4%	97.4%	58.9%
24. UNIT FORCED OUTAGE RATE	0.0%	0.0%	8.1%
25. FORCED OUTAGE HOURS	0.0	0.0	3401.2

26. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE, DURATION):
Refueling outage (R6) starting 4/13/91 for 51 days.

27. IF CURRENTLY SHUTDOWN ESTIMATED STARTUP DATE: _____

DOCKET NO.: 50-397
 UNIT NAME: WNP-2
 DATE: FEBRUARY 1, 1991
 COMPLETED BY: LB HUTCHISON
 TELEPHONE: (509) 377-2486

UNIT SHUTDOWNS / REDUCTIONS

REPORT PERIOD: JANUARY 1991

NO. DATE TYPE HOURS REASON METHOD LER NO SYSTEM COMPONENT CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE

None.

SUMMARY: WNP-2 operated routinely during January with no outages or significant power reductions.

<u>TYPE</u>	<u>REASON</u>	<u>METHOD</u>	<u>SYSTEM & COMPONENT</u>
F-FORCED S-SCHED	A-EQUIP FAILURE B-MAINT OR TEST C-REFUELING D-REGULATORY RESTRICTION E-OPERATOR TRAINING & LICENSE EXAM	F-ADMIN G-OPER ERROR H-OTHER	EXHIBIT F & H INSTRUCTIONS FOR PREPARATION OF DATA ENTRY SHEET LICENSEE EVENT REPORT (LER) FILE (NUREG -0161)
		1-MANUAL 2-MANUAL SCRAM 3-AUTO SCRAM 4-CONTINUED 5-REDUCED LOAD 9-OTHER	

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.: 50-397
UNIT: WNP-2
DATE: JANUARY 1991
COMPLETED BY: LB HUTCHISON
TELEPHONE: (509) 377-2486

MONTH: JANUARY 1991

DAY AVERAGE DAILY POWER LEVEL
(MWe-NET)

DAY AVERAGE DAILY POWER LEVEL
(MWe-NET)

1.	1074
2.	1074
3.	1076
4.	1078
5.	1082
6.	1082
7.	1079
8.	1081
9.	1079
10.	1079
11.	987
12.	968
13.	1061
14.	1066
15.	1075
16.	1079

17.	1080
18.	1069
19.	1088
20.	1088
21.	1084
22.	1086
23.	1084
24.	1079
25.	1083
26.	1079
27.	1077
28.	1041
29.	1075
30.	1078
31.	1076

INSTRUCTIONS

ON THIS FORM, LIST THE AVERAGE DAILY UNIT POWER LEVEL IN MWe-NET FOR EACH DAY IN THE REPORTING MONTH. COMPUTE TO THE NEAREST WHOLE MEGAWATT.

THESE FIGURES WILL BE USED TO PLOT A GRAPH FOR EACH REPORTING MONTH. NOTE THAT WHEN MAXIMUM DEPENDABLE CAPACITY IS USED FOR THE NET ELECTRICAL RATING OF THE UNIT, THERE MAY BE OCCASIONS WHEN THE DAILY AVERAGE POWER LEVEL EXCEEDS THE 100% LINE (OR THE RESTRICTED POWER LEVEL LINE). IN SUCH CASES, THE AVERAGE DAILY UNIT POWER OUTPUT SHEET SHOULD BE FOOTNOTED TO EXPLAIN THE APPARENT ANOMALY.

November 19, 1990

DISTRIBUTION:
 Docket File
 PDV r/f/
 DFoster

DOCKET NO(S) 50-397

To attached addresses

SUBJECT: WPPSS NUCLEAR PROJECT UNIT 205 - Environmental Reports

The following documents concerning our review of the subject facility are transmitted for your information.

✓	DESCRIPTION OF DOCUMENT	DATED
	Notice of Receipt of Application	
	Draft/Final Environmental Statement	
	Notice of Availability of Draft/Final Environmental Statement	
	Safety Evaluation Report, or Supplement No. _____	
	Environmental Assessment and Finding of No Significant Impact	
	Notice of Issuance of Environmental Assessment	
	Notice of Consideration of Issuance of Facility Operating License or Amendment to Facility Operating License	
	Biweekly Notice; Applications and Amendments to Operating Licenses Involving No Significant Hazards Conditions See Page(s) _____	
	Exemption	
	Construction Permit No. CPPR- _____, Amendment No. _____	
	Facility Operating License No. _____, Amendment No. _____	
	Order	
XX	Monthly Operating Report for <u>Aug & Sept & Revised Aug 1990</u> transmitted by Letter	8/31/90 10/8/90
	Annual/Semi-Annual Report: _____ transmitted by Letter	
XX	Other <u>Forwards NPDES Waste Discharge Permit...by State of WA 900910</u>	10/4/90

Office of Nuclear Reactor Regulation

Doris J. Foster, Licensing Asst.
 Project Directorate V
 Division of Reactor Projects III/IV/V

*ACRS-1
 List*

Enclosures:
 As Stated

cc:

OFFICE▶	LA:PDV <i>DFoster</i>					
SURNAME▶	Foster:df					
DATE▶	11/19/90					

ADDRESSES:

**Chief
Division Ecological Services
Bureau of Sport Fisheries and Wildlife
U.S. Department of the Interior
Washington, D.C. 20240**

**Dr. William Cunningham
FDA Research Chemist
National Institute of Standards & Technology
Reactor Building 235, Room B108
Gaithersburg, Maryland 20899**

**U.S. Environmental Protection Agency
Region X Office
Attention: Regional Radiation Representative
1200 6th Avenue
Seattle, Washington 98101**