

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9105240173 DOC. DATE: 91/05/15 NOTARIZED: NO DOCKET # 05000397
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe

AUTH. NAME AUTHOR AFFILIATION
 SORENSEN, G.C. Washington Public Power Supply System
 RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Provides response to questions asked by licensee in 910510 ltr re rept on flaw in reactor recirculation piping. Drawing ref refers to drawings included w/Ref 2.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 27
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES	LTTR	ENCL	RECIPIENT ID CODE/NAME	COPIES	LTTR	ENCL
	PD5 LA	1		1	PD5 PD	1		1
	ENG, P.L.	2		2				
INTERNAL:	ACRS	6		6	NRR/DET/ECMB 9H	1		1
	NRR/DET/ESGB	1		1	NRR/DOEA/OTSB11	1		1
	NRR/DST 8E2	1		1	NRR/DST/SELB 8D	1		1
	NRR/DST/SICB8H3	1		1	NRR/DST/SRXB 8E	1		1
	NUDOCS-ABSTRACT	1		1	OC/LFMB	1		0
	OGC/HDS1	1		0	REG-FISE 01	1		1
	RES/DSIR/EIB	1		1				
EXTERNAL:	NRC PDR	1		1	NSIC	1		1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 22

MJA

R
I
D
S
/
A
D
D
S
/
A
D
D
S

1950

U.S. DEPARTMENT OF COMMERCE
BUREAU OF ECONOMIC ANALYSIS
WASHINGTON, D. C.



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

May 15, 1991
G02-91-098

Docket No. 50-397

U. S Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Subject: NUCLEAR PLANT NO. 2, OPERATING LICENSE NPF-21
REPORT ON FLAW IN REACTOR RECIRCULATION PIPING,
ADDITIONAL INFORMATION (TAC NO. 80358)

References: 1) Letter, G02-91-096, G.C. Sorensen (SS) to NRC,
same subject, dated May 10, 1991

2) Letter, G02-89-123, G. C. Sorensen (SS) to NRC,
"Supply System's Response to Generic letter 88-01
Request for Additional Information", dated July 20, 1989

The following is provided in response to questions asked by the Staff of the Reference 1 submittal.

1. **Water Chemistry History** - The history of the WNP-2 water chemistry is provided in Attachment 2.
2. **UT Characterization of 20RRC(6)-8 Indication** - The characterization of this indication is provided in Attachment 3.
3. **Input to Flaw Evaluation** - This is provided in Attachment 4.
4. **Post-IHSI Examination** - IHSI was performed on this weld but it was not post IHSI UT examined because the IHSI was done on this weld prior to service.
5. **Location of 20RRC(6)-8** - The location of this weld is shown on Figure RRC-105 of Reference 2.

9105240173 910515
PDR ADOCK 05000397
P PDR

A001
4/1

11/14

11/14

11/14



REPORT ON FLAW IN REACTOR RECIRCULATION PIPING
ADDITIONAL INFORMATION

6. WNP-2 R6 Flaw Evaluation Summary - The summary provided in Reference 1 has been revised to define the code allowable crack depth of 0.62 inches based upon the welding process used for this weld. The revised summary is included as Attachment 1. Page 3 of this attachment discusses the need for the revision in more detail.
7. Sample Expansion - Three circumferential welds were scheduled to be examined during R6. As a result of the indication found on 20RRC(6)-8 the examination was expanded by an additional three circumferential welds of the same category (Category B).

<u>Weld</u>	<u>Drawing</u>
20RHR(2)-1	RHR-104
20RHR(2)-2	RHR-104
12RRC(7)B-1	RRC-107

The drawing reference refers to the drawings included with Reference 2.

Very truly yours,



G. C. Sorensen, Manager
Regulatory Programs

AGH/bk
Attachments

cc: JB Martin - NRC RV
NS Reynolds - Winston & Strawn
PL Eng - NRC
DL Williams - BPA/399
NRC Site Inspector - 901A

Attachment 1

WNP-2 R6 FLAW EVALUATION SUMMARY (Rev. 1)

INTRODUCTION

A fracture mechanics evaluation was performed to evaluate a linear indication found during in-service inspection of ISI weld number 20 RRC (6)-8. This particular weld consists of a SA-358 GR. 304 stainless steel pipe welded to a valve manufactured from SA-351 CF8M stainless steel. The indication was found on the upstream side of valve RHR-V-113. The defect is located in the 304 base metal at the top of the pipe centered at the 0° location (twelve o'clock position). The defect was sized at 0.15 inches deep and 4.5 inches long. The size of the defect exceeds the 1986 ASME Code Section XI Table IWB 3514-2 allowable and thus requires evaluation per paragraph IWB 3640 of the Code. The following discussion provides a comprehensive summary of the fracture mechanics model, applied loads (stresses), and Code evaluations that were performed.

METHODOLOGY

Stress (Loads) Evaluation

The stress state at the location of the flaw is required to determine the driving force for crack propagation. Stresses for the applicable loading conditions were extracted from the ASME Class 1 Stress Report for the subject RHR piping (Calculation No. 8.14.107) to complete the RHR piping flaw evaluation.

The following load combinations were evaluated to determine if the crack would grow under the imposed loads. Two of the evaluations (fatigue and intergranular stress corrosion cracking (IGSCC)) encompass the requirements of IWB-3640. The third evaluation was done to evaluate the flaw growth under the relatively short duration applied load caused by the worst thermal transient experienced by the system, i.e. plant shutdown.

The imposed load for fatigue evaluation consists of superimposing the pressure, deadweight bending, normal operating thermal bending stress and the weld residual stress to complete the evaluation of the minimum fracture stress intensity. Pressure, deadweight bending, and thermal bending stresses are conservatively combined with the worst case faulted dynamic bending stresses (without regard to the direction of the applied stress) to complete the evaluation of the maximum fracture stress intensity range. This methodology conservatively includes faulted dynamic stresses in the normal/upset evaluation and conservatively adds additional thermal stresses into the faulted evaluation. The number of dynamic loading cycles is based on the design basis main steam safety relief valve actuations which yield approximately 300 stress cycles per year. The peak

Attachment 1

WNP-2 R6 FLAW EVALUATION SUMMARY (Rev. 1)

dynamic loading includes 300 cycles of the Safe Shutdown Earthquake event even though the plant design basis is 10 stress cycles.

The IGSCC evaluation was completed using the steady state deadweight pressure and bending stress and the normal plant operation thermal stress.

The thermal transient load evaluation superimposed the pressure and deadweight bending stresses on the thermal bending and thermal gradient stresses. The dynamic stress was not included due to the low probability of occurrence during the short duration of the peak thermal gradient stress.

In each loading condition the above stress states were then superimposed on the weld residual stress distribution to complete the respective flaw evaluations. The resulting flaw sizes were then evaluated against the end of evaluation period depth-to-thickness ratios from Tables IWB-3641-5 and IWB-3641-6.

Flaw Evaluation

The indication was evaluated using the NASCRAC computer code developed by Failure Analysis Associates. This code uses stress field influence functions as the basis for flaw propagation. The NASCRAC model selected is a shell element containing an elliptically shaped circumferential flaw. The model is identified as 703 in the NASCRAC manual. This particular model includes three crack growth degrees of freedom encompassing the respective circumferential and crack depth coordinates. The evaluation was performed using conservative linear elastic fracture mechanics principles.

The modeling applies the requirements identified in NRC Generic Letter 88-01. The flaw was evaluated as an intergranular stress corrosion crack using the crack growth rate equation provided in the generic letter. The weld residual stress distribution provided in the letter was also used even though the weld in question had induction heat stress improvement (IHSI) performed on it in 1983. The weld residual stresses are developed from room temperature yield for 304 material (30 ksi) as the normalization stress outlined in the generic letter. The flaw aspect ratio was reviewed and compared to the requirements of NUREG-0313, Rev. 2. The aspect ratio was determined to be 30:1 which exceeds the NRC requirements for maintaining the same aspect ratio during crack growth. Therefore the final crack growth aspect ratio was determined by the NASCRAC flaw model.

In performing the evaluation the flaw model was run to evaluate fatigue damage for a one year operating cycle. The crack was evaluated using both a da/dn curve

Attachment 1

WNP-2 R6 FLAW EVALUATION SUMMARY (Rev. 1)

for BWR water environments and an air environment for austenitic stainless steel. The da/dn equation used for BWR environments was provided in the EPRI report NP-4690-SR "Evaluation of Flaws in Austenitic Piping" dated July 1986, page 3-2, Equation 3-1. In this EPRI equation the E-factor selected for a BWR environment was taken as ten. The curve used for the air environment is that provided in ASME Code Section XI, Appendix C, Figure C-3210-1 for an R-ratio of 0.79.

Upon completion of the fatigue evaluation the NASCRAC flaw model was executed to complete the IGSCC evaluation. The crack dimensions for the evaluation period as determined by fatigue would normally be used as input for the initial crack dimensions for the IGSCC model. However the growth due to the 300 fatigue cycles did not yield a significant change in the initial crack size. Therefore the original flaw size was used as the input for the IGSCC model. The equation used for the IGSCC crack growth rate, as mentioned earlier, was that provided in the generic letter.

The above described flaw evaluation and computer outputs are documented in Supply System calculation ME-02-91-30.


CONCLUSION

Based on the flaw evaluation results it is determined that WNP-2 may operate for the single cycle evaluation period before reevaluation of the linear indication is again required. The evaluation demonstrates that under the worst imposed loading conditions the flaw meets the acceptance criteria of ASME Section XI Tables IWB-3641-5 and 3641-6. The Fatigue evaluation for the flaw propagation shows that growth due to the piping system mechanical loads is insignificant. The fracture mechanism which can propagate the flaw is intergranular stress corrosion cracking. If the IGSCC phenomena is active the crack will increase in depth to 0.29 inches in the next year which is less than the ASME Code allowable of 0.62 inches per Table IWB-3641-5 and 6.

Revision 1: The weld root and hot passes were performed using gas tungsten-arc welding (GTAW) for an approximate thickness of 1/8 to 3/16 inch. The remainder of the weld was performed utilizing shielded metal arc welding (SMAW). Therefore the acceptance criteria of tables IWB-3641-5 and IWB-3641-6 is used in lieu of IWB-3641-1 and IWB-3641-2.

ATTACHMENT 2
WATER CHEMISTRY HISTORY

GENERAL ELECTRIC COMPANY



REACTOR WATER CHLORIDE AVG. (PPB)

84. 85. 86. 87. 88. 89. 90. 91.

YEAR

HANFORD 2

ALL CYCLES

06/25/90 14.61

FRAME 18

WEEKLY AVERAGE OF DAILY READINGS




11

11

REACTOR CHLORIDE WNP-2

PPB



CL
B
-----*

1990

1991

DAILY READINGS



Small cluster of dots in the top right corner.

Small mark on the left side.


Faint vertical mark in the center.

Faint horizontal mark in the middle.

Faint vertical mark in the lower center.

Faint horizontal mark at the bottom.

GENERAL ELECTRIC COMPANY



REACTOR WATER CHLORIDE MAX. (PPB)

84. 85. 86. 87. 88. 89. 90. 91.

YEAR

HANFORD 2

ALL CYCLES

06/25/90 14.61

FRAME 24

WEEKLY MAXIMUM OF DAILY READINGS



Small cluster of faint marks or characters in the top right corner.

Small, faint mark or character.

Small, faint mark or character.

Small, faint mark or character.

Small, faint mark or character.

Small, faint mark or character.

Vertical column of small, faint marks or characters on the right side.

Small, faint mark or character.

Small, faint mark or character.

Small, faint mark or character.


Small, faint mark or character.

Small, faint mark or character.

Small, faint mark or character.

Small, faint mark or character at the bottom right.


GENERAL ELECTRIC COMPANY



APR 19 1964

REACTOR pH
WNP-2

pH



PH
8
-----*

1990

1991



• • • • •
• • • • •
• • • • •

• • • • •
• • • • •

•
•
•

• • • • •
• • • • •

•


•

• • • • •
• • • • •
• • • • •

•

•

GENERAL ELECTRIC COMPANY



REACTOR WATER CONDUCTIVITY AVG. (UMHO/CM)

84.

85.

86.

87.

88.

89.

90.

91.

YEAR

HANFORD 2

ALL CYCLES

06/25/90 14.61

FRAME 6

WEEKLY AVERAGE OF DAILY READINGS



Small cluster of dots in the top right corner.

Small mark or dot.


Small mark or dot.

Vertical line of small marks or dots.

Vertical line of small marks or dots.

REACTOR CONDUCTIVITY WNP-2

UMHOS/CM





2

2

11-11-11

7

1

1

1

1

1


1

1

1

1

GENERAL ELECTRIC COMPANY



REACTOR WATER CONDUCTIVITY MAX. (UMHO/CM)

84. 85. 86. 87. 88. 89. 90. 91.

YEAR

HANFORD 2

ALL CYCLES

06/25/90 14.61

FRAME 12

WEEKLY MAXIMUM OF DAILY READINGS


ATTACHMENT 3

UT CHARACTERIZATION OF 20RRC(6)-8

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

WNP-2 ISI Evaluation Sheet

Evaluation Sheet No.: 1-065		Examination Method Volumetric <input checked="" type="checkbox"/> Surface <input type="checkbox"/> Visual <input type="checkbox"/>		Examination Report No.: IRRU-155 IRRU-156	
Project: WNP-2		System: RRC		ISI Drawing No.: RRC-105	
Originator: DON WELCH		Examination Procedure No.: DCI 6-3RO/6-25 R.O.		Revision No.: 0/0	
Weld/Part Description: PIPE TO VALVE			Weld/Part No.: 20 RRC (6) - 8		
Description of Reportable Indication: 60° & 70° RL DATA length of 2.5" however SIZING DATA of 30/70/70 RESULT is 4.5". THRU WALL DATA USING SIZING TECHNIQUES REVEALS MAXIMUM of 15% THRU WALL (.015") (a/l = .03 a/+% ISI MAX = 10.66)			Acceptance Criteria: IWB 3514-3 AND IGSCC GO/NOGO		
			Evaluation of Surface or Visual Indication Acceptable <input type="checkbox"/> Rejectable, Submit to RTO <input checked="" type="checkbox"/>		
Evaluation of Volumetric Indication (check all applicable boxes): Acceptable: <input type="checkbox"/> Geometry: <input type="checkbox"/> Flaw Size <80% <input type="checkbox"/> Flaw Size ≥80% of acceptance <input checked="" type="checkbox"/> See justification below See justification below of acceptance level level, submit to RTO					
Justification:					
Level III Review:		Date:		RTO Concurrence:	
Reexamination No.:		Results:		Evaluation Sheet No.:	





GE Nuclear Energy

INDICATION PLOT SHEET

SITE: WNP-2 UNIT: 2


REPORT NO.
IRRU-155
IRRU-156

PROJECT NO: WF-751

SYSTEM: RRC

COMPONENT ID NO: ZORRC(6)-8

CONFIGURATION: PIPE VALVE





Wesley C. Money III 5391
 Drawn By Level Date

[Signature] 5491
 Reviewed By Level Date

Reviewed By Title Date

Page Of
 FORM 137 1-13-90

ATTACHMENT TO EVAL SKT 1-065



ULTRASONIC CALIBRATION SHEET

PROJECT: <u>WNP-2</u>		SYSTEM: <u>RRC</u>		SHEET NO.: <u>314</u>	
EXAMINER: <u>Wes Money (h) CE</u>		LEVEL: <u>III</u>		DATE: <u>5-3-91</u>	
EXAMINER: <u>Dennis L. Hebert GE</u>		LEVEL: <u>II</u>		THERMOMETER S/N: <u>43169-21 4239-21</u>	
				INSTRUCTION NO.: <u>OCT 16-3</u>	
				REVISION: <u>0</u>	
CALIBRATION STANDARD		CALIBRATION STANDARD SIMULATOR		TRANSducer	
SERIAL NUMBER <u>UT 9</u>	S/N _____	TEMP _____ °F	S/N <u>RTD 88-319</u>	WAVE MODE <u>RL</u>	CABLE TYPE <u>(2) RG 174</u>
THICKNESS <u>1.031"</u>	AMP _____	SWEEP _____ IN.	SIZE <u>2(6x18)mm</u>	FREQ <u>2</u> MHz	LENGTH <u>8'</u>
TEMPERATURE <u>70</u> °F	GAIN IN db _____		ACTUAL ANGLE <u>60°</u>		COUPLANT <u>ULTRAGEL II</u>
CHART RECORDER TYPE: <u>N/A</u>		S/N: <u>N/A</u>	UT INSTRUMENT TYPE: <u>SONEC 136</u>		S/N: <u>1020382-21</u>

INSTRUMENT CALIBRATION

PREVIOUSLY PERFORMED ON CALIBRATION SHEET NUMBER N/A

SCREEN HEIGHT LINEARITY FOR CONTINUOUS GAIN CONTROL										SCREEN HEIGHT LINEARITY FOR 2db STEP GAIN CONTROL										AMPLITUDE CONTROL LINEARITY				
HIGH	100	90	80	70	60	50	40	30	20	db	+2	0	-2	-4	-6	-8	-10	-12	-14	AMPLITUDE %	80	80	40	20
LOW	50	45	40	35	30	25	20	15	10	HIGH		80								db CHANGE	-8	-12	+8	+12
										LOW		40								READING %	32	16	90	96
																				LIMITS %				
																				32-48 16-24 64-96 64-96				

INITIAL CAL TIME: 1340 SYSTEM CALIBRATION FINAL CAL TIME: 1620

INSTRUMENT SETTINGS	REFLECTORS	AMPLITUDE %FSH	SWEEP READING IN INCHES	SCREEN DAC PRESENTATION	CAL CHECKS
COARSE RANGE - <u>1.50</u>	<u>1/8 NODE</u>	<u>80%</u>	<u>.96</u>	<p style="margin: 0;">FULL SCREEN SWEEP <u>2 DEPTH</u> IN.</p>	<p style="margin: 0;">N/A</p>
COARSE DELAY - <u>.405</u>	<u>N/A 8 NODE</u>				
RANGE CALIB - <u>1.50</u>	<u>N/A 8 NODE</u>				
DELAY CALIB - <u>.405</u>	<u>N/A 8 NODE</u>				
FREQUENCY - <u>2.25</u>	<u>N/A 8 NODE</u>				
GAIN IN db - <u>67.6dB</u>	<u>N/A 8 NODE</u>				
DAMPING - <u>500 n</u>	<u>N/A 8 NODE</u>				
REJECT - <u>OFF</u>	BKR <u>N/A</u> db				
FILTER - <u>FTL 2</u>	SEARCH UNIT ORIENTATION	<input checked="" type="checkbox"/> AXIAL <input type="checkbox"/> CIRCUMFERENTIAL			
WELDS OR PARTS EXAMINED					
<u>20 RRC (6) - 8</u>					
<u>N/A</u>					
<u>N/A</u>					
<u>N/A</u>					
<u>N/A</u>					

REVIEWED BY LEVEL III: [Signature] DATE: 5-4-91 REVIEWED BY: _____ DATE: _____



11

12

13

14

15

16

17

18

19

20

21

22

23

24

ULTRASONIC EXAMINATION DATA SHEET

REPORT NO.: 100 IRRU-155

PROJECT: <u>WNP-2</u>										SYSTEM: <u>RRC</u>										ISI DRAWING NO.: <u>RRC-105 REV.3</u>							
WELD/PART DESCRIPTION: <u>20" PIPE TO VALVE CIR WELD</u>																				WELD/PART NO.: <u>20 RRC (6)-8</u>							
MATERIAL TYPE: <u>SS</u>										CAL STANDARD NO.: <u>UT 9</u>										THICKNESS: <u>1.031</u>							
NO. OF SCAN DIRECTIONS: <u>(3) A, C, D</u>										LIMITED EXAM: <input type="checkbox"/> NO <input checked="" type="checkbox"/> YES										ACCEPTANCE CRITERIA: <u>OCI 6.3 REVO</u>							
INSTRUCTION NO.: <u>OCI 6-3</u>										REVISION: <u>0</u>					ANGLE: <u>60° RL</u>					ANGLE: /			ANGLE: /				
EXAMINER: <u>Wes Money (H) GE</u>										LEVEL: <u>III</u>					DATE: <u>5.3.91</u>					DATE: /			DATE: /				
EXAMINER: <u>Dennis L. Hebert (H) GE</u>										LEVEL: <u>II</u>					TIME START: <u>1505</u>					TIME START: <u>N/A</u>			TIME START: <u>N/A</u>				
THICKNESS MEASUREMENTS										TIME STOP: <u>1555</u>					TIME STOP: /					TIME STOP: /							
WELD HEIGHT <u>.10"</u>										WELD WIDTH <u>1.2"</u>										PART TEMP: <u>89.6 °F</u>							
SURFACE ONE										SURFACE TWO										PART TEMP: /							
CAL SHEET NO.: <u>314</u>																											
CHART NO.: <u>N/A</u>																											
NOTES: * NO EXAM ONST DUE TO VALVE CONFIGURATION																											
0°		90°		180°		270°		BM		COUNTER BORE		HAZ		WELD E		HAZ		COUNTER BORE		BM							
/		/		/		/		/		/		/		/		/		/		/							

INDICATION NUMBER	LOCATION INTERVAL A-B OR PART NO.	BEAM ANGLE β	SCAN SURFACE	BEAM DIRECTION	SOUND PATH	EXTENT	DAMPABLE	MAX AMP %DAC	100 TO 100			50 TO 50			20 TO 20			SEARCH UNIT POSITION AT MAXIMUM AMP		THROUGH WALL DATA				SP	SP COS β	EVALUATION	
									LENGTH			L	W	SP	D	SP	D	ACCEPT	REJECT								
#1	0-90	60°	Z	A	2.16"	0-2.5"	N/A	200	1"	2"	2.5"	2.0"	2.05"	N/A											✓		

REVIEWED BY LEVEL III: [Signature] DATE: 5-4-91 REVIEWED BY: DATE:



ULTRASONIC CALIBRATION SHEET

PROJECT: <u>WNP-2</u>	SYSTEM: <u>RRC</u>	SHEET NO.: <u>315</u>
EXAMINER: <u>Wes Money</u> <u>GE</u>	LEVEL: <u>III</u>	DATE: <u>5-3-91</u>
EXAMINER: <u>Donna L. Hebert</u> <u>GE</u>	LEVEL: <u>II</u>	THERMOMETER S/N: <u>42169-21 4239-21</u>
INSTRUCTION NO.: <u>OCI 6-3</u>		REVISION: <u>0</u>
CALIBRATION STANDARD	CALIBRATION STANDARD SIMULATOR	TRANSDUCER
SERIAL NUMBER <u>UT-9</u>	S/N _____ TEMP _____ °F	S/N <u>RTD 88-222</u> WAVE MODE <u>RL</u>
THICKNESS <u>1.031"</u>	AMP _____ SWEEP _____ IN.	LENGTH <u>8'</u>
TEMPERATURE <u>70</u> °F	GAIN IN db _____	SIZE <u>2(10x18)mm</u> FREQ <u>2</u> MHz
		CABLE TYPE <u>(2) RG174</u>
		COUPLANT <u>ULTRAGEL II</u>
		BATCH NO. <u>8764</u>
CHART RECORDER TYPE: <u>N/A</u>	S/N: <u>N/A</u>	UT INSTRUMENT TYPE: <u>SONIC 136</u>
		S/N: <u>020382-21</u>

INSTRUMENT CALIBRATION

PREVIOUSLY PERFORMED ON CALIBRATION SHEET NUMBER N/A

SCREEN HEIGHT LINEARITY FOR CONTINUOUS GAIN CONTROL										SCREEN HEIGHT LINEARITY FOR 2db STEP GAIN CONTROL							AMPLITUDE CONTROL LINEARITY							
HIGH	100	90	80	70	60	50	40	30	20	db	+2	0	-2	-4	-6	-8	-10	-12	-14	AMPLITUDE %	80	80	40	20
LOW	50	45	40	35	30	25	20	15	10	HIGH	80									db CHANGE	-8	-12	+6	+12
										LOW	40									READING %	32	16	90	96
																				LIMITS %	32-48	16-24	64-96	64-96

INITIAL CAL TIME: 1330 SYSTEM CALIBRATION FINAL CAL TIME: 1615

INSTRUMENT SETTINGS	REFLECTORS	AMPLITUDE %FSH	SWEEP READING IN INCHES	SCREEN DAC PRESENTATION					CAL CHECKS	
COARSE RANGE - <u>2.00</u>	<u>4/8 NODE</u>	<u>80%</u>	<u>.45</u>						<p>N/A</p>	
COARSE DELAY - <u>.592</u>	<u>N/A</u> /8 NODE									
RANGE CALIB - <u>2.00</u>	/8 NODE									
DELAY CALIB - <u>.592</u>	/8 NODE									
FREQUENCY - <u>2.25</u>	/8 NODE									
GAIN IN db - <u>73.8dB</u>	/8 NODE									
DAMPING - <u>500</u>	<u>N/A</u> /8 NODE									
REJECT - <u>OFF</u>	<u>BKR</u> <u>N/A</u> db									
FILTER - <u>FL 2</u>	SEARCH UNIT ORIENTATION	<input checked="" type="checkbox"/> AXIAL <input type="checkbox"/> CIRCUMFERENTIAL								
WELDS OR PARTS EXAMINED										
<u>20RRC(b)-8</u>										
<u>N/A</u>										

FULL SCREEN SWEEP 1.5 DEPTH IN.

REVIEWED BY LEVEL III: [Signature] DATE: 5-4-91 REVIEWED BY: _____ DATE: _____



Small cluster of illegible marks in the top right corner.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

Small illegible mark.

ULTRASONIC EXAMINATION DATA SHEET

REPORT NO.: IRRU-156


PROJECT: <u>WNP-2</u>				SYSTEM: <u>RRC</u>				ISI DRAWING NO.: <u>RRC-105 REV 3</u>																																											
WELD/PART DESCRIPTION: <u>20" PIPE TO VALVE CIR WELD</u>				WELD/PART NO.: <u>20RRC (6)-8</u>																																															
MATERIAL TYPE: <u>SS</u>				CAL STANDARD NO.: <u>UT-9</u>				THICKNESS: <u>1.031</u>																																											
NO. OF SCAN DIRECTIONS: <u>(3) A, C, D</u>				LIMITED EXAM: <input type="checkbox"/> NO <input checked="" type="checkbox"/> YES				ACCEPTANCE CRITERIA: <u>GCI 6-3 REV 0</u>																																											
INSTRUCTION NO.: <u>GCI 6-3</u>				REVISION: <u>0</u>		ANGLE: <u>70° RL</u>		ANGLE: <u>/</u>		ANGLE: <u>/</u>																																									
EXAMINER: <u>Wes Money</u> <u>GE</u>				LEVEL: <u>III</u>		DATE: <u>5-3-91</u>		DATE: <u>/</u>		DATE: <u>/</u>																																									
EXAMINER: <u>Donna L. Hebert</u> <u>GE</u>				LEVEL: <u>II</u>		TIME START: <u>1400</u>		TIME START: <u>N/A</u>		TIME START: <u>N/A</u>																																									
THICKNESS MEASUREMENTS				TIME STOP: <u>1500</u>		TIME STOP: <u>/</u>		TIME STOP: <u>/</u>																																											
WELD HEIGHT SURFACE ONE: <u>.10"</u>				WELD WIDTH: <u>1.2"</u>				PART TEMP: <u>89.6 °F</u>		PART TEMP: <u>°F</u>		PART TEMP: <u>°F</u>																																							
				SURFACE TWO: <u>→</u>				CAL SHEET NO.: <u>315</u>		CAL SHEET NO.: <u>/</u>		CAL SHEET NO.: <u>/</u>																																							
				CHART NO.: <u>N/A</u>				CHART NO.: <u>/</u>		CHART NO.: <u>/</u>																																									
				NOTES: * NO EXAM DNST DUE TO VALVE CONFIGURATION * SHEAR COMPONENT METAL PATH																																															
				<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:10%;"></td> <td style="width:10%;">BM</td> <td style="width:10%;">COUNTER BORE</td> <td style="width:10%;">HAZ</td> <td style="width:10%;">WELD E</td> <td style="width:10%;">HAZ</td> <td style="width:10%;">COUNTER BORE</td> <td style="width:10%;">BM</td> </tr> <tr> <td>0°</td> <td>1.03"</td> <td>N/A</td> <td>1.03"</td> <td>1.15"</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> </tr> <tr> <td>90°</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>180°</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>270°</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>					BM	COUNTER BORE	HAZ	WELD E	HAZ	COUNTER BORE	BM	0°	1.03"	N/A	1.03"	1.15"	N/A	N/A	N/A	90°								180°								270°											
	BM	COUNTER BORE	HAZ	WELD E	HAZ	COUNTER BORE	BM																																												
0°	1.03"	N/A	1.03"	1.15"	N/A	N/A	N/A																																												
90°																																																			
180°																																																			
270°																																																			
INDICATION NUMBER	LOCATION INTERVAL A-B OR PART NO.	BEAM ANGLE θ	SCAN SURFACE	BEAM DIRECTION	SOUND PATH	EXTENT	DAMPABLE	MAX AMP %DAC	100 TO 100	50 TO 50	20 TO 20	SEARCH UNIT POSITION AT MAXIMUM AMP		THROUGH WALL DATA				EVALUATION																																	
									LENGTH			L	W	MAXIMUM		MINIMUM		SP	SP COS θ	ACCEPT	REJECT																														
														SP	D	SP	D																																		
#1	0-90	70°	2	A	2.66	0-25	1/2	100%	1.0"	2.0"	2.5"	2.0"	2.7"	1/2							✓																														
#1	0-90	70°	2	A	1.32	0-25	N/A	100%	1.0"	2.0"	2.5"	2.0"	1.1"	1/2							N/A																														

REVIEWED BY LEVEL III:

DATE: 5-4-91

REVIEWED BY: _____

DATE: _____



WASHINGTON PUBLIC POWER SUPPLY SYSTEM POWER SUPPLY SYSTEM

ULTRASONIC FLAW SIZING CALIBRATION SHEET SHEET NO. 316

Project: WNP-2 Date: 5-4-91 System: RRC
 Examiner: P.L. TOMPKINS (PL) Level: JT Instruction No.: QCF 6-25 Rev D
 Examiner: n/a Level: n/a Cable Type: BNC / DUAL LEAD
 Couplant: ULTRAGELT Batch No.: 8872 Length: 6' to 16'

Transducer Model	S/N	Frequency	Size	Type/Wave Mode	Focal Distance	Nominal Angle
WS4-70-2	56526	2MHz	1/2" dia.	30-70-70 CREEP (SINGLE)	n/a	
RTD TRCZ Aust	81-436	2MHz	2(6x3mm)	DUAL CREEPING	10mm	
ADEPT 60	158/85	4MHz?	1/2" dia	DUAL LONG. SHEAR	n/a	
KBA shear	59067	3.5MHz	1/2" dia	SINGLE SHEAR	n/a	
MEGASONICS Shear	002	1.5MHz	1/2" dia	SINGLE SHEAR	n/a	

Instrument & Serial #	Screen Height Linearity								Amplitude Control Linearity						
	dB	+2	0	-2	-4	-6	-8	-10	-12	% FSH	dB	80 - 6	80 - 12	40 + 6	20 + 12
SONIC 136 C070383	High		80							% FSH					
	Low		40							% FSH					
	High		80							% FSH					
	Low		40							% FSH					
	High		80							% FSH					
	Low		40							% FSH					
	High		80							% FSH					
	Low		40							% FSH					


Calibration Standard S/N: UT-95 Calibration Standard S/N: n/a
 Thickness: 1" Temp: 77° Thickness: Temp °F:
 Initial Cal Time: 12:15 Final Cal Time: 13:25 Thermometer S/N:

Method	30-70-70 (1)	HIGH GAIN (2)	MOST (3)	SHEAR (4)	SHEAR (5)	(6) SHEAR
Transducer	WS4-70-2	RTD TRCZ AUST	ADEPT 60	45° 3.5MHz Shear	45° 3.5MHz Shear	45° 1.5MHz Shear
Cal Block	UT-95	UT-95	UT-95	UT-95	UT-95	UT-95
Screen Presentation	31-40% FSH 21-30% FSH 11-10% FSH cel 222 6.8 DIV 7.5 DIV	1 DIV 10% TWD 2 DIV = 20% TWD	1 DIV 10% TWD 4 DIV 20% TWD	SPOT 10% TWD ALL 40% TWD 4 DIV TP MAX	TIPS PART 60% TWD 2 DIV 8 DIV	EDGE CAL 1/2 V notch 60% 8 DIV UT-95 cal block
Instrument S/N	SONIC 136	SONIC 136	SONIC 136	SONIC 136	SONIC 136	SONIC 136
Single/Dual	SINGLE	DUAL	DUAL	SINGLE	SINGLE	SINGLE
Frequency	2.25 MHz	2.25 MHz	2.25 MHz	5 MHz	5 MHz	1 MHz
Gain	63	64	68	52	54	44
Comp. Sweep	n/a	n/a	n/a	n/a	n/a	n/a
Gain Fine	5.24	1.00	2.80	7.46	1.52	2.50
Delay	309	1738	1.11	1.33	1335	1335
Damping	500Ω 222ns	500Ω 222ns	500Ω 222ns	500Ω 100ns	500Ω 100ns	500Ω 100ns
Calibration Simulator	FILTER 2 127µs	FILTER 2 135µs	FILTER 2 127µs	FILTER 1 0.127µs	FILTER 1 127µs	FILTER 3 127µs
Cal Check						
Cal Check						

Welds or Parts Examined: 2DRRC (16) - 8
 Reviewed By: [Signature] Date: 5-4-91 Reviewed By: Date:

STAVELEY INSTRUMENTS - SONIC 136 PLUS DATA REPORT

STORED DISPLAY # 1 CAL PROGRAM 3 - MOST



<u>RANGE</u>		<u>RECEIVER</u>	
RANGE	2.80in	GAIN	74.0dB
DELAY	1.11in	DISPLAY	FILT2
VEL	0.227 in/us	FREQ	2.25MHZ
UNITS	in	REJECT	OFF
<u>GATE</u>		<u>PULSER</u>	
LEVEL	OFF	PULSE	222ns
POSN	1.81in	DAMPING	500 ²
WIDTH	0.701in	DUAL	
POLARITY	+	REP RATE	4 KHZ
<u>GAIN REFERENCE</u>			
GAIN	74.0dB		
REF LVL	40.0dB	66	66
% CHANGE	XXXX		
dB CHANGE	34.0		

INSPECTION REPORT

COMPANY Supply System

ADDRESS _____

OPERATOR P.L. TOMPKINS TIME 13:47

INSP. PROCEDURE QCI 6-25 Rev. C

CODE/SPEC _____

ACCEPTANCE LEVEL SIZING

JOB NUMBER _____

OBJECT _____ MATERIAL SS

TRANSDUCER TYPE ADEPT 60 - MOST

COMMENTS _____

SIGNATURE Paul h. Tompkins DATE 5-4-91

ATTACHMENT TO
IRTRU-157



Small cluster of faint marks or characters in the top right corner.

Faint marks or characters in the upper left quadrant.

Faint mark or character in the middle left area.

Faint mark or character in the middle center area.

Faint mark or character in the middle right area.

Vertical line of faint marks along the left edge.

Horizontal line of faint marks across the middle of the page.


Vertical line of faint marks on the left side, lower down.

Small faint mark near the bottom center.

Small faint mark near the bottom right.

STAVELEY INSTRUMENTS - SONIC 136 PLUS DATA REPORT

STORED DISPLAY # 2 CAL PROGRAM 3 - MOST



RANGE
 RANGE 2.80in
 DELAY 1.11in
 VEL 0.227 in/us
 UNITS in

RECEIVER
 GAIN 74.0dB
 DISPLAY FILT2
 FREQ 2.25MHz
 REJECT OFF

GATE
 LEVEL OFF
 POSN 1.81in
 WIDTH 0.701in
 POLARITY +

PULSER
 PULSE 222ns
 DAMPING 500R
 DUAL
 REP RATE 4 KHz

GAIN REFERENCE
 GAIN 74.0dB
 REF LVL ~~40.0dB~~ 66 (PW)
 % CHANGE XXXX
 dB CHANGE 34.0

INSPECTION REPORT

COMPANY Supply System

ADDRESS _____

OPERATOR P. L. TOMPKINS TIME 13:50

INSP. PROCEDURE RCI 6-25 Rev C

CODE/SPEC _____

ACCEPTANCE LEVEL SIZING

JOB NUMBER _____

OBJECT _____ MATERIAL SS

TRANSDUCER TYPE ADAPT 60 MOST

COMMENTS _____


SIGNATURE Paul L. Tompkins DATE 5-4-91

ATTACHMENT TO
 IRRU-157

STAVELEY INSTRUMENTS - SONIC 136 PLUS DATA REPORT

STORED DISPLAY # 3

CAL PROGRAM #4 SPOT



RANGE		RECEIVER	
RANGE	0.746in	GAIN	66.2dB
DELAY	1.33in	DISPLAY	FILT1
VEL	0.127 in/us	FREQ	5MHz
UNITS	in	REJECT	OFF
GATE		PULSER	
LEVEL	85%	PULSE	100ns
POSN	1.68in	DAMPING	500
WIDTH	0.119in	PULSE ECHO	
POLARITY	+	REP RATE	4 KHz
GAIN REFERENCE			
GAIN	66.2dB		
REF LVL	36.2dB	52	52
% CHANGE	XXXX		
dB CHANGE	30.0		

INSPECTION REPORT

COMPANY Supply System

ADDRESS _____

OPERATOR P.L. Tompkins TIME 14:10

INSP. PROCEDURE QLI 6-25 Rev. 0

CODE/SPEC _____

ACCEPTANCE LEVEL SIZING

JOB NUMBER _____

OBJECT _____ MATERIAL SS

TRANSDUCER TYPE ACFT 60 - ACFT SPOT 3.5 MHz shear 45°

COMMENTS _____

SIGNATURE Paul h. Tompkins DATE 5-4-91

ATTACHMENT TO
IRRU-157

INPUT TO THE FLAW EVALUATION

Stress (Loads) Evaluation

The stress state at the location of the flaw is required to determine the driving force for crack propagation. Stresses for the applicable loading conditions were extracted from the ASME Class 1 Stress Report for the subject RHR piping (Calculation No. 8.14.107) to complete the RHR piping flaw evaluation.

The input data and loads for the RHR-V-113 flaw evaluation are tabulated below.

Pipe Stresses and Geometry:

Deadweight (Dwt)	1494 psi
Pressure (P)	6062 psi
Upset	1754 psi
Emergency	1907 psi
Faulted (F)	3275 psi
Thermal NPO (TH)	1050 psi

Total Load $Dwt + P + TH + F = 11881$ psi

Physical Dimensions:

Nominal Pipe OD.	20 in.
Nominal Pipe Thick.	1.031 in.
Moment of Inertia	2770 in ⁴

Material Allowable:

SA-358 type 304 $S_m = 16675$ psi.

Load Combinations:

The following load combinations were evaluated to determine if the crack would grow under the imposed loads. The evaluations (fatigue and intergranular stress corrosion cracking (IGSCC)) encompass the requirements of IWB-3640.

The imposed load for fatigue evaluation consists of superimposing the pressure, deadweight bending, normal operating thermal bending stress and the weld residual stress to complete the evaluation of the minimum fracture stress intensity. Pressure, deadweight bending, and thermal bending stresses are conservatively combined with the worst case faulted dynamic bending stresses (without regard to the direction of the applied stress) to complete the evaluation of the maximum fracture stress intensity range. This methodology conservatively includes faulted dynamic stresses in the normal/upset evaluation and conservatively adds additional thermal stresses into the faulted evaluation. The number of dynamic loading cycles is based on the design basis main steam safety relief valve actuations which yield approximately 300 stress cycles per year. The peak dynamic loading also includes 300 cycles of the Safe Shutdown Earthquake event even though the plant design basis is 10 stress cycles.

Fatigue Stress: $Dwt + P + TH + F = 11881$ psi



12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

31

The IGSCC evaluation was completed using the steady state deadweight pressure and bending stress and the normal plant operation thermal stress.

IGSCC Stress: $Dwt + P + TH = 8606 \text{ psi}$

In each loading condition the above stress states were then superimposed on the weld residual stress distribution to complete the respective flaw evaluations. The resulting flaw sizes were then evaluated against the end of evaluation period depth-to-thickness ratios from Tables IWB-3641-5 and IWB-3641-6.