

March 2, 1992

Docket No. 50-397

9203120326 920302
PDR ADDCK 05000397
P PDR

Mr. G. C. Sorensen, Manager
Regulatory Programs
Washington Public Power Supply System
3000 George Washington Way
P.O. Box 968
Richland, Washington 99352

Dear Mr. Sorensen:

SUBJECT: RESPONSE TO GENERIC LETTER 91-11, "RESOLUTION OF GENERIC ISSUES 48
'LCO'S FOR CLASS 1E VITAL INSTRUMENT BUSES,' AND 49, 'INTERLOCKS
AND LCO'S FOR CLASS 1E TIE BREAKERS,' PURSUANT TO 10 CFR 50.54(f)"
FOR WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PLANT NO. 2
(TAC NO. M82488)

On July 18, 1991, the NRC issued Generic Letter (GL) 91-11 which contained the staff resolution of Generic Issues 48 and 49. The GL required that licensees certify that procedures exist that contain time limitations and surveillance requirements for vital instrument buses (VIB), inverters or other onsite power sources for VIB, and tie breakers. If procedures do not exist, a justification demonstrating the reasons why the controls are not needed is required.

By letter dated December 5, 1991, you responded to the GL. You indicated that procedures for time limitations and surveillance requirements are in place at your site.

The staff has reviewed your response and finds that it meets the reporting requirements set forth in GL 91-11. This completes the staff's activities on TAC No. M82488.

Sincerely,

Original signed by

Patricia L. Eng, Project Manager
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

cc:
See next page

DISTRIBUTION:

Docket File
PDV r/f
PEng

NRC/Local PDRs
DFoster
TQuay

BBoger
MVirgilio
OGC(15B18)

ACRS(10)(P315)
PDV p/f
RZimmerman,RV

OFC	PDV/LA	PDV/PM	PDV/D		
NAME	D. Foster	P. Eng	T. Quay		
DATE	3/2/92	3/2/92	3/2/92		

OFFICIAL RECORD COPY
Document Name: WNP82488.LTR

100129

NRC FILE CENTER COPY

MAY

DFol
1/0

... ..
... ..
... ..
... ..

... ..
... ..
... ..
... ..

... ..
... ..
... ..
... ..

... ..
... ..
... ..
... ..

... ..
... ..
... ..
... ..

... ..
... ..
... ..
... ..

... ..
... ..
... ..
... ..

... ..
... ..
... ..
... ..

... ..
... ..
... ..
... ..



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
March 2, 1992

Docket No. 50-397

Mr. G. C. Sorensen, Manager
Regulatory Programs
Washington Public Power Supply System
3000 George Washington Way
P.O. Box 968
Richland, Washington 99352

Dear Mr. Sorensen:

SUBJECT: RESPONSE TO GENERIC LETTER 91-11, "RESOLUTION OF GENERIC ISSUES 48
'LCO'S FOR CLASS 1E VITAL INSTRUMENT BUSES,' AND 49, 'INTERLOCKS
AND LCO'S FOR CLASS 1E TIE BREAKERS,' PURSUANT TO 10 CFR 50.54(f)"
FOR WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PLANT NO. 2
(TAC NO. M82488)

On July 18, 1991, the NRC issued Generic Letter (GL) 91-11 which contained the staff resolution of Generic Issues 48 and 49. The GL required that licensees certify that procedures exist that contain time limitations and surveillance requirements for vital instrument buses (VIB), inverters or other onsite power sources for VIB, and tie breakers. If procedures do not exist, a justification demonstrating the reasons why the controls are not needed is required.

By letter dated December 5, 1991, you responded to the GL. You indicated that procedures for time limitations and surveillance requirements are in place at your site.

The staff has reviewed your response and finds that it meets the reporting requirements set forth in GL 91-11. This completes the staff's activities on TAC No. M82488.

Sincerely,

A handwritten signature in dark ink, appearing to read "Patricia L. Eng", is written over the typed name.

Patricia L. Eng, Project Manager
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

cc:
See next page

Mr. G. C. Sorensen
Washington Public Power Supply System

WPPSS Nuclear Project No. 2
(WNP-2)

CC:

Mr. J. W. Baker
WNP-2 Plant Manager
Washington Public Power Supply System
P.O. Box 968, MD 927M
Richland, Washington 99352

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

G. E. C. Doupe, Esq.
Washington Public Power Supply System
3000 George Washington Way
P. O. Box 968, MD 396
Richland, Washington 99352

Chairman
Benton County Board of Commissioners
P. O. Box 190
Prosser, Washington 99350-0190

Mr. R. G. Waldo, Chairman
Energy Facility Site Evaluation Council
Mail Stop PY-11
Olympia, Washington 98504

Mr. R. C. Sorensen
U. S. Nuclear Regulatory Commission
P. O. Box 69
Richland, Washington 99352

Mr. Alan G. Hosler, Licensing Manager
Washington Public Power Supply System
P. O. Box 968, MD 956B
Richland, Washington 99352

Nicholas S. Reynolds, Esq.
Winston & Strawn
1400 L Street, N.W.
Washington, D.C. 20005-3502

Mr. A. Lee Oxsen, Assistant
Managing Director for Operations
Washington Public Power Supply System
P. O. Box 968, MD 1023
Richland, Washington 99352

Mr. L. L. Grumme, Acting Director
Licensing and Assurance
Washington Public Power Supply System
P. O. Box 968, MD 280
Richland, Washington 99352