

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9205200041 DOC. DATE: 92/05/14 NOTARIZED: NO DOCKET # 05000397
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe
 AUTH. NAME AUTHOR AFFILIATION
 SORENSEN, G.C. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Submits rept on flaw in reactor recirculation piping, per Generic Ltr 88-01. Indication in ISI weld 20RRC(6)-8 reexamined on 920421 to determine any size change. Results listed on encl submitted for approval for restart on 920629.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 8
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL	ID CODE/NAME		LTR	ENCL
	PD5 LA		1	1	PD5 PD		1	1
	DEAN, W.		2	2				
INTERNAL:	ACRS		6	6	NRR/DET/ECMB 7D		1	1
	NRR/DET/ESGB		1	1	NRR/DOEA/OTSB11		1	1
	NRR/DST 8E2		1	1	NRR/DST/SELB 7E		1	1
	NRR/DST/SICB8H7		1	1	NRR/DST/SRXB 8E		1	1
	NUDOCS-ABSTRACT		1	1	OC/LFMB		1	0
	OGC/HDS1		1	0	<u>REG FILE</u> 01		1	1
	RES/DSIR/EIB		1	1				
EXTERNAL:	NRC PDR		1	1	NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 24 ENCL 22

MAY

R
I
D
S
/
A
D
D
S

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

May 14, 1992
G02-92-123

9205200041 920514
PDR ADDCK 05000397
P PDR

Docket No. 50-397

U.S Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: WNP-2, OPERATING LICENSE NPF-21
REPORT ON FLAW IN REACTOR RECIRCULATION PIPING (TAC No. 80358)

- References:
- 1) Letter, G02-91-098, dated May 15, 1991, GC Sorensen (SS) to NRC, "Report on Flaw in Reactor Recirculation Piping Additional Information (TAC No. 80358)"
 - 2) Letter, G02-91-096, dated May 10, 1991, GC Sorensen (SS) to NRC, "Report on Flaw in Reactor Recirculation Piping (TAC No. 80358)"
 - 3) Letter, G02-92-085, dated April 10, 1992, GC Sorensen (SS) to NRC, "Request for Amendment to Technical Specification in Accordance with Generic Letter 88-01"
 - 4) Letter dated February 14, 1992, PL Eng (NRC) to GC Sorensen (SS), "Safety Evaluation of a Flaw in the Reactor Recirculation Piping at the Washington Public Power Supply System (WPPSS) Nuclear Project Number 2 (TAC No. M80358)"

The indication in ISI weld 20RRC(6)-8, as reported in References 1 and 2, was reexamined April 21, 1992 to determine any size change. No significant changes in the indication depth nor signal characteristics were noted. The flaw depth was found to be 0.17 inch (0.15 inch at R-6) and the length was unchanged at 4.5 inches. The slight difference in depth is attributed to the minor differences in calibration and data point locations along the indication length. The indication does not exhibit the UT signals characteristic of IGSCC.

Between R-6 and R-7, the Supply System enhanced the construction radiographs. No reason for the indication could be seen on the enhanced film.

190112


Aool
111

During this same period, the fracture mechanics analysis was also refined. The analysis predicts a crack depth of 0.29 inches after 365 days if the IGSCC mechanism is active. The analysis also predicts that the depth would exceed the maximum allowable depth of 0.62 inches after 5 additional years. The current flaw depth is 0.17 inches. This depth is approximately 14% of the predicted growth as determined by analysis. Review of the program output for both the fatigue analysis and the IGSCC analysis showed the current crack size is well within the limits of our evaluation that was previously performed. Therefore, based on the analysis and the examination results, the indication is determined to be acceptable for continued operation without repair until the next examination.

The Supply System will continue to monitor this indication. At refueling outage R-8, Spring 1993, the indication will be resized. If it still does not show any signs of growth, it will be reanalyzed to justify increasing the examination frequency. This weld is still classified as an IGSCC, Category "F" weld. This also requires augmented leak detection as described in Reference 3.

The results of this reexamination and evaluation are submitted for your review and approval for plant restart scheduled for June 29, 1992 (Reference 4).


Sincerely,



G. C. Sorensen, Manager
Regulatory Programs (Mail Drop 280)

DPR/bk
Enclosure: Ultrasonic Report Number IRRU-166

cc: JB Martin - NRC RV
NS Reynolds - Winston & Strawn
WM Dean - NRC
DL Williams - BPA/399
NRC Site Inspector - 901A



⑤ DIC = 1104.1
 MID = 20 RRC(6)-8

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

REPORT # IRRU-166
 PG 1 of 6


ULTRASONIC FLAW SIZING DATA SHEET

PROJECT: <i>WNP-2</i>	SYSTEM: <i>RRC</i>	ISI DRAWING NO.: <i>RRC-105 Rev.2</i>
WELD/PART DESCRIPTION: <i>PIPE TO VALVE</i>	WELD/PART NO.: <i>20 RRC(6)-8</i>	
IGSCC DETECTION REPORT NO: <i>R-6 REPORT IRRU-155, 156 & 157</i>	UT SIZING CALIBRATION REPORT: <i>344</i>	
FLAW LENGTH: <i>4.5"</i>	CALIBRATION BLOCK NO.: <i>UT-95</i>	
FLAW AREA THICKNESS: <i>1"</i>	CALIBRATION BLOCK THICKNESS: <i>1.02"</i>	
INSTRUCTION NO.: <i>QCI 6-25 Rev. 1</i>	EXAMINER: <i>P.L. Tompkins (PLT)</i>	LEVEL: <i>II</i>
DATE: <i>4-21-92</i>	EXAMINER: <i>n/a</i>	LEVEL: <i>n/a</i>
TIME START: <i>13:15</i>	TIME STOP: <i>13:40</i>	PART TEMP: <i>106°F</i>

FLAW NO.	30-70-70	HIGH ANGLE L WAVE	MOST	AATT	RATT	FULL VEE	%TWD	CRACK DEPTH	ACTUAL
<i># 1</i>	<i>CE-1 17% FSH LENGTH 3 5/8" AT REFERENCE GAIN = 0.14" BY AMP.</i>	<i>NO INDICATION</i>	<i>17% FURTHEST TIP</i>	<i>15%</i>	<i>12% MAX</i>	<i>n/a</i>	<i>17%</i>	<i>.17"</i>	
	<i>NOTE: FLAW LENGTH OF 4.5" WAS LAST YEAR'S R-6 LENGTH BASED ON 12db OVER REFERENCE TO DETERMINE INITIAL LENGTH OF FLAW BASED ON CE-2 SIGNAL DISAPPEARING INTO BASELINE. LENGTH OF 3 5/8" IS BASED ON EPR/NDE PRACTICE FOR IGSCC DETECTION OF LENGTH BASED ON A REFERENCE GAIN. NO CHANGE IN LENGTH WAS NOTED.</i>								
								<i>(PLT)</i>	

FINAL REPORTED CRACK DEPTH: <i>.17"</i>	COMMENTS: <i>I FOUND NO SIGNIFICANT CHANGES IN THE INDICATIONS DEPTH OR SIGNAL CHARACTERISTICS OVER LAST YEAR. THE VERY SLIGHT INCREASE IN THE INDICATIONS TWP MAY BE DUE TO MINOR DIFFERENCES IN CALIBRATION AND DATA POINTS AMONG LOCATIONS ALONG INDICATIONS LENGTH. CALIBRATION & EXAMINATION WITNESSED BY ANII, (PLT)</i>
--	---

REVIEWED BY LEVEL III: <i>[Signature]</i>	DATE: <i>4-25-92</i>	REVIEWED BY: <i>[Signature]</i> ANII	DATE: <i>4/27/92</i>
---	----------------------	--------------------------------------	----------------------



RANGE
 RANGE 5.40in
 DELAY 0.324in
 VEL 0.227 in/us
 UNITS in

RECEIVER
 GAIN 67.0dB
 DISPLAY FILT2
 FREQ 2.25MHz
 REJECT OFF

GATE
 LEVEL OFF
 POSN 1.45in
 WIDTH 3.40in
 POLARITY +

PULSER
 PULSE 222ns
 DAMPING 500 Ω
 PULSE ECHO
 REP RATE 2 KHz

GAIN REFERENCE
 GAIN 67.0dB
 REF LVL 67.0dB
 % CHANGE 0.0
 dB CHANGE 0.0

INSPECTION REPORT


COMPANY Supply System
 ADDRESS _____
 OPERATOR P. L. Tompkins TIME 13:20
 INSP. PROCEDURE QLI 6-25 Rev. 1
 CODE/SPEC IGSCC SIZING
 ACCEPTANCE LEVEL N/A
 JOB NUMBER _____
 OBJECT 20 RRC (6)-8 MATERIAL STAINLESS STEEL
 TRANSDUCER TYPE WS4 70-2
 COMMENTS 30-70-70 technique
slight CE-1 signal indicating approx. depth of 15% TWB

SIGNATURE Paul L. Tompkins DATE 4-21-92
Dan Hoggarth AWSI 4/27/92

IRRU-166
 Pg 2 of 6

STAVELEY INSTRUMENTS - SONIC 136 PLUS DATA REPORT

STORED DISPLAY # 2



<u>RANGE</u>		<u>RECEIVER</u>	
RANGE	2.95in	GAIN	73.0dB
DELAY	1.13in	DISPLAY	FILT2
VEL	0.227 in/us	FREQ	2.25MHz
UNITS	in	REJECT	OFF
<u>GATE</u>		<u>PULSER</u>	
LEVEL	OFF	PULSE	222nS
POSN	1.75in	DAMPING	500 ^Ω
WIDTH	1.86in	DUAL	
POLARITY	+	REP RATE	2 KHz
<u>GAIN REFERENCE</u>			
GAIN	73.0dB		
REF LVL	67.0dB		
% CHANGE	99.5		
dB CHANGE	6.0		

INSPECTION REPORT

COMPANY Supply System

ADDRESS _____

OPERATOR P. L. Tompkins TIME 13:28

INSP. PROCEDURE QCI 6-25 Rev. 1

CODE/SPEC IGSC SIZING

ACCEPTANCE LEVEL N/A

JOB NUMBER _____

OBJECT 20 RRC (6)-8 MATERIAL STAINLESS STEEL

TRANSDUCER TYPE ADEPT-60


COMMENTS THICKNESS APPEARED TO BE SLIGHTLY LESS THAN 1" AT LOCATION
17% TWD IS A GOOD READING.
PROBABLY VERY TIP EDGE OF INDICATION
(SEE STORED DISPLAY #3

SIGNATURE Paul L. Tompkins DATE 4-21-92
Don [unclear] ANII 4/27/92

IRRU-166
 Pg 3 of 6

STAVELEY INSTRUMENTS - SONIC 136 PLUS DATA REPORT

STORED DISPLAY # 3



RANGE
 RANGE 2.95in
 DELAY 1.13in
 VEL 0.227 in/us
 UNITS in

RECEIVER
 GAIN 73.0dB
 DISPLAY FILT2
 FREQ 2.25MHz
 REJECT OFF

GATE
 LEVEL OFF
 POSN 1.75in
 WIDTH 1.86in
 POLARITY +

PULSER
 PULSE 222ns
 DAMPING 500 Ω
 DUAL
 REP RATE 2 KHz

GAIN REFERENCE
 GAIN 73.0dB
 REF LVL 67.0dB
 % CHANGE 99.5
 dB CHANGE 6.0

INSPECTION REPORT

COMPANY Supply System
 ADDRESS _____
 OPERATOR P.L. Tompkins TIME 13:28
 INSP. PROCEDURE QCI 6-25 Rev.1
 CODE/SPEC IGSCC SIZING
 ACCEPTANCE LEVEL N/A
 JOB NUMBER _____
 OBJECT 20 RRC (6)-8 MATERIAL STAINLESS STEEL
 TRANSDUCER TYPE ADEPT 60
 COMMENTS TIP SIGNALS MAX AMPLITUDE AT 10% TWD


SIGNATURE Paul L. Tompkins DATE 4-21-92
Don Hoggan AWEF 4/27/92

IRRU-1166
 Pg 4 of 6

STAVELEY INSTRUMENTS - SONIC 136 PLUS DATA REPORT

45° SHEAR AATT

STORED DISPLAY # 4



RANGE
 RANGE 0.762in
 DELAY 1.14in
 VEL 0.127 in/us
 UNITS in

RECEIVER
 GAIN 67.2dB
 DISPLAY FILT1
 FREQ 5MHz
 REJECT OFF

GATE
 LEVEL OFF
 POSN 1.30in
 WIDTH 0.480in
 POLARITY +

PULSER
 PULSE 100ns
 DAMPING 500Ω
 PULSE ECHO
 REP RATE 2 KHz

GAIN REFERENCE
 GAIN 67.2dB
 REF LVL 53.0dB
 % CHANGE 412.9
 dB CHANGE 14.2

HIGH GAIN OVER
 REFERENCE REQUIRED

INSPECTION REPORT

COMPANY Supply System

ADDRESS _____

OPERATOR PAUL L. TOMPKINS TIME 13:35

INSP. PROCEDURE RCI 6-25 Rev 1

CODE/SPEC TBSCU SIZING

ACCEPTANCE LEVEL N/A

JOB NUMBER _____

OBJECT 20 RRC (6)-8 MATERIAL STAINLESS STEEL

TRANSDUCER TYPE 45° SHEAR


COMMENTS SLIGHT THICKNESS DIFFERENCES - DETERMINE TIP TO CORNER
SEPARATION MAKE THIS PROBABLY 15% TWD
17%

SIGNATURE Paul L. Tompkins DATE 4-21-92
Dan Hoggan - ANI 4/27/92

IRRU-166
 Pg 5 of 6

STAVELEY INSTRUMENTS - SONIC 136 PLUS DATA REPORT

STORED DISPLAY # 5



<u>RANGE</u>		<u>RECEIVER</u>	
RANGE	0.762in	GAIN	67.2dB
DELAY	1.14in	DISPLAY	FILT1
VEL	0.127 in/us	FREQ	5MHz
UNITS	in	REJECT	OFF
<u>GATE</u>		<u>PULSER</u>	
LEVEL	OFF	PULSE	100nS
POSN	1.30in	DAMPING	500 μ
WIDTH	0.480in	PULSE ECHO	
POLARITY	+	REP RATE	2 KHz
<u>GAIN REFERENCE</u>			
GAIN	67.2dB	HIGH GAIN OVER REFERENCE REQUIRED	
REF LVL	53.0dB		
% CHANGE	412.9		
dB CHANGE	14.2		

INSPECTION REPORT

COMPANY Supply System

ADDRESS _____

OPERATOR P.L. TOMPKINS TIME 13:40

INSP. PROCEDURE QCI 6-25 REV.1

CODE/SPEC TGSCC BIZING

ACCEPTANCE LEVEL N/A

JOB NUMBER _____

OBJECT 20 RRC (6)-8 MATERIAL STAINLESS STEEL

TRANSDUCER TYPE 45 $^{\circ}$ SHEAR RATT TECHNIQUE

COMMENTS DOUBLET SEPARATION, MAX SEPARATION 1.2 DIV = 12 μ

SIGNATURE Paul L. Tompkins DATE 4-21-92

Don Higginbotham AND 4/27/92

IRRU-166
Pg 6 of 6