

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9207020274 DOC. DATE: ~~92/05/31~~ NOTARIZED: NO DOCKET #
FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
AUTH. NAME AUTHOR AFFILIATION
HUTCHISON, L.B. Washington Public Power Supply System
BAKER, J.W. Washington Public Power Supply System
RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for May 1992 for WNP Unit 2 W/920610
ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5.LA	3 3	PD5 PD	1 1
	DEAN, W.	1 1		
INTERNAL:	ACRS	10 10	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	NRR/DLPQ/LPEB10	1 1
	NRR/DOEA/OEAB	1 1	<u>REG FILE 01</u>	1 1
	RGN5	1 1		
EXTERNAL:	EG&G BRYCE, J.H	1 1	NRC PDR	1 1
	NSIC	1 1		

*Cert NO
188318*

Rec'd 7/2/92

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 24

MR

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

Docket No. 50-397
June 10, 1992

GO2-92-138

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Subject: **NUCLEAR PLANT NO. 2**
MONTHLY OPERATING REPORT
MAY 1992

Transmitted herewith is the Monthly Operating Report for the month of May 1992 as required by our Technical Specifications 6.9.1.6.

Very truly yours,

J.W. Baker
WNP-2 Plant Manager
(MD 927M)

LBH:bap
Enclosure

cc: Mr. W.H. Lovelace, NRC, Washington DC
Mr. J.B. Martin, NRC Region V
Ms. Dottie Sherman, ANI, Farmington CT
Mr. C. Sorensen, NRC Resident Inspector (901A)
Mr. J.T. Wheelock, INPO
Mr. F. Yost, Utility Data Institute

*Cut 100
188 316*

Rec'd 7/2/92

*IE24
11*

9207020274 920531
PDR ADDCK 05000397
R PDR



11

12

13

14

OPERATING DATA REPORT
WNP-2

DATE: 01-Jun-92

1. DOCKET: 50-397
2. REPORTING PERIOD: May-92 OUTAGE + ON-LINE HOURS 744
3. UTILITY CONTACT: LEONARD HUTCHISON (509) 377-2486
4. LICENSED THERMAL POWER (MWt): 3323
5. NAMEPLATE RATING (GROSS MWe): 1200.9
6. DESIGN ELECTRICAL RATING (NET MWe): 1100
7. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): 1129
8. MAXIMUM DEPENDABLE CAPACITY (NET MWe): 1085

9. IF CHANGES OCCUR ABOVE SINCE LAST REPORT, GIVE REASONS:
None

10. POWER TO WHICH RESTRICTED, IF ANY (NET MWe): _____

11. REASONS FOR RESTRICTIONS, IF ANY: None.

	MONTH	YEAR	CUMULATIVE
12. REPORT PERIOD HOURS	744	3647	65431.2
13. HOURS REACTOR CRITICAL	0.0	2085.0	45475.7
14. RX RESERVE SHTDWN HRS	0.0	0.0	340.4
15. HRS GENERATOR ON LINE	0.0	2042.6	43842.5
16. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	381.7
17. GROSS THERMAL ENERGY (MWH)	0	6588250	126204072
18. GROSS ELECTRICAL ENERGY (MWH)	0	2233530	42089350
19. NET ELECTRICAL ENERGY (MWH)	-6532	2129315	40387354
20. UNIT SERVICE FACTOR	0.0%	56.0%	67.0%
21. UNIT AVAILABILITY FACTOR	0.0%	56.0%	67.6%
22. UNIT CAPACITY FACTOR (MDC NET)	0.0%	53.8%	56.4%
23. UNIT CAPACITY FACTOR (DER NET)	0.0%	53.1%	56.1%
24. UNIT FORCED OUTAGE RATE	0.0%	21.3%	13.5%
25. FORCED OUTAGE HOURS	0.0	552.0	6855.8

26. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE, DURATION):

27. IF CURRENTLY SHUTDOWN ESTIMATED STARTUP DATE: 7/1/92



11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

DOCKET NO.: 50-397
 UNIT NAME: WNP-2
 DATE: JUNE 1, 1992
 COMPLETED BY: LB HUTCHISON
 TELEPHONE: (509) 377-2486

UNIT SHUTDOWNS / REDUCTIONS

REPORT PERIOD: MAY 1992

<u>NO.</u>	<u>DATE</u>	<u>TYPE</u>	<u>HOURS</u>	<u>REASON</u>	<u>METHOD</u>	<u>LER NO</u>	<u>SYSTEM</u>	<u>COMPONENT</u>	<u>CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE</u>
92-03	4/18/92	S	744	C	4	--	RC	FUEL XX	Refueling outage continuing.

SUMMARY: Continuation from previous month.

<u>TYPE</u>	<u>REASON</u>	<u>METHOD</u>	<u>SYSTEM & COMPONENT</u>
F-FORCED S-SCHED	A-EQUIP FAILURE B-MAINT OR TEST C-REFUELING D-REGULATORY RESTRICTION E-OPERATOR TRAINING & LICENSE EXAM	F-ADMIN G-OPER ERROR H-OTHER	1-MANUAL 2-MANUAL SCRAM 3-AUTO SCRAM 4-CONTINUED 5-REDUCED LOAD 9-OTHER
			EXHIBIT F & H INSTRUCTIONS FOR PREPARATION OF DATA ENTRY SHEET LICENSEE EVENT REPORT (LER) FILE (NUREG-0161)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.: 50-397
UNIT: WNP-2
DATE: MAY 1992
COMPLETED BY: LB HUTCHISON
TELEPHONE: (509) 377-2486

MONTH: MAY 1992

DAY AVERAGE DAILY POWER LEVEL
(MWe-NET)

1.	0
2.	0
3.	0
4.	0
5.	0
6.	0
7.	0
8.	0
9.	0
10.	0
11.	0
12.	0
13.	0
14.	0
15.	0
16.	0

DAY AVERAGE DAILY POWER LEVEL
(MWe-NET)

17.	0
18.	0
19.	0
20.	0
21.	0
22.	0
23.	0
24.	0
25.	0
26.	0
27.	0
28.	0
29.	0
30.	0
31.	0

INSTRUCTIONS

ON THIS FORM, LIST THE AVERAGE DAILY UNIT POWER LEVEL IN MWe-NET FOR EACH DAY IN THE REPORTING MONTH. COMPUTE TO THE NEAREST WHOLE MEGAWATT.

THESE FIGURES WILL BE USED TO PLOT A GRAPH FOR EACH REPORTING MONTH. NOTE THAT WHEN MAXIMUM DEPENDABLE CAPACITY IS USED FOR THE NET ELECTRICAL RATING OF THE UNIT, THERE MAY BE OCCASIONS WHEN THE DAILY AVERAGE POWER LEVEL EXCEEDS THE 100% LINE (OR THE RESTRICTED POWER LEVEL LINE). IN SUCH CASES, THE AVERAGE DAILY UNIT POWER OUTPUT SHEET SHOULD BE FOOTNOTED TO EXPLAIN THE APPARENT ANOMALY.

1954

2000

1000000000

1