92-26

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION V

1450 MARIA LANE
WALNUT CREEK, CALIFORNIA 94596-5368

JUL - 7 1992

Docket No.: 50-397

Washington Public Power Supply System
P.O. Box 968
Richland, Washington 99352

Attention: Mr. G. C. Sorenson
Manager, Regulatory Programs

Gentlemen:

SUBJECT: NRC INSPECTION AT WNP-2

This refers to the routine announced inspection conducted by Mr. D. Corporandy of this office during the week of June 15, 1992 of activities authorized by NRC Operating License No. NPF-21, and to the discussion of our findings held by the inspector with Mr. J. Baker and other members of the Supply System's staff at the conclusion of the inspection.

Areas examined during this inspection are described in the enclosed inspection report. Within these areas, the inspection consisted of selected examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

As discussed in the enclosed inspection report, the inspector found isolated minor deficiencies in some of your procedures. Field change notices were not always incorporated into drawings in a timely manner, and this made determination of as-built status cumbersome. In general, however, your plant modifications program and procedures for snubbers were thorough and well controlled. Calculations appeared adequate, and the program staff appeared knowledgeable of regulations and related technical issues. No violations or deviations of NRC requirements were identified within the scope of this inspection.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosure will be placed in the NRC Public Document Room.

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

L. F. Miller, Chief
Reactor Safety Branch

Enclosure:
Inspection Report No. 50-397/92-26

9207270149 920707
PDR ADOCK 05000397
Q PDR

IE01

cc: A. L. Oxsen, Deputy Managing Director
J. V. Parrish, Assistant Managing Director for Operations
L. L. Grumme, Acting Director, Licensing and Assurance
J. W. Baker, WNP-2 Plant Manager
A. G. Hosler, WNP-2 Licensing Manager
G. E. Doupe, Esq.
Winston & Strawn
State of Washington

bcc w/enclosure:
Docket File
Resident Inspector
Project Inspector
G. Cook
B. Faulkenberry
J. Martin

bcc w/o enclosure:
J. Bianchi
M. Smith
J. Zollicoffer

Region V/ann

DCorporandy	AGody	PJohnson	LMiller
7/7/92	7/7/92	7/7/92	7/7/92

REQUEST COPY	REQUEST COPY	REQUEST COPY	REQUEST COPY	SEND TO PDR
YES / NO	YES / NO	YES / NO	YES / NO	YES / NO