

# ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9305070060      DOC. DATE: ~~92/12/31~~ NOTARIZED: NO      DOCKET #  
FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397  
AUTH. NAME                      AUTHOR AFFILIATION  
SORENSEN, G.C.                  Washington Public Power Supply System  
RECIP. NAME                      RECIPIENT AFFILIATION

SUBJECT: "WNP-2 Cooling Water Blowdown Discharges, 1992." W/930426  
ltr.

DISTRIBUTION CODE: IE25D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 2  
TITLE: Environmental Monitoring Rept (per Tech Specs)

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL	ID CODE/NAME	LTR	ENCL	
	PDV LA		3	3	PDV PD	1	1	
	CLIFFORD, J		1	1				
INTERNAL:	ACRS		1	1	NRR/DRSS/PRPB11	2	2	
	<u>REG FILE</u>	01	1	1	RGN5 DRSS/RPB	1	1	
	RGN5 FILE	02	1	1				
EXTERNAL:	EG&G SIMPSON, F		2	2	NRC PDR	1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 14 ENCL 14

*Er-1*

R  
I  
D  
S  
/  
A  
D  
D  
S  
/  
A  
D  
D  
S  
/  
A  
D  
D  
S



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

April 26, 1993  
G02-93-095

Docket No. 50-397

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

Subject: **NUCLEAR PLANT NO. 2, OPERATING LICENSE NPF-21  
1992 ANNUAL ENVIRONMENTAL OPERATING REPORT**

This letter is submitted per reporting requirements of Section 5.4.1 of the WNP-2 Environmental Protection Plan (EPP; Appendix B to OL).

A summary of the effluent data reported to the State of Washington on the monthly discharge monitoring reports is attached. No design or operational changes or tests in 1992 involved an unreviewed environmental question. Also, no non-routine nonradiological reports (within the context of EPP Section 5.4.2) were required for 1992.

Please contact us if you require additional information on this report.

Sincerely,

G. C. Sorensen, Manager  
Regulatory Programs (Mail Drop PE20)

Attachment: Table of 1992 effluent data

cc: JB Martin - NRC RV  
JW Clifford - NRC NRR  
RC Barr - NRC RI/901A  
JJ Zeller - EFSEC

050040

9305070060 921231  
PDR ADOCK 05000397  
R PDR

*JFB*  
11



Handwritten marks or scribbles in the top right corner.

Main body of the document containing several lines of extremely faint, illegible text.

WNP-2 COOLING WATER BLOWDOWN DISCHARGES, 1992

Month	Days of Discharge	pH		TRC (mg/l)	Discharge Volume (millions of gallons)		
		High	Low		Total	Ave*	Max**
Jan	31	8.5	7.9	≤0.1	111.8	3.61	5.62
Feb	26	8.5	7.8	≤0.1	95.16	3.66	5.18
Mar	15	8.6	7.4	≤0.1	45.90	3.06	5.40
Apr	25	8.7	7.0	≤0.1	77.23	3.09	6.05
May	31	8.8	7.2	≤0.1	69.65	2.25	2.27
Jun	25	8.7	7.0	≤0.1	53.58	2.14	2.27
Jul	26	8.7	7.7	≤0.1	66.02	2.54	4.10
Aug	29	8.5	6.8	≤0.1	131.0	4.52	6.48
Sep	28	8.5	7.0	≤0.1	97.67	3.49	5.83
Oct	31	8.6	7.5	≤0.1	104.5	3.37	5.94
Nov	29	8.6	7.5	≤0.1	99.18	3.42	5.94
Dec	31	8.7	7.6	≤0.1	105.0	3.39	5.62
Permit Limit		9.0	6.5	0.1		5.00	9.40

\* Average daily discharge during the month.

\*\* Maximum daily discharge during the month.

1950  
APR 1 1950