

# ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9307280191      DOC. DATE: 93/07/15      NOTARIZED: NO      DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe      05000397  
 AUTH. NAME      AUTHOR AFFILIATION  
 PARRISH, J.V.      Washington Public Power Supply System  
 RECIP. NAME      RECIPIENT AFFILIATION  
                          Document Control Branch (Document Control Desk)

SUBJECT: Forwards change to ERDS data point library, consisting of ref  
 file re Rx bldg high-range monitor.

DISTRIBUTION CODE: A026D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 3  
 TITLE: Emergency Response Data System (ERDS)

## NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	AEOD/IRB      01	2      2	NRR/PD3-2	1      1
	CLIFFORD, J	1      1		
INTERNAL:	ACRS	1      1	AEOD	1      1
	AEOD/DOA/IRB	1      1	NRR/DRSS/PEPB	1      1
	OC/LFDCB	1      0	<u>REG FILE</u>	1      1
	RGN5      ERC	1      1	RGN5      FILE	1      1
EXTERNAL:	NRC PDR	1      1		

## NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR      13      ENCL      12

MA 4



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

July 15, 1993  
G02-93-186

Docket No. 50-397

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Subject: WNP-2, OPERATING LICENSE NPF-21  
EMERGENCY RESPONSE DATA SYSTEM, CHANGE TO  
DATA POINT LIBRARY

- References:
- 1) Letter GO2-92-257 dated November 24, 1992, GC Sorensen (SS) to NRC, "Response to ERDS Rule, 10CFR50, Appendix E"
  - 2) Letter GO2-93-056 dated March 10, 1993, GC Sorensen (SS) to NRC, "Request for Amendment To Technical Specification 3/4.3.7.5, Accident Monitoring Instrumentation, Reactor Building Post LOCA Grab Sampler and Effluent Noble Gas Radiation Monitor"
  - 3) Letter GO2-93-068 dated March 24, 1993, GC Sorensen (SS) to NRC, "NRC Inspection Reports 85-20 and 90-29 Reactor Building Post-LOCA Grab Sampler"

The following information is provided to the NRC to satisfy the requirement of 10CFR50, Appendix E, Section VI.3.a that any hardware or software that affect the transmitted data points identified in the ERDS Data Point Library be submitted to the NRC within 30 days after the changes are completed. In Reference 1 we provided the base Data Point Library from which we would notify the NRC of changes to the library.

270044

9307280191 930715  
PDR ADDCK 05000397  
F PDR




AD36 / 1

Page Two

**EMERGENCY RESPONSE DATA SYSTEM, CHANGE TO  
DATA POINT LIBRARY**

References 2 and 3 described changes to be made to the Reactor Building Post LOCA Grab Sampler and Effluent Noble Gas Radiation Monitor. The changes affect ERDS Data Point 406 (now 392) for WNP-2 for which the new data was available to the ERDS on July 15, 1993. The attachment provides the new data.

Sincerely,



J. V. Parrish (Mail Drop 1023)  
Assistant Managing Director, Operations

AGH/bk  
Attachment

cc: BH Faulkenberry - NRC RV  
NS Reynolds - Winston & Strawn  
JW Clifford - NRC  
DL Williams - BPA/399  
NRC Site Inspector - 901A  
J Jolicoeur - NRC

## BWR Data Point Library Reference File

Reactor Unit:	WP2
NRC ERDS Parameter:	EFF-GAS-RAD1
Point ID:	392 (previously 406)
Plant Spec Point Desc:	Rx Bldg High Range Effluent Monitor
Generic/Cond Desc:	Eff Gas Rad
Analog/Digital:	A
Engr Units/Dig States:	cps
Eng Units Conversion:	N/A
Minimum Instr Range:	10
Maximum Instr Range:	10 <sup>6</sup>
Zero Point Reference:	N/A
Reference Point Notes:	N/A
Number of sensors:	1
Sensor Locations:	Reactor Building, 617 ft level
Alarm/Trip Setpoints:	None
NI Detector Power Supply Cut-Off Power Level:	N/A
NI Detector Power Supply Turn-On Power Level:	N/A
Instrument Failure Mode:	Can not be predicted
Temperature Compensation for dp Transmitters:	N/A
Level Reference Leg:	N/A
Unique System Desc:	Reactor Building Effluent Monitor
EPN:	PRM-LCRM-1C (previously CMS-RIS-27D)

