

# FORD 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9311190050      DOC.DATE: 93/11/05      NOTARIZED: NO      DOCKET #  
 FACIL:50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397  
 AUTH.NAME      AUTHOR AFFILIATION  
 LUEHMAN,J.      Ofc of Enforcement (Post 870413)  
 LIEBERMAN,J.      Ofc of Enforcement (Post 870413)  
 RECIP.NAME      RECIPIENT AFFILIATION

SUBJECT: EN-93-110:on 931110 proposed imposition of civil penalty in amount of \$75,000 issued to licensee.Action based on failure to follow procedural requirements re RHR sys.State of Washington notified.

DISTRIBUTION CODE: IE33D      COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 1  
 TITLE: Enforcement Notice (EN)

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
INTERNAL:	AEOD/DOA	1	AEOD/DSP/ROAB	1
	AEOD/DSP/TPAB	1	NRR/DORS/OEAB	1
	NRR/DRSS/PEPB	1	NRR/PMAS/ILPB	1
	NUDOCS FULL TXT	1	OE DIR	1
	OE FILE      01	1	<del>REG FILE</del> 02	1
EXTERNAL:	NRC PDR	1	NSIC	1

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.  
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 12 ENCL 0

*JAS*

R  
I  
D  
S  
/  
F  
O  
R  
D  
D  
O  
C  
U  
M  
E  
N  
T

OFFICE OF ENFORCEMENT  
NOTIFICATION OF SIGNIFICANT ENFORCEMENT ACTION

Licensee: Washington Public Power Supply System (EA 93-191)  
(WNP-2)  
Docket No. 50-397

Subject: PROPOSED IMPOSITION OF CIVIL PENALTY - \$75,000

This is to inform the Commission that a Notice of Violation and Proposed Imposition of Civil Penalty in the amount of \$75,000 will be issued on or about November 10, 1993 to the Washington Public Power Supply System. This action is based on the failure to follow procedural requirements with regard to simultaneously placing both trains of the residual heat removal system in the suppression pool cooling mode while the plant was in operation. The three separate occasions that this occurred have collectively been classified as a Severity Level III violation. The base civil penalty was escalated by 50 percent after partially offsetting escalation for prior poor performance and corrective actions with mitigation for licensee identification.

It should be noted that the licensee has not been specifically informed of the enforcement action. The schedule of issuance and notification is:

Mailing of Notice November 10, 1993  
Telephone Notification of Licensee November 10, 1993

The State of Washington will be notified.

The licensee has thirty days from the date of the Notice in which to respond. Following NRC evaluation of the response, the civil penalty may be remitted, mitigated, or imposed by Order.

Contact: J. Luehman, OE, 504-3280 J. Lieberman, OE, 504-2741

Distribution:

OWFN <u>10:00</u>	OWFN <u>10:00</u>	MNBB <u>10:00</u>	PHIL <u>10:00</u>	NL <u>10:00</u>
Chairman Selin	EDO	OC	IRM	
Comm. Rogers	DEDR	AEOD		
Comm. Remick	DEDS	Op Ctr		
Comm. de Planque	OE			
	NMSS			
SECY	NRR			
OCA	OI			
OSP	OGC			
GPA				
		Regional Offices	MAIL	
		RI <u>10:00</u>	ADM: Doc. Mgt. Br.	
		RIV <u>10:00</u>	PDR	ACRS
		RII <u>10:00</u>	RES	OIG
		RIII <u>10:00</u>		

PRELIMINARY INFORMATION - NOT FOR PUBLIC  
DISCLOSURE UNTIL PUBLICLY ANNOUNCED

*JE33 1/6*