9402170190 940208
PDR ADOCK 05000397
P PDR

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES

VALVE FUNCTION AND NUMBER	VALVE GROUP(a)	MAXIMUM ISOLATION TIME (Seconds)
a. Automatic Isolation Valves (Continued)		
Reactor Core Isolation Cooling		
RCIC-V-8	8	26 ~~15(j)~~
RCIC-V-63	8	16~~(j)~~
RCIC-V-76	8	22
Low Pressure Core Spray		
LPCS-V-12	10	180
High Pressure Core Spray		
HPCS-V-23	11	180
b. Excess Flow Check Valves(e)		
Containment Atmosphere		N.A.
PI-EFC-X29d		
PI-EFC-X29f		
PI-EFC-X30a		
PI-EFC-X30f		
PI-EFC-X42c		
PI-EFC-X42f		
PI-EFC-X61c		
PI-EFC-X62b		
PI-EFC-X69f		
PI-EFC-X78a		

DELETION OF THIS PAGE REQUESTED IN PREVIOUS SUBMITTAL
SEE: GO2-93-256, DATED OCTOBER 21, 1993

CONTROLLED COPY

STATE OF WASHINGTON)
)
COUNTY OF BENTON)

Subject: Request for Amend to Tech Spec
Table 3.6.3-1, Primary Containment

I. J. V. PARRISH, being duly sworn, subscribe to and say that I am the Assistant Managing Director, Operations for the WASHINGTON PUBLIC POWER SUPPLY SYSTEM, the applicant herein; that I have the full authority to execute this oath; that I have reviewed the foregoing; and that to the best of my knowledge, information, and belief the statements made in it are true.

DATE 9 February, 1994

J. V. Parrish, Assistant Managing Director
Operations

On this date personally appeared before me J. V. PARRISH, to me known to be the individual who executed the foregoing instrument, and acknowledged that he signed the same as his free act and deed for the uses and purposes herein mentioned.

GIVEN under my hand and seal this 9 day of February, 1994.

Notary Public in and for the
STATE OF WASHINGTON

Residing at Richland, WA

My Commission Expires Dec. 97