

# ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9405020370    DOC.DATE: 94/04/25    NOTARIZED: NO    DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe    05000397 R  
 AUTH.NAME    AUTHOR AFFILIATION  
 PARRISH, J.V.    Washington Public Power Supply System    I  
 RECIP.NAME    RECIPIENT AFFILIATION  
                  Document Control Branch (Document Control Desk)    D

SUBJECT: Clarifies intent of 931220 request for amend to TS    D  
           3/4.6.1.8, "Drywell & Suppression Chamber Purge Sys" & suppl    S  
           by 940325 ltr.    S

DISTRIBUTION CODE: A001D    COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2 /  
 TITLE: OR Submittal: General Distribution    /

NOTES:


	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	
	PDIV-3 LA CLIFFORD, J	1 4 2 2	PDIV-3 PD	1 1	D
INTERNAL:	ACRS	6 6	NRR/DE/EELB	1 1	D
	NRR/DORS/OTSB	1 1	NRR/DRCH/HICB	1 1	S
	NRR/DRPW	1 1	NRR/DSSA/SPLB	1 1	
	NRR/DSSA/SRXB	1 1	NUDOCS-ABSTRACT	1 1	
	OC/LFDCB	1 0	OGC/HDS1	1 0	
	<u>REG FILE</u> 01	1 1			
EXTERNAL:	NRC PDR	1 1	NSIC	1 1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL ~~20~~ 0

AA2





---

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

---

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

---

April 25, 1994  
G02-94-094

Docket No. 50-397

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Subject: **WNP-2, OPERATING LICENSE NPF-21  
REQUEST FOR AMENDMENT TO TECHNICAL SPECIFICATION  
3/4.6.1.8, DRYWELL AND SUPPRESSION CHAMBER PURGE  
SYSTEM - SUPPLEMENTAL INFORMATION**

- Reference:
- 1) Letter GO2-93-296, dated December 20, 1993, JV Parrish (SS) to USNRC, "Request for Amendment to Technical Specification 3/4.6.1.8, Drywell and Suppression Chamber Purge System"
  - 2) Letter G02-94-069, dated March 25, 1994, JV Parrish (SS) to USNRC, "Request for Amendment to Technical Specification 3/4.6.1.8, Drywell and Suppression Chamber Purge System - Supplemental Information"


The purpose of this letter is to clarify the intent of the Supply System's request for amendment to Technical Specification 3/4.6.1.8, Drywell and Suppression Chamber Purge System, which was submitted by Reference 1 and supplemented by Reference 2. Technical Specification Table 3.6.3-1 identifies a maximum isolation time of four (4) seconds for the Containment Purge Exhaust and Supply valves. Reference 1, in the technical background and "No Significant Hazards Consideration" discussion, identifies a maximum isolation time of five (5) seconds. This is a typographical error. Technical Specification maximum isolation time for the Containment Purge Exhaust and Supply valves is not being modified by References 1 or 2.

Containment Purge Supply and Exhaust valves CEP-V-1A & -2A, CSP-V-3 & -4 have been designed, procured, purchased, and qualified to meet the 4 second maximum isolation time.

020034

9405020370 940425  
PDR ADCK 05000397  
P PDR

ADD 1/0




Page Two

**REQUEST FOR AMENDMENT TO TECHNICAL SPECIFICATION 3/4.6.1.8,  
DRYWELL AND SUPPRESSION CHAMBER PURGE SYSTEM -  
SUPPLEMENTAL INFORMATION**

The design and procurement specifications define functional and performance requirements including valve closure, from the full open position, against the design pressure of 45 psig within 4 seconds. The purchase order specifies that butterfly valves are to be furnished in strict accordance to the Supply System procurement specification. The valves and pneumatic operators have been seismically and environmentally qualified to meet the intended safety function when subjected to applicable dynamic and design basis accident profile conditions. Upon receipt at WNP-2, the Supply System receipt inspection will ensure that the valves and pneumatic operators have been submitted in accordance with the purchase order. The assembly will also be functionally tested following installation.

Should you have any questions or desire additional information regarding this matter, please call me or Herbert E. Kook at (509) 377-4278.

Sincerely,



J. V. Parrish (Mail Drop 1023)  
Assistant Managing Director, Operations

JVP/LCF/bk

cc: LJ Callan - NRC RIV  
KE Perkins, Jr. - NRC RIV, Walnut Creek Field Office  
NS Reynolds - Winston & Strawn  
JW Clifford - NRC  
DL Williams - BPA/399  
NRC Sr. Resident Inspector - 927N

