

June 2, 1990

Docket No. 50-397

Mr. J. V. Parrish (Mail Drop 1023)
Assistant Managing Director, Operations
Washington Public Power Supply System
P. O. Box 968
Richland, Washington 99352-0958

Dear Mr. Parrish:

SUBJECT: CLOSEOUT OF GENERIC LETTER 89-19, "REQUEST FOR ACTION RELATED TO RESOLUTION OF UNRESOLVED SAFETY ISSUE A-47 'SAFETY IMPLICATION OF CONTROL SYSTEMS IN LWR NUCLEAR POWER PLANTS' PURSUANT TO 10 CFR 50.54(f)," FOR WNP-2 (TAC NO. M75019)

Enclosed is the NRC Safety Evaluation (SE) addressing the BWR Owners' Group (BWROG) response, dated April 2, 1990, to the above subject. Based on the staff's review of the response and the cost/safety benefit analysis, the staff has concluded that upgrading the existing automatic overfill protection systems to achieve additional separation is not warranted. Your letter, dated March 19, 1990 (G02-90-057), stated that you had reviewed your design against the Generic Letter (GL) and determined that your design was acceptable.

Furthermore, your letter provided a discussion of your review of procedures and training in response to the Generic Letter (GL) for your facility. Your plant-specific response confirms that your plant provides a satisfactory design for the overfill protection and also has the Technical Specifications, procedures, and training addressing all the GL recommendations. Your confirmation provides an adequate basis to consider NRR's review of your response complete. Further NRC review, if any, will be performed by inspection or audit.

If you have any questions concerning this matter, please contact me at (301) 504-1323.

Sincerely,

Original signed by:

James W. Clifford, Senior Project Manager
Project Directorate IV-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

9406080256 940602
PDR ADDCK 05000397
P PDR

Enclosure:
As stated

cc w/enclosure:
See next page

NRC FILE GENERIC COPY

DISTRIBUTION:

Docket File EAdensam OGC KPerkins, RIV (WCFO)
NRC & Local PDRs TQuay ACRS (10)
PDIV-3 R/F DFoster-Curseen SRhow
JRoe JClifford KJabbour


OFC	LA:PDIV-3 <i>J-C</i>	PM:PDIV-3	BC:NICB:DRCH	D:PDIV-3
NAME	DFoster-Curseen	JClifford	JWentzel	TQuay <i>TQ</i>
DATE	5/24/94	5/24/94	5/26/94	6/2/94

OFFICIAL RECORD COPY/FILENAME: A:\WNP75019.SER

000033

AA3

DF01



June 2, 1990

Docket No. 50-397

Mr. J. V. Parrish (Mail Drop 1023)
Assistant Managing Director, Operations
Washington Public Power Supply System
P. O. Box 968
Richland, Washington 99352-0958

Dear Mr. Parrish:

SUBJECT: CLOSEOUT OF GENERIC LETTER 89-19, "REQUEST FOR ACTION RELATED TO RESOLUTION OF UNRESOLVED SAFETY ISSUE A-47 'SAFETY IMPLICATION OF CONTROL SYSTEMS IN LWR NUCLEAR POWER PLANTS' PURSUANT TO 10 CFR 50.54(f)," FOR WNP-2 (TAC NO. M75019)

Enclosed is the NRC Safety Evaluation (SE) addressing the BWR Owners' Group (BWROG) response, dated April 2, 1990, to the above subject. Based on the staff's review of the response and the cost/safety benefit analysis, the staff has concluded that upgrading the existing automatic overfill protection systems to achieve additional separation is not warranted. Your letter, dated March 19, 1990 (G02-90-057), stated that you had reviewed your design against the Generic Letter (GL) and determined that your design was acceptable.

Furthermore, your letter provided a discussion of your review of procedures and training in response to the Generic Letter (GL) for your facility. Your plant-specific response confirms that your plant provides a satisfactory design for the overfill protection and also has the Technical Specifications, procedures, and training addressing all the GL recommendations. Your confirmation provides an adequate basis to consider NRR's review of your response complete. Further NRC review, if any, will be performed by inspection or audit.

If you have any questions concerning this matter, please contact me at (301) 504-1323.

Sincerely,

James W. Clifford, Senior Project Manager
Project Directorate IV-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation


Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION:

Docket File	EAdensam	OGC	KPerkins, RIV (WCFO)
NRC & Local PDRs	TQuay	ACRS (10)	
PDIV-3 R/F	DFoster-Curseen	SRhow	
JRoe	JClifford	KJabbour	

OFC	LA:PDIV-3 <i>D-C</i>	PM:PDIV-3	BC:NICB:DRCH	D:PDIV-3
NAME	DFoster-Curseen	JClifford	JWentzel	TQuay <i>TQ</i>
DATE	5/24/94	5/24/94	5/26/94	6/2/94





UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 2, 1994

Docket No. 50-397

Mr. J. V. Parrish (Mail Drop 1023)
Assistant Managing Director, Operations
Washington Public Power Supply System
P. O. Box 968
Richland, Washington 99352-0958

Dear Mr. Parrish:

SUBJECT: CLOSEOUT OF GENERIC LETTER 89-19, "REQUEST FOR ACTION RELATED TO RESOLUTION OF UNRESOLVED SAFETY ISSUE A-47 'SAFETY IMPLICATION OF CONTROL SYSTEMS IN LWR NUCLEAR POWER PLANTS' PURSUANT TO 10 CFR 50.54(f)," FOR WNP-2 (TAC NO. M75019)

Enclosed is the NRC Safety Evaluation (SE) addressing the BWR Owners' Group (BWROG) response, dated April 2, 1990, to the above subject. Based on the staff's review of the response and the cost/safety benefit analysis, the staff has concluded that upgrading the existing automatic overfill protection systems to achieve additional separation is not warranted. Your letter, dated March 19, 1990 (G02-90-057), stated that you had reviewed your design against the Generic Letter (GL) and determined that your design was acceptable.

Furthermore, your letter provided a discussion of your review of procedures and training in response to the Generic Letter (GL) for your facility. Your plant-specific response confirms that your plant provides a satisfactory design for the overfill protection and also has the Technical Specifications, procedures, and training addressing all the GL recommendations. Your confirmation provides an adequate basis to consider NRR's review of your response complete. Further NRC review, if any, will be performed by inspection or audit.

If you have any questions concerning this matter, please contact me at (301) 504-1323.

Sincerely,

A handwritten signature in cursive script that reads "James W. Clifford".

James W. Clifford, Senior Project Manager
Project Directorate IV-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page



7
10
7

Mr. J. V. Parrish
Washington Public Power Supply System

WPPSS Nuclear Project No. 2
(WNP-2)

cc:

Mr. J. H. Swales
WNP-2 Plant Manager
Washington Public Power Supply System
P. O. Box 968
Richland, Washington 99352-0968

Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
Harris Tower & Pavilion
611 Ryan Plaza Drive, Suite 400
Arlington, Texas 76011-8064

G. E. C. Doupe, Esq. (Mail Drop 396)
Washington Public Power Supply System
3000 George Washington Way
Richland, Washington 99352-0968

Chairman
Benton County Board of Commissioners
P. O. Box 69
Prosser, Washington 99350-0190

Mr. Warren Bishop, Chairman
Energy Facility Site Evaluation Council
P. O. Box 43172
Olympia, Washington 98504-3172

Mr. R. C. Barr
U. S. Nuclear Regulatory Commission
P. O. Box 69
Richland, Washington 99352-0968

Mr. H. K. Kook (Mail Drop PE20)
WNP-2 Licensing Manager
Washington Public Power Supply System
P. O. Box 968
Richland, Washington 99352-0968

M. H. Philips, Jr., Esq.
Winston & Strawn
1400 L Street, NW.
Washington, DC 20005-3502

Mr. Paul R. Bemis (Mail Drop PE20)
Regulatory Programs Manager
Washington Public Power Supply System
P. O. Box 968
Richland, Washington 99352-0968

