

Table 3.3.7.5-1 (Continued)

ACCIDENT MONITORING INSTRUMENTATION

ACTION STATEMENTS

ACTION 80 -

- a. With the number of OPERABLE accident monitoring instrumentation channels less than the Required Number of Channels shown in Table 3.3.7.5-1, restore the inoperable channel(s) to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours.
- b. With the number of OPERABLE accident monitoring instrumentation channels less than the Minimum Channels OPERABLE requirements of Table 3.3.7.5-1, restore the inoperable channel(s) to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 12 hours.

ACTION 81 - With the number of OPERABLE accident monitoring instrumentation channels less than required by the Minimum Channels OPERABLE requirement, either restore the inoperable channel(s) to OPERABLE status within 72 hours, or:

- a. Initiate the preplanned alternate method of monitoring the appropriate parameter(s), and
- b. In lieu of any other report required by Specification 6.9.1, prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 14 days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status.

ACTION 82 - With the number of OPERABLE Safety/Relief Valve Position Indicator instrumentation channels less than the Minimum Channels OPERABLE requirement of Table 3.3.7.5-1,

- a. Restore an inoperable channel to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours, and
- b. Verify operability and perform daily surveillance of the Tailpipe Temperature Monitoring instrument for the affected SRV until the Minimum Channels OPERABLE requirement is satisfied. Absent an OPERABLE Tailpipe Temperature monitor for the affected SRV restore the inoperable Tailpipe Temperature Monitor to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 12 hours.

9407280161 940721
PDR ADDCK 05000397
P PDR

TABLE 4.3.7.5-1

ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>
1. Reactor Vessel Pressure	M	R	1,2
2. Reactor Vessel Water Level	M	R	1,2
3. Suppression Chamber Water Level	M	R	1,2
4. Suppression Chamber Water Temperature	M	R	1,2
5. Suppression Chamber Air Temperature	M	R	1,2
6. Primary Containment Pressure	M	R	1,2
7. Drywell Air Temperature	M	R	1,2
8. Drywell Oxygen Concentration	M	R	1,2
9. Drywell Hydrogen Concentration	M	Q	1,2
10. Safety/Relief Valve Position Indicators*	M	R [#]	1,2
11. Suppression Chamber Pressure	M	R	1,2
12. Condensate Storage Tank Level	M	R	1,2
13. Main Steam Line Isolation Valve Leakage Control System Pressure	M	R	1,2
14. Neutron Flux:			
APRM	M	R	1,2
IRM	M	R	1,2
SRM	M	R	1,2
15. RCIC Flow	M	R	1,2
16. HPCS Flow	M	R	1,2
17. LPCS Flow	M	R	1,2

*This includes acoustic monitor, valve stem position, and tailpipe temperature instrument channels.

[#]The provisions of Specification 4.0.4 are not applicable provided the surveillance is performed within 12 hours after reactor steam pressure and flow are adequate to perform the test.

WASHINGTON NUCLEAR - UNIT 2

3/4 3-74

Amendment No. 78, 105, 128
 REVISED BY NRC LETTER DATED: 7/21/94