

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>VALVE GROUP(a)</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>
a. <u>Automatic Isolation Valves (Continued)</u>		
Reactor Closed Cooling	4	60
RCC-V-5		
RCC-V-21		
RCC-V-40		
RCC-V-104		
Radiation Monitoring Supply & Return	4	5
PI-VX-250		
PI-VX-251		
PI-VX-253		
PI-VX-256		
PI-VX-257		
PI-VX-259		
Residual Heat Removal		
RHR-V-123A, B(g)	5	15
RHR-V-8(g) (k)	6	40
RHR-V-9(g)	6	40
RHR-V-23(g)	6	90
RHR-V-53A, B(g)	6	40
RHR-V-24A, B(c)	10	270
RHR-V-21	10	270
RHR-V-27A, B(c)	10	36
Reactor Water Cleanup System	7	
RWCU-V-1(d)		30(j)
RWCU-V-4		21(j)

WASHINGTON NUCLEAR - UNIT 2

3/4 6-23

Amendment No. 58

9409230052 940914
PDR ADDCK 05000397
PDR

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>VALVE GROUP(a)</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>
a. <u>Automatic Isolation Valves (Continued)</u>		
Reactor Core Isolation Cooling		
RCIC-V-8	8	26
RCIC-V-63	8	16
RCIC-V-76	8	22
Low Pressure Core Spray		
LPCS-V-12	10	180
High Pressure Core Spray		
HPCS-V-23	11	180
b. <u>Excess Flow Check Valves(e)</u>		
Containment Atmosphere		
PI-EFC-X29b		N.A.
PI-EFC-X29f		
PI-EFC-X30a		
PI-EFC-X30f		
PI-EFC-X42c		
PI-EFC-X42f		
PI-EFC-X61c		
PI-EFC-X62b		
PI-EFC-X69f		
PI-EFC-X78a		

WASHINGTON NUCLEAR - UNIT 2

3/4 6-24

Amendment No. 25, 25, 125, 127

Corrected by NRC ltr. dtd. Sept. 14, 1994

TABLE 3.6.3-1 (Continued)
PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>VALVE GROUP(a)</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>
a. <u>Automatic Isolation Valves (Continued)</u>		
Reactor Core Isolation Cooling		
RCIC-V-8	8	26
RCIC-V-63	8	16
RCIC-V-76	8	22
Low Pressure Core Spray		
LPCS-V-12	10	180
High Pressure Core Spray		
HPCS-V-23	11	180
b. <u>Excess Flow Check Valves(e)</u>		
Containment Atmosphere		
PI-EFC-X29b		N.A.
PI-EFC-X29f		
PI-EFC-X30a		
PI-EFC-X30f		
PI-EFC-X42c		
PI-EFC-X42f		
PI-EFC-X61c		
PI-EFC-X62b		
PI-EFC-X69f		
PI-EFC-X78a		

WASHINGTON NUCLEAR - UNIT 2

3/4 6-24

Amendment No. 26, 25, 127
Corrected by NRC ltr. dtd. Sept. 14, 1994

