

PRIORITY 1

ACCELERATED RIDS PROCESSING

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9410200083 DOC.DATE: 94/10/12 NOTARIZED: NO DOCKET #
FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
AUTH.NAME AUTHOR AFFILIATION
PARRISH, J.V. Washington Public Power Supply System
RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards corrections to proposed Bases 3/4.2.6, "Power/Flow Instability," correcting error identified in proposed statement for Bases 3/4.2.6 to reflect that power/flow map, Region C not discussed in context w/Figure 3.2.6-1.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+2
TITLE: OR Submittal: General Distribution

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
| | PD4-2 LA CLIFFORD, J | 1 1 1 1 | PD4-2 PD | 1 1 |
| INTERNAL: | ACRS | 6 6 | FILE CENTER 01 | 1 1 |
| | NRR/DE/EELB | 1 1 | NRR/DRCH/HICB | 1 1 |
| | NRR/DRPW | 1 1 | NRR/DSSA/SPLB | 1 1 |
| | NRR/DSSA/SRXB | 1 1 | NUDOCS-ABSTRACT | 1 1 |
| | OGC/HDS3 | 1 0 | | |
| EXTERNAL: | NOAC | 1 1 | NRC PDR | 1 1 |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 18

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

October 12, 1994
GO2-94-234

Docket No. 50-397

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: **WNP-2, OPERATING LICENSE NPF-21
REQUEST FOR AMENDMENT TO THE FACILITY OPERATING
LICENSE AND TECHNICAL SPECIFICATIONS TO INCREASE
LICENSED POWER LEVEL FROM 3323 MWt TO 3486 MWt WITH
EXTENDED LOAD LINE LIMIT AND A CHANGE IN SAFETY RELIEF
VALVE SETPOINT TOLERANCE, SUPPLEMENTARY INFORMATION**

Reference: Letter GO2-94-221, dated September 26, 1994, JV Parrish (SS) to NRC,
same subject

The reference provided supplementary information to support an increase in licensed power level. Included with the reference were proposed changes to the WNP-2 Technical Specifications and Bases. An error has been identified in the proposed statement for Bases 3/4.2.6, "Power/Flow Instability." Attachment 1 indicates the corrections to the proposed Bases 3/4.2.6. Attachment 2 is a replacement page for proposed Bases 3/4.2.6.

A part of this Bases discusses how the power/flow map is divided into several regions of varying concern (Regions A, B and C) as recommended by the General Electric Service Information Letter (SIL) 380. Both regions A and C were discussed in the 3/4.2.6 Bases provided by the reference. The discussion of how Region C was determined is correct but should not have been discussed in context with Figure 3.2.6-1 because this figure is for Region A only. The attached replacement page for Bases 3/4.2.6 corrects this error.

9410200083 941012
PDR ADDCK 05000397
P PDR

A001
1/1

THE UNIVERSITY OF CHICAGO
DIVISION OF THE PHYSICAL SCIENCES
DEPARTMENT OF PHYSICS
530 SOUTH EAST ASIAN AVENUE
CHICAGO, ILLINOIS 60607

Page 2

**REQUEST FOR AMENDMENT TO TECHNICAL SPECIFICATIONS TO INCREASE
POWER LEVEL FROM 3323 MWt TO 3486 MWt, SUPPLEMENTARY INFORMATION**

This is an editorial correction to the proposed 3/4.2.6 Bases and does not affect the conclusions provided in the reference with respect to the no significant hazards determination or the categorical exclusion for an environmental assessment provided by the reference. The State of Washington has been provided a copy of this letter.

Should you have any questions or desire additional information regarding this matter, please call me or Mr. D.A. Swank, Licensing Manager, at (509) 377-4563.

Sincerely,



J. V. Parrish (Mail Drop 1023)
Assistant Managing Director, Operations

PLP/ml
Attachments

cc: LJ Callan - NRC RIV
KE Perkins, Jr. - NRC RIV, Walnut Creek Field Office
NS Reynolds - Winston & Strawn
JW Clifford - NRC
DL Williams - BPA/399
NRC Sr. Resident Inspector - 927N

THE UNITED STATES OF AMERICA
DEPARTMENT OF JUSTICE
FEDERAL BUREAU OF INVESTIGATION

MEMORANDUM FOR THE DIRECTOR

RE: [Illegible]

[Illegible]