

PRIORITY 1
(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9503310155 DOC.DATE: 95/03/24 NOTARIZED: YES DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH.NAME AUTHOR AFFILIATION
 PARRISH, J.V. Washington Public Power Supply System
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Addresses follow-up RAI re GL 92-08, "Thermo-Lag Fire Barriers," as detailed in NRC 941229 ltr.

DISTRIBUTION CODE: A029D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 3
 TITLE: Generic Letter 92-008 Thermal-Lag 330 Fire Barrier

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD4-2 LA		1	0		PD4-2 PD		1	1
	CLIFFORD, J		1	1					
INTERNAL:	FILE CENTER-01		1	1		NRR/DE/EELB		1	1
	NRR/DRPW/PD3-1		1	1		NRR/DSSA/SPLB		2	2
	RGN4 FILE		1	1					
EXTERNAL:	NOAC		1	1		NRC PDR		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 11 ENCL ~~10~~ 9

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



.

.

.

.

.

.

.

.

.

.....

.

.

.

.

.

.

.

.

.

.....

.....

.

.

.

.

.

.

.



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

March 24, 1995
GO2-95-057

Docket No. 50-397

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: **WNP-2, OPERATING LICENSE NPF-21
RESPONSE TO FOLLOW-UP REQUEST FOR ADDITIONAL
INFORMATION REGARDING GENERIC LETTER 92-08 "THERMO-LAG
330-1 FIRE BARRIERS"**

- References:
- 1) Letter GI2-95-002 dated December 29, 1994, RP Zimmerman (NRC) to JV Parrish (SS); "Follow-up To The Request For Additional Information Regarding Generic Letter 92-08, Thermo-Lag 330-1 Fire Barriers, Issued Pursuant to 10 CFR 50.54(f) For the Washington Public Power Supply System (Supply System), Nuclear Project No. 2 (WNP-2) (TAC No. M85624)"
 - 2) Letter GO2-94-254 dated November 9, 1994, JV Parrish to USNRC, "10 CFR 50.54(f) Response To Follow-up Request For Additional Information Regarding Generic letter 92-08, Thermo-lag 330-1 Fire Barriers"

This letter addresses the follow-up request for additional information regarding Thermo-Lag fire barriers, as detailed in Reference 1.

As indicated in Reference 2, we have been reevaluating plant design in light of the problems involved in using Thermo-Lag 330-1 to protect equipment used to reach a safe shutdown condition in event of a fire. A mixture of approaches have been considered including minimization of systems and components needed to achieve safe shutdown, circuit re-routing, additional fire suppression, and use of alternative fire barrier materials. While our process is not complete as yet, we have determined that in all likelihood we can adequately protect safe shutdown capability without continued reliance on Thermo-Lag 330-1. A summary of the results

310060

9503310155 950324
PDR ADOCK 05000397
P PDR

A029
110

100-100000

100-100000

100-100000

100-100000

100-100000



Page.2

**RESPONSE TO FOLLOW-UP REQUEST FOR ADDITIONAL INFORMATION
REGARDING GENERIC LETTER 92-08 "THERMO-LAG 330-1 FIRE BARRIERS"**

of our reevaluation will be presented by May 1, 1995, as discussed informally with staff at the March 14 public meeting concerning interpretation of the 10 CFR 50.54(f) requests for information about use of Thermo-Lag. The requested schedule will be included in the May 1, 1995, submittal.

As a result of our decision, we have discontinued efforts to qualify Thermo-Lag 330-1 installations intended to protect safe shutdown capability. From this perspective, we have not included any of the information requested by Reference 1, because our resources are focused on finalization of the reevaluation process. Should future developments require reconsideration of decision to forgo use of Thermo-Lag 330-1 to protect safe shutdown capability, we will advise staff promptly, and provide the requested information within 90 days of that notification.

Should you have any questions or desire additional information regarding this matter, please call me or D.A. Swank at (509) 377-4563.

Sincerely,



J.V. Parrish (Mail Drop 1023)
Vice-President, Nuclear Operations

CJF/ml

cc: LJ Callan - NRC RIV
KE Perkins, Jr. - NRC RIV, Walnut Creek Field Office
NS Reynolds - Winston & Strawn
JW Clifford - NRC
DL Williams - BPA/399
NRC Sr. Resident Inspector - 927N
INPO Records Center, Atlanta Georgia

1971-1972
1970-1971
1969-1970

()
()

1970-1971


1970-1971

STATE OF WASHINGTON)
)
COUNTY OF BENTON)

Subject: Response to Follow-up Request for
Additional Information Regarding
Generic Letter 92-08, "Thermo-Lag
330-1 Fire Barriers"

I, J. V. PARRISH, being duly sworn, subscribe to and say that I am the Vice-President, Nuclear Operations for the WASHINGTON PUBLIC POWER SUPPLY SYSTEM, the applicant herein; that I have the full authority to execute this oath; that I have reviewed the foregoing; and that to the best of my knowledge, information, and belief the statements made in it are true.

DATE 24 March, 1995




J. V. Parrish, Vice-President
Nuclear Operations

On this date personally appeared before me J. V. PARRISH, to me known to be the individual who executed the foregoing instrument, and acknowledged that he signed the same as his free act and deed for the uses and purposes herein mentioned.

GIVEN under my hand and seal this 24th day of March 1995.





Notary Public in and for the
STATE OF WASHINGTON

Residing at Kennewick, WA

My Commission Expires 8/9/95



11
12
13
14
15

