



GE Nuclear Energy

EXAMINATION SUMMARY SHEET

REPORT NO.:
R-R11-019PROJECT: WNP2 - RFO11
1FR9ZPROCEDURE: UT-WNP2-208V0 REV: 0 FRR: N/A
N/A
N/A

SYSTEM: RECIRCULATION

UT-WNP2-207V0 REV: 0 FRR: N/A
N/A
N/A

WELD NO.: 20RRC(6)-8

N/A REV: N/A FRR: N/A
N/A
N/A

CONFIGURATION: PIPE TO VALVE

EXAMINER: R. PASZKOWSKI LEVEL: II

 MT PT UT VT

EXAMINER: C. VAN HECKE LEVEL: II

 CIRCUMFERENTIAL

EXAMINER: N/A LEVEL: N/A

 LONGITUDINAL OTHER N/ADATA SHEET NO.(S): DA-R11-001
DA-R11-002CAL SHEET NO.(S): CA-R11-001
CA-R11-002
CA-R11-003

During the ultrasonic examination of the above referenced weld, one (1) reportable ID connected planar indication was recorded with the "Smart 2000" system utilizing a 45° shear wave and 60° refracted longitudinal wave search units. This weld was examined for purposes of indication monitoring only. The indication has the following parameters:

Ind. No.	Distance from Zero Reference	Total Length	Thru Wall Dimension	Remaining Ligament	Side of Weld	Type of Reflector	Search Unit
* 1.	-1.00"	3.60"	18.7%	.80"	UPST	CIRC	45°S / 60°RL

* The reflector face appears to be smooth and non-faceted without the presence of axial components, which is not typical of IGSCC type indications. This indication straddles "Lo" reference and starts at approximately 1.0" counterclockwise from top dead center.

Supplemental relooks and thru-wall depth sizing were performed with the "Smart 2000" system utilizing the 60° RL search unit. The thru-wall depth of this reflector was determined by the high angle absolute arrival time tip diffraction method. The length of this indication was determined by measurements taken from the "Smart 2000" 60° RL data with allowances for beam spread. This indication was sized per NUREG 0313 requirements which are more stringent than ASME Section XI. This indication has not exhibited any noticeable thru-wall propagation or length since it was sized during the R10 ISI outage in 1995, or previous outages.

The 45° shear also recorded non-relevant indications and beam redirect, along with the above referenced indication, from the upstream side of the weld.

The 60° RL also recorded inside surface geometry, along with the above referenced indication, from the upstream side of the weld.

No examination was performed downstream due to the valve configuration.

Previous data was reviewed prior to this summary.

<input checked="" type="checkbox"/> EXAM COMPLETE	<input type="checkbox"/> PARTIALLY EXAMINED (EXPLAIN IN COMMENTS)	<input type="checkbox"/> EXAM COMPLETE IN COMBINATION WITH DATA SHEETS BELOW	CODE COVERAGE OBTAINED: N/A %
ADDITIONAL DATA SHEETS: N/A	COMARED TO: <input type="checkbox"/> PSI <input checked="" type="checkbox"/> ISI REPORT NO.(S): R-R10-001	NO. OF RECORDABLE INDICATIONS: 1	
EXAMINATION RESULTS: <input type="checkbox"/> ACCEPTABLE	<input checked="" type="checkbox"/> UNACCEPTABLE	NO. OF REPORTABLE INDICATIONS: 1	
SUMMARY BY: <i>[Signature]</i>	LEVEL: III DATE: 4/24/96	UTILITY REVIEW: <i>[Signature]</i>	DATE: 4-25-96
GE REVIEWED BY: <i>[Signature]</i>	LEVEL: III DATE: 4-25-96	ANII REVIEW: <i>[Signature]</i>	DATE: 4/26/96
PAGE: 1 OF: 11			

9605210397 960514
PDR ADDOCK 05000397
PDR

FORM UT-05 REV.9



GE Nuclear Energy

WALL THICKNESS
PROFILE SHEET

SITE: WNP UNIT: 2

REPORT NO.:

PROJECT: 1ER9Z - REQ11

R-B11-019

SYSTEM: RECIRCULATION

COMPONENT ID NO.: 20BRC(6)-8


POSITION	0°	90°	180°	270°
1	1.00"	N/A	N/A	N/A
2	.98"	N/A	N/A	N/A
3	1.13"	N/A	N/A	N/A
4	N/A	N/A	N/A	N/A
5	2.06"	N/A	N/A	N/A

CROWN HEIGHT: FLUSH

CROWN WIDTH: 1.20"

NOM DIAMETER: 20.00"

WELD LENGTH: 63.00"



FLOW

60° & 45°

45°

60° &

45° SHEAR & 60° PL COVERAGE Plot.

TAKEN FROM 1992 GE DATA

DRAWN BY
D. M. Witter
GE REVIEWED BYLEVEL III DATE 4/25/96
LEVEL DATERon Weller 4-25-96
UTILITY REVIEW DATEH. F. Ernst
ANII REVIEW4/24/96
DATEPAGE: 2 OF: 11
FORM UT-01 REV. 4



GE Nuclear Energy

INDICATION PLOT SHEET

SITE: WNP UNIT: 2

REPORT NO.:

PROJECT: 1FR9Z - RFQ11


R-R11-019

SYSTEM: RECIRCULATION

COMPONENT ID NO.: 20RRC(6)-8

CONFIGURATION: PIPE

FLOW VALVE



Original Master


DRAWN BY <i>Adam Smith</i>	LEVEL III DATE 4/25/96
GE REVIEWED BY <i>Adam Smith</i>	LEVEL III DATE 4-24-96

Copy Master

UTILITY REVIEW <i>Copy Master</i>	DATE 4-25-96
--------------------------------------	--------------

Master Copy


ANII REVIEW <i>Master Copy</i>	DATE 4/26/96
PAGE: 3 OF: 11	FORM UT-02 REV. 5






GE Nuclear Energy

ULTRASONIC SCAN DATA PRINT SHEET (AUTOMATED WITH Smart 2000)



Non-Geometric Indication (Planar Indication #1)

SITE: WNP UNIT: 2 PROJECT NO.: 1ER9Z REPORT NO.: R-R11-019
WELD NO.: 20RRC(6)-8 SEARCH UNIT: 45° / SHR INDICATION NO.: 1 PAGE: 4 OF: 11





GE Nuclear Energy

INDICATION PLOT SHEET

SITE: WNP UNIT: 2

REPORT NO.:

PROJECT: 1ER9Z - REQ11

R-R11-019

SYSTEM: RECIRCULATION

COMPONENT ID NO.: 20RRC(6)-8

CONFIGURATION: PIPE

FLOW

VALVE

FLOW

(2) (3)

G


60° RL

- (2) — NON-GEOMETRIC INDICATION (PLANAR INDICATION #1 - BASE REFLECTOR)
(3) — NON-GEOMETRIC INDICATION (PLANAR INDICATION #1 - TIP REFLECTOR)

DRAWN BY
David White
LEVEL III
DATE 4/25/96
GE REVIEWED BY
LEVEL III
DATE 4/25/96
UTILITY REVIEW
DATE 4-25-96
ANII REVIEW
DATE 11/11/96
PAGE: 5 OF: 11
DATE 11/11/96
FORMAT 02 REV. S



GE Nuclear Energy

ULTRASONIC SCAN DATA PRINT SHEET
(AUTOMATED WITH Smart 2000)


Non-Geometric Indication (Planar Indication #1 Base Reflector)

SITE: WNP UNIT: 2 PROJECT NO.: 1FR9Z REPORT NO.: R-R11-019
WELD NO.: 20RRC(6)-8 SEARCH UNIT: 60° / RL INDICATION NO.: 2 PAGE: 6 OF: 11



GE Nuclear Energy

ULTRASONIC SCAN DATA PRINT SHEET (AUTOMATED WITH Smart 2000)



Non-Geometric Indication (Planar Indication #1 Tip Reflector)

SITE: WNP UNIT: 2 PROJECT NO.: 1ER9Z REPORT NO.: R-R11-019
WELD NO.: 20RRC(6)-8 SEARCH UNIT: 60° / RL INDICATION NO.: 3 PAGE: 7 OF: 11



GE Nuclear Energy

ULTRASONIC EXAMINATION DATA SHEET (AUTOMATED WITH Smart 2000)

SITE: WNP,	PROCEDURE NO.: UT-WNP2-208V0	REPORT NO.: R-R11-019
UNIT: 2	REVISION NO.: 0	DATA SHEET NO.: DA-R11-001
PROJECT NO.: 1FR9Z - RFO11	FRR NO.: N/A	CALIBRATION SHEET NO.: CA-R11-001
SYSTEM: RECIRCULATION EXAM SURFACE TEMP: 90 °E COPLANT: ULTRAGEL II EXAM START: 14:50		
WELD ID: 20RRC(6)-8 THERMOMETER S/N: 145989 BATCH NO.: 094041 EXAM END: 21:50		
SEARCH UNIT: 45° / SHR EXAMINATION SURFACE: OD COMPONENT: PIPE FLOW VALVE		
SCAN: A11	SCAN DIRECTION: AXUP GAIN(dB): 32.0	SCAN: A12
DISK/SIDE: D-01/A	FILENAME(S): RRC68A11 N/A	DISK/SIDE: D-01/A
EXAMINATION RESULTS:		
<input type="checkbox"/> NO RECORDED INDICATIONS <input type="checkbox"/> ACOUSTIC INTERFACE <input type="checkbox"/> ROOT GEOMETRY <input type="checkbox"/> INSIDE SURFACE GEOMETRY <input type="checkbox"/> COUNTERBORE GEOMETRY <input checked="" type="checkbox"/> NON-GEOMETRIC INDICATIONS <input checked="" type="checkbox"/> NON-RELEVANT INDICATIONS <input type="checkbox"/> OTHER: BEAM REDIRECT		
COMMENTS: Scan performed at gain level below recommended scanning sensitivity in order to maintain a 10-30% average ID noise level.		
SCAN: A50	SCAN DIRECTION: CWUP GAIN(dB): 32.0	SCAN: A51
DISK/SIDE: D-01/A	FILENAME(S): RRC68A50 N/A	DISK/SIDE: D-01/A
EXAMINATION RESULTS:		
<input type="checkbox"/> NO RECORDED INDICATIONS <input type="checkbox"/> ACOUSTIC INTERFACE <input type="checkbox"/> ROOT GEOMETRY <input type="checkbox"/> INSIDE SURFACE GEOMETRY <input type="checkbox"/> COUNTERBORE GEOMETRY <input type="checkbox"/> NON-GEOMETRIC INDICATIONS <input checked="" type="checkbox"/> NON-RELEVANT INDICATIONS <input type="checkbox"/> OTHER: N/A		
COMMENTS: Scan performed at gain level below recommended scanning sensitivity in order to maintain a 10-30% average ID noise level.		
SCAN: A70	SCAN DIRECTION: CCUP GAIN(dB): 32.0	SCAN: A71
DISK/SIDE: D-01/A	FILENAME(S): RRC68A70 N/A	DISK/SIDE: D-01/A
EXAMINATION RESULTS:		
<input type="checkbox"/> NO RECORDED INDICATIONS <input type="checkbox"/> ACOUSTIC INTERFACE <input type="checkbox"/> ROOT GEOMETRY <input type="checkbox"/> INSIDE SURFACE GEOMETRY <input type="checkbox"/> COUNTERBORE GEOMETRY <input type="checkbox"/> NON-GEOMETRIC INDICATIONS <input checked="" type="checkbox"/> NON-RELEVANT INDICATIONS <input type="checkbox"/> OTHER: N/A		
COMMENTS: Scan performed at gain level below recommended scanning sensitivity in order to maintain a 10-30% average ID noise level.		
REMARKS: No examination was performed downstream due to the valve configuration. Examination performed for purposes of indication monitoring only.		
EXAMINER: LEVEL III DATE 4-22-96 GE REVIEWED BY LEVEL III DATE 4-25-96		UTILITY REVIEW ANII REVIEW DATE 4-25-96 DATE 4-25-96
		PAGE: 8 OF: 11 FORM UT-07 REV. 6




GE Nuclear Energy

ULTRASONIC EXAMINATION DATA SHEET

(AUTOMATED WITH Smart 2000)

SITE: WNP	PROCEDURE NO.: UT-WNP2-207V0/208V0	REPORT NO.: R-R11-019		
UNIT: 2	REVISION NO.: 0	DATA SHEET NO.: DA-R11-002		
PROJECT NO.: 1FR9Z - RFO11	FRR NO.: N/A	CALIBRATION SHEET NO.: CA-R11-002_003		
SYSTEM: RECIRCULATION EXAM SURFACE TEMP: 90 °F COPLANT: ULTRAGEL II EXAM START: 23:45				
WELD ID: 20RRC(6)-8 THERMOMETER S/N: 145989 BATCH NO.: 094041 EXAM END: 02:27				
SEARCH UNIT: 60° / RL EXAMINATION SURFACE: OD COMPONENT: PIPE FLOW VALVE				
SCAN: C10	SCAN DIRECTION: LKDN GAIN(dB): 42.0	SCAN: C11	SCAN DIRECTION: LKDN GAIN(dB): 36.0	
DISK/SIDE: D-01/A	FILENAME(S): RRC68C10 N/A	DISK/SIDE: D-01/A	FILENAME(S): RRC68C11 N/A	
EXAMINATION RESULTS:				
<input type="checkbox"/> NO RECORDED INDICATIONS <input type="checkbox"/> ROOT GEOMETRY <input checked="" type="checkbox"/> COUNTERBORE GEOMETRY <input checked="" type="checkbox"/> NON-RELEVANT INDICATIONS		<input type="checkbox"/> ACOUSTIC INTERFACE <input type="checkbox"/> INSIDE SURFACE GEOMETRY <input checked="" type="checkbox"/> NON-GEOMETRIC INDICATIONS <input type="checkbox"/> OTHER: SHEAR COMPONENT		
COMMENTS: N/A				
SCAN: N/A	SCAN DIRECTION: N/A GAIN(dB): N/A	SCAN: N/A	SCAN DIRECTION: N/A GAIN(dB): N/A	
DISK/SIDE: N/A	FILENAME(S): N/A	DISK/SIDE: N/A	FILENAME(S): N/A	
EXAMINATION RESULTS:				
<input type="checkbox"/> NO RECORDED INDICATIONS <input type="checkbox"/> ROOT GEOMETRY <input type="checkbox"/> COUNTERBORE GEOMETRY <input type="checkbox"/> NON-RELEVANT INDICATIONS		<input type="checkbox"/> ACOUSTIC INTERFACE <input type="checkbox"/> INSIDE SURFACE GEOMETRY <input type="checkbox"/> NON-GEOMETRIC INDICATIONS <input type="checkbox"/> OTHER: N/A		
COMMENTS: N/A				
SCAN: N/A	SCAN DIRECTION: N/A GAIN(dB): N/A	SCAN: N/A	SCAN DIRECTION: N/A GAIN(dB): N/A	
DISK/SIDE: N/A	FILENAME(S): N/A	DISK/SIDE: N/A	FILENAME(S): N/A	
EXAMINATION RESULTS:				
<input type="checkbox"/> NO RECORDED INDICATIONS <input type="checkbox"/> ROOT GEOMETRY <input type="checkbox"/> COUNTERBORE GEOMETRY <input type="checkbox"/> NON-RELEVANT INDICATIONS		<input type="checkbox"/> ACOUSTIC INTERFACE <input type="checkbox"/> INSIDE SURFACE GEOMETRY <input type="checkbox"/> NON-GEOMETRIC INDICATIONS <input type="checkbox"/> OTHER: N/A		
COMMENTS: N/A				
REMARKS: Scans C10 and C11 inadvertently zeroed 50° upstream of weld centerline. No examination was performed downstream due to the valve configuration. Examination performed for purposes of indication monitoring only.				
<i>Robert Pawlak</i> EXAMINER <i>Donald Miller</i> GE REVIEWED BY		II 4-22-96 LEVEL DATE III 4/25/96 LEVEL DATE	<i>Karen Miller</i> UTILITY REVIEW <i>J. E. T. D.</i> ANII REVIEW	II 4-25-96 DATE III 4/27/96 DATE
PAGE: 9 OF: 11 FORM UT-07 REV. 6				





GE Nuclear Energy

ULTRASONIC SCAN PARAMETER SHEET

(AUTOMATED WITH Smart 2000)

SITE: WNP	PROCEDURE NO.: UT-WNP2-208V0	REPORT NO.: R-R11-019
UNIT: 2	REVISION NO.: 0	DATA SHEET NO.: DA-R11-001
PROJECT NO.: 1ER9Z - RFO11	FRR NO.: N/A	CALIBRATION SHEET NO.: CA-R11-001

SYSTEM: RECIRCULATION WELD ID: 20RRC(6)-8 MOTOR STEPS: CIR: 485.01/in TRA: 500.00/in
 WELD REFERENCE, (GE-ADM-1005): Lo: TOP DEAD CENTER Wo: WELD CENTERLINE SEARCH UNIT: 45° / SHR

EXAMINATION SETUP

COMPONENT DIA: 20.0" WELD LENGTH: 63.0" TRACK DIA: 24.0" ARM LENGTH: 12.0" TRACK LOCATION: 9.0" UPST OF WELD CENTERLINE

SCAN PARAMETERS

SCAN: A11	SCAN DIRECTION: AXUP	SKEW: 0°	SCAN: A12	SCAN DIRECTION: AXUP	SKEW: 0±10°
SCANNING "X": INDEXING "Y":			SCANNING "X": INDEXING "Y":		
START: 0°	-4.0°	SCANNER ZERO POSITIONS:	START: 0°	0°	SCANNER ZERO POSITIONS:
SIZE: 3.00"	8.0"		SIZE: 3.00"	63.50"	
OFFSET: 0°	-4.0°	CIR: 4.0" CCW FROM TOP DEAD CENTER	OFFSET: 0°	0°	CIR: TOP DEAD CENTER
RESOLUTION: 0260"	0804"	TRA: WELD CENTERLINE	RESOLUTION: 0247"	1814"	TRA: WELD CENTERLINE
MOTOR DIR: INVERSE	NORMAL	ROT: LOOKING DOWNSTREAM	MOTOR DIR: INVERSE	NORMAL	ROT: LOOKING DOWNSTREAM
SCAN: A50	SCAN DIRECTION: CWUP	SKEW: 50±10°	SCAN: A51	SCAN DIRECTION: CWUP	SKEW: 90°
SCANNING "X": INDEXING "Y":			SCANNING "X": INDEXING "Y":		
START: 0°	0°	SCANNER ZERO POSITIONS:	START: 0°	0°	SCANNER ZERO POSITIONS:
SIZE: 63.50"	2.35"		SIZE: 63.50"	2.35"	
OFFSET: 0°	0°	CIR: TOP DEAD CENTER	OFFSET: 0°	0°	CIR: TOP DEAD CENTER
RESOLUTION: 0350"	1880"	TRA: WELD CENTERLINE	RESOLUTION: 0350"	1880"	TRA: WELD CENTERLINE
MOTOR DIR: NORMAL	INVERSE	ROT: LOOKING DOWNSTREAM	MOTOR DIR: NORMAL	INVERSE	ROT: LOOKING DOWNSTREAM
SCAN: A70	SCAN DIRECTION: CCUP	SKEW: 50±10°	SCAN: A71	SCAN DIRECTION: CCUP	SKEW: 90±10°
SCANNING "X": INDEXING "Y":			SCANNING "X": INDEXING "Y":		
START: 0°	0°	SCANNER ZERO POSITIONS:	START: 0°	0°	SCANNER ZERO POSITIONS:
SIZE: 63.50"	2.35"		SIZE: 64.20"	2.50"	
OFFSET: 0°	0°	CIR: TOP DEAD CENTER	OFFSET: 0°	0°	CIR: TOP DEAD CENTER
RESOLUTION: 0350"	1880"	TRA: WELD CENTERLINE	RESOLUTION: 0350"	1880"	TRA: WELD CENTERLINE
MOTOR DIR: NORMAL	INVERSE	ROT: LOOKING DOWNSTREAM	MOTOR DIR: NORMAL	INVERSE	ROT: LOOKING DOWNSTREAM

REMARKS: No examination was performed downstream due to the valve configuration.
 Examination performed for purposes of indication monitoring only.

<i>Robert Paszakowski</i> EXAMINER <i>Donald Willis</i> GE REVIEWED BY	LEVEL III DATE 4/25/96	<i>John Clark</i> UTILITY REVIEW <i>John Clark</i> ANII REVIEW	DATE 4/25/96 PAGE: 10 OF: 11
---	---------------------------	---	---------------------------------



GE Nuclear Energy

ULTRASONIC SCAN PARAMETER SHEET

(AUTOMATED WITH Smart 2000)

SITE: WNP
UNIT: 2
PROJECT NO.: 1ER9Z - RFO11

PROCEDURE NO.: UT-WNP2-207V0/208V0
REVISION NO.: 0
FRR NO.: N/A

REPORT NO.: R-R11-019
DATA SHEET NO.: DA-R11-002
CALIBRATION SHEET NO.: CA-R11-002, 003

SYSTEM: RECIRCULATION WELD ID: 20RRC(6)-8 MOTOR STEPS: CIR: 485.01/in TRA: 500.00/in
WELD REFERENCE, (GE-ADM-1005): Lo: TOP DEAD CENTER Wo: TOP DEAD CENTER SEARCH UNIT: 60°/RL

EXAMINATION SETUP

COMPONENT DIA: 20.0" WELD LENGTH: 63.0" TRACK DIA: 24.0" ARM LENGTH: 12.0" TRACK LOCATION: 9.0" UPST OF WELD CENTERLINE

SCAN PARAMETERS

SCAN: C10	SCAN DIRECTION: LKDN	SKEW: 0±10°	SCAN: C11	SCAN DIRECTION: LKDN	SKEW: 0°
SCANNING "X": INDEXING "Y" START: 0° 0° SIZE: 3.80" 63.50" OFFSET: 0° 0° CIR: TOP DEAD CENTER RESOLUTION: 0260° 1402° TRA: WELD CENTERLINE MOTOR DIR: INVERSE NORMAL ROT: LOOKING DOWNSTREAM			SCANNING "X": INDEXING "Y" START: 0° -4.00° SIZE: 3.80" 9.00" OFFSET: 0° -4.00° CIR: 4.00° CCW OF TOP DEAD CENTER RESOLUTION: 0200° 1010° TRA: WELD CENTERLINE MOTOR DIR: INVERSE NORMAL ROT: LOOKING DOWNSTREAM		
N/A	SCAN DIRECTION: N/A	SKEW: N/A	N/A	SCAN DIRECTION: N/A	SKEW: N/A
SCANNING "X": INDEXING "Y" START: N/A N/A SIZE: N/A N/A OFFSET: N/A N/A CIR: N/A RESOLUTION: N/A N/A TRA: N/A MOTOR DIR: N/A N/A ROT: N/A			SCANNING "X": INDEXING "Y" START: N/A N/A SIZE: N/A N/A OFFSET: N/A N/A CIR: N/A RESOLUTION: N/A N/A TRA: N/A MOTOR DIR: N/A N/A ROT: N/A		
N/A	SCAN DIRECTION: N/A	SKEW: N/A	N/A	SCAN DIRECTION: N/A	SKEW: N/A
SCANNING "X": INDEXING "Y" START: N/A N/A SIZE: N/A N/A OFFSET: N/A N/A CIR: N/A RESOLUTION: N/A N/A TRA: N/A MOTOR DIR: N/A N/A ROT: N/A			SCANNING "X": INDEXING "Y" START: N/A N/A SIZE: N/A N/A OFFSET: N/A N/A CIR: N/A RESOLUTION: N/A N/A TRA: N/A MOTOR DIR: N/A N/A ROT: N/A		
N/A	SCAN DIRECTION: N/A	SKEW: N/A	N/A	SCAN DIRECTION: N/A	SKEW: N/A

REMARKS: No examination was performed downstream due to the valve configuration.
Examination performed for purposes of indication monitoring only.

Robert Pawlakowski II
EXAMINER
Omega Miller
GE REVIEWED BY

LEVEL
III
LEVEL


DATE
4/25/96
DATE

UTILITY REVIEW
Joe Clark
ANII REVIEW

DATE
4/25/96
DATE

PAGE: 11 OF: 11

FORM UT-08 REV. 6





GE Nuclear Energy

ULTRASONIC CALIBRATION DATA SHEET

(AUTOMATED WITH Smart 2000)

SITE: WNP : UNIT: 2CALIBRATION SHEET NO.: CA-R11-001PROJECT NO.: 1FR9Z - RFO11LINEARITY SHEET NO.: L-005PROCEDURE NO.: UT-WNP2-208V0REVISION: 0FRR: N/AInstrument TECRAD / TOMOSCAN
Manufacturer / ModelTTS10092113
System Serial No.Search Unit KBA
ManufacturerG28247
Serial No..500" 2.25 MHz 45° / SHR .45"
Size Freq. Angle/Mode Incident to wedge frontCable RG-58, RG-58, RG-174
Type250', 25', 3'
Length4 BNC, Micro Dot
No. of ConnectorsCalibration Standard UT-09
Serial No.SS
Material

1.031" Nominal Thickness

1.158" Measured Thickness

76 °F
Temp.Thermometer 145989
Serial No.Couplant ULTRAGEL II
Type094041
Batch No.CALIBRATIONORIENTATION: XT SDH CIRC / AXIALTYPE: 2/8V / 6/8V / 10/8V ID NOTCHESDEPTH: .579" / 1.737" / 2.895" 1.158" / 1.158"AMPLITUDE: 80% / 7% / * 44.9% / 42%SWEEP: .815" / 2.457" / 4.099" 1.654" / 1.778"GAIN: (dB) 24.0 20.0 / 24.0 TIME DEPTH METAL PATH

* 10/8 Nodal position = 20% FSH at 38.0 dB

BASIC SETTINGS1. DELAY: .5803 in2. TIMEBASE: 6.3214 in3. FREQUENCY: (MHz) 5.004. RATE: /S 20.0

5. UNITS:

 DISTANCE HALF PATH TIME6. VELOCITY: 123464 in/s7. SAMPLES: 512PULSER / RECEIVER1. MODE: PULSE ECHO THRU-TRANSMISSION2. PULSER: P1 TO P13. VOLTAGE: (v) 4004. WIDTH: (Ns) 2765. FILTER: NONE 0.5 - 2 MHz 1 - 5 MHz 2 - 10 MHz 5 - 15 MHz6. RECTIFICATION: NONE UNIPOLAR + UNIPOLAR -
 BIPOLAR7. SMOOTHING: NONE FAST MEDIUM SLOW

Circ Notch at 80% = 26.0 dB


Axial Notch at 80% = 30.0 dB

FIELD SIMULATOR: RHOMPAS S/N: CAL-RHOM-038REFLECTOR: NEAR SDH FAR SDHMAX AMPLITUDE: 80% 80%SWEEP: .383" 1.062"GAIN: (dB) 14.0 15.0CALIBRATION VERIFICATION

	TIME	DATE	OPER.	COMP.	REPORT NO
INITIAL	12:30	04/22/96	CVH	20RRC(6)-8	R-R11-019
VERIFIED	19:15	04/22/96	PAZ	20RRC(6)-8	R-R11-019
VERIFIED					
VERIFIED					
VERIFIED					
FINAL	22:05	04/22/96	PAZ	20RRC(6)-8	R-R11-019

Charles J. Valette
EXAMINER
GE REVIEWED BYLEVEL DATE
III 4/25/96
LEVEL DATEUtility Review
Signature
ANII Review
Signature4/25/96
DATE
SignaturePAGE: 1 OF: 1

FORM UT-08 REV. 11





GE Nuclear Energy

ULTRASONIC CALIBRATION DATA SHEET

(AUTOMATED WITH Smart 2000)

SITE: WNP UNIT: 2

CALIBRATION SHEET NO.: CA-R11-002

PROJECT NO.: 1ER9Z - RFO11

LINEARITY SHEET NO.: L-005

PROCEDURE NO.: UT-WNP2-207V0

REVISION: 0

FRR: N/A

Instrument TECRAD / TOMOSCAN
Manufacturer / ModelTTS10092113
System Serial No.Search Unit RTD
Manufacturer94-713
Serial No.2(8x14)mm
Size2.00
Freq.

MHz

60° / RL
Angle/Mode40°
Incident to wedge frontCable 2(RG-58, RG-58, RG-174)
Type2(250', 25', 3')
Length8 BNC, Lemo
No. of ConnectorsCalibration Standard UT-09
Serial No.SS
Material1.031"
Nominal Thickness1.158"
Measured Thickness76 °F
Temp.Thermometer 145989
Serial No.Couplant ULTRAGEL II
Type094041
Batch No.CALIBRATIONBASIC SETTINGS

ORIENTATION: CIRC N/A

1. DELAY: 1.0696 in

TYPE: ID NOTCH TIP N/A

2. TIMEBASE: 9.5240 in

DEPTH: 1.042" N/A

3. FREQUENCY: (MHz) 6.25

AMPLITUDE: 80% N/A

4. RATE: /S 20.0

SWEEP: 2.048" N/A

5. UNITS:

GAIN: (dB) 42.0 N/A

 DISTANCE HALF PATH TIME TIME DEPTH METAL PATH

6. VELOCITY: 232519 in/s

7. SAMPLES: 512

FIELD SIMULATOR: RHOMPAS S/N: CAL-RHOM-038

PULSER / RECEIVER

REFLECTOR: NEAR SDH FAR SDH

1. MODE: PULSE ECHO THRU-TRANSMISSION

MAX AMPLITUDE: 80% 80%

2. PULSER: P1 TO R1

SWEEP: .707" 1.302"

3. VOLTAGE: (v) 400

GAIN: (dB) 33.0 29.0

4. WIDTH: (Ns) 276

CALIBRATION VERIFICATION

INITIAL TIME 22:15 DATE 04/22/96 OPER. PAZ COMP. 20RRC(6)-8 REPORT NO R-R11-019

5. FILTER: NONE 0.5 - 2 MHz 1 - 5 MHz
 2 - 10 MHz 5 - 15 MHz

VERIFIED

6. RECTIFICATION: NONE UNIPOLAR + UNIPOLAR -
 BIPOLEAR

VERIFIED

7. SMOOTHING: NONE FAST MEDIUM SLOW

VERIFIED

FINAL TIME 02:40 DATE 04/23/96 OPER. PAZ COMP. 20RRC(6)-8 REPORT NO R-R11-019

Robert Pawlakoffi
EXAMINER
D. M. Williams
GE REVIEWED BY

LEVEL III DATE 4/15/96
LEVEL III DATE 4/15/96

Ron Ulrich
UTILITY REVIEW
J. F. Feltz
ANII REVIEW

4-25-96
DATE
11/11/96
DATE

PAGE: 1 OF: 1



GE Nuclear Energy

ULTRASONIC CALIBRATION DATA SHEET

(AUTOMATED WITH Smart 2000)

SITE: WNP

UNIT: 2

CALIBRATION SHEET NO.: CA-R11-003

PROJECT NO.: 1FR9Z - RFO11

LINEARITY SHEET NO.: L-005

PROCEDURE NO.: UT-WNP2-208V0

REVISION: 0

FRR: N/A

Instrument TECRAD/TOMOSCAN
Manufacturer / Model

TTS10092113

System Serial No.

Search Unit RTD
Manufacturer

94-713

2(8x14)mm

2.00

MHz

60° / RL

40"

Angle/Mode Incident to wedge front

Cable 2(RG-58, RG-58, RG-174)
Type

2(250', 25', 3')

Length

8 BNC, Lemo

No. of Connectors

Calibration Standard UT-09
Serial No.

SS

Material

1.031"

Nominal Thickness

1.158"

Measured Thickness

76 °F

Temp.

Thermometer 145989
Serial No.Couplant ULTRAGEL II
Type

094041

Batch No.

CALIBRATION

ORIENTATION: CIRC N/A

TYPE: ID NOTCH TIP N/A

DEPTH: 1.042" N/A

AMPLITUDE: 80% N/A

SWEEP: 2.046" N/A

GAIN: (dB) 42.0 N/A

 TIME DEPTH METAL PATH**BASIC SETTINGS**

1. DELAY: 1.0696 in

2. TIMEBASE: 9.5240 in

3. FREQUENCY: (MHz) 6.25

4. RATE: /S 20.0

5. UNITS:

 DISTANCE HALF PATH TIME

6. VELOCITY: 232519 in/s

7. SAMPLES: 512

PULSER / RECEIVER1. MODE: PULSE ECHO THRU-TRANSMISSION

2. PULSER: P1 TO R1

3. VOLTAGE: (V) 400

4. WIDTH: (Ns) 276

5. FILTER: NONE 0.5 - 2 MHz 1 - 5 MHz
 2 - 10 MHz 5 - 15 MHz6. RECTIFICATION: NONE UNIPOLAR + UNIPOLAR -
 BIPOLAR7. SMOOTHING: NONE FAST MEDIUM SLOW**CALIBRATION VERIFICATION**

	TIME	DATE	OPER.	COMP.	REPORT NO
INITIAL	22:15	04/22/96	PAZ	20RRC(6)-8	R-R11-019
VERIFIED					
FINAL	02:40	04/23/96	PAZ	20RRC(6)-8	R-R11-019

Robert Paczkowski **II** **4-23-96**
EXAMINER **LEVEL** **DATE**
Donald Miller **III** **4/25/96**
GE REVIEWED BY **LEVEL** **DATE**

John Welch **4/25/96**
UTILITY REVIEW
J. Welch **ANII REVIEW**

4/25/96
DATE
4/25/96 **DATE**

PAGE: 1 OF: 1

FORM UT-01 REV.11

