


This attachment does not constitute an LBD.

 WASHINGTON PUBLIC POWER SUPPLY SYSTEM	CALCULATION COVER SHEET		BDC Page NONE
	Equipment Piece No. RCIC-V-31, RCIC-MO-31	Project WNP 2	Page 1.000
	Discipline MECHANICAL	Calculation No. ME-02-96-23	
		Quality Class 1	
Remarks c:\mov\files\rcic\plcalc.doc			

TITLE/SUBJECT/PURPOSE

Title/Subject

PRESSURE LOCKING EVALUATION FOR RCIC-V-31

Purpose

DETERMINE THE OPEN THRUST REQUIREMENT FOR A POSTULATED PRESSURE LOCKING CONDITION CAUSED BY PRESSURE AT THE SUCTION LINE RELIEF VALVE SET PRESSURE BECOMING TRAPPED IN THE VALVE BONNET.

CALCULATION REVISION RECORD

REVISION NO.	STATUS/ F,P or S	REVISION DESCRIPTION	INITIATING DOCUMENTS	TRANSMITTAL NO.
0	F	INITIAL ISSUE	GL 95-07	17230

PERFORMANCE VERIFICATION RECORD

REVISION NO.	PERFORMED BY/DATE	VERIFIED BY/DATE	APPROVED BY/DATE
0	JE FELLMAN <i>J. Fellman</i> 7/11/96	W.H. Kelsold <i>W.H. Kelsold</i> 7/11/96	P. Harner <i>P. Harner</i> 7/12/96

9612030158 961125
PDR ADOCK 05000397
P PDR

Study calculations shall be used only for the purpose of evaluating alternate design options or assisting the engineer in performing assessments.





This attachment does not constitute an LBD.



WASHINGTON PUBLIC POWER
SUPPLY SYSTEM

VERIFICATION CHECKLIST FOR
CALCULATIONS AND CMRS

Page

Cont'd On Page

1.200

1.300

Calculation/CMR ME-02-96-23 Revision 0 was
verified using the following methods:

Checklist Below

Alternate Calculations

Checklist Item

Initial

Clear statement of purpose of analysis

WPK

Methodology clearly stated and sufficiently detailed and
appropriate to proposed application

WPK

Logical consistency of analysis

WPK

• Completeness of documenting references

WPK

• Completeness of documenting and updating output interface documents

WPK

Completeness of input

WPK

Consistency of input data with approved criteria

WPK

Completeness in stating assumptions

WPK

Validity of assumptions

WPK

Calculation sufficiently detailed

WPK

• Arithmetical accuracy

WPK

• Physical units specified and correctly used

WPK

Reasonableness of output conclusions

WPK

Supervisor independency check (if acting as Verifier)

- Did not specify analysis approach

- Did not rule out specific analysis options

- Did not establish analysis inputs

N/A

• If a computer program was used:

- Is the program appropriate for the proposed application?

- Have the program error notices been reviewed to determine
if they pose any limitations for this application?

- Is the program name, revision number, and date of run
inscribed on the output?

- Is the program identified on the Calculation Method form?

If so, is it listed in Chapter 10 of the Engineering
Standards Manual?

N/A

N/A

Other Elements Considered

None

• If a separate verifier was used for validating these functions or a portion of these functions, sign and
initial below.

Based on the foregoing, the calculation is adequate for the purpose intended.

Verifier Signature(s) / Date




Verifier Initials

WPK 7/12/96

WPK



This attachment does not constitute an LBD.

 WASHINGTON PUBLIC POWER SUPPLY SYSTEM	CALCULATION OUTPUT INTERFACE DOCUMENTS REVISION INDEX		Page 1.400	Cont On Page 2.000
			Calculation No. ME-02-96-23	
Prepared By / Date JE FELLMAN	 7/11/96	Verified By / Date  7/2/96	Revision No. 0	


The below listed output interface calculations and/or documents are impacted by the current revision of the subject calculation. The listed output interfaces require revision as a result of this calculation. The documents have been revised or the revision deferred with Manager approval, as indicated below.

AFFECTED DOCUMENT NO.	CHANGED BY (eg: BDC,SCN,CMR,Rev.)	CHANGE DEFERRED (RFTS NO.)	DEPT. MANAGER*
None			


* Required for deferred changes only.



This attachment does not constitute an LBD.

 WASHINGTON PUBLIC POWER SUPPLY SYSTEM	<h2>CALCULATION OUTPUT SUMMARY</h2>	Page 2.000	Cont On Page 3.000
		Calculation No. ME-02-96-23	
Discussion of Results		Revision No. 0	REV. BAR
		<p>1. THE TOTAL REQUIRED THRUST TO OPEN RCIC-V-31 WITH THE VALVE PRESSURIZED TO 116 PSIG IS 10244 LB.</p> <p>2. THE ACTUATOR OPEN THRUST CAPABILITY IS 13,454 LB . (31.3% POSITIVE THRUST MARGIN)</p> <p>3. THE MAXIMUM PREFERRED STATIC UNSEATING LOAD IS 9,948 LB TO ENSURE THAT THRUST LIMITATIONS OF THE VALVE OR ACTUATOR ARE NOT EXCEEDED.</p>	
Conclusions		<p>RCIC-V-31 REMAINS OPERABLE UNDER THE POSTULATED PRESSURE LOCKING CONDITIONS.</p>	

This attachment does not constitute an LBD.

 WASHINGTON PUBLIC POWER SUPPLY SYSTEM	<h2 style="margin: 0;">CALCULATION METHOD</h2>	Page 3.000	Cont'd On Page <i>Appendix A</i>
Prepared by/Date JE FELLMAN <i>[Signature]</i> 7/11/96		Verified by/Date <i>[Signature]</i> 7/12/96	
Calculation No. ME-02-96-23		Revision No. 0	
Analysis Method (Check appropriate boxes)			
<input checked="" type="checkbox"/> Manual (As required, document source of equations in Reference List)			
<input type="checkbox"/> Computer <input type="checkbox"/> Main Frame <input type="checkbox"/> Personal			
<input type="checkbox"/> In-House Program			
<input type="checkbox"/> Computer Service Bureau Program			
<input type="checkbox"/> BCS <input type="checkbox"/> CDC <input type="checkbox"/> PCC <input type="checkbox"/> Other _____			
<input type="checkbox"/> Verified Program: Code name/Revision _____			
<input type="checkbox"/> Unverified Program: Document in Appendix B			
Approach/Methodology			REV. BAR
<p><i>THIS CALCULATION IS BASED ON THE METHOD PRESENTED IN THE PROCEEDINGS OF THE WORKSHOP ON GATE VALVE PRESSURE LOCKING AND THERMAL BINDING HELD BY THE NRC FEB. 4, 1994, NUREG/CP-0146. THE METHOD DIRECTLY APPLIES THE EQUATIONS CONTAINED IN THE 5TH EDITION OF ROARK & YOUNGS FORMULAS FOR STRESS AND STRAIN, REF. 6.</i></p> <p><i>THE TOTAL REQUIRED THRUST FOR OPENING ANY VALVE, UNDER PRESSURIZED BONNET CONDITIONS, IS DEPENDENT ON THE FINAL WEDGING FORCE FROM THE PREVIOUS CLOSING CYCLE. FOR A GIVEN TORQUE SWITCH SETTING, THE WEDGING FORCE CAN VARY BECAUSE INERTIAL OVERSHOOT IS AFFECTED BY THE MAGNITUDE OF THE DIFFERENTIAL PRESSURE ACROSS THE DISC. TYPICALLY, THE HIGHEST WEDGING FORCE WOULD BE INTRODUCED WHEN THE VALVE IS CLOSED WITHOUT DIFFERENTIAL PRESSURE. THIS CALCULATION CONSERVATIVELY QUANTIFIES THE UNWEDGING FORCE BASED ON AN ACTUAL AS-TESTED UNWEDGING FORCE UNDER STATIC CONDITIONS, AND GIVEN BONNET PRESSURE AND UPSTREAM AND DOWNSTREAM EXTERNAL PRESSURES.</i></p> <p><i>THE CALCULATION ALSO MODELS A WEDGE PISTON EFFECT FOR FLEX WEDGE GATE VALVES WHEREBY LOWER EXTERNAL PRESSURES THAN THE INTERNAL BONNET PRESSURE CAN RESULT IN A NET DOWNWARD FORCE WHICH OPPOSES THE STEM PISTON EFFECT. CONVERSELY, HIGHER EXTERNAL PRESSURES CAN RESULT IN A NET UPWARD FORCE. THE NET FORCE IS EITHER POSITIVE OR NEGATIVE IN THE OVERALL DETERMINATION OF THE FORCE REQUIRED TO OPEN THE VALVE.</i></p>			



SECRET



This attachment does not constitute an LBD.

RC31PLR0.MCD

Appendix A

7/8/96

CALCULATION ME-02-96-23 REV. 0

Prepared By: JF

Verified By: WJH

**OPENING THRUST CAPABILITY CALCULATION FOR
RCIC-V-31; SUPPRESSION POOL SUCTION VALVE TO RCIC PUMP
UNDER POTENTIAL PRESSURE LOCKED CONDITION**

GIVEN:

Wetwell Chamber Pressure	WW_P := 0 psig	Assumed
Elevation Head on Valve, Wetwell Side (due to minimum WW level)	V_EHW := (466 - 453)·0.433 V_EHW = 5.6 psig	Ref. 2, pg. D-28
Elevation Head from Relief Valve to Valve (relief valve is below RCIC-V-31)	V_EHRV := (453 - 431)·0.433 V_EHRV = 9.5 psig	Ref. 2, pg. D-27,28
Internal Bonnet Pressure (relief valve setpoint)	PB := 125.5 - V_EHRV psig	Ref. 2, pg. D-28
Suction Pressure (CST head, keepfull pump off)	P_CST := (448 - 426)·0.433 P_CST = 9.5 psig	Ref. 19, 20
Valve Open Pressure	V_OP := WW_P psig	
Mean Seat Diameter	MSD := 8.17 in	Ref. 4
Valve Hub Radius	H_R := 3.38 in	Measured
Poisson's Ratio for carbon steel	v := 0.30	Ref. 7,p5-06
Valve Seat Angle (degrees), θ (radians)	VSA := 5θ := VSA·0.01745 θ = 0.1	Ref. 4, DR-1078, pg. 82
Measured Static Unwedging Load	SUW := 7646 lbf	Ref. 13
Measured Unwedging Load Reading Error	SUW_re := 0.104	Ref. 13
Measured Unwedging Load Full Scale Error	SUW_fse := 0 lbf	Ref. 13
Stem Diameter	SD := 1.625 in	Ref. 10
Measured Running Load	RL := 441 lbf	Ref. 13
Measured Stem Coefficient of Friction	μ := 0.0863	Ref. 13
Measured Valve Factor	VF := .6	Ref. 13
Degraded Voltage	DV := 0.8	Ref. 14
Threads Per Inch	TPI := 4	Ref. 15
Thread Starts (Lead x TPI)	TS := 2	Ref. 15
Motor Speed	MS := 1900 rpm	Ref. 15
Unit Overall Ratio	OAR := 36.2	Ref. 15
Motor Torque	MOT_TQ := 15 ft-lbs	Ref. 15
Torque Loss @ 250 F	MOT_TQ_loss := 0.0	Ref. 16, Att. 6.3, pg. 3
Torque Loss Temperature	TLT := 250 F	Ref. 16, Att. 6.3, pg. 3
Minimum Ambient Temp. for Torque Loss	ATL := 104 F	Ref. 16, Att. 6.3, Am. 93-14
Pullout Efficiency	PO_eff := 0.4	Ref. 16, Att. 6.5, Am. 93-05
Run Efficiency	RUN_eff := 0.5	Ref. 16, Att. 6.5, Am. 93-05
Stall Efficiency	STALL_eff := 0.6	Ref. 16, Att. 6.5, Am. 93-05
Operator Thrust Limit (162%)	OTL := 22680 lbf	Ref. 16 & 17
Valve Open Thrust Limit	VOL := 25167 lbf	Ref. 11
Max. Operating Temp.	T_max := 220 F	Ref. 8
Gear Rating	GR := 250 ft - lbs	Ref. 17
Measured Stem Factor	SFM := 0.0123	@ Unseating, Ref. 13



1950



1950

This attachment does not constitute an LBD.

RC31PLR0.MCD

7/8/96

CALCULATION ME-02-96-23 REV. 0

Prepared By: [Signature]
Verified By: [Signature]

Determine the force on the perimeter of the disc (Qa_Δhl, lb/in) on the low pressure side due to the external differential pressure.

$$Qa_{\Delta hl} := 0 - W_{hub} \Delta F \cdot \frac{r_o}{a} \qquad Qa_{\Delta hl} = -6.963$$

Determine the force on each seat ring due to the four pressure loading conditions

Determine the ring load on the high pressure side (Qr_h, lb/in)

$$Qr_h := Qa_i - Qa_h \qquad Qr_h = -27.2241$$

Determine the ring load on the low pressure side (Qr_l, lb/in)

$$Qr_l := Qa_i - Qa_l + Qa_{\Delta hl} \qquad Qr_l = -35.1838$$

Determine the total disc force on the high pressure side (F_h, lbf)

$$F_h := \pi MSD \cdot Qr_h \qquad F_h = -699$$

$$F_h := \text{if}(F_h \geq 0, (-1) \cdot F_h, F_h) \qquad F_h = -698.7571$$

Determine the total disc force on the low pressure side (F_l)

$$F_l := \pi MSD \cdot Qr_l \qquad F_l = -903$$

$$F_l := \text{if}(F_l \geq 0, 0, F_l) \qquad F_l = -903 \quad \text{lbf}$$

Determine Disc Area (DA, in²)

$$DA := \frac{\pi MSD^2}{4} \qquad DA = 52.4 \quad \text{in}^2$$

Valve Disc Factor

$$DF := VF \qquad DF = 0.6$$

Determine the total required thrust (RT, lbf)

Determine thrust required due to pressure only (RT_p, lbf)

$$RT_p := (F_l + F_h) \cdot DF$$

$$RT_p := \text{if}(RT_p > 0, RT_p, (-1) \cdot RT_p) \qquad RT_p = 961 \quad \text{lbf}$$



11-11-11 11:11:11 11-11-11 11:11:11 11-11-11 11:11:11



This attachment does not constitute an LBD.

RC31PLR0.MCD

7/8/96

CALCULATION ME-02-96-23 REV. 0

Prepared By: GA
Verified By: WHL

OPEN THRUST CAPABILITY OF THE OPERATOR (OTC, lbf)

Determine Stem Factor (SF, ft)

$$TANa := \frac{\frac{TS}{TPI}}{\pi \left[SD - \left(\frac{1}{TPI} \right) \cdot 0.5 \right]}$$

TANa = 0.1

$$SF1 := \frac{\left(SD - .5 \cdot \frac{1}{TPI} \right) \cdot (.96815 \cdot TANa + \mu)}{24 \cdot (.96815 - \mu \cdot TANa)}$$

SF1 = 0

SF := if(SFM > 0, SFM, SF1) SF = 0

Determine Torque Loss at Max. Operating Temperature (TL)

i := 1..2	vx _i :=	vy _i :=
	ATL	0
	TLT	MOT_TQ_loss

TL := linterp(vx, vy, T_max) TL = 0

Determine Motor Start Torque (MST, ft-lbs)

MST := MOT_TQ · (1 - TL) MST = 15

Determine Reduced Voltage Factor (RVF)

RVF := DV RVF = 0.8 DC motor

Determine Pullout Torque (POT)

POT := MST · OAR · PO_eff · RVF POT = 173.8 ft - lbs

POT := if(POT > GR, GR, POT) POT = 173.8 ft - lbs

OPERATOR OPEN THRUST CAPABILITY

OTC := $\frac{POT}{SF}$ OTC = 14127

MARGIN := OTC - RTO MARGIN = 3882 lbf



This attachment does not constitute an LBD.

RC31PLR0.MCD

7/8/96

CALCULATION ME-02-96-23 REV. 0

Prepared By: [Signature]
Verified By: [Signature]

OPEN THRUST CAPABILITY OF THE OPERATOR WITH 5% STEM FACTOR DEGRADATION (OTC1, lbf)

$$OTC1 := \frac{POT}{SF \cdot 1.05} \qquad OTC1 = 13454 \text{ lbf}$$

MAXIMUM PREFERRED STATIC UNWEDGING FORCE (MSUW)

$$T_LIM := \text{if}(VOL > OTC, OTC, VOL)$$

$$T_LIM := \text{if}(T_LIM > OTL, OTL, T_LIM)$$

$$T_LIM := \text{if}(T_LIM > OTC1, OTC1, T_LIM)$$

$$T_LIM = 13454 \text{ lbf}$$

$$VOL = 25167 \quad OTC1 = 13454 \quad OTL = 22680$$

$$MSUW := SUWC - (RTO - T_LIM) - 1000 - SUW_fse - SUW \cdot SUW_re \qquad MSUW = 9948 \text{ lbf}$$

$$\begin{aligned} T_LIM &= 13454 & RTO &= 10244 \\ SUWC &= 8533 & SUW_fse &= 0 \\ SUW &= 7646 & SUW_re &= 0.1 \end{aligned}$$

CONCLUSION :

- 1) The highest total required thrust to open (RTO = 10244 lbf) is less than the operator capability with 5% stem factor degradation (OTC1 = 13454 lbf). Therefore, the valve is capable of performing its safety function with a bonnet pressure of PB = 116 psig, pumpside pressure of P_CST = 9.5 psig, and wetwell chamber pressure of WW_P = 0 psig.
- 2) The maximum preferred static unwedging force was determined to be MSUW = 9948 lbf. The measured static unwedging force of SUW = 7646 lbf is less than the maximum preferred value. The maximum preferred unwedging force ensures the calculated required thrust to open will not exceed the thrust limitations of either the valve or the operator with a 1000 lb margin.