

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9704090127 DOC. DATE: 97/04/02 NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Power 05000397
 AUTH. NAME: SWANK, D.A. AUTHOR AFFILIATION: Washington Public Power Supply System
 RECIP. NAME: RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: Submits info to be added to initial evaluation re TS response time testing.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD4-2 LA		1			PD4-2 PD		1	
	COLBURN, T		1						
INTERNAL:	ACRS		1			FILE CENTER 01		1	
	NRR/DE/ECGB/A		1			NRR/DE/EMCB		1	
	NRR/DRCH/HICB		1			NRR/DSSA/SPLB		1	
	NRR/DSSA/SRXB		1			NUDOCS-ABSTRACT		1	
	OGC/HDS3		1						
EXTERNAL:	NOAC		1			NRC PDR		1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 0

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • Richland, Washington 99352-0968

April 2, 1997
GO2-97-061

Docket No. 50-397

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: **WNP-2, OPERATING LICENSE NPF-21
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION
REGARDING RESPONSE TIME TESTING**

Reference: Letter, GO2-97-057, PR Bemis (SS) to NRC "Request For Amendment, Under Exigent Circumstances, To Operating License Regarding Technical Specification Response Time Testing"

In a conference call with the staff on March 25, 1997, Mr TG Colburn requested additional information be submitted in support of the no significant hazards consideration submitted as Attachment 3 of the reference. The following provides the information to be added to the initial evaluation.

Operation of WNP-2 in accordance with the proposed amendment will not create the possibility of a new or different kind of accident from any accident previously evaluated.

The proposed amendment applies, in part, to the testing requirement for the components identified and does not result in any physical change to these or other components or their operation. The changes do not affect the capability of the associated systems to perform their intended function within the acceptable limits assumed in plant safety analyses and required for successful mitigation of an initiating event. The proposed amendment does not change the way in which any plant systems are operated or create the possibility of a new or different kind of accident. As a result, no new failure modes are introduced.

The proposed amendment also deletes the applicability of response time testing for ECCS systems during MODES 4 and 5. This change in testing requirements does not change the way in which any plant systems are operated or create the possibility of a new or different kind of accident. As a result, no new failure modes are introduced.

9704090127 970402
PDR, ADOCK 05000397
PDR



[illegible]

Page 2

RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

The proposed amendment represents reliance on a different, and previously staff approved, method to verify selected components remain fully functional. It also requests a reduction in test requirements for ECCS in MODES 4 and 5. These changes will not create the possibility of a new or different kind of accident from any accident previously evaluated.

Operation of WNP-2 in accordance with the proposed amendment change will not involve a significant reduction in the margin of safety.

Deleting the requirement to verify response times for ECCS during MODES 4 and 5 will not affect the capability of the associated systems to perform their intended function within the allowed response time used as the basis for the plant safety analyses.

Plant and system response to an initiating event will remain in compliance with the assumptions of the safety analyses, and therefore the margin of safety is not affected.

Should you have any questions or desire additional information regarding this matter, please call me at (509) 377-4563.

Respectfully,

A handwritten signature in cursive script, appearing to read "D.A. Swank for".

D.A. Swank
Manager, Regulatory Affairs
Mail Drop PE20

cc: EW Merschoff - NRC RIV
KE Perkins, Jr. - NRC RIV, WCFO
TG Colburn - NRR
NRC Sr. Resident Inspector - 297N
DL Williams - BPA/399
PD Robinson - Winston & Strawn

[illegible]

Condition	10 Years (Open Circles)	12 Years (Filled Circles)	14 Years (Open Squares)
1	65	75	85
2	75	80	90
3	80	85	95
4	82	80	90
5	85	70	80