



EQE INTERNATIONAL

SHEET NO. 3/34

JOB NO. 59031 JOB WPS5 JPEEE

BY RSH DATE 1-16-99

CALC. NO. C-042 SUBJECT Reactor Bldg

CHK'D AK DATE 7-20-99

TABLE OF CONTENTS

Subject	Page
Calculation Cover Sheet	1
Table of Revisions	2
Table of Contents	3
References	4
Objective	5
Summary	5
Preliminary Review	6
Technical Approach	8
Overturing Moment on East Exterior Wall At EL 422'-3"	9
Overturing Moment on Biological Shield Wall At EL 422'-3"	12
Shear on Biological Shield Wall At EL 471'-0"	14
Overturing Moment On Containment Vessel Outer Skirt	16
Overturing Moment On Containment Vessel Inner Skirt	22
Shear Transfer From Sacrificial Shield Wall to Reactor Pedestal	25
Overturing Moment on Sacrificial Shield Wall-Reactor Pedestal Interface	31
Shear Transfer From Drywell Floor to Containment Vessel	33
Attachment A - Excerpts from Reference 8	
Attachment B - Excerpts from Reference 3	
Attachment C - Excerpts from Reference 10	
Attachment D - Excerpts from Reference 4	



JOB NO. 59037 JOB WPPSS IPEEE BY PSH DATE 1-16-99
CALC. NO. C-042 SUBJECT Reactor Bldg CHK'D OHC DATE 7-20-99

REFERENCES

1. Structural drawings-S660, and S701-to-S899.
2. "A Methodology for Assessment of Nuclear Power Plant Seismic Margin" (Revision 1); Electric Power Research Institute, EPRI NP-6041-SL, Revision 1, August 1991.
3. EQE Engineering Consultants, Calculation No. 59037-C-037, "IPEEE Building Forces", Revision 0.
4. WNP-2 Final Safety Analysis Report.
5. "Code Requirements for Nuclear Safety Related Concrete Structures (ACI 349-90) and Commentary - ACI 349R-90," American Concrete Institute, 1990.
6. Manual of Steel Construction, Allowable Stress Design, Ninth Edition, American Institute of Steel Construction, 1990.
7. Manual of Steel Construction, Load and Resistance Factor Design, First Edition, American Institute of Steel Construction, 1986.
8. EQE Engineering Consultants, Calculation No. 59037-C-005, "Reactor Building Model", Revision 0.
9. Pittsburgh-Des Moines Steel Company, Final Stress Report, Section II, Subsection 6, Revision C, "Design of Suppression Chamber Head and Inner Seismic Support Skirt," 1974.
10. Pittsburgh-Des Moines Steel Company, Final Stress Report, Section II, Subsection 7, Revision B, "Design of Outer Skirt," 1974.
11. "ASME Boiler and Pressure Vessel Code," Section III, Division 1, Appendices, American Society of Mechanical Engineers, 1977.



JOB NO. 59037 JOB WPPSS ZPREE

BY PSH

DATE REV-3P

CALC. NO. C-642 SUBJECT Reactor Bldg

CHKD WC

DATE 7-20-91

OBJECTIVE

The objective of this calculation is to evaluate the seismic capacity of the reactor building. A seismic fragility for this building is needed if its median capacity and High Confidence of a Low Probability of Failure (HCLPF) capacity are less than about 1.5g and 0.5g, respectively.

SUMMARY

A preliminary review was performed to identify the more heavily loaded structural components of the reactor building (Reference 1). Based on this preliminary review, a subset of structural components was selected for more detailed evaluation.

High Confidence of a Low Probability of Failure (HCLPF) capacities for the selected components were calculated following the Conservative Deterministic Failure Margins (CDFM) method recommended in EPRI NP-6041-SL (Reference 2). Seismic responses for this evaluation were taken as the 84% values obtained by probabilistic response analyses performed for a peak ground acceleration of 0.50g (Reference 3). The following results were obtained:

<u>Structural Component</u>	<u>HCLPF Capacity</u>
Overturning moment on east exterior wall at EL 422'-3"	1.1g
Overturning moment on biological shield wall at EL 422'-3"	0.51g
Shear on biological shield wall at EL 471'-0"	0.68g
Overturning moment on containment vessel outer skirt	0.89g
Overturning moment on containment vessel inner skirt	0.51g
Shear on sacrificial shield wall-reactor pedestal interface	1.1g
Overturning moment on sacrificial shield wall-reactor pedestal interface	0.93g
Shear transfer from drywell floor to containment vessel	0.50g

It is noted that conservative approximations were included to simplify these calculations. More rigorous calculations could be performed to reduce these conservatisms and obtain HCLPF capacities even greater than those listed above.

It is concluded that the HCLPF capacity of the reactor-building is greater than 0.50g.



JOB NO. 59037 JOB WPPSS IPEEE

BY PEH DATE 7-16-99

CALC. NO. C-042 SUBJECT Reactor Bldg

CHK'D RC DATE 7-20-99

PRELIMINARY REVIEW

A preliminary review was performed to identify a subset of reactor building structural components for which more detailed evaluations should be performed. This review consisted of (1) review structural drawings (Reference 1), the Final Safety Analysis Report (FSAR) (Reference 4), and reactor building seismic responses for IPEEE (Reference 3), and (2) approximate calculations to estimate seismic capacities of certain structural components.

The drawing review was performed to identify the seismic load paths and any potentially significant seismic vulnerabilities. In general, the reactor building, containment vessel, and containment internal structure were found to be of relatively rugged construction, and no obvious seismic vulnerabilities were identified.

Further review, including simplified calculations, were performed for the following components: (1) Shear walls, including the biological shield wall, (2) floor diaphragms, (3) containment vessel, including the inner and outer skirts and shear transfer to the concrete foundation in which it is embedded, (4) reactor pedestal, including shear, overturning moment, and its connection to the inner skirt, (5) sacrificial shield wall, including shear, overturning moment, and the interface with the reactor pedestal, (6) stabilizer truss, including the truss members, and connections to the sacrificial shield wall and containment vessel, and (7) connection from the drywell floor to the containment vessel.

Based on the preliminary review, the following structural components were selected for more detailed evaluation:

- Overturning moment on the east exterior wall and biological shield wall at Elevation 422'-3". Approximate calculations indicated that this is controlling location for overturning moment on the shear walls.
- Shear on the biological shield wall at Elevation 471'-0". Approximate calculations indicated that this is controlling location for shear on the shear walls.
- Overturning moment on the containment vessel outer skirt. The skirt anchors do not satisfy the ductile anchorage requirements of ACI-349-90 (Reference 5) Appendix B. The containment has higher seismic capacity than the skirt, because seismic stresses for IPEEE are relatively low.
- Overturning moment on the containment vessel inner skirt. The skirt anchors do not satisfy the ductile anchorage requirements of ACI 349-90 Appendix B. The reactor pedestal has higher seismic capacity than the skirt.



EQE INTERNATIONAL

SHEET NO. 7/3A

JOB NO. 59037 JOB WPPSS 2PEEE BY: PSH DATE 7-16-99

CALC. NO. C-042 SUBJECT Reactor Bldg CHKD: AC DATE 7-20-99

Shear and overturning moment at the sacrificial shield wall reactor pedestal interface. The sacrificial shield wall anchors do not satisfy the ductile anchorage requirements of ACI 349-90 Appendix-B. This connection has been identified as being seismically vulnerable in past seismic PRAs.

Connection between the drywell floor and containment vessel.

More detailed evaluation of the stabilizer truss at the top of the sacrificial shield wall was not considered necessary. Past seismic PRAs have found stabilizer trusses to have lower seismic capacities than other reactor building components. However, the stabilizer for WNP-2 and its connections are relatively heavy and have seismic capacities at least those for the other structural components.



EQE INTERNATIONAL

SHEET NO. 3/34

JOB NO. 51031 JOB WPPSS PPEEE

BY: PSH DATE 7-16-99

CALC. NO. C-042 SUBJECT Reactor Bldg

CHK'D: MC DATE 7-20-99

TECHNICAL APPROACH

HCLPF-capacities for the selected reactor building structural components were calculated following the Conservative Deterministic Failure Margins (CDFM) approach recommended in EPRI NP-6041-SL (Reference 2).

Seismic demands on the structural components were based on 84% responses for a 0.50g peak ground acceleration calculated for use in IPEEE in Reference 3.

Seismic capacities of the structural components were determined following acceptance criteria recommended by EPRI NP-6041-SL. These acceptance criteria are specified in appendices to EPRI NP-6041-SL, ACI 349-90 (Reference 5), AISC Specifications (Reference 6), or the Load and Resistance Factor Design (LRFD) Specifications (Reference 7).

Following the recommendations of EPRI NP-6041-SL, an inelastic energy absorption factor of 1.25 was conservatively assigned to ductile failure modes in lieu of performing a more rigorous calculation.



JOB NO. 59037 JOB WIPSS TREE

BY RSH

DATE 7-15-99

CALC. NO. C-042 SUBJECT Reactor Bldg

CHK'D RC

DATE 7-20-99

Overturning Moment on East Exterior Wall At EL 420'-3"

Overturning Moment Demand

Flexibility of the shear wall is controlled by shear, rather than bending. Overall structure shears and, consequently, overturning moments, can be distributed to the walls in proportion to their shear areas. Distribution of the overall OT moment at EL 420'-3" will be conservatively based on the wall configuration at EL 470'. This conservatively neglects OT moments resisted by the various walls at the lower elevations.

+10 overall OT moment = 4.54×10^5 (32.2) Elmt. 1, Component 5
 $= 1.46 \times 10^7$ k-ft Ref. 3 (Att. B)

Stiffness Properties At EL 470' (See pp. 46 to 49, Ref. 8 - See Att. B)

Total N-S shear area = 1431 ft²

East wall is modeled by Segments 5 to 7. See p. 46, Ref. 8

Area of Seg. 5 = 2:5 (133)

= 333 ft²

Area of Segment 6 to 7 = 714 ft²

Area of Segment 5 to 7 = 714 - 333 = 381 ft²

OT Moment on east wall = $1.46 \times 10^7 \left(\frac{381}{1431} \right)$
 $= 3.89 \times 10^6$ k-ft

Overturning Moment Capacity

Compression Flange Width Based on Sect. 8.10.2, ACI 349-90 (Ref. 5)

1/4 span length

Equivalent span length = 2 x wall height

= 2(405 - 422)

= 366 ft

1/4 L = 1/4 (366)

= 91.5 ft



EQE INTERNATIONAL

SHEET NO. 10/3A

JOB NO. 59037 JOB WPPSS JEFFERIE

BY PSH DATE 7-15-94

CALC. NO. C-042 SUBJECT Reactor Bldg

CHK'D MC DATE 7-20-94

Overhang of 8" slab thickness

Thickness of intersecting wall = 4 ft

Web thickness = 4 ft

} D. S154

$$b_f = 8(4) + 4$$

$$= 36 \text{ ft}$$

Overhang of 1/2 distance to next web

$$b_f = \frac{143}{2} + 4$$

$$= 75.5 \text{ ft}$$


$$b_f = 36 \text{ ft}$$

Tension Flange Width (North wall, lower rebar than south wall)

Use 1/3 of wall height

$$b_f = \frac{1}{3} (605 - 420) + 4$$

$$= 65 \text{ ft}$$



JOB NO. 59037 JOB WRSS DEFEBY PSHDATE 7-15-94CALC. NO. C-042 SUBJECT Reactor BldgCHK'D MEDATE 7-20-94

Web

Conservatively neglect pilaster reinforcement, count only wall reinforcement. See Dr. 5704

N-8 to N - #14@9" EF

N to M - #18@10" EF (neglect 9" spacing)

M to K - #14@8" OF, #14@7" IF

K to H3 - #18@10" EF

$$A_{sw} = \frac{2(2.25)}{9} (24.83) (12) + \frac{2(4.00)}{10} (23.17) (12) + \left(\frac{2.25}{8} + \frac{2.25}{7} \right) (45) (12) + \frac{2(4.00)}{10} (37) (12)$$

$$= 1050 \text{ in}^2 \quad (\bar{c} = 0.014)$$

Flange (North Wall. See Dr. 5705)

Conservatively use #18@12" OF, #14@8" IF

$$A_{sf} = \left(\frac{4.00}{12} + \frac{2.25}{8} \right) (65) (12)$$

$$= 479 \text{ in}^2$$

Moment Capacity

Conservatively neglect axial load, Assume centroid at compression force at mid-depth of compression flange.

$$\phi M_n = 0.90 \left[1050 (600) \left(1\frac{35}{2} - \frac{4}{2} \right) + 479 (600) (135 - 4) \right]$$

$$= 7.10 \times 10^4 \text{ ft-k}$$

ACI PF Capacity

Conservatively use $F_u = 1.25$ per ACI 11.4.1.1. NP-6041-SL

$$\text{ACI PF Capacity} = \frac{7.10 \times 10^4 (1.25)}{(3.89 \times 10^4) (0.50)}$$

$$= 1.18 > 0.50 \text{ ok}$$



JOB NO. 59037 JOB WASS BREE

BY FSH DATE 7-15-94

CALC. NO. C-042 SUBJECT Reactor Bldg

CHK'D OK DATE 7-20-94

Overturning Moment On Biological Shield Wall At EL 421'-3"

Overturning Moment Demand

See distribution to east exterior wall.

Shear area of biological shield wall = 717 ft²

$$OT \text{ Moment to biological shield wall} = 1.46 \times 10^7 \left(\frac{717}{1431} \right)$$

$$= 7.32 \times 10^6 \text{ K-ft}$$

pp. 46 to 49, Fig. 8
See App. A

Overturning Moment Capacity

R₀ = 48'-2"

R_c = 40'-0" to inner skirt

} p. 5754

Vertical Reinforcement

See Dwg. 5741, 5754

Have 5-#11 @ 10" @ R = 47'-9 1/2" (360 sets of bars)

$$A_s = 5 (1.56) (360)$$

$$= 2810 \text{ in}^2$$

Axial Load

Include weight of bio. shield wall only, reduced for vertical EQ.

EL 421'-3" to EL 493'

R₀ = 48'-2"

R_c = 43'-2"

$$W = 0.15 \pi (48.17^2 - 43.17^2) (493 - 422)$$

$$= 15,300 \text{ K}$$

EL 493' to EL 572'

R₀ Tapers to 26'-8"

$$W = 0.15 \left(\frac{1}{2} \pi \right) (572 - 493) \left\{ [48.17^2 + 48.17(26.17) + 26.17^2] \right.$$

$$\left. - [43.17^2 + 43.17(21.17) + 21.17^2] \right\}$$

$$= 12,900 \text{ K}$$

$$\text{Total weight} = 15,300 + 12,900$$

$$= 28,200 \text{ K}$$



JOB NO. 59037 JOB WYSS BRIDGE

BY PSM

DATE 7-15-94

CALC. NO. C-042 SUBJECT Resistor Bridge

CHK'D

AK

DATE 7-20-95

Ann. $W_{eff} = 37A = 0.53g$ Excel; Node 19, EL 500', 0.5g men + 10'

$$P_{eff} = 28,200 [1 - 0.4(0.53)] \\ = 22,200 \text{ k}$$

OT Moment Capacity

Approximate as sum of reinforcement yield force and effective weight factored by effective lever arm of 0.8 times average radius. (conservative)

$$0.1A_c A_g = 0.1(4) \pi (48.17^2 - 43.17^2) (144) \\ = 82,600 \text{ k}$$

$$\frac{P}{0.1A_c A_g} = \frac{22,200}{82,600} \\ = 0.27$$

$$\phi = 0.9 - 0.2(0.27) \\ = 0.85$$

$$\bar{r} = 45.67'$$

$$\phi M_n \approx 0.85 [2810(60) + 22,200] (0.8)(45.67) \\ = 5.93 \times 10^4 \text{ k-ft}$$

HCLPF Capacity

Use conservative $F_n = 1.25$

$$\text{HCLPF Capacity} = \frac{5.93 \times 10^4 (1.25)}{(7.32 \times 10^4)} (0.50g) \\ = 0.51g$$



JOB NO. 59037 JOB WYSS ZEPPE

BY PSH

DATE 7-10-94

CALC. NO. C-042 SUBJECT Reator Body

CHKD JHC

DATE 7-20-94

Shear On Biological Shield Wall At EL 471'-0"

Shear Demand:

See ST moment distribution to biological shield wall at EL 471'-3"

Total shear at EL 471' = 2.72 x 10^5 (32.2) = 87,600 k

Reinf. 4, Comp. 3, Ref. 3 (see Att. B)

Shear to biological shield wall = 87,600 (717/165L) = 43,800 k

Shear Capacity

Follow approach in App. N of EPRC NP-6091-SL

R0 = 48'-2"

R1 = 43'-2"

f'c = 4000 psi

Reinf. - 4-#11 @ 10" horiz, 4-#11 @ 10" vert.

Dr. 3791

pn = pr = 4(1.56) / 10(60) = 0.0104

(psx)AVE = 0.0104(60,000) = 624 psi

Conservatively neglect axial compression

Vu = median ultimate shear stress

Eqn. #'s, EPRC NP-6091-SL (N-2)

= 0.8 sqrt(f'c) + (psx)AVE <= 2.1 sqrt(f'c) = 0.8 sqrt(4000) + 624 = 675 psi < 2.1 sqrt(4000) = 1334 psi

Vu = Shear capacity = phi Vu T D t / alpha

(N-1)





EQE INTERNATIONAL

SHEET NO. 15/34

JOB NO. 59037 JOB WPPSS - 2 PEE

BY PSH

DATE 7-16-94

CALC. NO. C-042 SUBJECT Reinforced Bridge

CHK'D MC

DATE 7-20-94

$$\phi = 0.85$$

$$\alpha = 2.5$$

Conservative Upper bound value

$$\bar{D} = 48.17 + 43.17$$

$$= 91.33 \text{ ft}$$

$$t = 5 \text{ ft}$$

$$V_u = \frac{0.85 (0.675) \pi (91.33) (5) (144)}{2.5}$$

$$= 47,400 \text{ L}$$

Conservative

HCLTF Capacity

$$F_u = 1.25$$

P-N-2, EPR/UP-6041-SL

$$\text{HCLTF Capacity} = \frac{47,400}{43,800} (1.25) (0.50)$$

$$= 0.689$$

Conservative





JOB NO. 59037 JOB WASS ZEEZ

BY JSH

DATE 11-90

CALC. NO. C-042 SUBJECT Reactor Sdg

CHKD OK

DATE 1-20-91

Overturning Moment On Containment Vessel Outer Skirt

Design details and calculations available in Pittsburgh-DeMare (PDM) calcs, Sect. II, Subsection (a) and (b) (Ref. 9 & 10). See Att. C.

Overturning Moment Demand

Seismic Loads At Base of Containment, Elmt. 12 (see Att. B)

OT moment = 1.14×10^4 (32.2) Elmt. 12, Force Comp. 5
= 367,000 k-ft

Axis force = 70.4 (32.2) Force Comp. 1
= 2270

Note: SSE design moment was 450,000 k-ft, PDM p. II-7-4

Overturning Moment Capacity

Anchor Bolts to Foundation

Have 2-2 1/2" ϕ A307 A.B @ 2.5'. Determine capacity per Sect. N of AISC Specs. (Ref. 6); factor allowable tensile stress of 20 ksi by 1.7,

$F_u = 1.7(20)$
= 34 ksi

$A_b = \frac{\pi}{4}(2.5)^2$
= 4.91 in²

$P_{ult} = 2(4.91)(34)$
= 334 k / 2 bolts

7 1/2" x 2 1/4" x 11-3 3/8" Anchor Plate

Check per Sect B.4.5.2, AISC 309-90 (Ref. 5)

a. Required area = $7.5(15.38) = 2(4.91)$
= 105 in²

2.5 x Bolt area = $2.5(2)(4.9)$
= 25 in² < 105 in² OK



JOB NO. 59051 JOB WIPSS PPEEE

BY BSH

DATE 7-14-94

CALC. NO. C-042 SUBJECT Reactor Bldg

CHK'D MC

DATE 7-20-94

$$\begin{aligned} \text{Anchor head thickness} &= 2.25'' \\ \text{Dimension from outer most edge of } R \text{ to face of A.B.} \\ &= \frac{7.5}{2} - \frac{2.5}{2} = 2.5'' \\ \text{or } &= 7.49 - 3.94 - \frac{2.5}{2} = 2.5'' \end{aligned} \quad \left. \vphantom{\begin{aligned} \text{Anchor head thickness} \\ \text{Dimension from outer most edge of } R \text{ to face of A.B.} \\ \text{or } \end{aligned}} \right\} > 2.25''$$

Doesn't quite satisfy, but ok since Heavy Hex nuts on back side of R (see 1990 supplement for ACI 349).

c. Bewing area approximately uniformly distributed - ok.

Concrete Pullout

Check per B. 4.2 of ACI 349-90

Bolts spaced at $2\frac{1}{2}''$ $R = 40'$

$$\text{Bolt hoop spacing} = \frac{2.5}{180} \pi (40)(12)$$

$$= 20.9 \text{ in}$$

$$\text{Embedment depth} = 36 - 2.25 \text{ --- Anchor } R$$

$$= 33.75''$$

$$\text{Effective stress area} = (33.75 + 15.38 + 33.75)(20.9) - 7.5(15.38)$$

$$= 1620 \text{ in}^2$$

$$\phi = 0.65$$

$$f'_c = 4000 \text{ psi}$$

$$P_c = 0.65(4\sqrt{4000})(10^{-3})(1620)$$

$$\approx 266 \text{ } \frac{1}{2} \text{ bolts}$$

Concrete pullout capacity req'd for ductile design (Sect. B.5.1.1) ACI 349-90

$$\text{Tensile stress req'd} = 4.00 \text{ in}^2 \quad 2\frac{1}{2}'' \phi \text{ bolt}$$

$$f_{ut} = \text{Tensile strength}$$

$$= 60 \text{ ksi}$$

A307

$$P_{req'd} = 4.00(60)(2)$$

$$\approx 480 \text{ } \frac{1}{2} \text{ bolts}$$

> 266

NOTE - FDM (Sub. 7, p. 14) designed embedment for a force of 250k using punching shear strength ($\phi = 0.85$)





JOB NO. 59037 JOB WIPES PIPES

BY ~~JK~~

DATE 7-16-94

CALC. NO. C-042 SUBJECT Reactor Skirt



CHK'D JHC

DATE 7-20-94

Skirt Bottom Flange

Plate is 3" x 17", fabricated at SA-516, Grade 70 steel.

Model as a one-way member, simply supported at the bolt &, subjected to an upward force at the skirt &.



$$M_{max} = \frac{PL}{4}$$

$$P_{all} = \frac{4M}{L}$$

$$= 0.5M$$

Min 4-in

Use plastic moment capacity. Assuming load spread from bolt & at 45° from axis orthogonal to skirt, use a plate effective width equal to two times the distance from the bolt & to skirt & $\approx 2(4) = 8"$

$$F_y = 38 \text{ ksi}$$

SA-516, Gr 70 ASME (Ref. 11)

$$M_p = \frac{1}{4} (8) (3)^2 (38)$$

$$= 684 \text{ k-in}$$

$$P_{all} = 0.5 (684)$$

$$= 342 \text{ k/2 bolts}$$

Skirt itself and welds are OK by inspection. Anchorage capacity is limited by non-ductile concrete pullout.




JOB NO. 59037 JOB WPPSS ZPREE

BY BSA DATE 7-16-98

CALC. NO. C-042 SUBJECT Reactor Edge

CHK'D AKC DATE 7-20-98OT Moment Capacity

Represent the skirt as a circular ring. In compression, the actual skirt thickness (11/16") is applicable. In tension, use the equivalent thickness based on the A.S. area. Conservatively neglect uplift resistance from axial compression. Determine the moment capacity at which concrete pullout occurs.



$$\begin{aligned} \frac{P}{2} &= \int_0^{\beta} F_t \frac{\cos \theta - \cos \beta}{1 - \cos \beta} t_{eq} R d\theta + \int_{\beta}^{\pi} F_t \frac{\cos \theta - \cos \beta}{1 - \cos \beta} t R d\theta \\ &= \frac{F_t R}{1 - \cos \beta} \left[t_{eq} \int_0^{\beta} (\cos \theta - \cos \beta) d\theta + t \int_{\beta}^{\pi} (\cos \theta - \cos \beta) d\theta \right] \\ &= \frac{F_t R}{1 - \cos \beta} \left[t_{eq} (\sin \theta - \theta \cos \beta) \Big|_0^{\beta} + t (\sin \theta - \theta \cos \beta) \Big|_{\beta}^{\pi} \right] \\ &= \frac{F_t R}{1 - \cos \beta} \left[t_{eq} (\sin \beta - \beta \cos \beta) + t (-\pi \cos \beta - \sin \beta + \beta \cos \beta) \right] \\ &= \frac{F_t R}{1 - \cos \beta} \left[(t_{eq} - t) (\sin \beta - \beta \cos \beta) - t \pi \cos \beta \right] \end{aligned}$$

$$P = 0 \quad (t_{eq} - t) (\sin \beta - \beta \cos \beta) - t \pi \cos \beta = 0 \quad (1)$$





JOB NO. 59037 JOB WFTSS OPERER

BY JEM DATE 1-16-94

CALC. NO. C-042 SUBJECT Reactor Bldg

CHK'D. MC DATE 7-20-99

$$\begin{aligned}
 \frac{M}{Z} &= \int_0^{\beta} F_t \frac{\cos \theta - \cos \beta}{1 - \cos \beta} t \operatorname{tg} (R \cos \theta) R d\theta \\
 &+ \int_{\beta}^{\pi} F_t \frac{\cos \theta - \cos \beta}{1 - \cos \beta} t (R \cos \theta) R d\theta \\
 &= \frac{F_t R^2}{1 - \cos \beta} \left[t \operatorname{tg} \int_0^{\beta} (\cos^2 \theta - \cos \beta \cos \theta) d\theta \right. \\
 &\quad \left. + t \int_{\beta}^{\pi} (\cos^2 \theta - \cos \beta \cos \theta) d\theta \right] \\
 &= \frac{F_t R^2}{1 - \cos \beta} \left[t \operatorname{tg} \left(\frac{\theta}{2} + \frac{1}{4} \sin 2\theta - \cos \beta \sin \theta \right) \Big|_0^{\beta} \right. \\
 &\quad \left. + t \left(\frac{\theta}{2} + \frac{1}{4} \sin 2\theta - \cos \beta \sin \theta \right) \Big|_{\beta}^{\pi} \right] \\
 &= \frac{F_t R^2}{1 - \cos \beta} \left[t \operatorname{tg} \left(\frac{\beta}{2} + \frac{1}{4} \sin 2\beta - \sin \beta \cos \beta \right) \right. \\
 &\quad \left. + t \left(\frac{\pi}{2} - \frac{\beta}{2} - \frac{1}{4} \sin 2\beta + \sin \beta \cos \beta \right) \right] \\
 &= \frac{F_t R^2}{1 - \cos \beta} \left[(t \operatorname{tg} - t) \left(\frac{\beta}{2} + \frac{1}{4} \sin 2\beta - \sin \beta \cos \beta \right) + t \frac{\pi}{2} \right] \\
 M &= \frac{2 F_t R^2}{1 - \cos \beta} \left[(t \operatorname{tg} - t) \left(\frac{\beta}{2} - \frac{1}{4} \sin 2\beta \right) + t \frac{\pi}{2} \right] \quad (2)
 \end{aligned}$$

$$R = 40 \text{ ft} = 480 \text{ ''}$$

$$t = 1/16 \text{ ''} = 0.688 \text{ ''}$$

$$t \operatorname{tg} = \frac{2(4.91)}{20.9}$$

$$= 0.470 \text{ ''}$$

$$F_t = \frac{P_c}{t \operatorname{tg} s}$$

$$= \frac{266}{0.470 (20.9)}$$

$$= 27.1 \text{ ksi}$$

Solving for β by Eqn. 1

$$\beta = 1.692 \text{ rad. } (97^\circ)$$



JOB NO. 59057 JOB WATTS ZEPHIE

BY ~~JK~~ DATE 7-16-94

CALC. NO. C-042 SUBJECT Reactor - Bldg

CHK'D AK DATE 7-20-94

$$M = \frac{2(27.1)(480)^2}{1 - \cos 1.692} \left\{ (0.470 - 0.688) \left[\frac{1.692}{2} - \frac{1}{4} \sin 2(1.692) \right] + 0.688 \frac{\pi}{2} \right\}$$

$$= 9.84 \times 10^6 \text{ k-in}$$

$$= 820,000 \text{ k-ft}$$

Use $\phi = 0.80$ Conservative

$$\therefore \phi M = 0.80 (820,000)$$

$$= 656,000 \text{ k-ft}$$

HCLPF Capacity

$F_n = 1.0$ since failure is non-ductile

$$\text{HCLPF Capacity} = \frac{656,000}{367,000} (0.509)$$

$$= 0.89$$



JOB NO. 59037 JOB WORKS SHEET

BY TSM

DATE 7-16-94

CALC. NO. C-042 SUBJECT Reactor Bldg

CHK'D MC

DATE 7-20-94

Overturning Moment On Containment Vessel Inner Skirt

Follow calculation for outer skirt

Overturning Moment Demand

Seismic Loads At Base of Reactor Pedestal, Point 29 (See Att. B)

OT moment = 7.75×10^3 (32.2) Force Comp. 5
= 250,000 k-ft

Axial force = 1.90×10^1 (32.2) " " " "
= 610 k

Axial force looks abnormally low. Factor internal structure & P.P.V. mass (Ref. 8, see Att. A thru Calc) by average vertical ZPA

Σ Mass, Nodes 56 to 67, 70, 72 to 78, 80 to 85, 86

= 72.0 + 48.3 + 26.4 + 32.3 + 118.1 + 29.1 + 31.7 + 16.5 + 32.5

+ 18.3 + 8.6 + 5.5 + 9.5 + 5.6 + 10.5 + 22.4 + 17.1 + 17.4

+ 10.8 + 8.0 + 22.0 + 13.1 + 18.2 + 14.7

= 609 k-sec²/ft

W = 19,600 k

Vertical ZPA, Node 60 (drywell floor) = 0.41 g

Seismic axial force = 19,600 (0.41)

= 8,000 k

Overturning Moment Capacity

Preliminary review shows that concrete pullout of the anchor plate governs the uplift capacity. Although, as shown below, the tensile capacity of the #11 bars from the reactor pedestal is very close.

Concrete Pullout

Bolt spacing = 40

Skirt radius = 12'-8"

Embedment depth = $6.5(12) - 2.25 = 75.75"$

Anchor PL = 18³/₈" wide, 9 segments total





JOB NO. EA037 JOB URRS TRREE BY JK DATE 1-16-99
 CALC. NO. C-042 SUBJECT Reactor Bldg CHK'D AK DATE 7-20-99

$$\text{Bolt loop spacing} = \frac{4}{180} \pi (152)$$

$$= 10.6''$$

$$\text{Effective stress area} = 10.6 (75.75 + 18.38 + 75.75) = 10.6 (18.38)$$

$$= 1610 \text{ in}^2$$

$$P_c = 0.65 (4 \sqrt{4000}) (10^{-3}) (1610)$$

$$= 265 \text{ k} / 2 \text{ bolts}$$

$$f_u = \frac{265}{10.6}$$

$$= 25.0 \text{ k/in}$$

Reactor Pedestal Reinforcement

Have 4-#11 bars @ 5' and welded to upper skirt assembly (Dr. S789)

$$F_u = 0.90 (60) (4) (1.56)$$

$$= 337 \text{ k} / 4 \text{ bars}$$

$$\phi = 0.90$$

$$\text{Bar spacing} = \frac{5}{180} \pi (152)$$

$$= 13.3''$$

$$f_u = \frac{337}{13.3}$$

$$= 25.4 \text{ k/in}$$

Overturning Moment Capacity

... Non-ductile concrete pullout capacity and ductile reinforcement yield capacity are about equal. Conservatively limit OT moment capacity to non-ductile concrete pullout capacity.

t = skirt thickness

= 15/16" per PDM drawings, Note: Dr. S740 calls out 15/16"

skirt thickness, PDM drawing conservatively used



JOB NO. 59037 JOB WASS PPEPE

BY FSH DATE 7-10-94

CALC. NO. C-042 SUBJECT Reactor Bldg

CHK'D MC DATE 7-20-94

$$t_{eq} = \frac{2 \left(\frac{\pi}{4} \right) (3)^2}{10.6}$$

= 1.33" > t ⇒ Buck stress distribution on elementary beam theory

Concrete pullout capacity, $q_u = 25.0 \text{ k/in}$

Axial Compression

Assume force of vertical seismic acts concurrent

$$F_{NET} = 11,400 - 0.4(18,000)$$

$$= 16,400 \text{ k}$$

$$q = \frac{16,400}{2\pi(152)}$$

$$= 17.2 \text{ k/in}$$

$$q_u = 25.0 + 17.2$$

$$= 42.2 \text{ k/in}$$

$$M_{all} = 42.2 \pi (152)^2$$

$$= 3.06 \times 10^6 \text{ k-in}$$

$$= 255,000 \text{ k-ft}$$

HCLPF Capacity

$$F_{h} = 1.0$$

$$\text{HCLPF Capacity} = \frac{255,000}{250,000} (0.50)$$

$$= 0.518$$

Note: This capacity is conservative, since the weight of the concrete above and below the containment vessel that further restrains uplift is conservatively neglected.





JOB NO. 59037 JOB WRPSS ZPEEE BY TAH DATE 1-16-99
CALC. NO. C-042 SUBJECT Reactor Bldg CHK'D ME DATE 7-20-99

Shear Transfer From Sacrificial Shield Wall to Reactor Pedestal
Shear Demand

Forces in elements at this interface. As an approximation, scale the SSE reported in the FSAR (Ref. 4) by the maximum ratio of the mean +1 σ ZPA for a 0.5g PGA to the SSE ZPA for the sacrificial shield wall nodes. See Att. B and D

N-S SSE shear = 750k Elmt. 26, Table 3.7-11, FSAR

SSE ZPA from Table 3.7-9, FSAR. 8470 ZPA for 0.5g PGA from Ref. 3

Elevation	SSE		ZPEEE, 0.5g PGA		
	Node #	ZPA	Node #	8470 ZPA	8470 ZPA / SSE ZPA
EL 567.38'	24	0.76g	66	0.81g	1.07
EL 519.56'	28	0.59g	62	0.54g	0.92

$V = 1.07 (750) = 803k$

$V = \text{Max. unit shear} = \frac{V}{(\frac{V}{2\pi R})} \quad \pi = 14 \text{ ft}$

$= \frac{803}{\pi (14)(12)} = 1.52 \text{ k/in}$

The SSE stress distribution (FSAR Table 3.7-11) indicates that shears at the top and bottom of the sacrificial shield wall are about equal. To check the shear demand above, estimate a shear as half of the total sacrificial shield wall mass times the average ZPA.

$\Sigma \text{ Mass, Nodes 43 to 46} = 16.5 + 32.5 + 18.3 + 8.6 = 75.9$
 $= 75.9 \text{ k-ft}^2/\text{ft}$

Total sac. shield wall weight = 2400k
Avg. ZPA = $\frac{1}{2} (0.81g + 0.54g) = 0.68g$

$V = \frac{1}{2} (2400) (0.68) = 830k \approx 803k$ Checks ok



JOB NO. 59057 JOB WPPSS DPEEE

BY TSH

DATE 7-16-94

CALC. NO. C-042 SUBJECT Reactor Bldg

CHKD AC

DATE 7-20-94

Estimate the seismic axial force as the mass times the average vertical acceleration

$$\text{Vert. ZPA, Node } U_6 = 0.49g$$

$$U_2 = 0.40g$$

} see Att. B

$$\bar{ZPA} = 0.45g$$

$$\text{Axial force} = 2400 (0.45)$$

$$= 1100 \text{ k}$$

Shear Capacity - See Drgs. S789, S792, S835

As shown below, tensile capacity of the sacrificial shield wall anchorage is limited by concrete pullout.

2 1/2" ϕ A.B., MK-91 (Dr. S792)

Assume A507. Per Dr. S860, have 2'-9" embedment, 1 1/4" x 6 1/2" x 6 1/2" anchor π .

Have cluster of 4 bolts @ 15° (Dr. S835)

$$A_s = \frac{\pi}{4} (2.5)^2$$

$$= 4.91 \text{ in}^2$$

$$P_{all} = 4 (4.91) (34)$$

$$= 668 \text{ k} / 4 \text{ bolts} = 167 \text{ k/bolt}$$

Concrete Pullout

- Radius to outermost A.B. for RPV = 10'-11" Dr. S792
- " " innermost A.B. for sec. shield wall = 13'-4 3/4" Dr. S835
- " " outermost " = 14'-6" Dr. S835
- " " outside face of reactor pedestal = 15'-2" Dr. S789

$$\text{Edge distance} = (15'-2") - (14'-6") = 8"$$

$$\text{Radial spacing between sec. shield wall A.B.} = (14'-6") - (13'-4 3/4")$$

$$= 1 1/4"$$

$$\text{Radial spacing between sec. shield wall + RPV A.B.}$$

$$= (15'-2") - (10'-11") = 29 3/4"$$





JOB NO. 59037 JOB WYSS TRESTLE

BY RSK DATE 7-16-94

CALC. NO. C-042 SUBJECT Reinfor Bldg

CHK'D ME DATE 7-20-94

$$\begin{aligned} \text{Hoop spacing between A.B. of 4 bolt cluster} &= 6.0 \\ &= \frac{6}{180} \pi (14.5 \text{ cm}) \end{aligned}$$

$$= 17.6''$$

$$\begin{aligned} \text{Hoop spacing between A.B. of adjacent clusters} &= 9.0 \\ &= 26.4'' \end{aligned}$$

$$\begin{aligned} \text{Effective stress area} &= (8 + 13.25 + \frac{29.75}{2}) (17.6 + 26.4) - 4 (6.5)^2 \\ &= 1420 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} P_c &= 0.65 (4 \sqrt{4000}) (10^{-3}) (1420) \\ &= 234 \text{ k/4 bolts} = 58 \text{ k/bolt} \end{aligned}$$

Req'd capacity for ductile design (see outer skirt calc)

$$\begin{aligned} \text{Req'd } P_c &= 4 (4.00) (60) \\ &= 960 \text{ k/4 bolts} > 234 \text{ k/4 bolts} \end{aligned}$$

Side Cover

Check side cover per Commentary to Sect. B.5.1.1 of ACI 349-90

$$\begin{aligned} m &= \text{Side cover measured to bolt } \phi \\ &= 8'' \end{aligned}$$

$$\text{Required } m = D \left(\frac{f_{ut}}{73 \sqrt{f'_c}} \right)^{1/2}$$

$$D = \text{Bolt diameter} = 2.5''$$

$$f_{ut} = \text{Bolt tensile strength} = 60,000 \text{ psi}$$

$$f'_c = 4000 \text{ psi}$$

$$\begin{aligned} \text{Required } m &= 2.5 \left(\frac{60,000}{73 \sqrt{4000}} \right)^{1/2} \\ &= 9.0'' > 8.0'' \text{ provided} \end{aligned}$$

Doesn't meet ACI 349-90 criteria, but no worse than concrete pullout.



JOB NO. 59037 JOB WPPSS REEF

BY PSH

DATE 7-16-94

CALC. NO. C-042 SUBJECT Reactor Bldg

CHK'D

PSH

DATE 7-20-94

1 1/4" x 6 1/2" x 6 1/2" Anchor Plate

Check per Sect. B.4.5.2, AISC 344-90

$$1. \text{ Bearing area} = 6.5^2 - \frac{\pi}{4} (2.5)^2$$

$$= 37 \text{ in}^2$$

$$2.5 \times \text{Bolt Area} = 2.5 (4.9)$$

$$= 12 \text{ in}^2 < 37 \text{ in}^2 \quad \text{OK}$$

b. Anchor head thickness = 1.25"

Dimension from outer most edge of fl to face of A.S.

$$= \frac{6.5}{2} \sqrt{2} - \frac{2.5}{2}$$

$$= 3.3" > 1.25" \quad \text{N.G.}$$

Check Bearing per Sect. B.4.5.1, AISC 344-90

Check against Sect. 10.15, AISC 344-90

$$A_2 = (8 + \frac{13.25}{2}) (\frac{17.6 + 26.9}{2}) - 4.9$$

$$= 317 \text{ in}^2$$

$$A_1 = 6.5^2 - 4.9$$

$$= 37 \text{ in}^2$$

$$\sqrt{A_2/A_1} = (\frac{317}{37})^{1/2}$$

$$= 2.9 > 2$$

$$P_u = \phi (0.85 F_c A_1) \sqrt{A_2/A_1}$$

$$= 0.70 (0.85) (4) (37) (2)$$

$$= 176 \text{ k/bolt}$$

Check Shear In Anchor fl at Face of Bolt

Per Sect. N, AISC Specs (Ref. 6)

$$F_u = 0.55 F_y$$

$$F_y = 36 \text{ ksi}$$

Assume A36 steel

$$P_u = 0.55 (36) \pi (2.5) (1.25)$$

$$= 194 \text{ k}$$



JOB NO. 59037 JOB WPPSS BPEFEBY JSA DATE 7-16-99CALC. NO. C-042 SUBJECT Reactor BldgCHK'D AK DATE 7-20-99 $\frac{7}{8}$ " ϕ Weld From R to A-B

Check per AISC Sect. 2.

Assume E70 electrodes. $F_u = 72 \text{ ksi}$

$$F_v = 0.3(72)$$

$$= 21 \text{ ksi}$$

$$P_u = 1.7(21) \pi (2.5) \left(0.875 \sqrt{2} \right)$$

$$= 174 \text{ k}$$

Capacity of anchor R (174 k) is just barely equal to bolt capacity (167 k).

Shear Capacity

The shear capacity will be based on shear-friction provided by the anchor bolts. The clamping force that can be developed will be limited by the concrete pullout capacity. Increased shear friction capacity due to axial compression will be included per Sect. 11.7.2 of ACI 349-90. Shear capacity of the studs shown in Sect. 2708, Dr. 8792 will be conservatively neglected.

$$V_n = A_n f_y \mu$$

Egn. 11-26, ACI 349-90

$$\phi = 0.85$$

$$\mu = 0.55 \text{ for grouted interfaces, per Sect. P.6.2.2.2, ACI 349-90}$$

Anchor Bolts

4 bolts spaced at 15° . Ave. R $\approx 14 \text{ ft}$

$$P_c = 234 \text{ k}$$

$$\text{Cluster spacing} = \frac{15}{180} \pi (14)(12)$$

$$= 44 \text{ ''}$$

$$q_u = \frac{234}{44}$$

$$= 5.32 \text{ ksi}$$





JOB NO. 59037 JOB WPSS PPEE

BY PSH

DATE 7-16-99

CALC. NO. C-012 SUBJECT Reactor Bldg

CHK'D

AK

DATE 7-21-99

Axial Compression

Assume 40% of seismic axial force acts concurrent with max horiz. seismic.

$$\begin{aligned}
 P_{DL} &= 2400 \text{ k} \\
 P_{EA} &= 1100 \text{ k} \\
 P_{NET} &= 2400 - 0.4(1100) \\
 &= 2000 \text{ k} \\
 q_{NET} &= \frac{2000}{2\pi(14)(12)} \\
 &= 1.86 \text{ k/in}
 \end{aligned}$$

$$\begin{aligned}
 v_0 &= 0.85(0.55)(5.32 + 1.86) \\
 &= 3.36 \text{ k/in}
 \end{aligned}$$

HCLPF Capacity

$$\begin{aligned}
 \text{HCLPF Capacity} &= \frac{3.36}{1.52} (0.508) \\
 &= 1.18
 \end{aligned}$$





JOB NO. 59037 JOB WPPSS REEE BY FSH DATE 7-16-99
CALC. NO. C-042 SUBJECT Reactor Bldg CHK'D MC DATE 7-20-99

Overturning Moment On Sacrificial Shield Wall - Reactor Pedestal Interface

Overturning Moment Demand

See shear evaluation.

S&E moment = 22,700 k-ft

Bottom of Elmt. 24, PSAC Table 3.74
See Att. D

$M = 1.07 (22,700)$
 $= 24,300 \text{ k-ft}$

Overturning Moment Capacity

Use approach for outer skirt

$\bar{R} = 14 \text{ ft} = 168''$

Equivalent Ring Thickness In Compression

Sec. shield wall moment of inertia = 713. ft⁴ p. 180, Ref. 8.
 $= 1.60 \times 10^7 \text{ in}^4$

$t = \frac{1.60 \times 10^7}{\pi (168)^3}$
 $= 1.08''$

Equivalent Ring Thickness In Tension

4 - 2 1/2" A.B @ 15°

$t_{eq} = \frac{4(4.91)}{\frac{15}{180} \pi (168)} = 1.4''$
 $= 0.447'$

Limit bolt stress to concrete pullout capacity

$P_c = 234 \text{ k/4 bolts}$

$F_t = \frac{234}{0.447(4)}$

$= 11.9 \text{ ksi}$





JOB NO. 59037 JOB WPPSS JPPFE BY ESH DATE 7-16-94

CALC. NO. C-042 SUBJECT Reactor #1dg CHK'D AK DATE 7-20-94

$\beta = 1.85 \text{ rad}$

$$M_{11} = \frac{2(11.9)(148)^2}{1 - \cos 1.85} \left\{ (0.447 - 1.08) \left[\frac{1.85}{2} - \frac{1}{4} \sin 2(1.85) \right] + 1.08 \frac{\pi}{2} \right\}$$

$$= 5.42 \times 10^5 \text{ k-in}$$

$$= 45,200 \text{ k-ft}$$

HCLPF Capacity

$$\text{HCLPF Capacity} = \frac{45,200}{29,300} (0.508)$$

$$= 0.93 \text{ g}$$



JOB NO. 59057 JOB WPPSS IPEEE

BY JSH

DATE 7-16-99

CALC. NO. C-042 SUBJECT Reactor Bldg

CHK'D

AK

DATE 7-20-99

Shear Transfer From Drywell Floor to Containment Vessel

Shear Demand

Similar to sacrificial shield wall - reactor pedestal shear transfer, scale SSE shear by max. ratio of 84% ZPA for 0.5g PGA to SSE ZPA. See Atts. B and D

SSE Shear = 17,500 k

Dr. S799

Elevation	SSE		IPEEE, 0.5g PGA		
	Node	ZPA	Node	84% ZPA	84% ZPA / SSE ZPA
EL 567.381	24	0.76g	64	0.81g	1.07
EL 519.561	26	0.59g	62	0.54g	0.92
EL 500	30	0.48g	60	0.52g	1.08
EL 448.33	34	0.31g	56	0.39g	1.26

Max ratio = 1.26

V = 1.26 (17,500)

= 22,000 k

Have 36 lugs spaced at 10° Dr. S799

Max V / lug = $\frac{22,000}{\frac{1}{2}(36)}$

= 1220 k / lug

Shear Capacity

Note: Shear Lug - See Sect. 2354, Dr. S803

Estimate lug is about 9" x 11". Assume A36 steel

$V_u = 0.55(36)(9)(11)$

= 1,960 k





JOB NO. 59037 JOB: WASS BREE

BY PSH

DATE 7-16-94

CALC. NO. L-042 SUBJECT Reactor Bldg

CHK'D

MC

DATE 7-20-94

$7/8" \phi \times 3" \times 1/4"$ Nelson Studs - See Sect. 1845, Dr. S799; Sect. 1836, Dr. S803
 Moment due to offset of load from centroid of stud pattern is taken out by the stiffer ring R at $R = 38' - 6 5/16"$, which acts as a lug. Conservatively assume studs take out all of tangential shear, neglecting resistance from embedded plates acting as lugs, there 40 studs tributary to each lug (Dr. S803). Determine stud shear capacity per Sect. J5.3 of AISC LRFD Manual (Ref. 7).

$$Q_n = 0.5 A_{sc} \sqrt{f'_c E_c} \leq A_{sc} F_u \quad \text{(J5-1)}$$

$$A_{sc} = \text{Stud cross-sectional area} = 0.601 \text{ in}^2$$

$$f'_c = \text{Concrete compressive strength} = 4 \text{ ksi}$$

$$F_u = \text{Minimum specified stud tensile strength} = 60 \text{ ksi (Gr. 55)}$$

$$E_c = \text{Concrete modulus of elasticity}$$

$$= 145 \sqrt{4}$$

$$= 3500 \text{ ksi} \quad \text{LRFD}$$

$$Q_n = 0.5 (0.601) [4 (3500)]^{1/2}$$

$$= 35.6 \text{ k/stud} < A_{sc} F_u = 0.601 (60) = 36.0 \text{ k}$$

Check Stud Spacing per J5.6, LRFD

Studs spaced at 7" $> 6\phi = 5 1/4"$ OK

The strength reduction, ϕ , for this application is not defined.

Use a conservative value of 0.85

$$V_u = 0.85 (35.6) (40)$$

$$= 1210 \text{ k}$$

HCLPF Capacity

$$\text{HCLPF Capacity} = \frac{1210}{1220} (0.50)$$

$$= 0.50 \text{ g}$$





11


12

S.O Summary

59037-G-012
Calc. 59037-G-005

sketch II


Reactor Building




LEGEND

- Rigid Elements
- Beam Elements
- Lumped Mass
- ⊙ Node Numbers
- △ Element Numbers

Containment Vessel



Reactor Pedestal/
Sacrificial Shield



Local 2 = Global X = E-W
3 = Global Y = N-S



JOB NO. 59037.01 JOB WPPSS SSI Analysis

BY Jm


DATE 7/7/93

CALC. NO. C-005 SUBJECT Reactor Building Model

CHK'D JMB

DATE 7/19/93

(5) Section Properties between $\pm 1.470'$ and $500'$ (Ref. drawing S756)



All walls are 3' thick, except where noted.

- Notes
- 1) Elevator and staircase walls are neglected
 - 2) walls smaller than 2' thick are neglected
 - 3) Columns are neglected
 - 4) Wall (7) is 2'-6" thick for a length of 23'-2"




JOB NO. 59037.01 JOB WPPSS SSI Analysis
 CALC. NO. -C-005 SUBJECT Reactor Building Model

BY JMB DATE 7/7/93
 CHK'D JMB DATE 7/19/93

SHEET NO. 17

Calculation of wall equivalent thickness

Wall 4 (Ref Jwg S756)



Neglect bending


$$\frac{K_1}{G} = \frac{(130.25 - 3.417) \times 2.5}{7.208} = 43.990$$

$$\frac{K_2}{G} = \frac{130.25 \times 2.5}{21.792} = 14.942$$

$$\frac{G}{K_{eq}} = \frac{G}{K_1} + \frac{G}{K_2} = 8.966 \times 10^{-2} = \frac{29}{130.25 \times t_{eq}}$$

$\therefore t_{eq} = 2.48' \therefore$ use $t = 2.5'$

Wall 1 (Ref Jwg S756)



$$K_1^* = \frac{(102.75 - 3.417) \times 3}{7.208} = 4.134 \times 10^1$$

$$K_2^* = \frac{102.75 \times 3}{21.792} = 1.415 \times 10^1$$

$$\frac{1}{K_{eq}} = 9.189 \times 10^{-2} = \frac{29}{102.75 \times t_{eq}}$$

$\therefore t_{eq} = 2.975'$

\therefore use $t = 3.0'$



JOB NO. 59037.01 JOB Seismic Analysis of WPN-2 SHEET NO. 48
 CALC. NO. C-005 SUBJECT Reactor Building Wall BY: Am DATE 7/27/93
 CHK'D: JMB DATE 7/19/93


For walls 1-7

$$A = 2.5 \times (33.75 \cdot 23.17 + 146.5 + 43.75 + 130.25) + 3.0(52 + 102.75) + 3.5 \times 21.58$$

$$= 1483.3 \text{ ft}^2$$

For walls 4, 5, 6 & 7, $y_{avg} = \left[\frac{3 \times 52 + 2.5(33.75 + 130.25) + 3.5 \times 21.58 + 2.5}{52 + 33.75 + 44.75} \right] \times \frac{1}{2} = 2.68'$

For walls 1, 2 & 3, $y_{avg} = \left[\frac{2.5 \times 43.75 + 3 \times 102.75 + 2.5}{146.5} \right] \times \frac{1}{2} = 2.68'$



For X shear:

$$A_x = (149 + 45) \times 2.5 + 104 \times 3$$

$$= 797.0 \text{ ft}^2$$

For Y shear

$$A_y = (133 + 35 + 23.17) \times 2.5 + 52 \times 3 + 22.83 \times 3.5$$

$$= 713.8 \text{ ft}^2$$

WPPSS SSI ANALYSIS
 REACTOR BUILDING MODEL
 EL. 470' TO 500'

Calculation 59037-C-005

By JMB Date 7/7/93
 Checked JMB Date 7/19/93

1. Calculation of Center of Rigidity

Wall	L or Ro (ft)	T (ft)	A (ft ²)	Ax (ft ²)	Ay (ft ²)	X (ft)	Y (ft)	Ax*Y (ft ³)	Ay*x (ft ³)	A*X (ft ³)	A*Y (ft ³)
1 THRU 7	NA	NA	1483.30	797.00	713.80	-5.50	-5.50	-4384	-3926	-12232	-12232
8	48.17	5.0	1434.66	717.33	717.33	0.00	0.00	0	0	0	0
Sum			2917.96	1514.33	1431.13			-4384	-3926	-12232	-12232

$X_s = -2.74$ ft $X_a = -4.19$ ft
 $Y_s = -2.89$ ft $Y_a = -4.19$ ft

2. Calculation of the Moments of Inertia

Wall	L or Ro (ft)	A (ft ²)	Ax (ft ²)	Ay (ft ²)	xs (ft)	ys (ft)	xa (ft)	ya (ft)	Ixx (ft ⁴)	Iyy (ft ⁴)	Izz (ft ⁴)
1 THRU 7	NA	1483.3	797.0	713.8	-2.76	-2.61	-1.31	-1.31	4.340E+06	5.162E+06	7.093E+06
8	48.17	1434.7	717.3	717.3	2.74	2.89	4.19	4.19	1.526E+06	1.526E+06	3.024E+06
Sum		2917.961	1514.33	1431.13					5.866E+06	6.688E+06	1.012E+07

59037-C-005



2	5376.52	2827.66	2439.13	1.630E+07	1.064E+07	1.260E+07
3	4533.96	2474.83	1958.89	1.467E+07	9.623E+06	1.152E+07
4	2917.96	1514.33	1431.13	1.012E+07	5.866E+06	6.688E+06
5	3194.74	1292.91	1616.30	7.939E+06	5.599E+06	6.520E+06
6	2711.53	1414.70	1283.02	7.673E+06	4.823E+06	5.166E+06
7	2663.73	1377.80	1223.99	6.895E+06	4.238E+06	5.446E+06
8	2958.97	1581.55	1234.90	6.954E+06	4.095E+06	5.797E+06
9	3794.10	2042.05	1318.43	7.494E+06	4.557E+06	7.819E+06
10	23.73	2.532	3.219	2.357E+04	9.397E+04	5.236E+04
11	21.95	1.568	2.820	1.737E+04	8.646E+04	4.802E+04
12	36.66	18.33	18.33	6.787E+04	3.394E+04	3.394E+04
13	34.85	17.43	17.43	6.438E+04	3.219E+04	3.219E+04
14	32.77	16.39	16.39	6.067E+04	3.033E+04	3.033E+04
15	33.89	16.95	16.95	6.275E+04	3.137E+04	3.137E+04
16	38.23	19.12	19.12	6.743E+04	3.372E+04	3.372E+04
17	29.47	14.74	14.74	4.500E+04	2.250E+04	2.250E+04
18	33.04	16.52	16.52	4.258E+04	2.129E+04	2.129E+04
19	22.83	11.42	11.42	2.527E+04	1.263E+04	1.263E+04
20	20.13	10.07	10.07	1.873E+04	9.363E+03	9.363E+03
21	16.00	8.00	8.00	1.135E+04	5.673E+03	5.673E+03
22	10.23	5.12	5.12	5.372E+03	2.686E+03	2.686E+03
23	8.14	4.07	4.07	2.792E+03	1.396E+03	1.396E+03
24	564.15	347.50	347.50	8.048E+05	4.024E+05	4.024E+05
25	400.59	200.30	200.30	6.660E+04	3.330E+04	3.330E+04
26	456.58	228.29	228.29	7.888E+04	3.594E+04	3.594E+04
27	7.95	3.98	3.98	1.547E+03	7.733E+02	7.733E+02
28	1.0e6	1.0e6	1.0e6	1.0e9	1.0e9	1.0e9

1	3	4	112	1	1
2	6	7	113	1	2
3	9	10	114	1	3
4	12	13	115	1	4
5	15	16	116	1	5
6	18	19	117	1	6
7	21	22	118	1	7
8	24	25	119	1	8
9	27	28	120	1	9
10	30	31	121	2	10
11	33	34	121	2	11
12	39	40	122	2	12
13	40	41	122	2	13
14	41	42	122	2	14
15	42	43	122	2	15
16	43	44	122	2	16
17	44	45	122	2	17
18	45	46	122	2	18
19	46	47	122	2	19
20	47	48	122	2	20
21	48	49	122	2	21
22	49	50	122	2	22
23	50	51	122	2	23
24	55	56	122	1	24
25	56	57	122	1	24
26	57	58	122	1	24
27	58	59	122	1	24
28	58	59	122	1	24
29	59	60	122	1	25
30	60	61	122	1	25
31	61	62	122	1	26
32	62	63	122	2	27
33	63	64	122	2	27
34	64	65	122	2	27

35	65	66	122	2	27	
36	1	2	122	1	28	
2	15	15	0	4		
1	3.744e6		0.30		0.03	
2	4.032e6		0.30		0.03	
3	3.816e6		0.30		0.03	
4	1.656e6		0.42		0.03	
1	1.0e4	37.85	37.85	9.39E+03	4.70E+03	4.70E+03
2	1.0e4	37.85	37.85	9.39E+03	4.70E+03	4.70E+03
3	1.0e4	18.75	18.75	4.40E+03	2.20E+03	2.20E+03
4	1.0e4	18.75	18.75	4.40E+03	2.20E+03	2.20E+03
5	1.0e4	18.75	18.75	4.40E+03	2.20E+03	2.20E+03
6	1.0e4	18.75	18.75	4.40E+03	2.20E+03	2.20E+03
7	1.0e4	24.31	24.31	5.83E+03	2.91E+03	2.91E+03
8	1.0e4	24.31	24.31	5.83E+03	2.91E+03	2.91E+03
9	1.0e3	5.47	5.47	1.20E+03	5.99E+02	5.99E+02
10	1.0e3	4.75	4.75	7.84E+02	3.92E+02	3.92E+02
11	1.0e3	4.47	4.47	6.54E+02	3.27E+02	3.27E+02
12	1.0e3	4.47	4.47	6.54E+02	3.27E+02	3.27E+02
13	1.0e3	4.47	4.47	6.54E+02	3.27E+02	3.27E+02
14	1.0e3	4.52	4.52	5.73E-01	2.87E-01	2.87E-01
15	1.0e3	4.52	4.52	5.73E-01	2.87E-01	2.87E-01

1	70	71	122	1	1	
2	71	72	122	1	2	
3	72	73	122	1	3	
4	73	74	122	1	4	
5	74	75	122	1	5	
6	75	76	122	1	6	
7	76	77	122	1	7	
8	77	78	122	1	8	
9	62	78	122	2	9	
10	80	81	122	3	10	
11	81	82	122	3	11	
12	82	83	122	3	12	
13	83	84	122	3	13	
14	81	86	122	3	14	
15	86	83	122	3	15	
2	12	12	0	4		
1	3.989e6		0.30		0.03	
2	4.032e6		0.30		0.03	
3	3.715e6		0.30		0.03	
4	1.627e6		0.42		0.03	
1	37.51	1.0e6	1.0e6	1.0e8	1.0e8	1.0e8
2	38.71	1.0e6	1.0e6	1.0e8	1.0e8	1.0e8
3	14.03	1.0e6	1.0e6	1.0e8	1.0e8	1.0e8
4	0.44	1.0e6	1.0e6	1.0e8	1.0e8	1.0e8
5	9.13	1.0e6	1.0e6	1.0e8	1.0e8	1.0e8
6	8.84	1.0e6	1.0e6	1.0e8	1.0e8	1.0e8
7	8.05	1.0e6	1.0e6	1.0e8	1.0e8	1.0e8
8	3.00	1.0e6	1.0e6	1.0e8	1.0e8	1.0e8
9	9.59	1.0e6	1.0e6	1.0e8	1.0e8	1.0e8
10	6.48	1.0e6	1.0e6	1.0e8	1.0e8	1.0e8
11	2.432e-2	1.0e5	1.0e5	1.0e6	1.0e6	1.0e6
12	3.882	1.0e6	1.0e6	1.0e8	1.0e8	1.0e8

1	87	88	122	1	1
2	88	89	122	1	2
3	89	62	122	2	3
4	90	91	122	3	4

59037-C-042

5	91	92	122	3	5
6	92	93	122	3	6
7	89	94	122	1	7
8	94	95	122	1	8
9	96	97	122	4	9
10	97	95	122	3	10
11	93	88	122	3	11
12	93	94	122	3	12
9	9	3	1		
1	23	50	24	0.03	
8.230e5					
	8.230e5				

-8.230e5
-8.230e5

8.230e5
8.230e5

2	50	66	122	0.03	
2.340e5					
	2.340e5				

-2.340e5
-2.340e5

2.340e5
2.340e5

3	44	60	122	0.07	
3.500e7					
	3.500e7				

-3.500e7
-3.500e7

3.500e7
3.500e7

4	66	73	122	0.03	
9.600e5					
	9.600e5				

-9.600e5
-9.600e5

9.600e5
9.600e5

5	51	71	122	0.03	
1.047e4					
	1.047e4				

6.047e4
6.047e4

-1.047e4
-1.047e4

-6.047e4
-6.047e4

1.047e4
1.047e4

6.047e4
6.047e4

6	78	84	122	0.03	
1.0e10					
	1.0e10				

1.0e10
1.250e8
1.250e8

1.0e11

-1.250e8
-1.250e8

1.0e10
1.0e10

1.0e10
1.250e8
1.250e8

1.0e11

7	29	36		.005	
68.32					
	67.89				

1.0e6
1.0e6

B9057-C-CHZ

			1.0e6				
-68.32				1.0e6			
	-67.89						
68.32							
	67.89						
		1.0e6					
			1.0e6				
				1.0e6			
8	40	52	.005			1.0e6	
271.8							
	271.8						
		1.0e6					
			1.0e6				
				1.0e6			
-271.8						1.0e6	
	-271.8						
271.8							
	271.8						
		1.0e6					
			1.0e6				
				1.0e6			
9	67	52	.005			1.0e6	
271.8							
	271.8						
		1.0e6					
			1.0e6				
				1.0e6			
-271.8						1.0e6	
	-271.8						
271.8							
	271.8						
		1.0e6					
			1.0e6				
				1.0e6			
5	0	570.56	570.56	764.52	9.19E+05	8.93E+05	1.61E+06
8	0	475.39	475.39	543.77	1.01E+06	1.07E+06	2.10E+06
11	0	653.72	653.72	653.72	1.35E+06	1.52E+06	2.80E+06
14	0	587.14	587.14	587.14	1.09E+06	1.19E+06	2.23E+06
17	0	562.54	562.54	562.54	9.46E+05	1.13E+06	2.04E+06
20	0	570.98	570.98	570.98	9.58E+05	1.16E+06	2.09E+06
23	0	309.31	309.31	385.21	2.63E+05	5.00E+05	7.55E+05
26	0	650.92	650.92	622.76	7.73E+05	1.34E+06	2.05E+06
29	0	646.47	646.47	616.77	9.10E+05	1.34E+06	2.18E+06
32	0	42.84	42.84	42.84	1.57E+05	1.51E+05	3.05E+05
35	0	73.49	73.49	73.49	1.74E+05	2.12E+05	3.81E+05
36	0	23.21	27.22	0.00	0.00E+00	0.00E+00	0.00E+00

40	0	53.18	53.18	23.90	3.77E+04	3.77E+04	7.42E+04
41	0	11.12	11.12	11.12	1.04E+04	1.04E+04	2.04E+04
42	0	8.00	8.00	8.00	7.46E+03	7.46E+03	1.47E+04
43	0	5.78	5.78	5.78	5.36E+03	5.36E+03	1.06E+04
44	0	7.32	7.32	7.32	6.47E+03	6.47E+03	1.28E+04
45	0	24.82	24.82	24.82	1.74E+04	1.74E+04	3.43E+04
46	0	13.28	13.28	13.28	8.02E+03	8.02E+03	1.48E+04
47	0	6.44	6.44	6.44	3.33E+03	3.33E+03	6.56E+03
48	0	34.52	34.52	34.52	1.50E+04	1.50E+04	2.90E+04
49	0	8.74	8.74	8.74	2.70E+03	2.70E+03	5.16E+03
50	0	30.40	30.40	30.40	7.52E+03	7.52E+03	1.40E+04
51	0	8.06	8.06	8.06	1.13E+03	1.13E+03	1.99E+03
52	0	127.03	127.03	0.00	0.00E+00	0.00E+00	0.00E+00
56	0	72.00	72.00	27.70	2.03E+04	2.03E+04	3.86E+04
57	0	48.34	48.34	28.61	9.51E+03	9.51E+03	1.51E+04
58	0	26.40	26.40	26.40	2.94E+03	2.94E+03	4.13E+03
59	0	32.30	32.30	32.30	3.03E+03	3.03E+03	5.05E+03
60	0	118.10	118.10	125.20	9.64E+03	9.64E+03	1.85E+04
61	0	29.10	29.10	29.10	2.59E+03	2.59E+03	4.55E+03
62	0	31.74	31.74	31.74	2.86E+03	2.86E+03	5.46E+03
63	0	16.50	16.50	16.50	1.87E+03	1.87E+03	3.23E+03
64	0	32.50	32.50	32.50	3.75E+03	3.75E+03	6.37E+03
65	0	18.30	18.30	18.30	2.26E+03	2.26E+03	3.59E+03
66	0	8.55	8.55	8.55	8.86E+02	8.86E+02	1.68E+03
70	0	5.49	5.49	0.00	354.90	354.90	709.80
72	0	9.51	9.51	0.00	2458.30	2458.30	4916.60
73	0	5.63	5.63	0.00	1455.40	1455.40	2910.80
74	0	10.50	10.50	0.00	1215.00	1215.00	2430.00
75	0	22.35	22.35	0.00	1124.50	1124.50	2249.00
76	0	17.09	17.09	0.00	1147.70	1147.70	2295.40
77	0	17.64	17.64	0.00	1406.20	1406.20	2812.40
78	0	10.80	10.80	0.00	1763.00	1763.00	3526.00
80	0	8.01	8.01	0.00	834.60	834.60	1669.20
81	0	21.98	21.98	0.00	1003.50	1003.50	2007.00
82	0	13.09	13.09	0.00	159.00	159.00	318.00
83	0	18.21	18.21	0.00	1213.80	1213.80	2427.60
86	0	14.73	14.73	0.00	1455.60	1455.60	2911.20
87	0	0.00	0.00	35.37	0.00	0.00	
88	0	0.00	0.00	12.40	0.00	0.00	
89	0	0.00	0.00	2.39	0.00	0.00	
90	0	0.00	0.00	7.03	0.00	0.00	
91	0	0.00	0.00	6.16	0.00	0.00	
92	0	0.00	0.00	1.61	0.00	0.00	
93	0	0.00	0.00	5.55	0.00	0.00	
94	0	0.00	0.00	6.25	0.00	0.00	
95	0	0.00	0.00	10.21	0.00	0.00	
96	0	0.00	0.00	8.21	0.00	0.00	
97	0	0.00	0.00	10.65	0.00	0.00	

50.0

57037-047





File: X:\WPPSS\REACTOR\IPEEE\50\SSINO.MSD Page: 1
 Program: MOPREX VER 1.0
 Version Date: 12-01-93 12:50
 Input File Name: SSINO

PROGRAM SSTR, IPEEE-80366/DOS VERSION 1.1P
 Compiler: SYC CS FORTRAN-77 Version 2.0.2, Release 1.1
 Compilation Date and Time: 12/17/93 09:08:17
 Execution Date and Time: 01/25/94 06:56:38

Three-Dimensional Rigid Foundation SSI Response Analysis
 Reference EOE/ECG QA Project Number AA-QA-04

CALCULATION NUMBER: 59037-C-024
 TITLE: Reactor Building IPEEE Analysis

PROBLEM DESCRIPTION:
 Reactor Building, IPEEE PCA-0.50g

RESPONSE HEADERS

11	fdn 1	abs accel	x-translation
21	fdn 1	abs accel	y-translation
31	fdn 1	abs accel	z-translation
41	fdn 1	abs accel	xx-rotation
51	fdn 1	abs accel	yy-rotation
61	fdn 1	abs accel	zz-rotation
71	str 1	base force	x-shear force
81	str 1	base force	y-shear force
91	str 1	base force	vertical force
101	str 1	base force	xx-ot-moment
111	str 1	base force	yy-ot-moment
121	str 1	base force	torsional moment
131	str 1	abs accel	node 5 x-tran
141	str 1	abs accel	node 5 y-tran
151	str 1	abs accel	node 5 z-tran
161	str 1	abs accel	node 5 xx-rot
171	str 1	abs accel	node 5 yy-rot
181	str 1	abs accel	node 5 zz-rot
191	str 1	abs accel	node 8 x-tran
201	str 1	abs accel	node 8 y-tran
211	str 1	abs accel	node 8 z-tran
221	str 1	abs accel	node 8 xx-rot
231	str 1	abs accel	node 8 yy-rot
241	str 1	abs accel	node 8 zz-rot
251	str 1	abs accel	node 11 x-tran
261	str 1	abs accel	node 11 y-tran
271	str 1	abs accel	node 11 z-tran
281	str 1	abs accel	node 11 xx-rot
291	str 1	abs accel	node 11 yy-rot
301	str 1	abs accel	node 11 zz-rot
311	str 1	abs accel	node 14 x-tran
321	str 1	abs accel	node 14 y-tran
331	str 1	abs accel	node 14 z-tran
341	str 1	abs accel	node 14 xx-rot
351	str 1	abs accel	node 14 yy-rot
361	str 1	abs accel	node 14 zz-rot

File: X:\WPPSS\REACTOR\IPEEE\50\SSINO.MSD Page: 3

1031	str 1	abs accel	node 60 x-tran
1041	str 1	abs accel	node 60 y-tran
1051	str 1	abs accel	node 60 z-tran
1061	str 1	abs accel	node 60 xx-rot
1071	str 1	abs accel	node 60 yy-rot
1081	str 1	abs accel	node 60 zz-rot
1091	str 1	abs accel	node 62 x-tran
1101	str 1	abs accel	node 62 y-tran
1111	str 1	abs accel	node 62 z-tran
1121	str 1	abs accel	node 62 xx-rot
1131	str 1	abs accel	node 62 yy-rot
1141	str 1	abs accel	node 62 zz-rot
1151	str 1	abs accel	node 66 x-tran
1161	str 1	abs accel	node 66 y-tran
1171	str 1	abs accel	node 66 z-tran
1181	str 1	abs accel	node 66 xx-rot
1191	str 1	abs accel	node 66 yy-rot
1201	str 1	abs accel	node 66 zz-rot
1211	str 1	elat force	elat 1-1 7p 1
1221	str 1	elat force	elat 1-2 7p 1
1231	str 1	elat force	elat 1-3 7p 1
1241	str 1	elat force	elat 1-4 7p 1
1251	str 1	elat force	elat 1-5 7p 1
1261	str 1	elat force	elat 1-6 7p 1
1271	str 1	elat force	elat 1-11 7p 1
1281	str 1	elat force	elat 1-12 7p 1
1291	str 1	elat force	elat 2-1 7p 1
1301	str 1	elat force	elat 2-2 7p 1
1311	str 1	elat force	elat 2-3 7p 1
1321	str 1	elat force	elat 2-4 7p 1
1331	str 1	elat force	elat 2-5 7p 1
1341	str 1	elat force	elat 2-6 7p 1
1351	str 1	elat force	elat 2-11 7p 1
1361	str 1	elat force	elat 2-12 7p 1
1371	str 1	elat force	elat 3-1 7p 1
1381	str 1	elat force	elat 3-2 7p 1
1391	str 1	elat force	elat 3-3 7p 1
1401	str 1	elat force	elat 3-4 7p 1
1411	str 1	elat force	elat 3-5 7p 1
1421	str 1	elat force	elat 3-6 7p 1
1431	str 1	elat force	elat 3-11 7p 1
1441	str 1	elat force	elat 3-12 7p 1
1451	str 1	elat force	elat 4-1 7p 1
1461	str 1	elat force	elat 4-2 7p 1
1471	str 1	elat force	elat 4-3 7p 1
1481	str 1	elat force	elat 4-4 7p 1
1491	str 1	elat force	elat 4-5 7p 1
1501	str 1	elat force	elat 4-6 7p 1
1511	str 1	elat force	elat 4-11 7p 1
1521	str 1	elat force	elat 4-12 7p 1
1531	str 1	elat force	elat 5-1 7p 1
1541	str 1	elat force	elat 5-2 7p 1
1551	str 1	elat force	elat 5-3 7p 1
1561	str 1	elat force	elat 5-4 7p 1
1571	str 1	elat force	elat 5-5 7p 1
1581	str 1	elat force	elat 5-6 7p 1
1591	str 1	elat force	elat 5-11 7p 1
1601	str 1	elat force	elat 5-12 7p 1
1611	str 1	elat force	elat 6-1 7p 1
1621	str 1	elat force	elat 6-2 7p 1
1631	str 1	elat force	elat 6-3 7p 1
1641	str 1	elat force	elat 6-4 7p 1
1651	str 1	elat force	elat 6-5 7p 1
1661	str 1	elat force	elat 6-6 7p 1
1671	str 1	elat force	elat 6-11 7p 1
1681	str 1	elat force	elat 6-12 7p 1

File: X:\WPPSS\REACTOR\IPEEE\50\SSINO.MSD Page: 2

371	str 1	abs accel	node 17 x-tran
381	str 1	abs accel	node 17 y-tran
391	str 1	abs accel	node 17 z-tran
401	str 1	abs accel	node 17 xx-rot
411	str 1	abs accel	node 17 yy-rot
421	str 1	abs accel	node 17 zz-rot
431	str 1	abs accel	node 20 x-tran
441	str 1	abs accel	node 20 y-tran
451	str 1	abs accel	node 20 z-tran
461	str 1	abs accel	node 20 xx-rot
471	str 1	abs accel	node 20 yy-rot
481	str 1	abs accel	node 20 zz-rot
491	str 1	abs accel	node 23 x-tran
501	str 1	abs accel	node 23 y-tran
511	str 1	abs accel	node 23 z-tran
521	str 1	abs accel	node 23 xx-rot
531	str 1	abs accel	node 23 yy-rot
541	str 1	abs accel	node 23 zz-rot
551	str 1	abs accel	node 26 x-tran
561	str 1	abs accel	node 26 y-tran
571	str 1	abs accel	node 26 z-tran
581	str 1	abs accel	node 26 xx-rot
591	str 1	abs accel	node 26 yy-rot
601	str 1	abs accel	node 26 zz-rot
611	str 1	abs accel	node 29 x-tran
621	str 1	abs accel	node 29 y-tran
631	str 1	abs accel	node 29 z-tran
641	str 1	abs accel	node 29 xx-rot
651	str 1	abs accel	node 29 yy-rot
661	str 1	abs accel	node 29 zz-rot
671	str 1	abs accel	node 32 x-tran
681	str 1	abs accel	node 32 y-tran
691	str 1	abs accel	node 32 z-tran
701	str 1	abs accel	node 32 xx-rot
711	str 1	abs accel	node 32 yy-rot
721	str 1	abs accel	node 32 zz-rot
731	str 1	abs accel	node 35 x-tran
741	str 1	abs accel	node 35 y-tran
751	str 1	abs accel	node 35 z-tran
761	str 1	abs accel	node 35 xx-rot
771	str 1	abs accel	node 35 yy-rot
781	str 1	abs accel	node 35 zz-rot
791	str 1	abs accel	node 42 x-tran
801	str 1	abs accel	node 42 y-tran
811	str 1	abs accel	node 42 z-tran
821	str 1	abs accel	node 42 xx-rot
831	str 1	abs accel	node 42 yy-rot
841	str 1	abs accel	node 42 zz-rot
851	str 1	abs accel	node 47 x-tran
861	str 1	abs accel	node 47 y-tran
871	str 1	abs accel	node 47 z-tran
881	str 1	abs accel	node 47 xx-rot
891	str 1	abs accel	node 47 yy-rot
901	str 1	abs accel	node 47 zz-rot
911	str 1	abs accel	node 50 x-tran
921	str 1	abs accel	node 50 y-tran
931	str 1	abs accel	node 50 z-tran
941	str 1	abs accel	node 50 xx-rot
951	str 1	abs accel	node 50 yy-rot
961	str 1	abs accel	node 50 zz-rot
971	str 1	abs accel	node 56 x-tran
981	str 1	abs accel	node 56 y-tran
991	str 1	abs accel	node 56 z-tran
1001	str 1	abs accel	node 56 xx-rot
1011	str 1	abs accel	node 56 yy-rot
1021	str 1	abs accel	node 56 zz-rot

File: X:\WPPSS\REACTOR\IPEEE\50\SSINO.MSD Page: 4

1691	str 1	elat force	elat 7-1 7p 1
1701	str 1	elat force	elat 7-2 7p 1
1711	str 1	elat force	elat 7-3 7p 1
1721	str 1	elat force	elat 7-4 7p 1
1731	str 1	elat force	elat 7-5 7p 1
1741	str 1	elat force	elat 7-6 7p 1
1751	str 1	elat force	elat 7-11 7p 1
1761	str 1	elat force	elat 7-12 7p 1
1771	str 1	elat force	elat 8-1 7p 1
1781	str 1	elat force	elat 8-2 7p 1
1791	str 1	elat force	elat 8-3 7p 1
1801	str 1	elat force	elat 8-4 7p 1
1811	str 1	elat force	elat 8-5 7p 1
1821	str 1	elat force	elat 8-6 7p 1
1831	str 1	elat force	elat 8-11 7p 1
1841	str 1	elat force	elat 8-12 7p 1
1851	str 1	elat force	elat 9-1 7p 1
1861	str 1	elat force	elat 9-2 7p 1
1871	str 1	elat force	elat 9-3 7p 1
1881	str 1	elat force	elat 9-4 7p 1
1891	str 1	elat force	elat 9-5 7p 1
1901	str 1	elat force	elat 9-6 7p 1
1911	str 1	elat force	elat 9-11 7p 1
1921	str 1	elat force	elat 9-12 7p 1
1931	str 1	elat force	elat 10-1 7p 1
1941	str 1	elat force	elat 10-2 7p 1
1951	str 1	elat force	elat 10-3 7p 1
1961	str 1	elat force	elat 10-4 7p 1
1971	str 1	elat force	elat 10-5 7p 1
1981	str 1	elat force	elat 10-6 7p 1
1991	str 1	elat force	elat 10-11 7p 1
2001	str 1	elat force	elat 10-12 7p 1
2011	str 1	elat force	elat 11-1 7p 1
2021	str 1	elat force	elat 11-2 7p 1
2031	str 1	elat force	elat 11-3 7p 1
2041	str 1	elat force	elat 11-4 7p 1
2051	str 1	elat force	elat 11-5 7p 1
2061	str 1	elat force	elat 11-6 7p 1
2071	str 1	elat force	elat 11-11 7p 1
2081	str 1	elat force	elat 11-12 7p 1
2091	str 1	elat force	elat 12-1 7p 1
2101	str 1	elat force	elat 12-2 7p 1
2111	str 1	elat force	elat 12-3 7p 1
2121	str 1	elat force	elat 12-4 7p 1
2131	str 1	elat force	elat 12-5 7p 1
2141	str 1	elat force	elat 12-6 7p 1
2151	str 1	elat force	elat 12-11 7p 1
2161	str 1	elat force	elat 12-12 7p 1
2171	str 1	elat force	elat 13-1 7p 1
2181	str 1	elat force	elat 13-2 7p 1
2191	str 1	elat force	elat 13-3 7p 1
2201	str 1	elat force	elat 13-4 7p 1
2211	str 1	elat force	elat 13-5 7p 1
2221	str 1	elat force	elat 13-6 7p 1
2231	str 1	elat force	elat 13-11 7p 1
2241	str 1	elat force	elat 13-12 7p 1
2251	str 1	elat force	elat 14-1 7p 1
2261	str 1	elat force	elat 14-2 7p 1
2271	str 1	elat force	elat 14-3 7p 1
2281	str 1	elat force	elat 14-4 7p 1
2291	str 1	elat force	elat 14-5 7p 1
2301	str 1	elat force	elat 14-6 7p 1
2311	str 1	elat force	elat 14-11 7p 1
2321	str 1	elat force	elat 14-12 7p 1
2331	str 1	elat force	elat 14-1 7p 1
2341	str 1	elat force	elat 14-2 7p 1

File: X:\WPPSS\REACTOR\IPEEE\50\SSINO.MSD Page: 5

Table with columns: str, elat, force, elat, 24-3, 1 pp 1. Rows 2351-2561.

CALCULATION RESULT

Table with columns: Row#, MEAN, MEAN+STD, 501, 84, 134. Rows 11-401.

File: X:\WPPSS\REACTOR\IPEEE\50\SSINO.MSD Page: 7

Table with columns: 1071, 1072, 1073, 1074, 1075, 1076, 1077, 1078, 1079, 1080, 1081, 1082, 1083, 1084, 1085, 1086, 1087, 1088, 1089, 1090, 1091, 1092, 1093, 1094, 1095, 1096, 1097, 1098, 1099, 1100, 1101, 1102, 1103, 1104, 1105, 1106, 1107, 1108, 1109, 1110, 1111, 1112, 1113, 1114, 1115, 1116, 1117, 1118, 1119, 1120, 1121, 1122, 1123, 1124, 1125, 1126, 1127, 1128, 1129, 1130, 1131, 1132, 1133, 1134, 1135, 1136, 1137, 1138, 1139, 1140, 1141, 1142, 1143, 1144, 1145, 1146, 1147, 1148, 1149, 1150, 1151, 1152, 1153, 1154, 1155, 1156, 1157, 1158, 1159, 1160, 1161, 1162, 1163, 1164, 1165, 1166, 1167, 1168, 1169, 1170, 1171, 1172.

File: X:\WPPSS\REACTOR\IPEEE\50\SSINO.MSD Page: 6

Table with columns: 411, 421, 431, 441, 451, 461, 471, 481, 491, 501, 511, 521, 531, 541, 551, 561, 571, 581, 591, 601, 611, 621, 631, 641, 651, 661, 671, 681, 691, 701, 711, 721, 731, 741, 751, 761, 771, 781, 791, 801, 811, 821, 831, 841, 851, 861, 871, 881, 891, 901, 911, 921, 931, 941, 951, 961, 971, 981, 991, 1001, 1011, 1021, 1031, 1041, 1051, 1061.


File: X:\WPPSS\REACTOR\IPEEE\50\SSINO.MSD Page: 8

Table with columns: 1721, 1731, 1741, 1751, 1761, 1771, 1781, 1791, 1801, 1811, 1821, 1831, 1841, 1851, 1861, 1871, 1881, 1891, 1901, 1911, 1921, 1931, 1941, 1951, 1961, 1971, 1981, 1991, 2001, 2011, 2021, 2031, 2041, 2051, 2061, 2071, 2081, 2091, 2101, 2111, 2121, 2131, 2141, 2151, 2161, 2171, 2181, 2191, 2201, 2211, 2221, 2231, 2241, 2251, 2261, 2271, 2281, 2291, 2301, 2311, 2321, 2331, 2341, 2351, 2361, 2371, 2381, 2391, 2401, 2411, 2421, 2431, 2441, 2451, 2461, 2471, 2481, 2491, 2501, 2511, 2521, 2531, 2541, 2551, 2561, 2571, 2581, 2591, 2601.


File: X:\WPPSS\REACTOR\IPEEE\50\SSINO.MSD Page: 9

2391	4.72477e+03	5.78670e+03	4.78600e+03	5.63430e+03
2401	4.32847e+03	5.31555e+03	4.08700e+03	5.58145e+03
2411	1.56204e+01	2.02884e+01	1.46350e+01	2.04335e+01
2421	1.06724e+02	1.32050e+02	1.04100e+02	1.22532e+02
2431	1.14039e+02	1.40205e+02	1.17050e+02	1.36615e+02
2441	1.11144e+01	1.32708e+01	1.07650e+01	1.27186e+01
2451	4.69363e+03	5.75920e+03	4.75450e+03	5.59759e+03
2461	4.29810e+03	5.27840e+03	4.05900e+03	5.54754e+03
2471	3.33980e+03	4.86448e+03	4.04350e+03	4.61082e+03
2481	3.59817e+03	4.47624e+03	3.37250e+03	4.61302e+03
2491	1.66200e+01	2.14160e+01	1.56050e+01	2.20137e+01
2501	1.84793e+02	1.90014e+02	1.33908e+02	1.93025e+02
2511	1.72440e+02	2.14618e+02	1.69300e+02	2.07948e+02
2521	6.18303e+00	8.13823e+00	5.84000e+00	7.58025e+00
2531	4.17960e+02	5.14680e+02	4.10700e+02	5.01609e+02
2541	4.57000e+02	5.85957e+02	4.38700e+02	5.23519e+02
2551	2.39650e+03	2.96781e+03	2.31800e+03	2.85497e+03
2561	2.22460e+03	2.70706e+03	2.23500e+03	2.74852e+03







PLAN OF VESSEL, CRANE TOWER, SHEAVES AND HOIST ANCHORS @ EL 422'3"




SECTION A-A
QUINCE SHRT ANCHORS
(TYP. TO PLACES EQUALLY SPACED)
180 ANCHORS TOTAL




SECTION B-B
QUINCE SHRT ANCHORS
(TYP. TO PLACES EQUALLY SPACED)
180 ANCHORS TOTAL




SECTION C-C
(TYP. FOR TWO SHEAVES, 8 ANCHORS
PER SHEAV EQUALLY SPACED)



SECTION D-D
(TYP. FOR TWO SHEAVES, 8 ANCHOR
BOLTS PER SHEAVE EQUALLY SPACED)



SECTION E-E
(TYP. FOR TWO SHEAVES, 8 ANCHORS
FOR EACH ANCHOR)



SECTION F-F
(TYP. FOR TWO SHEAVES, 8 ANCHORS
FOR EACH ANCHOR)

- NOTES:**
- 1 ALL PLATE MATERIAL UNLESS OTHERWISE NOTED SHALL BE A36
 - 2 ALL SHEAVES SHALL BE 2 1/2 INCH DIAMETER
 - 3 BOLT PLATES FOR THE CRANE TOWER, SHEAVES & HOIST ANCHORS SHALL BE A36 GR. C PER ASTM A307 & R. CONFORM WITH SECTION 2
 - 4 WORK THIS DRAWING WITH DWG D-3 (D-10)
 - 5 CRANE TOWER UPLIFT CARRIED BY WET SAND AND COLUMN STEEL WEIGHT
 - 6 FROM TO FURNISH ANCHOR BOLTS / SHEAR PLATES TO INSTALL ANCHOR BOLTS (SHEAR PLATES) FROM TO INSTALL THE CRANE TOWER, SHEAVES & HOIST ANCHORS MATERIALS ONLY.
 - 7 ALL BOLTING MATERIAL TO BE IN ACCORDANCE WITH ASTM A 307.
 - 8 ALL PLATE SHALL BE GALV. CO.

RECEIVED MAR 19 1973


ZK03226708

154051-C-012

TRANSMITTAL NO	D&R CONTRACT NO. 215
PITTSBURGH-BES-MAINES STEEL CO. ENGINEERS FABRICATORS CONTRACTORS 1000 BROADWAY PITTSBURGH, PA. 15203 WPPSS PRIMARY CONTAINMENT VESSEL HANFORD P.O. 2, P.O. BOX 100 ANCHOR BOLT PLAN / DETAILS	







INFORMATION ONLY
 ZK03226710

RECEIVED MAR 19 1973

TRANSMITTAL NO.	S/R CONTRACT NO. 213	PITTSBURGH-DIS. MOINIS STEEL CO. ENGINEERS FABRICATORS-CONTRACTORS SUPPLY COMPANY CONTAINMENT VESSEL MANAGED FOR FURNACE #1000000 INNER/OUTER SKIRT DETAILS



EQE INTERNATIONAL

SHEET NO. PI

JOB NO. 59037 JOB WPPSS IPEEE

BY PSH

DATE 7-14-94

CALC. NO. C-042 SUBJECT Reactor Body

CHK'D MC

DATE 7-20-94

ATTACHMENT D

EXCERPTS FROM REFERENCE 4

(6 pp. total)

TABLE 3.7-9

REACTOR BUILDING - SEISMIC ANALYSISHORIZONTAL N-S DIRECTION - SSEACCELERATION(UNITS IN $G \times 10^{-3}$)

MASS	MODE NUMBER										COMBINE
	1	2	3	4	5	6	7	8	9	10	
1	1171.05	-1177.02	276.94	- 15.31	.87	- 1.74	- .92	- 2.67	- .03	.07	1683.35
2	654.94	48.04	-235.69	31.90	- .40	12.34	5.36	11.52	.06	1.81	698.76
3	534.80	51.65	- 91.18	26.96	2.15	4.10	- 1.23	-14.37	- .43	1.24	545.88
4	466.20	50.43	- 14.14	29.59	2.33	- 1.10	- 3.80	-20.06	- .07	.80	470.67
5	380.53	46.92	76.24	30.63	2.51	- 5.66	- 5.26	-19.23	.37	- 2.55	392.93
6	315.55	43.12	138.21	30.23	2.76	- 6.89	- 5.07	-14.78	.52	- 2.61	349.14
7	222.28	35.73	212.77	27.47	2.63	- 6.34	- 2.67	.15	.51	- 1.26	311.07
8	147.65	28.85	260.19	24.60	2.87	- 3.06	- .03	9.96	.25	.16	301.76
9	124.64	26.45	270.16	25.01	3.51	- 1.65	.54	12.32	.24	.50	300.05
10	80.75	22.21	291.72	25.71	5.15	1.97	1.16	11.98	.39	.56	304.92
11	586.10	65.63	- 54.12	-143.56	27.90	4.05	- 6.72	1.91	- 5.25	1.08	610.12
12	539.23	62.56	- 01.39	-138.12	17.72	2.71	- 2.99	- 4.37	- 4.32	.57	560.50
13	502.89	61.95	60.02	-149.57	- .73	- .90	2.89	- 9.70	- 5.11	.25	531.88
14	447.87	60.25	142.44	-159.81	-22.93	- 4.93	9.99	-15.94	- 5.81	- .17	501.30
15	414.72	58.86	187.30	-162.70	-33.85	- 6.73	13.38	-18.69	- 5.87	- .38	489.14
16	386.14	57.51	223.71	-163.71	-42.05	- 7.97	15.87	-20.61	- 5.79	- .54	482.14
17	358.25	56.01	256.57	-162.99	-48.64	- 8.81	17.79	-21.95	- 5.57	- .67	477.42
18	320.84	53.69	295.97	-159.12	-55.07	- 9.31	19.44	-22.74	- 4.98	- .77	472.93
19	298.22	50.63	295.40	-135.23	-48.61	- 9.13	17.46	-18.19	- 4.53	- .67	448.09
20	257.60	44.89	290.39	- 89.37	-35.30	- 8.55	13.26	- 9.15	- 3.59	- .46	403.14
21	218.66	39.36	284.85	- 46.11	-21.94	- 7.56	8.99	- .65	- 2.60	- .23	365.06
22	182.03	34.27	280.84	- 8.04	- 9.49	- 6.18	5.01	6.57	- 1.66	- .04	336.91
23	147.68	28.86	260.31	24.53	2.85	- 3.07	- .02	9.95	.25	.16	301.86
24	576.53	83.03	99.10	-468.71	101.66	10.28	-21.16	34.47	- 7.83	- 1.00	763.14
25	542.07	82.06	181.51	-464.05	27.28	17.41	-27.05	35.37	- .76	- .07	744.18
26	482.18	78.19	284.55	-426.89	-57.65	16.91	-17.53	12.40	12.74	1.62	711.68
27	441.14	73.22	314.49	-368.87	-79.17	8.77	- 1.87	-10.08	13.06	1.42	664.52
28	394.20	65.99	318.01	-284.98	-75.63	- 3.30	16.83	-31.49	7.13	.42	591.78
29	368.69	61.84	313.11	-242.03	-70.47	- 5.60	18.40	-29.56	2.76	- .04	551.07
30	321.12	53.86	297.95	-161.22	-55.96	- 9.33	19.69	-23.20	- 4.98	- .78	475.25
31	288.45	48.96	293.32	-117.77	-47.57	-10.49	19.01	-17.62	- 8.10	- .99	435.07
32	240.68	41.82	283.08	- 60.23	-32.60	-10.38	15.33	- 7.27	- 9.40	- .85	381.06
33	196.89	35.51	273.50	- 16.25	-17.68	- 8.55	10.11	2.60	- 7.60	- .39	340.15
34	157.80	30.27	267.98	12.82	- 4.86	- 5.44	4.67	9.88	- 3.85	.15	313.17
35	124.65	26.46	270.19	25.01	- 3.49	- 1.66	.55	12.32	.23	.50	300.07

3.7-57

WNP-2

59037-C-042

DL

TABLE 3.7-11

REACTOR BUILDING - SEISMIC ANALYSIS

HORIZONTAL N-S DIRECTION - SSE

MEMBER SHEARS

(UNITS IN KIPS)

MEMBER	MODE NUMBER										COMBINED
	1	2	3	4	5	6	7	8	9	10	
1	3054.5	-3070.1	722.4	-39.9	2.3	-4.5	-2.4	-7.0	-.1	.2	4390.8
2	19772.	-1844.7	-5289.3	773.8	-7.9	310.1	134.3	286.9	1.4	46.4	20571.
3	35489.	41.4	-6362.8	-613.9	177.3	420.6	93.1	-92.0	-16.8	80.7	36064.
4	43688.	927.8	-6611.8	-93.6	218.3	401.2	26.4	-444.7	-18.1	66.6	44200.
5	50259.	1738.1	-5297.2	435.1	261.8	303.5	-64.4	-776.7	-11.7	22.5	50578.
6	55778.	2493.1	-2875.7	964.7	310.1	182.8	-153.2	-1035.7	-2.7	-23.2	55930.
7	60387.	3233.8	1545.9	1535.2	364.7	51.1	-208.6	-1032.6	7.9	-49.4	60527.
8	67346.	4217.0	8027.3	193.3	23.1	-14.3	-133.3	-954.9	-1.5	-48.7	67962.
9	72339.	5080.6	16175.	642.0	-79.8	-90.5	-59.8	-676.8	-26.1	-38.6	74305.
10	78827.	6851.0	39375.	2685.8	329.7	66.4	32.1	275.4	5.0	5.7	88422.
11	123.6	13.8	-11.3	-30.1	5.8	.8	-1.4	-.4	-1.1	.2	128.6
12	1572.5	-65.2	-808.0	281.3	167.4	20.4	-22.3	17.5	2.2	.3	1799.7
13	1606.2	-60.8	-803.6	270.6	167.3	20.4	-22.1	16.8	1.8	.3	1825.5
14	1696.3	-49.2	-776.6	240.3	163.0	19.4	-20.2	13.8	.7	.3	1889.1
15	1724.0	-44.8	-762.2	227.7	160.4	18.9	-19.2	12.4	.3	.3	1906.3
16	1772.1	-37.7	-734.7	207.2	155.2	17.9	-17.2	9.8	-.4	.2	1936.4
17	1857.7	-24.4	-673.8	169.3	143.6	15.9	-13.0	4.6	-1.8	0.0	1988.8
18	4049.4	404.6	1498.8	-1594.4	-318.9	9.3	45.7	-84.4	-3.2	-1.1	4633.4
19	4089.0	411.3	1538.7	-1612.8	-325.6	8.1	48.1	-86.8	-3.8	-1.2	4688.5
20	4132.4	419.4	1591.6	-1620.1	-332.1	6.5	50.5	-88.5	-4.5	-1.3	4750.7
21	4171.5	426.2	1642.6	-1637.4	-336.0	5.2	52.1	-88.6	-5.0	-1.4	4805.7
22	5024.9	587.6	2962.9	-1675.2	-380.6	-23.9	75.7	-57.7	-12.8	-1.5	6111.0
23	-415.2	-116.5	-457.2	597.7	-17.6	13.5	-28.7	43.0	-18.1	-1.8	870.7
24	-97.5	-68.2	-350.8	325.8	-1.6	23.7	-44.6	63.8	-18.6	-1.8	506.0
25	406.2	13.6	-53.1	-121.0	-62.0	41.4	-62.9	76.8	-5.2	-.1	455.7
26	643.9	52.5	114.3	-317.0	-104.1	46.0	-63.9	71.4	1.7	.7	749.8
27	1404.6	183.5	744.2	-881.9	-253.9	39.5	-30.6	9.1	15.8	1.5	1845.5
28	1775.6	241.0	1036.4	-1107.5	-319.7	34.3	-13.4	-18.6	18.4	1.4	2370.0
29	848.5	27.1	53.5	12.7	-80.2	3.5	6.4	-22.1	0.0	-.5	855.0
30	1233.3	90.2	430.0	-138.5	-141.4	-10.0	30.8	-44.8	-10.4	-1.8	1326.3
31	1432.4	125.1	666.6	-188.9	-168.5	-18.6	43.6	-50.8	-18.3	-2.5	1607.9
32	1615.0	157.9	919.1	-203.8	-184.8	-26.5	52.9	-48.4	-25.3	-2.8	1888.2
33	1847.1	201.7	1305.3	-185.5	-191.9	-34.3	59.7	-34.2	-30.8	-2.7	2288.7
34	-539.8	-420.3	-1512.9	2152.7	-124.3	5.8	6.1	-28.7	6.2	.9	2721.7
35	-1923.2	-333.6	-716.4	1824.1	-283.7	-13.4	26.6	-47.1	2.4	.8	2781.5
36	-6464.0	-635.0	-3498.0	1593.3	373.6	35.1	-75.9	23.8	12.0	1.0	7557.2
37	-1728.0	-231.0	-853.0	182.3	191.7	35.8	-60.6	18.4	30.6	2.0	1961.0
38	-2105.0	-421.4	-2112.1	1733.6	453.2	4.4	-54.8	83.9	.4	1.0	3507.1

3.7-59

RNP-2

59037-C-042

D3



TABLE 3.

REACTOR BUILDING - SEISMIC ANALYSIS

HORIZONTAL N-S DIRECTION - SSE

MEMBER MOMENTS

(UNITS IN FT - KIPS x 10³)

MEMBER	MODE NUMBER											
	1		2		3		4		5		6	
	TOP	BOTTOM	TOP	BOTTOM	TOP	BOTTOM	TOP	BOTTOM	TOP	BOTTOM	TOP	BOTTOM
1	14.62	158.94	.05	145.11	16.98	17.15	.02	1.91	.39	.28	.35	.14
2	251.79	1012.98	-145.39	216.41	86.79	290.43	2.03	-27.76	2.49	2.80	1.94	-13.88
3	1091.38	1814.46	-215.15	214.31	376.84	506.47	27.33	-14.83	4.61	.99	14.84	-23.41
4	1890.82	3026.67	-212.25	188.13	587.73	759.63	14.16	-11.73	2.73	2.95	23.65	-34.08
5	3103.17	4158.56	-185.04	148.54	838.79	950.03	10.85	-19.98	1.11	6.60	33.12	-39.49
6	4240.21	5913.52	-144.29	69.50	1031.02	1117.29	18.82	-47.76	4.46	-13.76	37.08	-42.56
7	6001.30	7631.71	63.67	23.65	1202.18	1160.43	45.71	-87.16	10.84	-20.69	37.34	-38.72
8	8057.97	8645.82	50.72	87.53	1158.00	1087.92	5.67	-7.36	9.85	-10.05	35.61	-35.49
9	8860.00	-10308.3	104.85	-206.56	-1097.75	773.93	-30.96	18.10	-1.00	2.60	29.62	-27.80
10	10964.1	-10964.1	255.01	-255.01	-1369.25	-1369.25	-41.39	41.39	-31.04	31.04	-37.44	37.44
11	.05	2.00	0.0	.22	.09	.27	0.0	.48	.02	.11	0.0	.02
12	2.02	17.51	.22	.42	.36	8.32	.48	-2.29	.12	-1.77	.02	.22
13	17.74	43.84	.41	1.40	8.39	21.44	2.28	-6.68	1.78	-4.50	.22	.55
14	43.71	61.10	1.39	1.89	21.68	29.64	6.66	-9.12	4.53	-6.20	.55	.75
15	61.45	77.13	1.88	2.29	29.73	36.67	9.10	-11.17	6.22	-7.67	.75	.92
16	77.66	93.91	2.27	2.62	36.82	43.56	11.13	-13.03	7.69	-9.11	.92	1.09
17	93.92	117.60	2.59	2.91	43.94	52.53	12.94	-15.10	9.13	-10.96	1.08	1.28
18	117.88	146.34	2.88	.03	52.92	42.38	14.98	-3.78	10.96	-8.72	1.27	-1.33
19	146.87	198.55	0.0	5.20	42.57	23.12	3.67	16.71	8.71	-4.59	1.32	-1.43
20	199.05	251.37	5.24	10.55	23.40	3.25	-16.83	37.45	4.60	.37	1.41	-1.49
21	251.34	304.20	10.58	15.98	3.50	17.31	-37.53	58.27	.35	3.91	1.47	-1.54
22	313.71	374.01	16.69	-23.74	9.99	45.55	-59.76	79.87	-4.43	8.99	.92	.63
23	4.26	.16	.37	.78	7.56	12.06	-4.64	-1.26	9.73	-9.55	-1.36	1.23
24	.37	1.22	.76	1.87	12.39	18.09	1.03	-6.33	9.94	-9.92	-1.27	.88
25	.82	3.34	1.82	1.68	18.46	19.00	5.85	-4.61	10.29	-9.66	.89	.47
26	3.54	10.92	1.66	1.06	19.09	17.78	4.33	.70	9.75	-8.55	.46	.07
27	13.54	23.11	.68	.57	17.70	12.63	3.11	9.12	8.34	-6.61	.23	.50
28	23.23	45.87	.61	3.68	12.61	.61	9.53	23.65	6.58	-2.51	.52	.95
29	46.91	54.81	3.84	4.09	.74	1.24	-25.12	25.01	2.28	-1.54	1.00	-1.03
30	55.21	72.71	4.15	5.43	1.28	7.39	-25.46	27.42	1.46	.55	1.04	.90
31	72.88	93.05	5.46	7.22	7.42	16.80	-27.65	30.31	.61	2.98	.90	.63
32	93.30	116.06	7.24	9.47	16.80	29.75	-30.49	33.36	3.03	5.64	.63	.25
33	116.31	142.28	9.50	12.33	29.67	48.02	-33.51	36.12	5.69	8.39	.23	.25
34	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
35	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
36	368.38	368.38	23.88	23.88	37.07	37.07	80.19	-80.19	9.22	-9.22	.14	.14
37	107.26	107.26	11.98	11.98	47.94	47.94	36.19	-36.19	8.41	-8.41	.28	.28
38	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

3.7-60

WNP-2

59037-C-042

04



TABLE 3.7-12 (Continued)

(UNITS IN FT-KIPS $\times 10^3$)

MEMBER	MODE NUMBER									
	7		8		9		10		COMBINED	
	TOP	BOTTOM	TOP	BOTTOM	TOP	BOTTOM	TOP	BOTTOM	TOP	BOTTOM
1	.64	-.53	3.71	-3.38	.15	-.15	-1.48	1.47	22.83	215.95
2	3.61	-8.77	19.85	-30.89	.57	-.62	-4.28	2.50	304.36	1076.96
3	10.87	-12.77	42.34	-40.47	.87	-.53	-4.09	2.45	1176.1	1896.69
4	14.31	-15.00	49.54	-37.98	.70	-.23	-3.63	1.89	1992.61	3126.87
5	15.89	-14.53	44.92	-28.61	.37	-.12	-2.76	2.29	3220.62	4268.73
6	14.86	-10.26	34.44	-3.37	.25	-.17	-2.96	3.66	4366.61	6018.91
7	9.80	-4.17	9.00	18.88	.30	-.51	-3.87	5.21	6121.17	7720.12
8	5.54	-4.38	-18.89	27.22	.19	-.17	-5.06	5.48	8141.03	8714.58
9	5.44	-4.24	-24.41	37.96	-.25	.77	-5.17	5.94	8928.51	10339.5
10	-3.82	3.82	24.49	-24.49	.22	-.22	1.26	-1.26	11052.4	11052.4
11	-.01	.03	0.0	0.0	0.0	.02	0.0	0.0	.10	2.09
12	-.03	.25	0.0	-.18	-.02	0.0	0.0	-.01	2.12	19.61
13	-.26	.62	.18	-.45	0.0	-.03	.01	-.01	19.84	49.50
14	-.63	.83	.46	-.60	.03	-.04	.01	-.02	49.49	68.84
15	-.84	1.01	.61	-.72	.04	-.04	.02	-.02	69.19	86.53
16	-1.02	1.18	.72	-.81	.04	-.04	.02	-.02	87.06	104.79
17	-1.19	1.35	.82	-.88	.03	-.01	.02	-.02	104.95	130.21
18	-1.35	1.03	.88	-.29	.01	.01	.03	-.02	130.60	152.66
19	-1.03	.42	.29	.81	-.02	.07	.02	0.0	153.21	200.72
20	-.42	-.22	-.81	1.93	-.07	.12	0.0	.01	201.25	254.39
21	.22	-.88	-1.93	3.05	-.13	.19	-.01	.03	254.39	310.68
22	.89	-1.80	-2.69	3.38	-.22	.38	0.0	.02	320.00	386.02
23	1.81	-1.52	-1.92	1.50	.29	-.11	.03	-.01	14.40	15.80
24	1.58	-.85	-1.54	.51	.11	.19	.01	.02	16.29	21.76
25	.85	-.21	-.50	-.29	-.17	.23	-.02	.02	22.08	22.14
26	.19	.54	.30	-1.12	-.21	.19	-.02	.01	22.23	22.65
27	-.64	.85	.92	-.98	.18	-.29	.03	-.04	24.06	28.71
28	-.86	1.03	.96	-.72	.33	-.56	.04	-.06	28.93	51.84
29	-1.03	.97	.58	-.37	.68	-.68	.07	-.07	53.44	60.44
30	-.96	.52	.32	.32	.71	-.56	.07	-.04	60.99	78.26
31	-.51	-.10	-.35	1.07	.57	-.31	.04	-.01	78.51	99.61
32	.12	-.87	-1.10	1.78	.31	.05	.01	.03	99.90	124.89
33	.88	-1.72	-1.80	2.28	-.06	.49	-.03	.07	125.15	155.22
34	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
35	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
36	-1.75	1.75	2.91	-2.91	.37	-.37	0.0	0.0	379.72	379.72
37	-1.72	1.72	2.25	-2.25	.49	-.49	.07	-.07	123.87	123.87
38	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0



