



ENGINEERING CONSULTANTS

CALCULATION COVER SHEET

Calculation No: 59037-C-044

Project: WPPSS TRFEE

Calculation Title: Turbine Building Seismic Evaluation

References: See p. 4

Attachments: Att. A (2 pp.), B (19 pp.), C (4 pp.)

Total Number of Pages (Including Cover Sheet): 34 Excluding attachments

Revision Number	Approval Date	Description of Revision	Originator	Checker	Approver
0	8/11/94	Original Issue	FSH	ALC	RJG

9906220063 990617
PDR ADDCK 05000397
P PDR





EQE INTERNATIONAL

SHEET NO. 3/39

JOB NO. 59037 JOB WPPSS JETPREE

BY FSH DATE 7-18-94

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D MC DATE 7-20-94

TABLE OF CONTENTS

Subject	Page
Calculation Cover Sheet	1
Table of Revisions	2
Table of Contents	3
References	4
Objective	5
Summary	5
Preliminary Review	6
Technical Approach	7
Seismic Demands On Column Line 13 Wall	8
Shear On Column Line 13 Wall At EL 441'-0"	13
Overturning Moment On Column Line 13 Wall At EL 441'-0"	16
Seismic Demands On Column Line A Wall	20
Shear On Column Line 13 Wall At EL 441'-0"	24
Overturning Moment On Column Line 13 Wall At EL 441'-0"	26
Diaphragm Between Column Lines A and B at EL 471'-0"	29
Attachment A - Excerpts from Reference 3	
Attachment B - Excerpts from Reference 5	
Attachment C - Excerpts from Reference 6	



EQE INTERNATIONAL

SHEET NO. 4/29

JOB NO. 59037 JOB WPPSS IPEEE BY FBH DATE 7-18-94
 CALC. NO. C-044 SUBJECT Turbine Bldg CHK'D AK DATE 7-20-94

REFERENCES

- | | |
|----|---|
| 1. | Structural drawings S601 to S681. |
| 2. | "A Methodology for Assessment of Nuclear Power Plant Seismic Margin (Revision 1);" Electric Power Research Institute, EPRI NP-6041-SL, Revision 1, August 1991. |
| 3. | EQE Engineering Consultants, Calculation No: 59037-C-037, "IPEEE Building Forces", Revision 0. |
| 4. | "Code Requirements for Nuclear Safety Related Concrete Structures" (ACI 349-90) and Commentary - ACI 349R-90," American Concrete Institute, 1990. |
| 5. | EQE Engineering Consultants, Calculation No: 59037-C-005, "Turbine Building Model", Revision 0. |
| 6. | EQE Engineering Consultants, Calculation No. 52182-C-017, "Quality Assurance Document For WALLD Version 1.0," Revision 0. |



JOB NO. 59037 JOB WPPSS IPETE

BY: [Signature] DATE 1-18-94

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D: [Signature] DATE 7-20-94

OBJECTIVE

The objective of this calculation is to evaluate the seismic capacity of the turbine building. A seismic fragility for this building is needed if its median capacity and High Confidence of a Low Probability of Failure (HCLPF) capacity are less than about 1.5g and 0.5g, respectively.

SUMMARY

A preliminary review was performed to identify the more heavily loaded structural components of the turbine building (Reference 1). Based on this preliminary review, a subset of structural components was selected for more detailed evaluation.

High Confidence of a Low Probability of Failure (HCLPF) capacities for the selected components were calculated following the Conservative Deterministic Failure Margins (CDFM) method recommended in EPRI NP-6041-SL (Reference 2). Seismic responses for this evaluation were taken as the 84% values obtained by probabilistic response analyses performed for a peak ground acceleration of 0.50g (Reference 3). The following results were obtained:

Structural Component	HCLPF Capacity
Shear on Column Line 13 wall at EL 441'-0"	0.51g
Overtopping moment on Column Line 13 wall at EL 441'-0"	0.60g
Shear on Column Line A wall at EL 441'-0"	0.52g
Overtopping moment on Column Line A wall at EL 441'-0"	0.63g
Shear on diaphragm between Column Lines A and B EL 441'-0"	0.57g
Moment on diaphragm between Column Lines A and B EL 441'-0"	0.55g

It is noted that conservative approximations were included to simplify these calculations. More rigorous calculations could be performed to reduce these conservatisms and obtain HCLPF capacities even greater than those listed above.

It is concluded that the HCLPF capacity of the turbine building is greater than 0.50g.



EQE INTERNATIONAL

SHEET NO. 4139

JOB NO. 59037 JOB WPPSS TRPFE

BY PSH DATE 7-18-94

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D MC DATE 7-20-94

PRELIMINARY REVIEW

A preliminary review was performed to identify a subset of turbine building structural components for which more detailed evaluations should be performed. This review consisted of (1) review structural drawings (Reference 1) and turbine building seismic responses for IPEEE (Reference 3), and (2) approximate calculations to estimate seismic capacities of certain structural components.

The drawing review was performed to identify the seismic load paths and any potentially significant seismic vulnerabilities. Diaphragm slabs between Column Lines A and B and between Column Lines F and H were observed to have relatively long spans between supporting shear walls. Further investigation of these diaphragms was considered appropriate.

Approximate calculations were performed to further scope the need for more detailed evaluation. These calculations revealed that the diaphragm between Column Lines A and B at Elevation 471'-0" has lower seismic capacity than the diaphragm between Column Lines A and B at Elevation 501'-0" (which has greater flexural reinforcement) and the diaphragm between Column Lines F and H at Elevation 531'-0".

Based on the preliminary review, the following structural components were selected for more detailed evaluation:

- Shear and overturning moment on the shear wall on Column Line 13 at Elevation 441'-0". This wall attracts a significant proportion of the N-S shear, and has less reinforcement than other major N-S shear walls.
- Shear and overturning moment on the shear wall on Column Line A at Elevation 441'-0". This wall attracts a significant proportion of the E-W shear, and has slightly less reinforcement than other major E-W shear walls.
- Shear and moment on the diaphragm between Column Lines A and B at Elevation 471'-0".

Evaluation of the steel superstructure was not performed. There are no essential components attached to this part of the turbine building. Even if the superstructure were to collapse, it would not impact the reactor and radwaste/control buildings.



EQE INTERNATIONAL

SHEET NO. 7/59

JOB NO. 51037 JOB WPPSS IPEEE

BY PSH

DATE 7-18-99

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D ME

DATE 7-20-99

TECHNICAL APPROACH

HCLPF capacities for the selected turbine building structural components were calculated following the Conservative Deterministic Failure Margins (CDFM) approach recommended in EPRI NP-6041-SL (Reference 2).

Seismic demands on the structural components were based on 84% responses for a 0.50g peak ground acceleration calculated for use in IPEEE in Reference 3.

Seismic capacities of the structural components were determined following acceptance criteria recommended by EPRI NP-6041-SL. These acceptance criteria are specified in appendices to EPRI NP-6041-SL and provisions of ACI 349-90 (Reference 4).

Following the recommendations of EPRI NP-6041-SL, an inelastic energy absorption factor of 1.25 was conservatively assigned to ductile failure modes in lieu of performing a more rigorous calculation.



JOB NO. 59037 JOB WYSS BRIDGE

BY RSK

DATE 7-18-94

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D [Signature]

DATE 7-20-94

Seismic Demands On Col. Lin. 13 Wall

Overall seismic loads from the response analysis can be distributed to the walls in proportion of their relative rigidities. The general approach developed in Ref. 6 (see Att. C) will be used. Because shear flexibility is much greater than bending flexibility for these walls, the wall relative rigidities can be based on the shear stiffness (K_x, K_y) listed in Ref. 5 (see Att. B). Wall centroidal locations (x, y) and overall story shear stiffnesses are also listed in Ref. 5 (Att. B). Overall story forces (shear, torsion) are obtained from Ref. 3 (see Att. A). The values listed in Ref. 3 are in units of force/g, and must be factored by 32.2 ft/sec^2 . The torsional moment will be conservatively assumed to be in phase with the N-S shear.

EL 501' to EL 531'

Wall modeled by Segments 11 and 12. See pp. 40 to 51, Ref. 5 (see

$$K_{y13} = \text{Shear stiffness of wall on Col. line 13} \quad \text{Att. B)} \\ = 1.84 \times 10^6 \text{ k/ft}$$

$$x_{13} = -68.0 \text{ ft}$$

$$K_y = \text{Total story stiffness} \\ = 6.62 \times 10^6$$

$$x_s = x \text{ coordinate of center of rigidity} \\ = 19.60 \text{ ft}$$

$$K_{tz} = \text{Torsional stiffness} \\ = 1.06 \times 10^{11} \text{ k-ft}$$

Story modeled by Flmt. 3 of structure model. Use 84% demands, 0.5g PGA.

$$V_y = V_z = 5.46 \times 10^2 (32.2) \\ = 17,600 \text{ k} \quad \text{Force component 3}$$

$$T = \text{Torsional Moment}$$

$$= 1.75 \times 10^4 (32.2)$$

Force component 4

$$= 5.64 \times 10^5 \text{ k-ft}$$

$$M_{xy} = \text{Moment about X (E-W) axis}$$

$$= 2.94 \times 10^4 (32.2)$$

Force component 5

$$= 9.47 \times 10^5 \text{ k-ft}$$

JOB NO. 89037 JOB WRPSS ZPEEEBY DSH DATE 7-18-94CALC. NO. C-044 SUBJECT Turbine BldgCHK'D MC DATE 7-20-94 $V_{D13} = \text{Direct shear}$

$$= V \frac{K_{213}}{K_y}$$

$$= 17,600 \left(\frac{1.84 \times 10^4}{6.62 \times 10^4} \right)$$

$$= 4,890 \text{ k}$$

 $V_{T13} = \text{Shear due to torsion}$

$$= T \frac{K_{213} |x_{13} - x_{s1}|}{K_{T2}}$$

$$= 5.64 \times 10^5 \frac{1.84 \times 10^4 | -68.0 - 19.6 |}{1.06 \times 10^8}$$

$$= 860 \text{ k}$$

 $V_{13} = \text{Total shear} = V_{D13} + V_{T13}$

$$= 4,890 + 860$$

$$= 5,750 \text{ k}$$

 $\Delta M_{xx} = \text{Total incremental moment}$

$$= 9.47 \times 10^5 - 0 = 9.47 \times 10^5 \text{ k-ft}$$

 $\Delta M_{xxD13} = \Delta M_{xx} \frac{K_{213}}{K_y} \quad \text{Direct moment}$

$$= 9.47 \times 10^5 \left(\frac{1.84 \times 10^4}{6.62 \times 10^4} \right)$$

$$= 2.63 \times 10^5 \text{ k-ft}$$

 $\Delta M_{xxT13} = \text{Incremental moment due to torsion}$

$$= V_{T13} \Delta h$$

$$= 860 (30)$$

$$= 2.58 \times 10^4 \text{ k-ft}$$

 $\Delta h = \text{story height} = 30 \text{ ft}$ $\Delta M_{xx13} = \text{Total well incremental moment}$

$$= \Delta M_{xxD13} + \Delta M_{xxT13}$$

$$= 2.63 \times 10^5 + 2.58 \times 10^4$$

$$= 2.89 \times 10^5 \text{ k-ft}$$



EQE INTERNATIONAL

SHEET NO. 10/3A

JOB NO. 59037 JOB WAFES JPEEE

BY PSA

DATE 7-18-94

CALC. NO. C-044 SUBJECT Turbine Bldg

CHKD Me

DATE 7-20-94

EL 471140 EL 5011

Wall modeled by Segments 11 and 15. See pt. 29 to 38, Part 5 (Att B)

$$K_{y13} = 1.34 \times 10^6 \text{ k-ft}$$

$$x_{13} = -68.0 \text{ ft}$$

$$K_{y2} = 18.69 \times 10^6 \text{ k-ft}$$

$$x_2 = 19.6 \text{ ft}$$

$$K_{z2} = 1.74 \times 10^{11} \text{ k-ft}$$

Story modeled by Element 4.

$$V_y = 1.67 \times 10^3 \text{ (32.2)}$$

$$= 53,800 \text{ k}$$

$$T = 3.25 \times 10^9 \text{ (32.2)}$$

$$= 1.06 \times 10^6 \text{ k-ft}$$

$$M_{xx} = 9.36 \times 10^4 \text{ (32.2)}$$

$$= 3.01 \times 10^6 \text{ k-ft}$$

Force Comp 3

$$V_{p13} = 53,800 \left(\frac{1.34 \times 10^6}{8.69 \times 10^6} \right)$$

$$= 8,300 \text{ k}$$

$$V_{T13} = 1.06 \times 10^6 \frac{1.34 \times 10^6 | -68.0 - 19.6 |}{1.74 \times 10^{11}}$$

$$= 715 \text{ k}$$

$$V_{13} = 8300 + 715$$

$$= 9,020 \text{ k}$$

$$\Delta M_{xx} = 3.01 \times 10^6 - 9.47 \times 10^5$$

$$= 2.06 \times 10^6 \text{ k-ft}$$

$$\Delta M_{xx \Delta 13} = -2.06 \times 10^6 \frac{1.34 \times 10^6}{8.69 \times 10^6}$$

$$= 3.18 \times 10^5 \text{ k-ft}$$

$$\Delta M_{xx T 13} = 715 \text{ (30)}$$

$$= 2.15 \times 10^6 \text{ k-ft}$$

$$\Delta M_{xx 13} = 3.18 \times 10^5 + 2.15 \times 10^6$$

$$= 5.40 \times 10^5 \text{ k-ft}$$



EQE INTERNATIONAL

SHEET NO. 11/39

JOB NO. 59037 JOB WIPSS TOWER

BY PSH

DATE 7-18-99

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D MK

DATE 7-20-99

EL 491' to EL 471'

WALL modeled by Segment 14. See pp 19 to 27, Ref. 5 (Att. B)

$$K_{13} = 1.69 \times 10^6 \text{ k/ft}$$

$$X_{13} = -68.0 \text{ ft}$$

$$K_{12} = 1.02 \times 10^7 \text{ k/ft}$$

$$X_2 = 3.91 \text{ ft}$$

$$K_{22} = 1.36 \times 10^8 \text{ k-ft}$$

Story modeled by Element 5

$$V_2 = 2.84 \times 10^5 \text{ (32.2)}$$

$$= 91,500 \text{ k}$$

$$T = 9.52 \times 10^4 \text{ (32.2)}$$

$$= 3.07 \times 10^4 \text{ k-ft}$$

$$M_{xx} = 1.96 \times 10^5 \text{ (32.2)}$$

$$= 6.31 \times 10^6 \text{ k-ft}$$

Force Comp. 3

" 4

" 5

$$V_{D13} = 91,500 \frac{1.69 \times 10^6}{1.02 \times 10^7}$$

$$= 15,200 \text{ k}$$

$$V_{T13} = 3.07 \times 10^4 \frac{1.69 \times 10^6 | -68.0 - 3.91}{1.36 \times 10^8}$$

$$= 2,740 \text{ k}$$

$$V_{13} = 15,200 + 2,740$$

$$= 17,900 \text{ k}$$

$$\Delta M_{xx} = 6.31 \times 10^6 - 3.01 \times 10^4$$

$$= 3.30 \times 10^6 \text{ k-ft}$$

$$\Delta M_{xx \text{ at } 13} = 3.30 \times 10^6 \frac{1.69 \times 10^6}{1.02 \times 10^7}$$

$$= 5.47 \times 10^5 \text{ k-ft}$$

$$\Delta M_{xx \text{ at } 13} = 2,740 \text{ (30)}$$

$$= 8.22 \times 10^4 \text{ k-ft}$$

$$\Delta M_{xx \text{ at } 13} = 5.47 \times 10^5 + 8.22 \times 10^4$$

$$= 6.29 \times 10^5 \text{ k-ft}$$



EQE INTERNATIONAL

SHEET NO. 12/39

JOB NO. 51037 JOB WRPSS ZPEEE

BY FSH DATE 7-18-74

CALC. NO. C-044 SUBJECT Turbine Body

CHK'D MC DATE 7-20-74

Net Work Forces At EL 441'

$$N = 17,900 \text{ k}$$

$$M = 2.89 \times 10^5 + 3.40 \times 10^5 + 6.29 \times 10^5 \\ = 1.26 \times 10^6 \text{ k-ft}$$



JOB NO. 59037 JOB WRPS BRFF

BY REK DATE 7-8-99

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D MC DATE 7-20-99

Shear On Column Line B Wall At EL 441'-0"

Shear Demand

$V = 17,900$

Shear Capacity - see Drgs S625, S626, S634

Wall thickness = 4'-0

Wall length

Conservatively neglect section at south end which is perforated by openings. Wall angles off at 45° at north end. Conservatively include only half of this section (note, wall taken as being continuous to Col. Line D in developing model properties).

Effective length $\approx 4(26.0) - 1.83 - 5.42 - 0.5 - 4.5 - 5 - \frac{14}{2}$
 $= 77.75$ ft

Wall reinforcement varies along length - Sects. 357 and 358 on

Drg. S626 cover most of length, use typical.

Reinf.: #10 @ 12" EF horiz, #9 @ 12" EF vert.

$\rho_h = \frac{2(1.27)}{12(48)}$

$= 0.00441$

$\rho_v = \frac{2(1.0)}{12(48)}$

$= 0.00347$

Wall axial load

Conservatively neglect floor slab. Include only weight of wall conservatively using only 3'-6" thickness and rises up to EL 524'-6". Reduce for vertical acceleration assuming 40% of vertical response act concurrent with max horizontal response.

$\sigma_{DL} = \frac{150(3.5)(524.5 - 441)}{48(12)}$

$= 76$ psi



JOB NO. 59037 JOB WRES TPEEF

BY FKH

DATE FEB-19

CALC. NO. C-044 SUBJECT Turbine Bldg

CHKD *He*

DATE 7-20-94

Vert. $f_{PA} = 0.55g$ Mode 4

$\sigma_c = 76 [1 - 0.4(0.55)]$
 $= 59 \text{ psi}$

Calculate shear capacity following App. L of EPCI NP-4041-SL, with exception that reinforcement characteristic strength is also reduced by $e^{-0.20}$ (equivalent to ϕ , strength reduction factor).

Conservatively use total wall height up to EL 531':

$h_w = 531 - 441$
 $= 90$
 $\frac{h_w}{l_w} = \frac{90}{179.75}$
 $= 1.13$

Effective reinforcement ratio, ρ_{se}

$A = h_w/l_w + 1.5 = 0.37$
 $B = h_w/l_w - 0.5 = 0.63$
 $\rho_{se} = A \rho_v + B \rho_h$
 $= 0.37(0.00347) + 0.63(0.00461)$
 $= 0.00406$

(1-2)

$f_c = 4,000 \text{ psi}$

$h_w/l_w = 1.13$

$N_A/l_w t_w = \sigma_c = 59 \text{ psi}$

$\rho_{se} = 0.00406$

$f_d = 60,000 \text{ psi}$

Added term)

$V_u = 6.8 \sqrt{f_c} - 2.8 \sqrt{f_c} (h_w/l_w - 0.5) + \frac{N_A}{4 l_w t_w} + \rho_{se} f_d e^{-0.20}$ (1-4)

$= 6.8 \sqrt{4000} - 2.8 \sqrt{4000} (1.13 - 0.5) + \frac{59}{4} + 0.00406 (60,000) e^{-0.20}$
 $= 533 \text{ psi}$



EQE INTERNATIONAL

SHEET NO. 15/39

JOB NO. 59037 JOB WASS PAPER

BY FBH DATE 7-18-99

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D MC DATE 7-20-99

Conservatively use $d = 0.6L_w$
 $= 0.6(79.75)(12)$
 $= 574 \text{ in}$

(L-6)

$V_u = V_u d t_n$
 $= 0.533(48)(574)$
 $= 14,700 \text{ k}$

(L-5)

HCLPF Capacity
 $F_r = 1.25$

HCLPF Capacity = $\frac{14,700}{17,900} (1.25) (0.50g)$
 $= 0.51g$

Note = This evaluation contains a number of conservatisms.



JOB NO. 59037 JOB WPPSS REEF

BY FSH

DATE 7-8-99

CALC. NO. C-044 SUBJECT Turbine Bldg

CHKD Mc


DATE 7-20-99

Overturning Moment On Column Line 13 Wall At TEL 441'-0"Moment Demand

$$M = 1.26 \times 10^6 \text{ ft-lb}$$

Moment Capacity

By inspection, lower bound moment capacity obtained for compression on south end. Include resistance provided by Column D13, and the intersecting walls on Column Line F and G.



Compression Flange, Wall On Col. Line H

Determine effective flange width per Sect. 8.10.3 of ACI 318-95

C Ref. \rightarrow

a. Use effective span length for cantilever of $2 \times$ wall height
 $\frac{1}{2}(2)(531-441) = 15 \text{ ft}$

b. $6 \times$ slab thickness = $6(2.0) = 12 \text{ ft}$ \leftarrow Control

c. $\frac{1}{2}$ clear distance doesn't control.

Total flange width = $12 + 4$ (web thickness)
 $= 16 \text{ ft}$

Web.

Use typical reinforcement of #9 @ 12" EF vert. (see shear capacity calc). Include replacement bars at openings. (Ct. S749)

$$L_{eff} = 52 + 52 - 7 = 97 \text{ ft}$$

$$A_{sw} = 2(11.0)(97) = 194 \text{ in}^2$$



JOB NO. 59037 JOB WPPSS TREE

BY JSA

DATE 7-18-94

CALC. NO. C-044 SUBJECT Turbine Pad

CHK'D RLC

DATE 7-20-94

$$d_w = \frac{97}{12} = 8.08 \text{ ft}$$

See sketch

Wall Just South of Col. Line G. Conservatively neglect shorter wall
Have replacement steel at opening, east of Col. Line B.

Effective tension flange width

$$\frac{1}{3} \text{ of wall height} = \frac{1}{3} (501 - 441) = 20 \text{ ft}$$

$$\frac{1}{2} \text{ clear distance to next wall} = \frac{1}{2} (20) = 10' = \text{Controls}$$

Wall reinf. - #18 @ 12" EF vert.

Sect. 537, An S626

$$A_{sG} = 2 (4.0) (10)$$

$$= 80 \text{ in}^2$$

$$d_G = 17.25 + 1.5 + \frac{d}{2}$$

$$= 20.75 \text{ ft}$$

Wall on Col. Line F - Ditto

Wall reinf. - 2-#18 @ 12" EF vert.

$$A_{sF} = 2 (4.0) (10)$$

$$= 160 \text{ in}^2$$

$$d_F = 52 + 1.5 - 0.75 + \frac{d}{2}$$

$$= 54.75 \text{ ft}$$

Column D13

Have 14-#11, An S628

$$A_{sD} = 14 (1.56)$$

$$= 22 \text{ in}^2$$

$$d_D = 52 + 52 + 1.5$$

$$= 105.5 \text{ ft}$$

Axial Load -

Use conservative effective vertical stress from shear capacity

calculation.

$$\sigma_e = 59 \text{ psi}$$

$$L_e = 97 \text{ ft}$$

See web steel code.

$$P = 0.059 (48) (97) (12)$$

$$= 3,300 \text{ k}$$



JOB NO. 59037 JOB WRSS JPEEE

BY RSH

DATE 7-18-99

CALC. NO. C-044 SUBJECT Turbine Balg

CHK'D Hc

DATE 7-20-99

$$d = \frac{(194 + 80 + 160 + 22)(60) + 3300}{0.85(4)(12)(12)}$$

$$= 47" > \text{Flange thickness} = 2'-0"$$

$$d = \frac{(194 + 80 + 160 + 22)(60) + 3300 - 0.85(4)(24)[16(12) - 48]}{0.85(4)(48)}$$

$$= 116"$$

Check stress in flange south of Col. Line C

$$c = \frac{116}{0.85}$$

$$= 137.1$$

$$= 11.4 \text{ ft}$$

$$f_b = 0.003(29,000) \frac{20.75 - 11.4}{11.4}$$

$$= 71.7 \text{ ksi} > 60 \text{ ksi} \quad \text{OK}$$

$$x' = \frac{[116(12) - 48](24)(29/2) + 48(116)(116/2)}{[116(12) - 48](24) + 48(116)}$$

$$= 40.4"$$

$$= 3.4 \text{ ft}$$

$$0.1 A_c A_s \approx 0.1(4) [48(97)(12) + 24(16)(12)]$$

$$= 24,200 \text{ k}$$

$$\frac{P}{0.1 A_c A_s} = \frac{3300}{24,200}$$

$$= 0.14$$

$$\phi = 0.9 - 0.2(0.14)$$

$$= 0.87$$

$$\phi M_n = 0.87 \left\{ [194(60) + 3300] (48.5 - 3.4) + 80(60) (20.75 - 3.4) + 160(60) (54.75 - 3.4) + 22(60) (105.5 - 3.4) \right\}$$

$$= 1.21 \times 10^6 \text{ k-ft}$$



EQE INTERNATIONAL

SHEET NO. 19/34

JOB NO. 59037 JOB WPPSS - EPEEE

BY JEN DATE 7-18-94

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D MC DATE 7-20-94

HCLPF Capacity

F_{pr} = 1.25

$$\begin{aligned}
 \text{HCLPF Capacity} &= \frac{1.21 \times 10^6}{1.76 \times 10^6} (1.25) (0.50g) \\
 &= 0.60g
 \end{aligned}$$



JOB NO. 51037 JOB WPTSS 3PFEF

BY FSH

DATE 7-18-94

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D [Signature]

DATE 7-20-94

Seismic Demands On Col. Line A Wall

Follow approach for Col. Line B wall

EL 501' to EL 531'

Wall modeled by Segment 2

$$K_{x2} = 3.12 \times 10^4 \text{ k/ft}$$

$$y_2 = 112.0 \text{ ft}$$

$$K_x = 7.86 \times 10^4 \text{ k/ft}$$

$$y_5 = 11.9 \text{ ft}$$

$$K_{22} = 1.06 \times 10^4 \text{ k-ft}$$

Story modeled by Elntr. 3

$$V_x = 5.22 \times 10^2 (32.2)$$

$$= 16,800 \text{ k}$$

Force Comp. 2

$$T = 5.64 \times 10^5 \text{ k-ft}$$

Col. Line B wall calc;

$$M_{y2} = 2.68 \times 10^4 (32.2)$$

$$= 8.63 \times 10^5 \text{ k-ft}$$

Force Comp. 6

$$V_{DA} = 16,800 \left(\frac{3.12 \times 10^4}{7.86 \times 10^4} \right)$$

$$= 6670 \text{ k}$$

$$V_{TA} = 5.64 \times 10^5 \frac{3.12 \times 10^4 (112.0 - 11.9)}{1.06 \times 10^4}$$

$$= 1,660 \text{ k}$$

$$V_A = 6670 + 1660$$

$$= 8330 \text{ k}$$

$$\Delta M_{y2} = 8.63 \times 10^5 \text{ k-ft}$$

$$\Delta M_{y2DA} = 8.63 \times 10^5 \frac{3.12 \times 10^4}{7.86 \times 10^4}$$

$$= 3.43 \times 10^5 \text{ k-ft}$$

$$\Delta M_{y2TA} = 1660 (30) = 4.98 \times 10^4 \text{ k-ft}$$

$$\Delta M_{y2A} = 3.43 \times 10^5 + 4.98 \times 10^4 = 3.93 \times 10^5 \text{ k-ft}$$

JOB NO. 57037 JOB WATER TOWERBY ASH DATE 7-18-94CALC. NO. C-044 SUBJECT Turbine BldgCHK'D He DATE 7-20-94EL 471' to EL 501'

Wall modeled by Segment 3

$$K_{xA} = 8.12 \times 10^4 \text{ k/ft}$$

$$\Delta_A = 112.0 \text{ ft}$$

$$K_x = 9.12 \times 10^4 \text{ k/ft}$$

$$y_s = 4.7 \text{ ft}$$

$$K_{zz} = 1.74 \times 10^6 \text{ k-ft}$$

Stone modeled by Element 4

$$V_x = 1.66 \times 10^5 (32.2)$$

$$= 53,500 \text{ k}$$

$$T = 1.06 \times 10^6 \text{ k-ft}$$

$$M_{x1} = 8.68 \times 10^4 (32.2)$$

$$= 2.80 \times 10^6 \text{ k-ft}$$

$$V_{0A} = 53,500 \frac{3.12 \times 10^6}{9.12 \times 10^4}$$

$$= 18,300 \text{ k}$$

$$V_{TA} = 1.06 \times 10^6 \frac{3.12 \times 10^6 (112.0 - 4.7)}{1.74 \times 10^6}$$

$$= 2040 \text{ k}$$

$$V_A = 18,300 + 2040$$

$$= 20,300 \text{ k}$$

$$A.M._{x1} = 2.80 \times 10^6 - 8.68 \times 10^5$$

$$= 1.94 \times 10^6 \text{ k-ft}$$

$$\Delta M_{x1} \text{ at } A = 1.94 \times 10^6 \frac{3.12 \times 10^6}{9.12 \times 10^4}$$

$$= 6.64 \times 10^5 \text{ k-ft}$$

$$\Delta M_{x2} \text{ at } A = 2040 (30)$$

$$= 6.12 \times 10^4 \text{ k-ft}$$

$$\Delta M_{x1} \text{ at } A = 6.64 \times 10^5 + 6.12 \times 10^4$$

$$= 7.25 \times 10^5 \text{ k-ft}$$

Force Comp. 2

Cul. Line 13 wall calc.

Force Comp. 6

JOB NO. 59037 JOB WRSS DREFEBY FSHDATE 7-18-94CALC. NO. C-044 SUBJECT Turbine BldgCHK'D MEDATE 7-20-94EL 491' to EL 471'

Wall modeled by Segments 3 & 5

$$K_{xT} = 2.82 \times 10^6 \text{ k/ft}$$

$$y_T = 112.0 \text{ ft}$$

$$K_x = 8.91 \times 10^6 \text{ k/ft}$$

$$y_S = 17.2 \text{ ft}$$

$$K_{TS} = 1.36 \times 10^{11} \text{ k-ft}$$

Story modeled by Elmt. 5

$$V_x = 2.89 \times 10^3 (32.2)$$

$$= 93,100 \text{ k}$$

$$T = 3.07 \times 10^6 \text{ k-ft}$$

$$M_{xT} = 1.85 \times 10^5 (32.2)$$

$$= 5.96 \times 10^6 \text{ k-ft}$$

$$V_{DA} = 93,100 \frac{2.82 \times 10^6}{8.91 \times 10^6}$$

$$= 29,500 \text{ k}$$

$$V_{TA} = 3.07 \times 10^6 \frac{2.82 \times 10^6 (112.0 - 17.2)}{1.36 \times 10^{11}}$$

$$= 6030 \text{ k}$$

$$V_T = 29,500 + 6030$$

$$= 35,500 \text{ k}$$

$$\Delta M_{xT} = 5.96 \times 10^6 - 2.80 \times 10^6$$

$$= 3.16 \times 10^6 \text{ k-ft}$$

$$\Delta M_{yDA} = 3.16 \times 10^6 \frac{2.82 \times 10^6}{8.91 \times 10^6}$$

$$= 1.00 \times 10^6 \text{ k-ft}$$

$$\Delta M_{yTA} = 6030 (30)$$

$$= 1.81 \times 10^5 \text{ k-ft}$$

$$\Delta M_{yDA} = 1.00 \times 10^6 + 1.81 \times 10^5$$

$$= 1.18 \times 10^6 \text{ k-ft}$$

Force Comp. 2

Col. Line 13 wall calc.

Force Comp. 0



EQE INTERNATIONAL

SHEET NO. 23/34

JOB NO. 59037 JOB WRSS BPEFE BY RSK DATE 7-15-94
CALC. NO. C-044 SUBJECT Turbine Bldg CHK'D. MC DATE 7-20-94

Net Wall Forces At EL 441'

$$V = 35,500 \text{ k}$$

$$M = 3.95 \times 10^5 + 7.25 \times 10^5 + 1.18 \times 10^6 \\ \approx 2.30 \times 10^6 \text{ k-ft}$$



JOB NO. 59037 JOB WYSS REEF

BY JSH DATE 7-18-98

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D MC DATE 7-20-98

Shear On Column Line A Wall At EL 491'-0"

Shear Demand

$V = 35,500$

Shear Capacity

Wall thickness = 4'-0"

Wall length = 139'-6"

Wall height = 83'-6"

Out to out

Col. Lines 7 to 13 only. Conservative

To top of wall at EL 524'-6". Conservative

Wall Reinforcement

Typical: #8 @ 12" EF EN

Sec. 351, Dr. 5675

27'-6" lengths at each end: #8 @ 12" EF horiz., #18 @ 12" EF vert.

Sec. 530, Dr. 5626

$f'_c = 4000 \text{ psi}$

$f_y = 60,000 \text{ psi}$

$\frac{h_w}{L_w} = \frac{83.5}{139.5}$

$\therefore = 0.60$

Effective Reinforcement Ratio

Horiz. reinf.

$\rho = \frac{260.795}{12(48)}$

$= 0.00274$

Vert. reinf. Use average value weighted by length. Conservatively

exclude #18 @ 12" at compression side

Typical reinf. ; $\rho = 0.00274$

At ends: $\rho = \frac{2(4 \times 0)}{12(48)}$

$= 0.0139$

$\bar{\rho}_v = \frac{0.00274(139.5 - 55) + 0.0139(27.5)}{(139.5 - 55) + 27.5}$

$= 0.00548$

$A = -0.60 + 1.5 = 0.90$

$B = 0.60 - 0.5 = 0.10$

$\rho_{sc} = 0.90(0.00548) + 0.10(0.00274)$

$= 0.00521$



EQE INTERNATIONAL

SHEET NO. 25/39

JOB NO. 59037 JOB URSS PIPE

BY PSH

DATE 7-18-99

CALC. NO. C-044 SUBJECT Turbine Body

CHK'D

ME

DATE 7-20-99

Axial Load. Conservatively use only wall weight.

$$\sigma_{DL} = 150(83.5)$$

$$= 12500 \text{ psi}$$

$$= 87 \text{ psi}$$

$$\sigma_{NET} = 87 [1 - 0.4(0.55)]$$

$$= 68 \text{ psi}$$

$$d = 0.6 L_w$$

$$= 0.6(139.5)(12)$$

$$= 1000 \text{ in}$$

$$v_u = 6.8 \sqrt{4000} - 2.8 \sqrt{4000} (0.60 - 0.50) + \frac{68}{4} + 0.0052(60,000) e^{-0.8}$$

$$= 685 \text{ psi}$$

$$V_u = 0.685(48)(1000)$$

$$= 32,900 \text{ lb}$$

HCLPF Capacity

$$F_u = 1.25$$

$$\text{HCLPF Capacity} = \frac{32,900}{35,500} (1.25) (0.50)$$

$$= 0.588$$



JOB NO. 59037 JOB WASS JPEE

BY [Signature]

DATE 7-18-94

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D [Signature]

DATE 7-20-94

Overturning Moment On Col. Line A Wall At TEL 9411-0"

Moment Demand

$M = 2.26 \times 10^4 \text{ ft-ft}$


Moment Capacity

Wall thickness = 9'-0"

Wall length = 139'-6"

Effective vertical reinforcement ratio = 0.00675

Effective axial stress = 68 psi



Compression Flange

$\frac{1}{2}$ clear distance $\approx 10'$

Total flange width = 14' = 168"

$A_{s1} = 2(9-0)(27.5)$

$= 220 \text{ in}^2$

$d_1 = 139.5 - \frac{27.5}{2}$

$= 126 \text{ ft}$

$A_{s2} = 2(0.79)(84.5)$

$= 134 \text{ in}^2$

$d_2 = 139.5/2$

$= 69.8 \text{ ft}$

$A_{s3} = 220 \text{ in}^2$

$d_3 = 27.5/2$

$= 13.8 \text{ ft}$



JOB NO. 59037 JOB WRESS DEFE

BY JSA

DATE 7-18-99

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D

AK

DATE 7-20-94

$$P_{NET} = 0.068 (4) (139.5) (144)$$

$$= 5500 \text{ lb}$$

Assume A_{23} is at field

$$d = \frac{(220 + 134 + 220) (60) + 5500}{0.85 (4) (168) f}$$

$$= 70" > t_f = 42"$$

Assume A_{23} is at $f_{23} = 32 \text{ ksi}$

$$d = \frac{(220 + 134) (60) + 5500 + 220 (32) - 0.85 (4) (42) (168 - 48)}{0.85 (4) (48)}$$

$$= 102" \approx$$

$$C = \frac{102}{0.85}$$

$$= 120' = 10.0 \text{ ft}$$

$$f_{23} = 0.003 (29,000) \frac{13.8 - 10.0}{10.0}$$

$$= 33 \text{ ksi} \approx 32 \text{ ksi} \quad \text{OK}$$

$$0.1 f_c A_2 = 0.1 (4) (48) (139.5) (12)$$

$$= 32,100 \text{ lb}$$

$$\frac{P}{0.1 f_c A_2} = \frac{5500}{32,100}$$

$$= 0.17$$

$$\phi = 0.90 - 0.2 (0.17)$$

$$= 0.87$$

$$\left(\frac{d}{2}\right) = \frac{(168 - 48) (42) (42/2) + (48) (102) (102/2)}{(168 - 48) (42) + 48 (102)}$$

$$= 35.8"$$

$$= 3.0 \text{ ft}$$



EQE INTERNATIONAL

SHEET NO. 28/39

JOB NO. 59037 JOB WASS FREE BY PSH DATE 7-18-94

CALC. NO. C-044 SUBJECT Turbine Bldg CHK'D [Signature] DATE 7-20-94

$$\begin{aligned} \phi M_u &= 0.87 \left[220(60)(126 - 3.0) + 134(60)(69.8 - 3.0) + 220(32)(13.8 - 3.0) \right. \\ &\quad \left. + 5500(69.8 - 3.0) \right] \\ &= 2.27 \times 10^6 \text{ k-ft} \end{aligned}$$

$$\begin{aligned} \bar{d} &= \frac{220(60)(126) + 134(60)(69.8) + 220(32)(13.8)}{220(60) + 134(60) + 220(32)} \\ &= 82.1 \text{ ft} \\ &= 985'' \end{aligned}$$

HCLPF Capacity

$$F_n = 1.25$$

$$\begin{aligned} \text{HCLPF Capacity} &= \frac{2.27 \times 10^6}{2.26 \times 10^6} (1.25) (0.50) \\ &= 0.638 \end{aligned}$$



JOB NO. 59637 JOB WRSS BRFF

BY PSH

DATE 7-18-94

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D

MC

DATE 7-20-94

Diaphragm Between Column Lines A and B At EL 471'-0"

Seismic Demand

Model the diaphragm as a flexible beam subjected to a uniform inertial load, with the following boundary conditions

- Fixed at Col. Line 7, accounting for restraint from walls at Col. Lines 6 & 7
- Simply supported by wall at Col. Line B
- Simply supported by continuous slab at Col. Line A; rotational restraint is limited.

Inertial Load

N-S (y-dir'n) ZPA, Node 5 = 0.84g

Masses

1'-6" floor slab - 150 (1.5) = 225 psf

3' x 3'-6 beams (typ) at 24' - 150 (3) (3.5-1.5) ($\frac{1}{2}$) = 38 psf

Col. Line A wall (4' thick) - 150 (4) ($\frac{1}{2}$) (501-441) ($\frac{1}{2}$) = 692 psf

Col. Line B columns (4' sq. typ) - 150 (4) (501-441) ($\frac{1}{2}$) ($\frac{1}{2}$) = 115 psf

Eqmt - Conservatively use 75 psf

Total - 1150 psf


$$q = 1.15 (26) (0.84)$$

$$= 25 \text{ klf}$$

$$\text{Col. Line A-B} = 26'$$

Diaphragm Internal Forces

Solve by moment distribution





JOB NO. 59037 JOB WRSS JPLIFE BY JEM DATE 7-18-94
 CALC. NO. C-044 SUBJECT Turbine Bldg CHK'D AK DATE 7-20-94

Fixed End moments

$$\text{Span AB - FEM} = \pm \frac{25(72)^2}{12}$$

$$= 210,800 \text{ k-ft}$$

$$\text{Span BC - FEM} = \pm \frac{25(136)^2}{12}$$

$$= \pm 38,500 \text{ k-ft}$$

Stiffness & Distribution Factors

$$K = \frac{EI}{L}$$

$$I = 1 \text{ nominal}$$

$$K_{BA} = 0.75 \frac{1}{72}$$

Simple support at A \Rightarrow 0.75 factor

$$= 1.04 \times 10^{-2}$$

$$K_{BC} = \frac{1}{136}$$

$$= 7.35 \times 10^{-3}$$

$$\Sigma K = 1.78 \times 10^{-2}$$

$$DF_{BA} = \frac{1.04 \times 10^{-2}}{1.78 \times 10^{-2}}$$

$$= 0.58$$

$$DF_{BC} = 1 - 0.58$$

$$= 0.42$$

Solution (Moments $\times 10^{-3}$)

	AB	BA	BC	CB
DF		0.58	0.42	
FEM	-10.8	+10.8	-38.5	+38.5
	+10.8	:		
		+5.4		
		+12.9	+9.4	
				+9.7
M	0	+29.1	-29.1	+43.2



EQE INTERNATIONAL

SHEET NO. 31/39

JOB NO. 59037 JOB WIPSS PFEF



BY FSH

DATE 7-18-94

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D

DATE 7-20-94



At distance $L/2 \approx 14'$ from support

$$V = 18,04 - 25(14)$$

$$= 1450 \text{ lb}$$

$$M = 43,200 - 1804(14) + \frac{1}{2}(25)(14)^2$$

$$= 20,400 \text{ lb-ft}$$





JOB NO. 59037 JOB WASS JEFFE

BY FEH

DATE 7-18-94

CALC. NO. C-044 SUBJECT Turbine Bldg

CHK'D

DATE 7-20-94

Moment Capacity - See Dr. C614; Sect. 748, Pr. 5616

Total depth of slab = 29'-8"

Concentrated reinforcement

11-#11 bars

$$A_s = 11(1.56) \\ = 17.2 \text{ in}^2$$

$$d = 29.67 - 0.58 \\ = 29.08 \text{ ft}$$

Slab Reinforcement

Slab 2325 - #6 @ 18" T & B E-W

OK to include both layers since slab is spanning more in N-S dir'n,

$$A_s = 2(0.44) \frac{29(12)}{18}$$

$$= 17.0 \text{ in}^2$$

$$d = \frac{1}{2}(29.67) \\ = 14.8 \text{ ft}$$

Conservatively neglect any beam reinforcement. Conservative neglect Col. Line A wall acting as a flange.

$$a = \frac{(17.2 + 17.0)(60)}{0.85(4)(18)}$$

$$= 34''$$

$$= 2.8 \text{ ft}$$

$$\phi M_n = 0.90 \left[17.2(60) \left(29.1 - \frac{2.8}{2} \right) + 17.0(60) \left(14.8 - \frac{2.8}{2} \right) \right] \\ = 38,000 \text{ ft-ft}$$

HCLPF Capacity

$$F_u = 1.25$$

$$\text{HCLPF Capacity} = \frac{38,000}{45,200} (1.25) (0.50C)$$

$$= 0.55g$$

(Note: Have additional capacity through yielding and redistribution).



JOB NO. 59037 JOB WASS JPEE BY FSH DATE 7-18-94
 CALC. NO. C-044 SUBJECT Turbine Bldg CHK'D FSH DATE 7-20-94

Shear Capacity

At distance $L/2 = 14'$ from support (west of Col. Line 7)

$$V = 1450 \text{ k}$$

$$M = 20,400 \text{ k-ft}$$

At the critical section, the slab is perforated by the stair opening. The diaphragm shear capacity will be determined by applying the approach for shear walls in App. L of EERI NP-6041. Only the slab section south of the opening will be included. The effective height of the panel will be conservatively taken as the E-W opening dimension (17'-0")

$$\text{Slab thickness} = 11\text{'-}6\text{'}$$

$$\begin{aligned} \text{Slab length} &= 29.67' - 8.08' - 4' \\ &= 17.6 \text{ ft} \end{aligned}$$

$$\text{Slab "height"} = 17'$$

$$\text{Slab reinf.} = \#6 @ 18" T + B \text{ E-W}, \#6 @ 12" T + B \text{ N-S} \quad \text{Mark No. 2S25}$$

$$\begin{aligned} \frac{h_w}{L_w} &= \frac{17}{17.6} \\ &= 0.97 \end{aligned}$$

Effective reinforcement ratio

$$p_v = \frac{2(0.44)}{18(17)}$$

$$= 0.00272$$

$$p_n = \frac{2(0.44)}{12(18)}$$

$$= 0.00407$$

$$A = -0.97 + 1.5 = 0.53$$

$$B = 0.97 - 0.5 = 0.47$$

$$\begin{aligned} p_{se} &= 0.53(0.00272) + 0.47(0.00407) \\ &= 0.00326 \end{aligned}$$



JOB NO. 59037 JOB WRESS TREE

BY FSH

DATE 1-18-99

CALC. NO. C-044 SUBJECT Turbin Bldg

CHK'D [Signature]

DATE 7-20-99

$$V_u = 6.8 \sqrt{4000} - 2.8 \sqrt{4000} (0.97 - 0.50) + 0.00336 (60,000) c^{-0.20}$$

Added term \uparrow

= 512 psi

Effective Section Depth

Slab Reinf. - #6 @ 18" TAB

$$\therefore A_s = 2(0.44) \frac{17.6(12)}{18}$$

$$= 10.3 \text{ in}^2$$

$$d \approx \frac{1}{2}(17.6)$$

$$= 8.8'$$

Reinf. at stair opening - 4-#11

$$A_s = 4(1.56)$$

$$= 6.24 \text{ in}^2$$

$$d \approx 17'$$

$$\bar{d} \approx \frac{10.3(8.8) + 6.24(17)}{10.3 + 6.24}$$

$$= 11.9 \text{ ft} = 143''$$

$$= 0.68 \text{ lw}$$

$$V_u = 0.512(18)(143)$$

$$= 1320 \text{ lb}$$

HCLPF Capacity

$$F_{cr} = 1.25$$

$$\text{HCLPF Capacity} = \frac{1520}{1450} (1.25) (0.50)$$

$$= 0.57$$

HCLPF Capacity

$$\text{HCLPF Capacity} = 0.55 \text{ . Controlled by moment}$$



EQE INTERNATIONAL

SHEET NO. A1

JOB NO. 59037 JOB WPSS IPETE BY FSH DATE 7-18-94
CALC. NO. C-044 SUBJECT Turbine Bldg CHK'D HC DATE 7-20-94

ATTACHMENT A

EXCERPTS FROM REFERENCE 3

(2 pp. total)



59037-C-044



EQE INTERNATIONAL

SHEET NO. B1

JOB NO. 59037 JOB WRPSS IFFEE BY PSH DATE 7-18-94
CALC. NO. C-044 SUBJECT Turbine Body CHK'D. OK DATE 7-20-94


ATTACHMENT B

EXCERPTS FROM REFERENCE 5

(19 pp. total)

JOB NO. 59037.01 JOB Seismic Analysis of WDN-2 BY JMB DATE 5/15/93
 CALC. NO. C-006 SUBJECT STIFFNESS CALCULATION CHKD. [Signature] DATE 6/22/93

BELOW MEZZ. FLOOR (ELEV. 471'0") - Wall & COLUMN GEOMETRY
 (X-Y reference at E(10))



W14x370	W14x176	W14x72	W14x214	W14x103	W14x136	W14x117
A = 0.76 ft ²	= 0.26	A = 0.11 ft ²	= 0.62	= 0.20	= 0.27	= 0.25
A _y = 0.64 ft	= 0.22	A _y = 0.11	= 0.51	= 0.16	= 0.21	= 0.19
A _x = 0.14 ft	= 0.07	A _x = 0.04	= 0.12	= 0.04	= 0.06	= 0.05
I _x = 0.76 ft ⁴	= 0.10	I _x = 0.04	= 0.21	= 0.05	= 0.07	= 0.07
I _y = 0.10 ft ⁴	= 0.04	I _y = 0.01	= 0.02	= 0.02	= 0.03	= 0.02

W14x264	W14x211	W14x142
A = 0.53	= 0.43	= 0.30
A _y = 0.42	= 0.34	= 0.24
A _x = 0.10	= 0.09	= 0.06
I _x = 0.16	= 0.13	= 0.08
I _y = 0.06	= 0.05	= 0.03

see drawings
 S601-602 +
 S633-634
 S628, S676

* Note: Closest section according to AISC 8th Edition

* See pages 16-17 for wall holes

59037-C-044

B4

WPPSS SSI ANALYSIS
 TURBINE BUILDING MODEL
 FINITE ELEMENT ANALYSIS TEST
 ELEV. 471'-0"

Calculation 59037-C-006

Page 25

By JMB

Date 6/10/93

Checked JMB
 (1 of 2)

Date 6/23/93

4. Calculation of the Torsional Constant

Wall		kx (k/ft)	ky (k/ft)	xs (ft)	ys (ft)	kzz (k-ft)	lz (ft ⁴)
w1a	y	2.05E+03	2.41E+05	-163.91	75.14	6.50E+09	1.10E+06
w1b	y	5.41E+03	8.05E+05	-163.91	-37.46	2.16E+10	3.66E+06
w2	y	1.44E+04	2.87E+05	-71.91	81.84	1.58E+09	2.67E+05
w3,5	x	2.82E+06	1.35E+05	1.06	94.84	2.53E+10	4.28E+06
w4	y	1.71E+04	3.04E+05	64.09	81.84	1.36E+09	2.31E+05
w6,7	y	3.98E+04	1.09E+06	88.09	43.15	8.50E+09	1.44E+06
w8	x	1.74E+05	1.25E+04	78.59	57.84	6.58E+08	1.11E+05
w9	x	1.74E+05	1.25E+04	78.59	19.84	1.46E+08	2.46E+04
w10	x	8.31E+05	4.73E+04	112.09	-17.16	8.38E+08	1.42E+05
w11,12	y	2.25E+04	1.66E+06	136.09	-15.55	3.08E+10	5.20E+06
w13	x	1.56E+06	1.97E+04	8.09	-95.16	1.41E+10	2.39E+06
w14	y	6.29E+04	1.69E+06	-71.91	-43.16	8.87E+09	1.50E+06
w15	x	8.31E+05	4.73E+04	-95.91	-43.16	1.98E+09	3.35E+05
w16	y	2.56E+04	3.48E+05	-95.91	-56.16	3.28E+09	5.54E+05
w17	x	3.04E+05	2.36E+04	-83.91	-69.16	1.62E+09	2.74E+05
w18	x	6.14E+05	2.43E+04	-25.91	-17.16	1.97E+08	3.33E+04
w19	y	2.16E+04	6.88E+05	-47.91	-43.16	1.62E+09	2.74E+05
w20	y	1.25E+04	5.73E+05	-27.91	-43.16	4.70E+08	7.94E+04
w21	x	4.65E+05	1.06E+04	-25.91	-69.16	2.23E+09	3.77E+05
w22	x	2.66E+05	1.58E+04	52.09	8.84	6.37E+07	1.08E+04
w23,24,31	y	3.05E+04	1.22E+06	40.09	-34.40	1.99E+09	3.37E+05
w25	x	1.90E+05	5.77E+03	28.09	-69.16	9.14E+08	1.54E+05
w26	x	2.66E+05	1.58E+04	28.09	-17.16	9.09E+07	1.54E+04
w27	x	1.03E+04	1.46E+02	131.39	-1.36	2.54E+06	4.30E+02
w28	x	1.03E+04	1.46E+02	131.39	-9.36	3.42E+06	5.79E+02
w30	y	2.95E+04	7.63E+05	6.09	-43.16	8.34E+07	1.41E+04
c1		6.26E+03	8.33E+03	-143.91	94.84	2.29E+08	3.87E+04
c2		6.26E+03	8.33E+03	-119.91	94.84	1.76E+08	2.98E+04
c3		6.26E+03	8.33E+03	-95.91	94.84	1.33E+08	2.25E+04
c4		4.92E+03	7.69E+03	112.09	94.84	1.41E+08	2.38E+04
c5		3.94E+03	3.94E+03	-41.91	68.84	2.56E+07	4.32E+03
c6		3.94E+03	3.94E+03	-27.91	68.84	2.17E+07	3.67E+03
c7		3.94E+03	3.94E+03	-3.91	68.84	1.87E+07	3.16E+03
c8		3.94E+03	3.94E+03	10.09	68.84	1.91E+07	3.22E+03
c9		3.94E+03	3.94E+03	40.09	68.84	2.50E+07	4.22E+03
c10		1.25E+03	1.25E+03	112.09	68.84	2.16E+07	3.64E+03
c11		1.25E+03	1.25E+03	112.09	38.84	1.75E+07	2.96E+03
c12		2.46E+02	2.46E+02	-41.91	8.84	4.51E+05	7.63E+01
c13		2.46E+02	2.46E+02	-27.91	8.84	2.11E+05	3.56E+01
c14		2.46E+02	2.46E+02	-3.91	8.84	2.30E+04	3.88E+00

21051-C-044

(2 of 2)
pg 26
B5

c15	2.46E+02	2.46E+02	10.09	8.84	4.43E+04	7.49E+00
c16	1.25E+03	1.25E+03	112.09	8.84	1.58E+07	2.66E+03
c17	2.31E+03	2.31E+03	64.09	-17.16	1.02E+07	1.72E+03
c18	8.68E+03	9.29E+03	-143.91	-43.16	2.09E+08	3.53E+04
c19	8.68E+03	9.29E+03	-3.91	-43.16	1.63E+07	2.76E+03
c20	8.68E+03	9.29E+03	16.09	-43.16	1.86E+07	3.14E+03
c21	8.68E+03	9.29E+03	64.09	-43.16	5.44E+07	9.19E+03
c22	8.68E+03	9.29E+03	88.09	-43.16	8.83E+07	1.49E+04
c23	8.68E+03	9.29E+03	112.09	-43.16	1.33E+08	2.25E+04
c24	2.31E+03	2.31E+03	64.09	-69.16	2.05E+07	3.47E+03
c25	1.25E+03	1.25E+03	88.09	-69.16	1.56E+07	2.64E+03
c26	1.25E+03	1.25E+03	112.09	-69.16	2.16E+07	3.65E+03
c27	2.31E+03	2.31E+03	112.09	-95.16	4.99E+07	8.44E+03
s1	4.80E+02	1.85E+02	-143.91	56.84	5.37E+06	9.08E+02
s2	7.38E+01	1.85E+02	-119.91	68.84	3.00E+06	5.08E+02
s3	7.38E+01	1.85E+02	-95.91	68.84	2.05E+06	3.46E+02
s4	1.85E+01	7.38E+01	-127.11	56.84	1.25E+06	2.12E+02
s5	3.88E+02	1.48E+02	-143.91	20.84	3.23E+06	5.45E+02
s6	1.85E+01	7.38E+01	-127.11	20.84	1.20E+06	2.03E+02
s7	3.69E+01	9.23E+01	-119.91	8.84	1.33E+06	2.25E+02
s8	5.54E+01	1.29E+02	-95.91	8.84	1.19E+06	2.02E+02
s9	7.38E+01	1.85E+02	-143.91	-17.16	3.84E+06	6.50E+02
s10	3.69E+01	1.29E+02	-119.91	-17.16	1.87E+06	3.16E+02
s11	3.69E+01	1.29E+02	-95.91	-17.16	1.20E+06	2.03E+02
s12	1.11E+02	2.95E+02	-143.91	-69.16	6.65E+06	1.12E+03
s13	9.23E+01	2.40E+02	-119.91	-69.16	3.89E+06	6.58E+02
s14	5.54E+01	1.48E+02	-95.91	-95.16	1.86E+06	3.14E+02
Sum	8.91E+06	1.02E+07			1.36E+11	2.31E+07

Ax = 1505.6 ft²
 Ay = 1717.4 ft²
 Iz = 2.31E+07 ft⁴

JOB NO. 59037.01 JOB Seismic Analysis of WPN-2

BY JMB DATE 6/10/93

CALC. NO. C-006 SUBJECT

CHK'D Jpr DATE 6/23/93

Properties below mezz. Floor (ELEV 471'-0")


$$\begin{aligned}
 A &= 4628.2 \text{ ft}^2 \\
 A_x &= 1505.6 \text{ ft}^2 \\
 A_y &= 1717.4 \text{ ft}^2 \\
 I_{zz} &= 2.31 \times 10^7 \text{ ft}^4 \\
 I_{xx} &= 1.82 \times 10^7 \text{ ft}^4 \\
 I_{yy} &= 3.12 \times 10^7 \text{ ft}^4 \\
 x_{CR} &= 3.91 \text{ ft} \\
 y_{CR} &= 17.16 \text{ ft}
 \end{aligned}$$

CONCRETE:

$$E = 415,295.6 \text{ Kcf}$$

$$G = 177,476.8 \text{ Kcf}$$

$$\nu = 0.17$$




Note: The center of wall area for vertical deformation will coincide with the center of rigidity in the structural model, since the differences are small.

JOB NO. 59037.01 JOB WPPSS
 CALC. NO. C-006 SUBJECT _____

SHEET NO. 29
 BY: JMB DATE 5/16/93
 CHK'D: [Signature] DATE 6/23/93

BELOW OPER. FLOOR (EL 501'-0") - WALL GEOMETRY



$W14 \times 111 \quad A_x = 0.174 \text{ ft}^2$
 $W14 \times 129 \quad A_y = 0.046 \text{ ft}^2$
 $I_x = 1240 \text{ in}^4 = 0.06 \text{ ft}^4$
 $I_y = 447 \text{ in}^4 = 0.022 \text{ ft}^4$
 $A = 32 \text{ in}^2 = 0.22 \text{ ft}^2$
 $W8 \times 26.4 \quad A_x = 0.42 \text{ ft}^2$
 $W14 \times 257 \quad A_y = 0.103 \text{ ft}^2$
 $I_x = 3400 \text{ in}^4 = 0.164 \text{ ft}^4$
 $I_y = 1290 \text{ in}^4 = 0.062 \text{ ft}^4$
 $A = 756 \text{ in}^2 = 0.525 \text{ ft}^2$
 $W14 \times 142 \quad A_y = 0.235 \text{ ft}^2$
 $W14 \times 145 \quad A_y = 0.06 \text{ ft}^2$
 $I_x = 0.083 \text{ ft}^4$
 $I_y = 0.033 \text{ ft}^4$
 $A = 0.3 \text{ ft}^2$

$W14 \times 237 \quad A_x = 0.38 \text{ ft}^2$
 $W14 \times 233 \quad A_y = 0.094 \text{ ft}^2$
 $I_{xx} = 3010 \text{ in}^4 = 0.145 \text{ ft}^4$
 $I_y = 1150 \text{ in}^4 = 0.055 \text{ ft}^4$
 $A = 68.5 \text{ in}^2 = 0.476 \text{ ft}^2$
 $W8 \times 8 \quad A_x = 0.11 \text{ ft}^2$
 $W14 \times 74 \quad A_y = 0.04 \text{ ft}^2$
 $I_x = 0.038 \text{ ft}^4$
 $I_y = 0.006 \text{ ft}^4$
 $A = 0.15 \text{ ft}^2$

[AISC Manual of Steel Construction, 9th Ed.]
 Sections are approximate (similar) to existing.

See drawings
 S614-619 +
 S637-638, 628,
 679, 625

Neglect small openings

541031-C-044

B9

WPPSS SSI ANALYSIS
 TURBINE BUILDING MODEL
 FINITE ELEMENT ANALYSIS TEST
 BELOW ELEV. 501'-0"

Calculation 59037-C-006

Page 36

By JMB

Date 6/16/93

(1 of 2)

Checked [Signature]

Date 6/23/93

4. Calculation of the Moments of Inertia

Wall		kx (k/ft)	ky (k/ft)	xs (ft)	ys (ft)	kzz (k-ft)	lzz (ft^4)
w1	y	9.9E+03	1.4E+06	-179.59	12.33	4.49E+10	7.59E+06
w2	y	3.6E+04	3.9E+05	-87.59	94.33	3.33E+09	5.62E+05
w3	x	3.1E+06	1.6E+05	-7.59	107.33	3.59E+10	6.07E+06
w4,5,6	y	1.3E+05	2.3E+06	72.41	51.33	1.24E+10	2.10E+06
w7	x	8.3E+05	4.7E+04	96.41	-4.67	4.57E+08	7.73E+04
w8,9	y	4.7E+04	2.3E+06	120.41	-10.42	3.40E+10	5.75E+06
w10	x	3.6E+06	1.4E+05	16.41	-82.67	2.44E+10	4.12E+06
w11,18	y	5.9E+04	1.3E+06	-87.59	-42.47	1.04E+10	1.76E+06
w12	x	8.3E+05	4.7E+04	-111.59	-30.67	1.37E+09	2.32E+05
w13	y	2.6E+04	3.5E+05	-111.59	-43.67	4.38E+09	7.40E+05
w14	x	3.0E+05	2.4E+04	-99.59	-56.67	1.21E+09	2.05E+05
w15	x	1.0E+04	1.5E+02	115.71	11.13	3.23E+06	5.46E+02
w16	x	1.0E+04	1.5E+02	115.71	3.13	2.06E+06	3.48E+02
w17	y	1.2E+02	6.6E+03	110.91	7.13	8.08E+07	1.37E+04
c1		4.9E+03	7.7E+03	-159.59	107.33	2.53E+08	4.27E+04
c2		4.9E+03	7.7E+03	-135.59	107.33	1.98E+08	3.35E+04
c3		4.9E+03	7.7E+03	-111.59	107.33	1.52E+08	2.58E+04
c4		4.9E+03	7.7E+03	96.41	107.33	1.28E+08	2.17E+04
c5		3.9E+03	3.9E+03	-57.59	81.33	3.91E+07	6.61E+03
c6		3.9E+03	3.9E+03	-43.59	81.33	3.35E+07	5.67E+03
c7		3.9E+03	3.9E+03	-19.59	81.33	2.76E+07	4.66E+03
c8		3.9E+03	3.9E+03	-5.59	81.33	2.62E+07	4.42E+03
c9		3.9E+03	3.9E+03	24.41	81.33	2.84E+07	4.80E+03
c10		3.7E+03	3.2E+03	48.41	81.33	3.20E+07	5.41E+03
c11		1.2E+03	1.2E+03	96.41	81.33	1.98E+07	3.35E+03
c12		1.2E+03	1.2E+03	96.41	51.33	1.49E+07	2.51E+03
c13		2.5E+02	2.5E+02	-57.59	21.33	9.28E+05	1.57E+02
c14		2.5E+02	2.5E+02	-43.59	21.33	5.79E+05	9.80E+01
c15		2.5E+02	2.5E+02	-19.59	21.33	2.06E+05	3.49E+01
c16		2.5E+02	2.5E+02	-5.59	21.33	1.20E+05	2.02E+01
c17		2.5E+02	2.5E+02	24.41	21.33	2.59E+05	4.37E+01
c18		2.3E+03	2.3E+03	48.41	21.33	6.46E+06	1.09E+03
c19		1.2E+03	1.2E+03	96.41	21.33	1.21E+07	2.05E+03
c20		3.1E+02	4.8E+02	-63.59	-4.67	1.95E+06	3.30E+02
c21		3.1E+02	4.8E+02	-43.59	-4.67	9.20E+05	1.55E+02
c22		3.1E+02	4.8E+02	-19.59	-4.67	1.91E+05	3.23E+01
c23		3.1E+02	4.8E+02	0.41	-4.67	6.80E+03	1.15E+00
c24		3.1E+02	4.8E+02	24.41	-4.67	2.93E+05	4.96E+01
c25		6.0E+02	6.0E+02	48.41	-4.67	1.42E+06	2.40E+02

51051-L-044

B10

(2 of 2)

pg 37

c26	8.7E+03	9.3E+03	-159.59	-30.67	2.45E+08	4.14E+04
c27	8.7E+03	9.3E+03	-63.59	-30.67	4.57E+07	7.73E+03
c28	8.7E+03	9.3E+03	-43.59	-30.67	2.58E+07	4.37E+03
c29	8.7E+03	9.3E+03	-19.59	-30.67	1.17E+07	1.98E+03
c30	8.7E+03	9.3E+03	0.41	-30.67	8.17E+06	1.38E+03
c31	8.7E+03	9.3E+03	24.41	-30.67	1.37E+07	2.32E+03
c32	8.7E+03	9.3E+03	48.41	-30.67	3.00E+07	5.06E+03
c33	8.7E+03	9.3E+03	72.41	-30.67	5.69E+07	9.62E+03
c34	8.7E+03	9.3E+03	96.41	-30.67	9.46E+07	1.60E+04
c35	1.0E+03	7.2E+02	-63.59	-56.67	6.25E+06	1.06E+03
c36	1.0E+03	7.2E+02	-43.59	-56.67	4.70E+06	7.95E+02
c37	1.0E+03	7.2E+02	-19.59	-56.67	3.61E+06	6.10E+02
c38	1.0E+03	7.2E+02	0.41	-56.67	3.33E+06	5.64E+02
c39	1.0E+03	7.2E+02	24.41	-56.67	3.76E+06	6.36E+02
c40	2.3E+03	2.3E+03	48.41	-56.67	1.28E+07	2.17E+03
c41	1.2E+03	1.2E+03	72.41	-56.67	1.05E+07	1.78E+03
c42	1.2E+03	1.2E+03	96.41	-56.67	1.56E+07	2.63E+03
s1	3.0E+02	1.1E+02	-159.59	69.33	4.37E+06	7.39E+02
s2	4.1E+01	1.1E+02	-135.59	81.33	2.30E+06	3.90E+02
s3	4.1E+01	1.1E+02	-111.59	81.33	1.65E+06	2.78E+02
s4	2.7E+02	1.0E+02	-159.59	33.33	2.88E+06	4.87E+02
s5	1.1E+01	7.0E+01	-135.59	21.33	1.29E+06	2.19E+02
s6	1.1E+01	7.0E+01	-111.59	21.33	8.78E+05	1.48E+02
s7	4.1E+01	1.1E+02	-159.59	-4.67	2.82E+06	4.77E+02
s8	1.1E+01	7.0E+01	-135.59	-4.67	1.29E+06	2.18E+02
s9	1.1E+01	7.0E+01	-111.59	-4.67	8.74E+05	1.48E+02
s10	6.1E+01	1.5E+02	-159.59	-56.67	4.10E+06	6.93E+02
s11	6.1E+01	1.5E+02	-135.59	-56.67	3.01E+06	5.09E+02
s12	4.1E+01	1.1E+02	-159.59	-82.67	3.10E+06	5.24E+02
s13	4.1E+01	1.1E+02	-135.59	-82.67	2.31E+06	3.91E+02
s14	4.1E+01	1.1E+02	-111.59	-82.67	1.66E+06	2.80E+02
Sum	9.12E+06	8.69E+06			1.74E+11	2.95E+07

Ax = 1541.5 ft²
 Ay = 1469.4 ft²
 Iz = 2.95E+07 ft⁴



JOB NO. 59037.01 JOB WPPSS BY JMB DATE 5/10/93
 CALC. NO. C-006 SUBJECT _____ CHK'D JMB DATE 6/23/93

Properties Below Operational Floor (EL. 501'-0")

$$A = 4211.0 \text{ ft}^2$$

$$A_x = 1541.5 \text{ ft}^2$$

$$A_y = 1469.4 \text{ ft}^2$$

$$I_{zz} = 2.95 \times 10^7 \text{ ft}^4$$

$$I_{xx} = 2.09 \times 10^7 \text{ ft}^4$$

$$I_{yy} = 3.67 \times 10^7 \text{ ft}^4$$

Concrete:


$$E = 415,295.6 \text{ Ksf}$$

$$G = 177,476.8 \text{ Ksf}$$

$$\nu = 0.17$$

$$X_{CR} = 19.59 \text{ ft}$$

$$Y_{CR} = 4.67 \text{ ft}$$



Note: Axial center of wall and column areas are taken at center of rigidity (X_{CR}, Y_{CR}), because the difference is small.

JOB NO. 59037.01 JOB Seismic Analysis of WPN-2

BY JMB



DATE 5/25/92

CALC. NO. C-006 SUBJECT

CHK'D J

DATE 6/17/93

Below Elev 531'-0" - WALL & COLUMN Geometry



COLUMN ANALOG LINE A

$$A = 2(2.25)(\frac{3}{12}) + \frac{2.25}{12}(2.5) = 1.59 \text{ ft}^2$$

$$A_x = 2(\frac{3}{12})(2.25) = 1.125 \text{ ft}^2$$

$$A_y = (2.25)(\frac{3}{12})(2.5) = 0.47 \text{ ft}^2$$

$$I_{xx} = \frac{1}{12}(\frac{2.25}{12})(2.5)^3 + 2[\frac{1}{12}(2.25)(0.25)^3 + (2.25)(0.25)(1.375)^2]$$

$$= 2.38 \text{ ft}^4$$

$$I_{yy} = \frac{1}{12}(2.5)(2.25(\frac{3}{12}))^3 + 2[\frac{1}{12}(\frac{3}{12})(2.25)^3]$$

$$= 0.48 \text{ ft}^4$$

COLUMN Line 17 & 4

W27x94:

$$A = \frac{27.7}{144} = 0.19 \text{ ft}^2$$

$$A_x = 0.10 \text{ ft}^2$$

$$A_y = 0.09 \text{ ft}^2$$

$$I_{xx} = 3270/144^2 = 0.16 \text{ ft}^4$$

$$I_{yy} = 124/144^2 = 0.006 \text{ ft}^4$$

W14x95 (Approx):

$$A = 26.5/144 = 0.18 \text{ ft}^2$$

$$A_x = 0.14 \text{ ft}^2$$

$$A_y = 0.04 \text{ ft}^2$$

$$I_{xx} = 199/144^2 = 0.05 \text{ ft}^4$$

$$I_{yy} = 362/144^2 = 0.02 \text{ ft}^4$$

W14x78:

$$A = 0.15 \text{ ft}^2$$

$$A_x = 0.11 \text{ ft}^2$$

$$A_y = 0.04 \text{ ft}^2$$

$$I_{xx} = 0.04 \text{ ft}^4$$

$$I_{yy} = 0.006 \text{ ft}^4$$

see drawing
Numbers 5619-624,
5640-5641,
627,672,675,676,678

{ AISC Manual of Steel Construction, 9th Ed. Section are similar to existing.

By JMB

Date 6/17/93

Checked [Signature]

Date 6/23/93

3. Calculation of Center of Rigidity

Story ht = 30 ft
 E = 415295.601 ksf
 G = 177470.8 ksf

Wall or Column		L (ft)	T (ft)	I _{xx} (ft ⁴)	I _{yy} (ft ⁴)	I _{xx} (k/ft)	I _{yy} (k/ft)	X (ft)	Y (ft)	I _{xx} Y (k)	I _{yy} X (k)
w1	y	26.00	3.50	5.13E+03	9.29E+01	1.71E+04	3.04E+05	-68.0	99.0	1.70E+06	-2.07E+07
w2	x	160.00	4.00	8.53E+02	1.37E+03	3.12E+03	1.58E+05	12.0	112.0	3.49E+08	1.89E+06
w3	y	86.00	3.50	1.86E+05	3.07E+02	5.67E+04	1.42E+06	92.0	69.0	3.91E+06	1.31E+08
w4	x	24.00	3.00	5.40E+01	3.46E+03	2.28E+05	9.97E+03	80.0	26.0	5.93E+06	7.97E+05
w5,6	y	104.00	3.50	3.28E+05	3.72E+02	6.86E+04	1.74E+06	68.0	-26.0	-1.78E+07	1.19E+08
w7,9-11	x	48.00	3.00	1.64E+04	4.18E+04	6.50E+05	3.03E+04	116.0	-26.0	-1.69E+07	3.52E+06
w8	y	52.00	1.50	1.76E+04	1.46E+01	2.70E+03	3.44E+05	140.0	-52.0	-1.40E+05	4.81E+07
w9	x	24.00	2.50	3.13E+01	2.88E+03	1.90E+05	5.77E+03	128.0	-78.0	-1.48E+07	7.38E+05
w10	x	136.00	3.50	4.86E+02	7.34E+05	2.31E+03	8.97E+04	0.0	-78.0	-1.80E+08	0.00E+00
w11,12	y	104.00	3.75	2.28E+05	4.63E+02	8.55E+04	1.84E+06	-68.0	-24.3	-2.08E+06	-1.25E+08
w13,2-3	x	48.00	2.51	1.14E+02	2.50E+04	5.26E+05	2.11E+04	-96.8	-26.0	-1.37E+07	-2.04E+06
w14	x	48.00	2.50	6.25E+01	2.30E+04	5.19E+05	1.15E+04	92.0	-71.8	-3.73E+07	1.06E+06
w15	y	30.00	1.00	2.25E+03	2.50E+00	4.61E+02	1.09E+05	140.0	22.8	1.05E+04	1.53E+07
w16	y	30.00	1.00	2.25E+03	2.50E+00	4.61E+02	1.09E+05	130.5	22.8	1.05E+04	1.42E+07
w17	x	9.50	1.00	7.92E-01	7.14E+01	1.03E+04	1.46E+02	135.3	7.8	8.03E+04	1.98E+04
w18	x	9.50	1.00	7.92E-01	7.14E+01	1.03E+04	1.46E+02	135.3	15.8	1.63E+05	1.98E+04
w19	x	9.50	1.00	7.92E-01	7.14E+01	1.03E+04	1.46E+02	135.3	37.8	3.89E+05	1.98E+04
w20	y	52.00	1.50	1.76E+04	1.46E+01	2.70E+03	3.44E+05	-160.0	-52.0	-1.40E+05	-5.50E+07
c1		5.00	4.83	5.03E+01	4.70E+01	8.68E+03	9.29E+03	-140.0	-26.0	-2.26E+05	-1.30E+06
c4		5.00	4.83	5.03E+01	4.70E+01	8.68E+03	9.29E+03	-44.0	-26.0	-2.26E+05	-4.09E+05
c5		5.00	4.83	5.03E+01	4.70E+01	8.68E+03	9.29E+03	-24.0	-26.0	-2.26E+05	-2.23E+05
c6		5.00	4.83	5.03E+01	4.70E+01	8.68E+03	9.29E+03	0.0	-26.0	-2.26E+05	0.00E+00
c7		5.00	4.83	5.03E+01	4.70E+01	8.68E+03	9.29E+03	20.0	-26.0	-2.26E+05	1.86E+05
c8		5.00	4.83	5.03E+01	4.70E+01	8.68E+03	9.29E+03	44.0	-26.0	-2.26E+05	4.09E+05
s1				2.38E+00	4.80E-01	8.86E+02	4.39E+03	-160.0	112.0	9.92E+04	-7.03E+05
s2				2.38E+00	4.80E-01	8.86E+02	4.39E+03	-140.0	112.0	9.92E+04	-6.15E+05
s3				2.38E+00	4.80E-01	8.86E+02	4.39E+03	-116.0	112.0	9.92E+04	-5.10E+05
s4				2.38E+00	4.80E-01	8.86E+02	4.39E+03	-92.0	112.0	9.92E+04	-4.04E+05
s5				2.38E+00	4.80E-01	8.86E+02	4.39E+03	116.0	112.0	9.92E+04	5.10E+05
s6				2.38E+00	4.80E-01	8.86E+02	4.39E+03	140.0	112.0	9.92E+04	6.15E+05
s7				5.00E-02	2.00E-02	3.69E+01	9.23E+01	-140.0	-52.0	-1.92E+03	-1.29E+04
s8				5.00E-02	2.00E-02	3.69E+01	9.23E+01	-116.0	-52.0	-1.92E+03	-1.07E+04
s9				5.00E-02	2.00E-02	3.69E+01	9.23E+01	-92.0	-52.0	-1.92E+03	-8.49E+03
s10				5.00E-02	2.00E-02	3.69E+01	9.23E+01	-44.0	-52.0	-1.92E+03	-4.06E+03
s11				5.00E-02	2.00E-02	3.69E+01	9.23E+01	-24.0	-52.0	-1.92E+03	-2.21E+03
s12				5.00E-02	2.00E-02	3.69E+01	9.23E+01	0.0	-52.0	-1.92E+03	0.00E+00
s13				5.00E-02	2.00E-02	3.69E+01	9.23E+01	20.0	-52.0	-1.92E+03	1.85E+03
s14				5.00E-02	2.00E-02	3.69E+01	9.23E+01	44.0	-52.0	-1.92E+03	4.06E+03
s15				5.00E-02	2.00E-02	3.69E+01	9.23E+01	92.0	-52.0	-1.92E+03	8.49E+03
s16				5.00E-02	2.00E-02	3.69E+01	9.23E+01	116.0	-52.0	-1.92E+03	1.07E+04
s17				4.00E-02	6.00E-03	1.11E+01	7.38E+01	-140.0	-78.0	-8.64E+02	-1.03E+04
s18				4.00E-02	6.00E-03	1.11E+01	7.38E+01	-116.0	-78.0	-8.64E+02	-8.56E+03
s19				4.00E-02	6.00E-03	1.11E+01	7.38E+01	-92.0	-78.0	-8.64E+02	-6.79E+03
s20				4.00E-02	6.00E-03	1.11E+01	7.38E+01	92.0	-78.0	-8.64E+02	6.79E+03
s21				6.00E-03	1.60E-01	2.95E+02	1.11E+01	-160.0	93.8	2.77E+04	-1.77E+03
s22				6.00E-03	1.60E-01	2.95E+02	1.11E+01	-160.0	77.0	2.27E+04	-1.77E+03
s23				6.00E-03	1.60E-01	2.95E+02	1.11E+01	-160.0	62.0	1.83E+04	-1.77E+03
s24				6.00E-03	1.60E-01	2.95E+02	1.11E+01	-160.0	44.0	1.30E+04	-1.77E+03
s25				6.00E-03	1.60E-01	2.95E+02	1.11E+01	-160.0	23.4	6.91E+03	-1.77E+03
s26				6.00E-03	1.60E-01	2.95E+02	1.11E+01	-160.0	7.8	2.30E+03	-1.77E+03
s27				6.00E-03	1.60E-01	2.95E+02	1.11E+01	-160.0	-7.8	-2.30E+03	-1.77E+03
s28				6.00E-03	1.60E-01	2.95E+02	1.11E+01	140.0	93.8	2.77E+04	1.55E+03
s29				6.00E-03	1.60E-01	2.95E+02	1.11E+01	140.0	77.0	2.27E+04	1.55E+03
s30				6.00E-03	1.60E-01	2.95E+02	1.11E+01	140.0	62.0	1.83E+04	1.55E+03
s31				6.00E-03	1.60E-01	2.95E+02	1.11E+01	140.0	44.0	1.30E+04	1.55E+03
s32				6.00E-03	1.60E-01	2.95E+02	1.11E+01	140.0	-7.8	-2.30E+03	1.55E+03
SUM						7.86E+06	6.62E+06			9.39E+07	1.30E+08

Xs = 19.69 ft Center of Rigidity
 Ys = 11.91 ft

59037-C-044

B19

WPPSS SSI ANALYSIS
 TURBINE BUILDING MODEL
 FINITE ELEMENT ANALYSIS TEST
 BELOW ELEV. 531'-0"

Calculation 59037-C-006

Page 49By JMBDate 6/17/93 (1 of 2)Checked JDate 6/23/93

4. Calculation of the Moments of Inertia

Wall		kx (k/ft)	ky (k/ft)	xs (ft)	ys (ft)	kzz (k-ft)	lzz (ft ⁴)
w1	y	1.7E+04	3.0E+05	-87.60	87.06	2.47E+09	4.17E+05
w2	x	3.1E+06	1.6E+05	-7.60	100.06	3.12E+10	5.28E+06
w3	y	5.7E+04	1.4E+06	72.40	57.06	7.64E+09	1.29E+06
w4	x	2.3E+05	1.0E+04	60.40	14.06	8.15E+07	1.38E+04
w5,6	y	6.9E+04	1.7E+06	48.40	-37.94	4.18E+09	7.07E+05
w7,c9-11	x	6.5E+05	3.0E+04	96.40	-37.94	1.22E+09	2.06E+05
w8	y	2.7E+03	3.4E+05	120.40	-63.94	4.99E+09	8.44E+05
w9	x	1.9E+05	5.8E+03	108.40	-89.94	1.60E+09	2.71E+05
w10	x	2.3E+06	9.0E+04	-19.60	-89.94	1.87E+10	3.16E+06
w11,12	y	8.5E+04	1.8E+06	-87.60	-36.24	1.42E+10	2.40E+06
w13,c2-3	x	5.3E+05	2.1E+04	-116.40	-37.94	1.04E+09	1.76E+05
w14	x	5.2E+05	1.2E+04	72.40	-83.69	3.70E+09	6.25E+05
w15	y	4.6E+02	1.1E+05	120.40	10.86	1.58E+09	2.67E+05
w16	y	4.6E+02	1.1E+05	110.90	10.86	1.34E+09	2.27E+05
w17	x	1.0E+04	1.5E+02	115.70	-4.14	2.13E+06	3.60E+02
w18	x	1.0E+04	1.5E+02	115.70	3.86	2.11E+06	3.57E+02
w19	x	1.0E+04	1.5E+02	115.70	25.86	8.84E+06	1.49E+03
w20	y	2.7E+03	3.4E+05	-179.60	-63.94	1.11E+10	1.88E+06
c1		8.7E+03	9.3E+03	-159.60	-37.94	2.49E+08	4.21E+04
c4		8.7E+03	9.3E+03	-63.60	-37.94	5.01E+07	8.47E+03
c5		8.7E+03	9.3E+03	-43.60	-37.94	3.02E+07	5.10E+03
c6		8.7E+03	9.3E+03	-19.60	-37.94	1.61E+07	2.72E+03
c7		8.7E+03	9.3E+03	0.40	-37.94	1.25E+07	2.11E+03
c8		8.7E+03	9.3E+03	24.40	-37.94	1.80E+07	3.05E+03
s1		8.9E+02	4.4E+03	-179.60	100.06	1.51E+08	2.55E+04
s2		8.9E+02	4.4E+03	-159.60	100.06	1.21E+08	2.04E+04
s3		8.9E+02	4.4E+03	-135.60	100.06	8.96E+07	1.52E+04
s4		8.9E+02	4.4E+03	-111.60	100.06	6.36E+07	1.07E+04
s5		8.9E+02	4.4E+03	96.40	100.06	4.97E+07	8.40E+03
s6		8.9E+02	4.4E+03	120.40	100.06	7.26E+07	1.23E+04
s7		3.7E+01	9.2E+01	-159.60	-63.94	2.50E+06	4.23E+02
s8		3.7E+01	9.2E+01	-135.60	-63.94	1.85E+06	3.12E+02
s9		3.7E+01	9.2E+01	-111.60	-63.94	1.30E+06	2.20E+02
s10		3.7E+01	9.2E+01	-63.60	-63.94	5.24E+05	8.86E+01
s11		3.7E+01	9.2E+01	-43.60	-63.94	3.26E+05	5.52E+01
s12		3.7E+01	9.2E+01	-19.60	-63.94	1.86E+05	3.15E+01
s13		3.7E+01	9.2E+01	0.40	-63.94	1.51E+05	2.55E+01
s14		3.7E+01	9.2E+01	24.40	-63.94	2.06E+05	3.48E+01
s15		3.7E+01	9.2E+01	72.40	-63.94	6.35E+05	1.07E+02

5-1057-C-044

B5
(2 of 2)
pg 50

s16	3.7E+01	9.2E+01	96.40	-63.94	1.01E+06	1.70E+02
s17	1.1E+01	7.4E+01	-159.60	-89.94	1.97E+06	3.33E+02
s18	1.1E+01	7.4E+01	-135.60	-89.94	1.45E+06	2.45E+02
s19	1.1E+01	7.4E+01	-111.60	-89.94	1.01E+06	1.71E+02
s20	1.1E+01	7.4E+01	72.40	-89.94	4.77E+05	8.06E+01
s21	3.0E+02	1.1E+01	-179.60	81.86	2.34E+06	3.95E+02
s22	3.0E+02	1.1E+01	-179.60	65.06	1.61E+06	2.72E+02
s23	3.0E+02	1.1E+01	-179.60	50.06	1.10E+06	1.85E+02
s24	3.0E+02	1.1E+01	-179.60	32.06	6.61E+05	1.12E+02
s25	3.0E+02	1.1E+01	-179.60	11.46	3.96E+05	6.69E+01
s26	3.0E+02	1.1E+01	-179.60	-4.14	3.62E+05	6.12E+01
s27	3.0E+02	1.1E+01	-179.60	-19.74	4.72E+05	7.98E+01
s28	3.0E+02	1.1E+01	120.40	81.86	2.14E+06	3.62E+02
s29	3.0E+02	1.1E+01	120.40	65.06	1.41E+06	2.38E+02
s30	3.0E+02	1.1E+01	120.40	50.06	9.01E+05	1.52E+02
s31	3.0E+02	1.1E+01	120.40	32.06	4.64E+05	7.85E+01
s32	3.0E+02	1.1E+01	120.40	-19.74	2.76E+05	4.66E+01
	7.86E+06	6.62E+06			1.06E+11	1.79E+07

Ax = 1329.10 ft²
Ay = 1119.63 ft²
Iz = 1.79E+07 ft⁴

EQE ENGINEERING

SHEET NO. 51JOB NO. 59037.01 JOB Seismic Analysis of WPN-2BY JMB DATE 5/27/93CALC. NO. C-006 SUBJECT _____CHK'D Jr DATE 6/23/93Properties below Elev. 531'-0"

$$A = 3310.5 \text{ ft}^2$$

$$A_x = 1329.1 \text{ ft}^2$$

$$A_y = 1119.6 \text{ ft}^2$$

$$I_{zz} = 1.79 \times 10^7 \text{ ft}^4$$

$$I_{xx} = 1.75 \times 10^7 \text{ ft}^4$$

$$I_{yy} = 2.13 \times 10^7 \text{ ft}^4$$

$$x_{cr} = 19.60 \text{ ft}$$


$$y_{cr} = 11.94 \text{ ft}$$

Concrete:

$$E = 415,295.6 \text{ Ksf}$$

$$G = 177,476.8 \text{ Ksf}$$

$$\nu = 0.17$$



Note: Axial center of wall and column areas are taken at center of rigidity (x_{cr}, y_{cr}), because the difference is small.


JOB NO. 59037.01 JOB Seismic Analysis of WPN-2

BY GM.B DATE 6/22/93

CALC. NO. C-006 SUBJECT _____

CHK'D Jr DATE 6/23/93

TURBINE BUILDING STICK MODEL REPRESENTATION



1**** Algor (c) Dynamic Modal Analysis SSAP1 05/03/91 ver 9.20/387

DATE: JUNE 23,1993
 TIME: 04:46 PM
 INPUT FILE.....turbine

Seismic Analysis of WPN-2 - Turbine Building

1**** CONTROL INFORMATION

number of node points (NUMNP) = 29
 number of element types (NELTYP) = 1
 number of load cases (LL) = 0
 number of frequencies (NF) = 30
 geometric stiffness flag (GEOSTF) = 0
 analysis type code (NDYN) = 1
 solution mode (MODEX) = 0
 equations per block (KEQB) = 0
 weight and c.g. flag (IHTCG) = 0
 bandwidth minimization flag (MINBND) = 0
 gravitational constant (GRAV) = 3.2200E+01

bandwidth minimization specified

1**** NODAL DATA

NODE NO.	BOUNDARY CONDITION CODES						NODAL POINT COORDINATES			
	DX	DY	DZ	RX	RY	RZ	X	Y	Z	T
1	0	0	0	0	0	0	-1.000E+01	4.300E+01	5.691E+02	0.000E+00
2	0	0	0	0	0	0	2.600E+01	5.330E+01	5.427E+02	0.000E+00
3	0	0	0	0	0	0	9.100E+00	-2.850E+01	5.310E+02	0.000E+00
4	0	0	0	0	0	0	2.020E+01	8.500E+00	5.010E+02	0.000E+00
5	0	0	0	0	0	0	9.900E+00	-2.900E+00	4.710E+02	0.000E+00
6	0	0	0	0	0	0	-3.560E+01	5.740E+01	5.010E+02	0.000E+00
7	0	0	0	0	0	0	-3.060E+01	5.600E+01	4.710E+02	0.000E+00
8	0	0	0	0	0	0	-7.700E+00	4.300E+01	5.691E+02	0.000E+00
9	0	0	0	0	0	0	-7.700E+00	4.300E+01	5.427E+02	0.000E+00
10	0	0	0	0	0	0	-7.700E+00	3.780E+01	5.427E+02	0.000E+00
11	0	0	0	0	0	0	-7.700E+00	3.780E+01	5.310E+02	0.000E+00
12	0	0	0	0	0	0	1.960E+01	1.190E+01	5.310E+02	0.000E+00
13	0	0	0	0	0	0	1.960E+01	1.190E+01	5.010E+02	0.000E+00
14	0	0	0	0	0	0	1.960E+01	4.700E+00	5.010E+02	0.000E+00
15	0	0	0	0	0	0	1.960E+01	4.700E+00	4.710E+02	0.000E+00
16	0	0	0	0	0	0	3.900E+00	1.720E+01	4.710E+02	0.000E+00
17	0	0	0	0	0	0	3.900E+00	1.720E+01	4.410E+02	0.000E+00
18	0	0	0	0	0	0	-4.750E+01	5.600E+01	5.010E+02	0.000E+00
19	0	0	0	0	0	0	-4.750E+01	5.600E+01	4.710E+02	0.000E+00
20	0	0	0	0	0	0	-4.900E+01	5.610E+01	4.710E+02	0.000E+00
21	0	0	0	0	0	0	-4.900E+01	5.610E+01	4.410E+02	0.000E+00
22	1	1	1	1	1	1	-6.600E+00	2.960E+01	4.265E+02	0.000E+00
23	1	1	1	1	1	1	-6.700E+00	4.300E+01	5.691E+02	0.000E+00
24	1	1	1	1	1	1	-6.700E+00	3.780E+01	5.427E+02	0.000E+00
25	1	1	1	1	1	1	2.060E+01	1.190E+01	5.310E+02	0.000E+00
26	1	1	1	1	1	1	2.060E+01	4.700E+00	5.010E+02	0.000E+00
27	1	1	1	1	1	1	4.900E+00	1.720E+01	4.710E+02	0.000E+00
28	1	1	1	1	1	1	-4.800E+01	5.610E+01	4.710E+02	0.000E+00
29	1	1	1	1	1	1	-4.650E+01	5.600E+01	5.010E+02	0.000E+00

**** PRINT OF EQUATION NUMBERS SUPPRESSED

1**** BEAM ELEMENTS

number of beam elements = 21
 number of area property sets = 9

number of fixed end force sets = 0
 number of materials = 2
 number of intermediate load sets = 0

1**** MATERIAL PROPERTIES

INDEX	E	NU	MASS DENSITY	WEIGHT DENSITY	THERMAL EXPANSION			REFERENCE TEMPERATURE
					X	Y	Z	
1	4.15E+05	.170	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.000E+00
2	4.18E+06	.300	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.000E+00

1**** AREA PROPERTIES

INDEX	AREAS			TORSION	FLEXURAL INERTIAS		
	AXIAL A(1)	SHEAR A(2)	SHEAR A(3)		J(1)	I(2)	I(3)
1	3.430E+01	4.100E+00	2.490E+00	3.740E+04	1.520E+05	3.350E+05	
2	3.140E+01	4.210E+00	2.490E+00	3.770E+04	1.370E+05	3.090E+05	
3	3.311E+03	1.329E+03	1.120E+03	1.790E+07	1.750E+07	2.130E+07	
4	4.211E+03	1.542E+03	1.469E+03	2.950E+07	2.090E+07	3.670E+07	
5	4.628E+03	1.506E+03	1.717E+03	2.310E+07	1.820E+07	3.120E+07	
6	1.703E+03	8.627E+02	1.273E+03	7.550E+06	7.290E+05	6.690E+06	
7	1.808E+03	8.104E+02	2.813E+02	1.840E+06	8.810E+05	7.250E+06	
8	1.000E+06	1.000E+06	1.000E+06	1.000E+12	1.000E+12	1.000E+12	
9	2.000E+06	2.000E+06	2.000E+06	2.000E+12	2.000E+12	2.000E+12	

1**** STRESS PROPERTIES

INDEX	SECTION MODULI	
	S(2)	S(3)
1	0.000E+00	0.000E+00
2	0.000E+00	0.000E+00
3	0.000E+00	0.000E+00
4	0.000E+00	0.000E+00
5	0.000E+00	0.000E+00
6	0.000E+00	0.000E+00
7	0.000E+00	0.000E+00
8	0.000E+00	0.000E+00
9	0.000E+00	0.000E+00

1**** ELEMENT LOAD MULTIPLIERS

	CASE A	CASE B	CASE C	CASE D
	X-DIR	0.000E+00	0.000E+00	0.000E+00
Y-DIR	0.000E+00	0.000E+00	0.000E+00	0.000E+00
Z-DIR	0.000E+00	0.000E+00	0.000E+00	0.000E+00

1**** ELEMENT CONNECTIVITY DATA

ELEMENT NO.	NODE I	NODE J	NODE K	MAT'L INDEX	SECTN INDEX	ELEMENT LOADS				RELEASE CODES		MEMBER NO.
						A	B	C	D	I-END	J-END	
1	9	8	23	2	1	0	0	0	0	0	0	0
2	11	10	24	2	2	0	0	0	0	0	0	0
3	13	12	25	1	3	0	0	0	0	0	0	0
4	15	14	26	1	4	0	0	0	0	0	0	0
5	17	16	27	1	5	0	0	0	0	0	0	0
6	19	18	29	1	6	0	0	0	0	0	0	0
7	21	20	28	1	7	0	0	0	0	0	0	0
8	1	8	9	2	8	0	0	0	0	0	0	0
9	2	9	8	2	8	0	0	0	0	0	0	0
10	2	10	11	2	8	0	0	0	0	0	0	0

59037-C-044

B18

file: C:\WPSS\TURBINE\SSAP\TURBINE.L Page: 3

11	3	11	10	1	8	0	0	0	0	0	0
12	3	12	13	1	8	0	0	0	0	0	0
13	4	13	12	1	8	0	0	0	0	0	0
14	4	14	15	1	8	0	0	0	0	0	0
15	5	15	14	1	8	0	0	0	0	0	0
16	5	16	17	1	8	0	0	0	0	0	0
17	6	18	19	1	8	0	0	0	0	0	0
18	7	19	18	1	8	0	0	0	0	0	0
19	7	20	21	1	8	0	0	0	0	0	0
20	22	21	20	1	9	0	0	0	0	0	0
21	22	17	16	1	9	0	0	0	0	0	0

1**** BANDWIDTH MINIMIZATION

minbnd (bandwidth control parameter) = 1
 bandwidth before resequencing = 84
 bandwidth after resequencing = 12

**** EQUATION PARAMETERS

total number of equations = 126
 bandwidth = 12
 number of equations in a block = 125
 number of blocks = 2
 blocking memory (kilobytes) = 2793
 available memory (kilobytes) = 2793

**** Hard disk file size information for processor:

Available hard disk space on C drive = 116.232 megabytes
 Estimated required hard disk space = .293 megabytes

1**** NODAL LOADS (STATIC) OR MASSES (DYNAMIC)

NODE NUMBER	LOAD CASE	X-AXIS FORCE	Y-AXIS FORCE	Z-AXIS FORCE	X-AXIS MOMENT	Y-AXIS MOMENT	Z-AXIS MOMENT
1	0	7.940E+01	7.940E+01	7.940E+01	1.090E+05	6.030E+05	7.120E+05
2	0	2.790E+01	2.790E+01	2.790E+01	9.860E+04	2.720E+05	3.130E+05
3	0	3.172E+02	3.172E+02	3.172E+02	1.160E+06	2.330E+06	3.450E+06
4	0	1.143E+03	1.143E+03	1.143E+03	5.030E+06	7.730E+06	1.320E+07
5	0	1.442E+03	1.442E+03	1.442E+03	5.410E+06	9.860E+06	1.470E+07
6	0	6.424E+02	6.424E+02	6.424E+02	2.330E+05	2.290E+06	2.460E+06
7	0	3.546E+02	3.546E+02	3.546E+02	1.730E+05	1.420E+06	1.560E+06

1**** ELEMENT LOAD MULTIPLIERS

load case	case A	case B	case C	case D
1	0.000E+00	0.000E+00	0.000E+00	0.000E+00

1**** STIFFNESS MATRIX PARAMETERS

minimum non-zero diagonal element = 2.6056E+09
 maximum diagonal element = 1.8157E+18
 maximum/minimum = 6.9682E+08
 average diagonal element = 9.3139E+16
 density of the matrix = 2.2367E+01

1**** EIGENVALUE ANALYSIS

**** SUBSPACE ITERATION ALGORITHM EXECUTED

1**** MODAL ANALYSIS CONTROL INFORMATION

file: C:\WPSS\TURBINE\SSAP\TURBINE.L

flag for additional printing (IFPR) = 0
 Sturm sequence check flag (IFSS) = 0
 maximum iteration cycles (NITEM) = 32
 convergence tolerance (RTOL) = 1.0000E-05
 cut-off frequency (hertz) (COFQ) = 5.0000E+01
 no. of starting iteration vectors (NFO) = 0
 est. no. of rigid body modes (NSF) = 0
 eigen value shift (given) (SHIFT) = 0.0000E+00
 orthogonality check flag (NORTH) = 0

**** SOLUTION SOUGHT FOR FOLLOWING EIGENPROBLEM

number of equations = 126
 half bandwidth of stiffness matrix = 12
 number of equation blocks = 2
 number of equations per block = 125
 number of eigenvalues required = 30

1**** ITERATION NUMBER.....

sweep number in jacobi = 10

relative tolerance reached on eigenvalues:

.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01
.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01
.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01
.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01
.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01
.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01
.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01
.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01
.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01
.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01	.1000D+01

1**** ITERATION NUMBER.....

sweep number in jacobi = 8

relative tolerance reached on eigenvalues:

.1959D-15	.7541D-15	.1903D-14	.1909D-14	.3678D-15	.2637D-14
.2593D-14	.1170D-14	.1208D-15	.1440D-13	.2545D-14	.5289D-15
.9067D-15	.6172D-14	.4515D-14	.1267D-14	.6443D-13	.1177D-14
.1751D-14	.2740D-15	.2027D-13	.5994D-14	.3053D-14	.1449D-13
.4280D-14	.1124D-14	.4158D-14	.2210D-13	.2100D-13	.5749D-11
.3390D-10	.2997D-14	.7175D-10	.8751D-10	.3065D-13	.1879D-10
.1697D-14	.1431D-11	.1459D-09	.7896D-12	.7771D-09	.4839D-09

**** CONVERGENCE ACHIEVED IN EIGSOL

number of eigenvalues = 30
 relative tolerance = 1.0000E-05

1**** WE SOLVED FOR THE FOLLOWING EIGENVALUES:

1.16054D+03	1.20610D+03	1.67294D+03	1.90581D+03	2.47284D+03	2.58721D+03
2.63053D+03	3.10910D+03	3.76481D+03	1.16236D+04	1.28671D+04	1.37575D+04
1.40427D+04	1.50295D+04	1.57124D+04	1.72268D+04	1.86340D+04	2.16327D+04
2.28528D+04	2.65515D+04	3.05167D+04	3.27730D+04	3.33668D+04	3.71684D+04
4.42035D+04	4.53108D+04	5.24902D+04	5.53031D+04	6.16825D+04	7.88087D+04

**** UPPER BOUNDS ON EIGENVALUE CLUSTERS

1.16634D+03	1.21213D+03	1.68130D+03	1.91534D+03	2.48520D+03	2.60014D+03
2.64368D+03	3.12464D+03	3.78363D+03	1.16817D+04	1.29314D+04	1.38263D+04
1.41130D+04	1.51046D+04	1.57910D+04	1.73129D+04	1.87272D+04	2.17408D+04
2.29671D+04	2.66843D+04	3.06693D+04	3.29368D+04	3.35337D+04	3.73543D+04

59077-C-044

B19

59037-C-044



EQE INTERNATIONAL

SHEET NO. C1

JOB NO. 59037 JOB WRSS IPTBTE BY PSH DATE 7-18-94
CALC. NO. _____ SUBJECT Turbine Bldg CHK'D MC DATE 7-20-94

ATTACHMENT C

EXCERPTS FROM REFERENCE 6

(4 pp. total)

TITLE MILLION 3

BY PSH DATE 12/1/83

CHKD. BY _____ DATE 1/1



STRUCTURAL
MECHANICS
ASSOCIATES
A Calif. Corp.

54037-C-044

PAGE 46 OF 60 Job No. 20601-0

COMMENTS Load Distributor

pg 46 of 60

E = Modulus of elasticity

ν = Poisson's ratio

G = Shear modulus

t_i = Wall thickness

l_i = Wall length

h = Story height

x_i = x-coordinate of wall centroid

z_i = z-coordinate

K_{V_i} = Wall shear stiffness

$$= \frac{A_i G}{h}$$

A_i = Wall cross-sectional area

$$= t_i l_i$$

K_{B_i} = Wall bending stiffness

$$= \frac{12 E I_i}{h^3} \quad \text{fixed fixed}$$

I_i = Wall moment of inertia

$$= \frac{1}{12} t_i l_i^3$$

K_i = Wall stiffness

$$= \frac{K_{V_i} K_{B_i}}{K_{V_i} + K_{B_i}}$$

$$K_{V_i} + K_{B_i}$$

K_x = Story ^{lateral} stiffness in x-direction

$$= \sum_i K_{ix}$$

K_z = Story ^{lateral} stiffness in z-direction

$$= \sum_i K_{iz}$$

K_{ix}, K_{iz} = Wall stiffnesses in x, z directions



$$\begin{aligned}
 x_{cr} &= \text{x-coordinate of center of rigidity} \\
 &= \frac{\sum_i K_{iz} x_i}{K_z}
 \end{aligned}$$

$$\begin{aligned}
 z_{cr} &= \text{z-coordinate of center of rigidity} \\
 &= \frac{\sum_i K_{ix} z_i}{K_x}
 \end{aligned}$$

$$\begin{aligned}
 K_p &= \text{Story torsional stiffness} \\
 &= \sum_i \left[K_{ix} (z_i - z_{cr})^2 + K_{iz} (x_i - x_{cr})^2 \right]
 \end{aligned}$$

For ground motion excitation direction j

V_x^j, V_z^j = Overall story shears in x, z directions

T^j = Overall story torsional moment

$M_{xx,t}^j, M_{zz,t}^j$ = Overall OT moments at top of story about x, z axes.

$M_{xx,b}^j, M_{zz,b}^j$ = Overall OT moments at bottom of story about x, z axes

$$\begin{aligned}
 V_{ix,d}^j &= \text{Wall shear in x-direction due to direct shear} \\
 &= V_x^j \frac{K_{ix}}{K_x}
 \end{aligned}$$

$$\begin{aligned}
 V_{ix,t}^j &= \text{Wall shear in x-direction due to torsional moment} \\
 &= \left| T^j \frac{K_{ix} (z_i - z_{cr})}{K_p} \right| \quad (\text{absolute value})
 \end{aligned}$$

$$\begin{aligned}
 V_{ix}^j &= \text{Total wall shear in x-direction} \\
 &= V_{ix,d}^j + V_{ix,t}^j
 \end{aligned}$$

Wall shears in z -direction are calculated similarly

TITLE Millstone 3

BY PSH DATE 12/1/83

CHKD. BY _____ DATE 1/1



57057-2-0-114 LD-40
STRUCTURAL PAGE _____ OF _____ Job No. 20001.01
MECHANICS COMMENTS Load Distribution
ASSOCIATES
A Calif. Corp. pg 48 of 60

$$\begin{aligned}\Delta M_{xx}^j &= \text{Incremental OT moment about } x\text{-axis} \\ &= M_{xx,b}^j - M_{xx,t}^j\end{aligned}$$

$$\begin{aligned}\Delta M_{zz}^j &= \text{Incremental OT moment about } z\text{-axis} \\ &= M_{zz,b}^j - M_{zz,t}^j\end{aligned}$$

$$\begin{aligned}\Delta M_{ixx,d}^j &= \text{Wall incremental OT moment about } x\text{-axis due} \\ &\quad \text{to (direct) incremental OT moment} \\ &= \Delta M_{xx}^j \frac{K_{ix}}{K_z}\end{aligned}$$

$$\begin{aligned}\Delta M_{ixx,t}^j &= \text{Wall incremental OT moment about } x\text{-axis due} \\ &\quad \text{to torsional moment} \\ &= V_{iz,t}^j h\end{aligned}$$

$$\begin{aligned}\Delta M_{ixx}^j &= \text{Total wall incremental OT moment about } x\text{-axis} \\ &= \Delta M_{ixx,d}^j + \Delta M_{ixx,t}^j\end{aligned}$$