

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

SYSTEM REVIEW
of the
PALO VERDE NUCLEAR GENERATING STATION
EQUIPMENT QUALIFICATION

Before the
EQUIPMENT QUALIFICATION REVIEW BOARD

**RETURN TO REACTOR DOCKET
FILES**

VOLUME I OF III
Pages 1 - 213


Phoenix, Arizona
September 25 & 26, 1980

8012170530

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

VOLUME I
September 25, 1980
I N D E X

Participants	i
Introduction	14
Background	17
Design Criteria	
Overview	67
Environmental Qualification Criteria	
Standard Review Plan 3.11 and General Design Criteria 1, 2, 4, 23	87
IEEE Standards	106
Reg. Guides	143
NUREG 0588, Commission Order CLI 80-21, IE Bulletin 79-01B, 10CFR50 Appendix B	150
PVNGS Environmental Classifications	174
Recapitulation of Open Items	206



1 VOLUME I

2 September 25, 1980

3 BOARD MEMBERS

4 EDWIN E. VAN BRUNT, Jr.
5 APS Vice President
6 Nuclear Projects Management
7 ANPP Project Director

8 JOHN M. ALLEN
9 Nuclear Engineering Manager
10 Arizona Public Service Company

11 A. CARTER ROGERS
12 Nuclear Engineering Manager
13 Arizona Public Service Company

14 JOHN T. BARROW
15 Supervising Electrical Engineer
16 Arizona Public Service Company

17 WILLIAM F. QUINN
18 Supervising Licensing Engineer
19 Arizona Public Service Company

20 EDWARD C. STERLING III
21 Supervising Instrumentation and
22 Controls Engineer
23 Arizona Public Service Company

24 NORMAN L. HOEFERT
25 PVNGS Operations Engineering Supervisor
Arizona Public Service Company

ROGER W. CLARK
Supervisor of Electrical Design
Generation Engineering Department
Arizona Public Service Company


JOHN A. ROEDEL
Manager, Quality Assurance
Arizona Public Service Company

KARL KREUTZIGER
Chief Electrical Engineer
Bechtel Power Corporation

- 1 DR. SHELDON FREID
Nuclear Staff Group Leader
Bechtel Power Corporation
- 2
- 3 PETER C. NEWCOMB
Supervisor of Equipment Qualification
Instrumentation and Control
Engineering Department
Combustion Engineering, Inc.
- 4
- 5
- 6 PAUL WOLFE
PVNGS Assistant Project Manager
Combustion Engineering, Inc.
- 7
- 8 DR. GEORGE SLITER
Coordinator of EPRI/Utility
Equipment Qualification Owners Group
Electric Power Research Institute
- 9
- 10
- 11 VINCENT S. NOONAN
Assistant Director for Materials
and Qualification Engineering
Division of Engineering
Nuclear Regulatory Commission
- 12
- 13
- 14 DR. ZOLTAN R. ROSZTOCZY
Chief, Environmental Qualification Branch
Nuclear Regulatory Commission
- 15

PARTICIPANTS

- 16
- 17
- 18 WILLIAM G. BINGHAM
PVNGS Project Engineering Manager
Bechtel Power Corporation
- 19
- 20 DENNIS KEITH
PVNGS Assistant Project Engineer
Bechtel Power Corporation
- 21
- 22 GERALD KOPCHINSKI
PVNGS Nuclear Group Supervisor
Bechtel Power Corporation
- 23
- 24 ROBERT CARSON
Electrical Staff Engineer
Bechtel Power Corporation
- 25



1	BRUCE LINDERMAN Bechtel Civil/Structural Staff
2	Seismic Qualification Working Group Leader
3	Bechtel Power Corporation
4	KENNETH SCHECHTER Deputy Group Supervisor
5	PVNGS Civil/Structural Group Bechtel Power Corporation
6	
7	ROBERT STIENS PVNGS Assistant Project Engineer
8	Bechtel Power Corporation
9	TERRY F. QUAN Licensing Engineer
10	Arizona Public Service Company
11	J. PATRICK SHREWSBERRY Licensing Engineer
12	Arizona Public Service Company
13	EDWARD J. GOUVIER Electrical Engineer
14	Arizona Public Service Company
15	MARTIN L. RAINES Electrical Engineer
16	Arizona Public Service Company
17	MARK L. HYPSE Electrical Engineer
18	Arizona Public Service Company
19	LEONARD A. YORK PVNGS Operations-Technical Engineer
20	Arizona Public Service Company
21	SARJAPUR M. JAYADEV PVNGS Operations Electrical Engineer
22	Arizona Public Service Company
23	JANE A. BRAND Manager of Community Relations
24	Arizona Public Service Company
25	DR. HAROLD R. DENTON Director, Office of Nuclear Reactor Regulation Nuclear Regulatory Commission

1 RICHARD A. VOLLMER
2 Director, Division of Engineering
Nuclear Regulatory Commission

3 JANIS D. KERRIGAN
4 PVNGS Project Manager
5 Licensing Branch #3
Division of Licensing
Nuclear Regulatory Commission

6 JOHN BERGGREN
7 CESSAR Project Manager
8 Standardization and Special
Projects Branch
9 Division of Licensing
Nuclear Regulatory Commission

10 HERMAN E. LaGOW
11 Systems Consultant
Nuclear Regulatory Commission

12 ARTHUR C. GEHR
13 Attorney at Law
Snell & Wilmer

14 CHARLES A. BISCHOFF
15 Attorney at Law
Snell & Wilmer

16 OBSERVERS

17 KENNETH COOK
18 Washington Public Power
19 Supply System


20 W. C. MOODY
Southern California Edison Company

21 THOMAS C. GROZAN
22 Florida Power and Light Company


23 J. K. MARTIN
Public Service Company of Oklahoma

24 S. A. BERNSEN
Bechtel Power Corporation

25 WILLIAM H. WILSON
Bechtel Power Corporation




1	NORA MEADOR Arizona Public Service Company
2	
3	LAURIE MOORE Arizona Public Service Company
4	
5	DON LAWSON Arizona Public Service Company
6	
7	ROD CHAPIN Arizona Public Service Company
8	
9	REX KRAMER Arizona Public Service Company
10	
11	LEON ICARD Arizona Public Service Company
12	
13	MARTHA MCKINLEY Arizona Public Service Company
14	
15	L. E. VORDERBRUEGGEN Nuclear Regulatory Commission
16	
17	ED REIS Nuclear Regulatory Commission
18	
19	STAN NOURIKI Nuclear Regulatory Commission
20	
21	DENNIS J. CHIN Florida Power and Light Company
22	
23	PAUL GROSSMAN Ebasco Services, Inc.
24	
25	JEFF COHEN
	JILL LEGG
	LEE HOURIHAN



1 The Equipment Qualification Review Board of the Palo
2 Verde Nuclear Generating Station convened in Pizarro Room C,
3 Del Webb's Townhouse Hotel, Phoenix, Arizona, on the 25th
4 day of September, 1980, Mr. Edwin E. Van Brunt, Jr., Vice-
5 President, Nuclear Projects Management, Arizona Public
6 Service Company, Presiding.


7
8 MR. VAN BRUNT: My name is Ed Van Brunt. I am Vice-
9 President, Nuclear Projects Management for Arizona Public
10 Service Company, and I am the officer responsible on a full-
11 time basis for the engineering, design, construction, and
12 quality assurance for the Palo Verde Nuclear Generating
13 Station.

14 The purpose of today's meeting is to perform a
15 system review of the Palo Verde Nuclear Generating Station
16 Equipment Qualification Program. The concept of performing
17 system reviews was developed in a number of meetings which we
18 had with Dr. Denton. With this concept, the design of a
19 specific plant system or the structure of a specific program
20 is thoroughly reviewed for adequacy of design and compliance
21 with regulations by Bechtel project personnel in the technical
22 disciplines that are encompassed by the particular system or
23 program in question. Bechtel Power Corporation, as I am sure
24 most of you are aware, is the architect, engineer, and
25 construction manager for the Palo Verde Plant. The system



1 review is then formally presented by the Bechtel project
2 staff to a review board of technical experts for concurrence.
3 Participation by Nuclear Regulatory Commission personnel in
4 this presentation is encouraged and should aid their under-
5 standing of the system design bases or criteria, detailed
6 design, construction, program philosophy, review procedures,
7 and system operation, thereby minimizing, if not eliminating,
8 the review manhours required for that particular system or
9 program.

10 As a result of the discussions that I have had with
11 Dr. Denton on this subject, APS to date has performed several
12 system reviews. They include the DC and AC Class IE Power
13 Systems and the Auxiliary Feedwater System. The first system
14 review of the DC Power System was performed here in Phoenix.
15 The second review of the AC Power System was done in the
16 Nuclear Regulatory Commission offices in Bethesda, Maryland,
17 to provide an opportunity for greater participation and
18 observation by NRC management and staff. The latest review
19 was of the Auxiliary Feedwater System and was held here in
20 Phoenix late last month. Figure 1 provides the current
21 status of ongoing activities for these past system reviews
22 and also indicates the reviews that we have planned at least
23 through January or February of next year. You can see at the
24 top that the DC Power System review is just about complete
25 and we are in the process of getting ready to submit the final




1 information to the NRC staff. The AC Power System review
2 has been completed, the transcript has been sent to NRC, and
3 we are in the process right now of resolving outstanding
4 items, which will then be ultimately sent to the staff. The
5 Aux Feedwater System, which was done a couple of weeks ago,
6 is at the stage of review of the transcript to correct
7 errors, and as soon as that is completed, we will be sending
8 that to the staff and then proceeding with the rest of the
9 activities. The Equipment Qualification, of course, will be
10 started here today, and we have scheduled in the month of
11 October balance of plant instrumentation and control systems.
12 Then we have in early December fire protection, and then
13 after the first of the year, we are looking at the control
14 room design. Depending on the outcome of further discussions
15 with the staff, we may have some additional reviews to cover
16 other systems or other parts of our application. That is
17 kind of the status.

18 We did a little research. We went back and looked
19 at how long it took us to do the DC Power System review
20 at construction permit time using what I would call the
21 20-questions type of approach. Surprisingly enough, it took
22 us about eight months, and if you look here from start to
23 finish on this, assuming that there won't be any further
24 questions, it has only taken about six months, so there is a
25 saving in time involved in proceeding this way which I thought

1 was of some interest.

2 As I indicated, today we will be performing a review
3 of the Equipment Qualification Program for the safety-related
4 balance of plant equipment, particularly as it relates to
5 compliance with NUREG-0588 for electrical equipment and
6 applicable IEEE Standards. To explain what I mean by balance
7 of plant, I would like to mention that Palo Verde is a
8 standardized plant with a separate Final Safety Analysis
9 Report for the Nuclear Steam Supply System portion of plant.
10 The Combustion Engineering Standard Safety Analysis Report
11 Final is referred to extensively in the Palo Verde Final
12 Safety Analysis Report whenever information concerning the
13 Nuclear Steam Supply System is needed. The balance of plant
14 for this project is the equipment not within the Combustion
15 Engineering scope of supply. The CE scope of supply includes
16 the standard Nuclear Steam Supply plant plus various other
17 options that APS has purchased from Combustion Engineering... The
18 responsibility for the adequacy of the qualification of
19 equipment supplied by Combustion Engineering is clearly the
20 ultimate responsibility of the applicant referencing the
21 Combustion Engineering Safety Analysis Report; in this parti-
22 cular case, Arizona Public Service Company. However, the
23 details of this information is addressed using topical reports
24 CENPD-255 and CENPD-182 for Instrumentation and Control
25 Equipment and by CESSAR for other equipment in Combustion




1 Engineering's scope.

2 We had planned to review this information as a part
3 of the review of CESSAR and have not prepared any specific
4 presentations today for that part of the equipment qualifica-
5 tion. However, in some discussions we had here earlier, we
6 have been requested to at least indicate how we plan to
7 handle the equipment qualification for CESSAR. We will do
8 that today and we will try and provide some other information
9 and respond to any questions anybody has to the best of our
10 ability. We do not really have the appropriate people from
11 Combustion Engineering here today to make a detailed presenta-
12 tion.

13 The Bechtel project staff has prepared the Balance
14 of Plant Equipment Qualification Review, and it will cover
15 the following general areas: Qualification Criteria, review
16 procedures, specific examples, and difficult qualification
17 areas.


18 Bechtel will prepare formal responses to any open
19 issues defined by the Review Board during this review. These
20 responses will be reviewed by the Review Board for concurrence.
21 Final resolution of these items will be provided to the
22 Nuclear Regulatory Commission.

23 For today's review, we have assembled a review board
24 with a varied background due to the complexity of the program
25 being reviewed. Since the responsibility for an adequate



1 review lies with the applicant, that is, Arizona Public
2 Service Company, the board's basic formation starts with
3 selected APS technical personnel complemented with personnel
4 from other groups who have expertise and experience not
5 necessarily available within the Arizona Public Service
6 Company organization. Prior to this meeting, board members
7 were provided with appropriate sections of several documents
8 to familiarize them with the Palo Verde Equipment Qualification
9 Program. These included sections from the Palo Verde Final
10 Safety Analysis Report, various IEEE Standards, related
11 NUREG documents including NUREG-0588, the Palo Verde Nuclear
12 Services Project Procedures Manual, and the Standard Review
13 Plan. At this time, I would like to introduce the members of
14 the board and say a few things about their responsibilities
15 in their various organizations.

16 John Roedel is the APS Nuclear Quality Assurance
17 Manager and reports directly to me. John is responsible for
18 development and compliance with the Corporate Quality
19 Assurance Program for Arizona Public Service Company. John
20 Allen, sitting here to my left, is one of two APS Nuclear
21 Engineering Managers who report directly to me. John is
22 responsible for the areas of electrical engineering, instru-
23 mentation and control, licensing, and health physics and has
24 the primary responsibility for equipment qualification at
25 Arizona Public Service Company. He is also responsible for



1 our records management section, which will be the ultimate
2 resting place for all of these records. Carter Rogers is the
3 other APS Nuclear Engineering Manager who reports directly to
4 me. Carter has responsibilities for mechanical engineering,
5 chemical engineering, civil engineering, nuclear fuel, and
6 other nuclear-related items. Bill Quinn is the Supervising
7 Licensing Engineer. Bill reports to John Allen and has
8 responsibility for all licensing matters and coordinating the
9 day-to-day interface with the Nuclear Regulatory Commission
10 assigned project manager in such matters. John Barrow is a
11 Supervising Electrical Engineer who reports to John Allen.
12 He is responsible for the review of the Palo Verde electrical
13 systems for APS and the day-to-day interface with Bechtel
14 and Combustion Engineering personnel in these areas. He also
15 has the responsibility of coordinating the APS effort for
16 Equipment Qualification. Ed Sterling is a Supervising
17 Instrumentation and Control Engineer who also reports to
18 John Allen. He is responsible for the review of the Palo
19 Verde instrumentation and control systems and the day-to-day
20 interface with Bechtel and Combustion Engineering on these
21 systems. Norm Hoefert is the Operations Engineering
22 Supervisor at the Palo Verde Plant and is responsible to the
23 Engineering and Technical Services Superintendent for mech-
24 anical and electrical engineering support, including
25 monitoring station performance and the in-service inspection

1 program.


2 We have also asked Roger Clark, Supervisor of
3 Electrical Design with the Arizona Public Service Company's
4 Generation Engineering Department, to participate as an
5 independent member from APS on this board. Roger is not
6 directly involved in the Palo Verde Project, although from
7 time to time, he has been utilized as a consultant in various
8 areas. Roger has been with APS for nine years and has been
9 involved in electrical system design for APS' fossil power
10 plants. Prior to APS, he was with Stone and Webster for
11 ten years as an electrical engineer and for four of those
12 years worked on nuclear projects, namely Surry 1 and 2 and
13 North Anna 1.

14 Two review board members are from the Bechtel
15 Engineering staff. These representatives are Karl Kreutziger,
16 Chief Electrical Engineer, and Dr. Sheldon Freid, Nuclear
17 Staff Group Leader. They are not directly involved in the
18 design of the Palo Verde Project; however, they may be used
19 as consultants to the Bechtel Palo Verde Project Group as
20 required.

21 Representing Combustion Engineering on the review
22 board are Paul Wolfe, Palo Verde Assistant Project Manager,
23 and Pete Newcomb, Supervisor of Equipment Qualification,
24 Instrumentation and Controls Engineering. Paul reports
25 directly to the CE Project Manager and is responsible for the


1 CE interface with APS, specifically the Palo Verde Project
2 Nuclear Steam Supply System equipment qualification and
3 the generic equipment qualification for all the System 80
4 projects. He is also responsible for providing licensing
5 support, technical support, and liaison with the CE plant
6 engineering staff. Pete works in the Instrumentation and
7 Controls Engineering group and does not report to the CE
8 Palo Verde Project Manager. However, he is responsible for
9 all CE Nuclear Steam Supply System Instrumentation and
10 Controls equipment qualification. Combustion Engineering,
11 the Palo Verde Nuclear Steam Supplier, is involved in this
12 review only to deal with the BOP-Nuclear Steam Supply System
13 interface requirements and, as I indicated previously, it
14 had been our plan to discuss in a separate meeting the
15 equipment qualification for the CE equipment for Palo Verde
16 and to clearly define at that time the utility's supervision
17 and responsibilities in that program. We will try and deal
18 with some of that here today as we can.

19 To provide added expertise on the board in the
20 relatively new area of equipment qualification, APS has
21 asked Dr. George Sliter, of the Electric Power Research
22 Institute, to participate on this board. George is the
23 coordinator of the EPRI/Utility Equipment Qualification
24 Owner's Group. He is also the EPRI Project Manager for the
25 Equipment Qualification Data Bank.



1 The NRC has sent a number of representatives, as
2 Janis Kerrigan has introduced, to participate in this system review
3 and we welcome their full participation.

4 We will provide a transcript of this review to the
5 Nuclear Regulatory Commission as soon as we have received and
6 proofed it from the court reporter. For the benefit of the
7 court reporter, I would ask that the review board members or
8 anyone else, for that matter, please identify themselves
9 before making any statements, and I would appreciate if you
10 would not make any statements or anything else until you are
11 recognized by the Chair so we can at least have a little order
12 out of chaos. We encourage the NRC representatives present
13 to participate in this review as well. As indicated by Janis,
14 we will not entertain questions from the public during the
15 review. However, members of my staff and members of the
16 Commission will be available following the meeting to answer
17 any questions that members of the general public might have
18 relative to this interchange of information that is going to
19 go on here today. At the completion of the review, any open
20 items which have been identified will be reviewed and, when
21 agreement on their scope has been reached, Bechtel or other
22 responsible organizations assigned for response will be
23 designated to prepare appropriate responses, which will be sent
24 to the members of the board for their review, comments, and
25 ultimate concurrence. Upon complete board concurrence with



1 the responses, these will then be formally sent to the
 2 Nuclear Regulatory Commission for their review. In this
 3 connection, I would ask Terry Quan, from my staff, and Gerry
 4 Kopchinski, of Bechtel's project staff, to keep independent
 5 notes of open items and then we will kind of back through
 6 them and backcheck when the meeting is completed.

7 Bill Bingham, who leads the Bechtel group, will
 8 indicate how they are going to make their presentation, and
 9 I would request in that context, Bill, that, at the appropriate
 10 points in your presentation, the board be given opportunity
 11 to ask questions.

12 Incidentally, as a side issue, I will be leaving
 13 the meeting at about 11:30 to accompany Dr. Denton on a tour
 14 of the Palo Verde construction site, and at that time I
 15 will turn coordination of the meeting over to John Allen and
 16 he will complete the activities for the day.

17 With that, if there are no questions from the board
 18 members or anyone in the audience, Bill, I would like to turn
 19 it over to you and ask you to introduce your representatives
 20 that are here and then we'll go from there.

21 MR. NOONAN: Before we start into discussion with the
 22 balance of plant, could you give me some indication as to
 23 the percentages of the scope of review for the CE scope of
 24 review versus the balance of plant scope of review.

25 MR. VAN BRUNT: I am not sure I understand what you

1 mean by percentages.

2 MR. NOONAN: Well, amount of equipment. In other
3 words, is 50% of the equipment under the CE scope of review
4 and 50% under balance of plant, or is it 60-40? Can you just
5 give me rough numbers?

6 MR. VAN BRUNT: I would guess it is about a 50-50
7 proposition. It is kind of hard to measure. If you are
8 looking at physical size, certainly the largest pieces
9 equipment coming from Combustion Engineering are the steam...
10 generators and reactor vessel. If you are looking at numbers of
11 pieces of equipment, electrical equipment, I think 50-50 might
12 be that order. It certainly wouldn't be any more than that
13 in my view.

14 MR. NOONAN: Would most of the equipment inside the
15 containment be related to Combustion Engineering or would
16 they be split pretty evenly?


17 MR. VAN BRUNT: The majority of it would be, yes, sir.
18 Not all, but the majority.

19 MR. NOONAN: The majority would be Combustion?

20 MR. VAN BRUNT: That's correct.

21 MR. NOONAN: You indicated right now that we made a
22 request earlier that we have some Combustion people here to
23 talk about their scope of review. Can I get your views on
24 that right now?

25 MR. VAN BRUNT: Well, we have talked to the CE



1 representatives here and we'll see what we can do. We will
2 try and deal as much as we can with that. We will certainly
3 tell you what our participation with CE will be and we will
4 try and do as much as we can with the CE program in the
5 limited time. As I indicated in my opening remarks, we had
6 really not intended to deal with that particular area today.
7 We understand our responsibilities relative to that equipment
8 and plan to carry them out to the full extent, but we had
9 intended to deal with that particular aspect of the balance
10 of plant in a separate meeting.


11 MR. NOONAN: I guess, speaking for the NRC people
12 here, that we can make ourselves available to accommodate the
13 Combustion people whenever they can get here.

14 MR. VAN BRUNT: We'll see what we can do. We have
15 talked to the CE people here and we'll see what arrangements
16 we can make.

17 MR. NOONAN: Thank you.

18 DR. ROSZTOCZY: Did I understand this correctly that
19 you completed your part of the presentation and you are
20 planning to hand it over now to Bechtel? Is there any other
21 presentation from Arizona Public Service?

22 MR. VAN BRUNT: Not a formal presentation by APS.
23 Mr. Bingham will be making a presentation and many of the
24 things that are incorporated in his presentation are relative
25 to things that Arizona Public Service Company does in this



1 particular program. We will be pursuing the program that
2 has been developed jointly by APS and Bechtel. They are
3 implementing the program, if you like. We are working with
4 them, and I think it will become clear from Mr. Bingham's
5 presentation what our role is in that particular program.
6 My remarks were basically intended to set the stage for the
7 meeting, to have everyone understand who is here, what the
8 players are, and how the meeting will be performed.

9 DR. ROSZTOCZY: I have a few questions which relate
10 to Arizona Public Service's role in the equipment qualifica-
11 tion. Is this the appropriate time to ask those or should I
12 wait for some time later?

13 MR. VAN BRUNT: I would suggest that you wait until
14 Mr. Bingham presents at least the first part of his presenta-
15 tion. I have not seen his presentation, so I am just
16 speculating on what he is going to present. After he makes
17 at least the first part of his presentation, then if you
18 have questions that relate to APS' participation, ask those
19 at that time and I am sure that we can answer those questions
20 for you.


21 DR. ROSZTOCZY: Thank you.

22 MR. VAN BRUNT: Are there any other questions?

23 Okay, Bill, I would like to turn it over to you.

24 MR. BINGHAM: Thank you.


25 My name is Bill Bingham. I am the Project Engineering



1 Manager for Bechtel. As Ed indicated, we are here today to
2 present equipment qualification at the fourth formal meeting
3 of the PVNGS Systems Review Board. I have with me today
4 from the project Dennis Keith and Bob Stiens, who are
5 Assistant Project Engineers, also Gerry Kopchinski, the
6 Engineering Group Supervisor for the nuclear discipline, and
7 Ken Schechter, Deputy Civil/Structural Group Supervisor. I
8 also have with me Bob Carson, Bechtel Electrical staff, who
9 is responsible for environmental qualification for our
10 Los Angeles Power Division, and Bruce Linderman, Bechtel
11 Civil/Structural staff, who is responsible for seismic quali-
12 fication for the Los Angeles Power Division.

13 As Ed indicated, our agenda today will include the
14 background of the PVNGS qualification program and a review of
15 our intended compliance with the various design criteria.
16 The design criteria will consist of an overview, environmental
17 qualification criteria, and seismic qualification criteria.
18 I think it is important to mention for the board that during
19 the presentation today, you may have the impression that all
20 of this work, from the manner in which it is presented, is in
21 order. I want to indicate to the board that, while we are
22 very sure of what we have to do, not all is going well with
23 the various suppliers that we are working with, and we will
24 try the best we can to point this out during the meeting.

25 By the way, if you cannot hear, please put your




1 hand up in the back so we can be sure to speak a little bit
2 louder, and I also might indicate that, Ed, there are some
3 spaces on the side for those people way in the back. If
4 they would like to move their chairs up, this might be an
5 appropriate time to do that.

6 (Thereupon a brief off-the-record discussion ensued,
7 after which proceedings were resumed as follows:)

8 MR. BINGHAM: After the background, that I will go
9 through in just a few minutes, we have set up the presentation
10 to look at an overview of the design criteria, a review of
11 environmental qualification criteria, and then we will have
12 the seismic qualification criteria separately. There are
13 several subheadings, as you have seen, and, based upon the
14 length of the presentation, I will entertain questions at the
15 end of the various subheadings.

16 We will talk about the equipment qualification
17 process. I think this is important for the board to under-
18 stand and it will give you an overview of how APS has set
19 up their review team and, how Bechtel supports them. We will
20 also talk a little bit about the reviews of the group, and,
21 finally, will get into the qualification plans, the checklists,
22 the auditing procedures, and how APS and Bechtel assure that
23 what is done in the work is correct and meets the established
24 criteria. Finally, we will go through documentation, and
25 then we have some examples that we would like to present for



1 the board's information. We do understand that some back-
 2 ground material is necessary and we will spend a little time
 3 on that. Then, finally, for the board's information, we will
 4 present some of the major problem areas that we are having
 5 today with the various equipment suppliers.

6 Ed, I would also like to request that, as we have
 7 at the past meetings, all questions be directed to me and I
 8 will assure that the appropriate person answers the question.

9 MR. VAN BRUNT: Okay, fine.

10 MR. BINGHAM: With that, I would like to get on to
 11 the presentation.

12 MR. VAN BRUNT: Excuse me, Bill.


13 Dr. Rosztoczy, I think that the time for your
 14 question is when we are talking about how the whole program
 15 works. Then you can pursue the issue of how Arizona Public
 16 Service Company is involved. I think it will become more
 17 obvious then and you may get your questions answered or it
 18 would be a better time to ask those particular questions.

19 Does anybody on the board have any other questions
 20 at this point?

21 If not, Bill, go ahead and proceed with your
 22 presentation.

23 MR. BINGHAM: Thanks, Ed.


24 Figure 2 shows the PVNGS design development. That
 25 is a slide that we have put up before for the board. However,



1 as Ed mentioned, the membership of the board has changed.
2 There are other utilities and observers here and I will spend
3 a few minutes going through the design development on Palo
4 Verde.

5 As you see on Figure 2, the hub of the work is
6 called the Design Criteria. This is the basic document that
7 is used, reviewed, and sets the criteria for the project.
8 It consist of three volumes, which I have shown here, that
9 list all the criteria for all of the systems as well as
10 the environmental work, qualifications, seismic criteria in
11 the book. It is a very dynamic document. It is kept up-to-
12 date and is revised as appropriate during the life of the
13 plant.


14 From this document, we then go to the development
15 of our design. From the design, we develop our procurement
16 specifications, system descriptions, schedules, construction
17 specifications, test specifications, and station manual.
18 At the same time, we set up the plant arrangement and from
19 that feed back to the development of our design. As I have
20 indicated before, this is one of the projects that has a very
21 large-scale design model. Our model is three-quarters inch
22 to the foot, and on that we show in detail all of the piping,
23 equipment, electrical conduit, and trays in order to assure
24 that the design does not have inconsistencies in it and we
25 can review it for system applications or in many cases for our



1 separation reviews and assurance that the design does meet
2 the established criteria. From that, we develop our detailed
3 construction drawings and our planning photographs.

4 As input to the design criteria come our standard
5 criteria, our basic P&ID's, and information from the NSSS
6 vendor, in this case Combustion Engineering.

7 Figure 3 indicates how the design criteria for
8 equipment qualification are implemented. I think it is
9 important for the board to understand that equipment qualifica-
10 tion is not a system, but it is a necessary part of the
11 overall program to have qualified equipment for use in safety
12 systems, so we are organized a little bit in this area. There
13 are other areas in this control room design and in our overall
14 environmental concerns where we handle specific issues a
15 little bit different than the review process, which many of
16 the members on the board have heard before. I would like to
17 indicate that when we talk about environmental qualification
18 for a piece of equipment, we are talking about a substantial
19 amount of paper. This (indicating) happens to be for one
20 piece of equipment and represents the documentation just for
21 environmental qualification. As the board knows, there are
22 other qualifications that certification documentation is
23 required that make up a substantial package to assure that the
24 equipment does meet the established criteria. APS has set
25 up an environmental qualification team. This team is headed



1 by John Barrow, who Ed mentioned earlier, and Bechtel supports
2 this team for all of the work that is involved with the
3 environmental qualifications. The design criteria is input
4 to the specifications. These go to the supplier. The supplier
5 then prepares the qualification plans and the reports. There
6 is a qualifications summary that goes into the FSAR and it
7 also indicates that records will be available for all the
8 equipment. It has become necessary to establish this
9 independent APS/Bechtel sponsored qualifications program for
10 what we call our recalcitrant vendors and suppliers to assure
11 that we do have compliance with our criteria. You will be
12 hearing more in detail later on about the problem areas that
13 we are having and specifically how they relate to meeting
14 the intended criteria that we have established.

15 Figure 4 indicates the scope of the PVNGS qualifica-
16 tion program.


17 DR. DENTON: Ed --

18 MR. VAN BRUNT: Yes, Harold.

19 DR. DENTON: Could I go back to the previous slide a
20 moment?


21 MR. BINGHAM: Certainly.

22 DR. DENTON: Could you tell me a bit about the basis
23 of the review team and the resources that you have actually
24 put there? Is it a one-man office or a 100-man office or
25 something in between?



1 MR. BINGHAM: Overall size, there are about, I would
2 guess, four or five people from APS that are involved. In
3 the Bechtel organization, we have four or five people that
4 focus particularly on equipment qualification. They are
5 supported by individuals in the various disciplines on the
6 project. The way we are set up, Dr. Denton, is that on our
7 team of some 300 engineers and designers, we have responsible
8 engineers that look after various purchase orders or various
9 pieces of equipment with the vendors and their responsibility
10 is essentially to follow that piece of equipment from the
11 specification through the evaluation to receiving the vendor
12 information and its application into the total system. We
13 have in the neighborhood of 50 responsible engineers on this
14 project and the team then would be the five or so APS indivi-
15 duals monitoring, reviewing our work, and on the Bechtel side,
16 there would be five people coordinating the efforts, assuring
17 that the information comes at a proper time and that the
18 reviews are conducted properly, and then some 50 people below
19 that that look at the individual equipment. We also have
20 people that assist and review not only balance of plant
21 suppliers, but, as Ed probably mentioned, we do assist him
22 in the review of the NSSS suppliers as well.

23 MR. NOONAN: I would like to ask a question back on
24 Figure 2 a little bit, if you could go back to that one. It
25 showed the utility as giving you specific requirements and



1 there is a design criteria then evidently established, and that
2 design criteria is established by Bechtel, is that correct?


3 MR. BINGHAM: Well, the design criteria is drafted by
4 Bechtel based upon inputs from the utility. The utility then
5 reviews and approves the design criteria for application for
6 this particular project.

7 MR. NOONAN: The utility then does actually approve
8 the design criteria?

9 MR. BINGHAM: This is the document that they approve,
10 that's correct.

11 MR. NOONAN: How is the interface then carried on with
12 your NSSS vendor as far as this design criteria being
13 compatible with their part of it where your interfaces come
14 together? How is that handled?

15 MR. BINGHAM: I will touch on that a little bit later,
16 Vince, but let me just give an overview. The way that we
17 operate with Combustion Engineering is through a formal
18 system of sending the information, for example, the design
19 criteria, to them for review to assure from their viewpoint
20 that the criteria really reflect the interface requirements
21 that they have. There are subsequent things that go on.
22 That information is documented. It is fed into the licensing
23 documents. The licensing documents then are again reviewed
24 in what we call our four-party review where all of the
25 participants are together. The review is documented and signed



1 off by all the parties involved, APS, Bechtel, Combustion
2 Engineering, and perhaps some other consultant that may be
3 there at the time for a particular section. Then during the
4 course of the work, all of the criteria that are given to
5 Bechtel either through what Combustion calls their IR
6 documents, which indicate criteria that we must meet, or
7 through letters and correspondence, we then incorporate that
8 information into drawings and specs and into our design criteria.
9 We have a procedure that we use to send back this document
10 to Combustion. Combustion reviews it, and then they respond
11 in writing either it is satisfactory or you didn't interpret
12 it properly, please correct this. This is the flow of how we handle
13 the interfaces to assure ourselves that Combustion Engineering
14 in this case has made a review of our interpretation of their
15 requirements to assure that we have interpreted and applied
16 it properly.


17 MR. NOONAN: Then does APS act in a role as an overall
18 coordinator between the NSSS and the balance of plant to make
19 sure that these requirements are all meshed together properly?

20 MR. BINGHAM: Ed.

21 MR. VAN BRUNT: The way we are set up, Arizona Public
22 Service Company has contracted with Combustion Engineering
23 to provide the Nuclear Steam Supply System, and that contract
24 is directly with Arizona Public Service Company, as are our
25 contracts for all of our equipment. We have also contracted

1 with Bechtel to be our engineer/constructor. As I
2 indicated in my opening remarks, Bechtel has been delegated
3 the responsibility to administer, at least as far as the
4 technical aspects are concerned, the Combustion contract.
5 Basically, the information that Bill has been talking about
6 goes back and forth between Combustion and Bechtel. However,
7 copies of all of that information are sent to us and, in
8 parallel with the review that Bechtel is doing of those
9 documents, we are reviewing them as well. This is a matter
10 of expediency, so it doesn't go from one person to another
11 and back, it is a parallel review, and we concur in parallel
12 with the activities that are going on with Combustion or
13 Bechtel. If we have a problem, we raise the issue. So we
14 in house, through our own procedures setup; within my
15 organization review the same documents and look at the things
16 that Bechtel's people are doing and things that Combustion
17 are doing.

18 Might I say for convenience of getting the meeting
19 done more expeditiously Bill is going to leave points after
20 various segments of his presentation for questions and I
21 think the presentation would go along a little faster if we
22 would hold our questions until that point in time unless
23 you've got some clarification or something that you need from
24 something he has said. Then we will let all the questions
25 be asked at one time. Otherwise, it kind of gets disjointed,




1 and I think with some of the flow of the presentation, we
2 get lost. So if I could ask that everybody would hold their
3 questions until the end of each segment of the presentation,
4 I would appreciate it. Each segment is normally broken down
5 into pieces that are not so large that you lose your train of
6 thought.

7 MR. BINGHAM: Thank you, Ed. I believe we are on
8 Figure 4, which indicates the scope of the Palo Verde
9 qualification program. As we have discussed, it is broken up
10 between the Combustion Engineering equipment and the Bechtel
11 equipment. Under Combustion, there is instrumentation and
12 control equipment and non-NSSS instrumentation and control
13 equipment, so we have essentially split the two, and, of
14 course, we have the same under the Bechtel scope.

15 Looking further at the figure, for the information
16 of the board, I have tried to indicate where this information
17 is covered. Of course, for the Bechtel information, this is
18 in the PVNGS FSAR. The instrumentation and control equipment
19 is covered by Combustion Engineering under their two topicals,
20 CENPD 255 and CENPD 182. The balance of the equipment
21 supplied by Combustion Engineering is covered in CESSAR-F in
22 Sections 3.10 and 3.11.


23 Further, we have depicted some examples for the
24 board's information. Under Combustion Engineering, you will
25 find the plant protective system, in-containment sensors and



1 transmitters, and supplementary protection system. Under
2 the non-instrumentation control, you will see the LPSI pump,
3 the high pressure safety injection pump, and valves. These
4 are examples. It is not an inclusive list.

5 For Bechtel, you will see the balance of plant
6 ESFAS, the battery charger, and BOP instrumentation; under
7 non-electrical equipment, diesel generator, auxiliary feed-
8 water system, and essential spray pond pumps.


9 Figure 5 shows the relationship of the PVNGS
10 project milestones to the various qualification requirements.
11 We put this together to give the board an idea of the time
12 frame, because, as you know, this project started back in
13 1973 and I think the keys that we want to focus in on are the
14 construction permit in May of 1976, the applicable qualifica-
15 tion standards committed to at that time, the IEEE 323-1974,
16 IEEE 344-1975, and Reg Guide 1.89. You can see from Figure
17 5 long lead items occurred from 1975 through early '77. This
18 includes the safety injection pumps, pressurizer valves,
19 solenoid valves, charging pumps, equipment of that nature.
20 The major BOP purchase orders started about the beginning of
21 1976 and are essentially complete at the end of 1978 except
22 for some small items. The FSAR then was docketed in 1980.
23 The bulletins and guides that we will be talking about,
24 NUREG 0588, IE Bulletin 79-01B, IEEE Standard 627, and
25 Commission Order CLI 80-21, have fallen substantially after.



1 we have completed the procurement of the equipment. I
2 indicated earlier to the board that we are attempting to
3 assure that our criteria, which you will hear about in a
4 little while, is reflected in our purchase orders that were
5 placed some two to three, in some cases four, years ago.

6 Figure 6 shows our qualification program development,
7 and we have separated for understanding by the board the
8 qualification of IE components, that is, electrical components,
9 and qualification of other safety-related components. We
10 have split the presentation into two parts for ease of
11 understanding. We will look at the environmental conditions,
12 that is, temperature, pressure, radiation, chemical, and then
13 we will look at the seismic issues separately today. The
14 major qualifications for the IE equipment fall under NUREG
15 0588, and you will hear more about that a little later,
16 IEEE 323-1974 and IEEE 344-1975. For our non-IE components,
17 our other safety-related components, we will be looking at
18 IEEE 627-1980 and IEEE 344-1975.


19 Table 1 is a brief summary of the equipment
20 qualification methods from our design criteria. Basically,
21 what it depicts for various safety-related categories are the
22 qualification methods and it gives some examples of the type
23 of equipment that fall within those categories. We are looking
24 at four categories, A, B, C, and D, on Table 1, in-containment
25 equipment, outside containment - possible harsh environment,



1 outside containment - non-harsh environment, outside contain-
2 ment - no age-sensitive components, but physical integrity
3 required.

4 We have listed five methods of qualification.
5 Method 1 is type testing, Method 2 documented analysis,
6 Method 3 documented operating experience, Method 4 ongoing
7 qualification program; then we have a last method, which is
8 allowable by the codes, which is a combination of the other
9 methods. As you can see under qualification methods, we have
10 all the methods and we have noted that type testing is our
11 preferred method. Items that fall in this category for
12 balance of plant are wire and cable and valves. In Category
13 B, outside containment - possible harsh environment, again
14 we treat this in the same manner. In this particular case,
15 we are looking at motor control centers and valves and valve
16 operators. For outside containment - non-harsh environment,
17 which is Category C, again we do prefer to have type testing.
18 Some of the examples are the diesel generator and the control
19 panels for the balance of plant. Our final category, Category
20 D, we are looking at Methods 2, 3, and 4, or a combination.
21 Examples there are things like Q cooling coils and the control
22 room ceiling.

23 Figure 7 is a simplified indication of the qualifica-
24 tion process. It shows the interfaces between APS/Bechtel
25 qualification team and the equipment suppliers. I did discuss



1 a little bit earlier on the question from Vince Noonan some
2 of these principles, but I would like to spend just a moment
3 and go through this slide for the board. Figure 7 is
4 essentially split in two, the APS/Bechtel side over here
5 (indicating), Equipment Suppliers on this side (indicating),
6 and I am focusing now on the balance of plant equipment
7 suppliers. We started with the design criteria. Of course,
8 that goes into the specifications. The specifications
9 indicate inspection, hold, and witness points for the equip-
10 ment. That goes to the supplier, who performs the design,
11 manufactures the equipment, develops qualification plans and
12 procedures as we are depicting focusing on the equipment
13 qualification issue. This information flows to the qualifica-
14 tion team for review, again is reviewed in APS, goes to
15 Bechtel for review, down to the 50 responsible engineers that
16 we discussed earlier. Input is given to the equipment
17 supplier, comments are made, and we follow up to assure that
18 the qualification plans and procedures of the equipment
19 supplier reflect our criteria. From that point, the supplier
20 then goes through the qualification program. It may be testing,
21 analysis, or combinations. We have an audit of testing
22 programs. I would indicate to the board at this point that
23 we have not yet conducted an audit of the testing program.
24 Our first one will be coming up with some of our electrical
25 equipment toward the end of this year. From this then is a

1 supplier qualification report, the reports I showed you
2 earlier, which is the document like this (indicating). That
3 goes to the qualification team for review, input back and
4 forth to assure that everything is acceptable and complete.
5 Data then is summarized and, at the appropriate time, submitted
6 in summary form in the FSAR. The qualification report and
7 other qualification documentation is sent to Palo Verde for
8 retention.

9 Figure 8 is the PVNGS schedule for equipment
10 qualification. From the slide, you note that we have the
11 balance of plant equipment on the bottom part of the slide
12 and the CE equipment on the top. I will just spend a minute,
13 since there is interest in the schedule. CENPD 182, which is
14 the seismic qualification for the equipment, as I explained
15 before, was submitted in May, 1977. CENPD 255 environmental
16 qualification was submitted in July of 1980. Let me make a
17 note. This shows in May, but we will correct this for the
18 record, Ed. It should be July. They are presently in the
19 process of review. There will be documentation prepared and
20 information submitted on the same schedule as the balance of
21 plant information.

22 Looking at the balance of plant, we have about
23 44 different suppliers for this equipment. We have been
24 holding qualification review meetings with all of them,
25 meetings to assure that the programs are going to meet the

1 established criteria, and have been reviewing and validating
 2 in some cases our review of the qualification plans and
 3 information that has been submitted to us for review. This,
 4 of course, has all been in preparation for submittal of the
 5 final information for our operating license.

6 I do show here, the milestone, Equipment Qualification
 7 Review Board. That is us today. We intend to have two
 8 submittals, the first submittal in November of 1981, which
 9 will encompass about 70% of the information. Summaries will
 10 be submitted to the licensing documents and the records will
 11 be available with APS. The final submittal is scheduled for
 12 April of '82. Again, information for the licensing documents,
 13 and the records then will become available. Finally, at that
 14 time, presently scheduled is the SER Supplement, and the
 15 Unit 1 fuel load date on that schedule shows November, 1982.

16 Figure 9 is a summary of the BDB equipment
 17 qualification status. Of the 59 purchase orders requiring
 18 qualification, you can see how they are split amongst the
 19 various disciplines. Our purchase orders with qualifications
 20 completed prior to NUREG 0588 come out with 15. We have
 21 re-reviewed these and find that we have one that is now
 22 complete in accordance with that document. We are going to be
 23 discussing the details later on in the presentation of this
 24 particular area and the comparison, so I won't spend more
 25 time than that on that at this time, Ed.

1 With that, I would like to ask if there are
2 questions from the board.

3 MR. VAN BRUNT: I have a couple myself, but I will let
4 the board go first. Anyone want to raise any particular
5 point? Carter.


6 MR. ROGERS: Bill, I would like to go back to Figure
7 2, if I could. I would like to continue along the line of
8 Vince Noonan's questioning and try to further understand
9 Figure 2. Figure 2 shows at the top of the figure Utility
10 Applicant Specific Requirements inputting into the design
11 criteria and you mentioned, Bill, that the design criteria
12 is a rather dynamic document. It does vary from time to time;
13 it is kept up to date. Can you tell me how APS ensures that
14 its criteria requirements are met throughout the plant design
15 looking at all of the other peripheral parts of the design
16 criteria? What procedures does the utility or does APS use
17 to ensure that its requirements which are found in the
18 design criteria are met?

19 MR. BINGHAM: I think, Ed, that that is really a
20 question the utility should answer.

21 MR. VAN BRUNT: I think, if I can rephrase his
22 question for him, he would like to understand the interfaces
23 and where the utility interacts with Bechtel.


24 MR. ROGERS: That's right.

25 MR. VAN BRUNT: I agree with you that that is probably




1 a question that either Carter or I should answer.

2 MR. BINGHAM: We do have several meetings with APS
3 over the course of the design. Generally, we meet and have
4 met since the beginning of the project about once a month.
5 At those meetings, we review the status of the project from
6 the design, and I think it is that review that is documented,
7 that is followed up, that APS uses for part of the assurance
8 that goes on. I will discuss the process. I guess that is
9 what Carter is asking for. I did discuss it a little bit
10 when we were dealing with Vince Noonan's question, but, in
11 addition to that, of course, there is information that comes
12 out of those meetings. As far as interfaces, Bechtel will
13 make statements about what they are doing, and that has
14 follow-on audits by APS and our own house. Maybe one example
15 I could mention came from our review last month on the
16 auxiliary feedwater system where there was a concern about
17 whether Bechtel had indeed been diligent in assuring that
18 Combustion Engineering's interface requirements were
19 incorporated in the design and was it documented. APS held
20 an audit just recently to assure themselves that things were
21 in order. So there are checks and balances that go on. The
22 process basically is one of assuring that we work together
23 with the utility. We have documented procedures that we use
24 on the project to assure that we have made sure that interfaces
25 are put into the design properly, and from my experience at



1 least on this project, we have had a tremendous amount of
2 encouragement from APS to focus on this particular issue,
3 because later on it becomes very difficult to backfit criteria
4 in the particular plant. So the process is something like
5 this: A piece of information will come in, it is reviewed by
6 Bechtel at the proper levels, the information also goes to
7 APS, we incorporate it in the design, we get together and
8 review the design, particular problem areas, set between us
9 the course of action that we wish, make any modifications as
10 appropriate to the design criteria, then we incorporate it
11 in the drawings. The drawings then come back to APS for
12 review. APS as well as the other suppliers, in the case we
13 were talking earlier Combustion Engineering, will send back
14 their comments. We incorporate the comments, and many times
15 we have to have special meetings to resolve particular issues.
16 Once those are incorporated, the final review is done and
17 the drawings are released for construction. That is generally
18 the overall program.

19 MR. ROGERS: Let me make it a little easier. On
20 Figure 2, we see that the utility applicant specific require-
21 ments go to design criteria. An arrow comes out of there
22 over to development of standard design and then down on the
23 right-hand side of Figure 2 to procurement specifications,
24 system descriptions, engineering schedule, construction
25 specifications, and so on. I don't see an arrow going back




1 to the utility. Is there indeed such an arrow going back?
2 Does the utility receive copies of procurement specifications?
3 What happens there so that the utility might review those,
4 for instance?

5 MR. BINGHAM: Yes, they do, Carter. All the key
6 documents are reviewed and approved by the utility and all
7 the documents go to the utility for comments. It doesn't
8 show on this particular slide, because I was trying to
9 portray the overall process and not all of the detailed flow
10 of information on the project.

11 MR. ROGERS: Now let me see if I can word this second
12 one so you can answer it. How does Bechtel interface with
13 APS with regard to the CE interface specifically?

14 MR. BINGHAM: As Ed mentioned earlier, Carter,
15 Bechtel has been asked to administer technically, at least,
16 the contract with Combustion Engineering, so we support the
17 review of the contract as well as all of the interface
18 information. We have people that are assigned to devote their
19 time fully to looking at the Combustion Engineering interfaces
20 and information that comes to us to assure that it is provided
21 in the proper time frame for the project. We have design
22 review meetings with Combustion at which APS is a participant
23 periodically. During the formative stages of this project,
24 we were meeting every two months or so back at Combustion
25 in Windsor. We now have meetings on the order of every three



1 to four months, because most of the design information is
2 available. We have focused our attention then on meeting
3 with Combustion in the field looking at the interfaces and
4 the requirements that come up in the field as they pertain
5 to the engineer and the requirements the engineer has. Those
6 are held about every six weeks.


7 MR. VAN BRUNT: Carter, excuse me, let's go to Shelly.

8 MR. FREID: On Figure 7, I have two questions. As you
9 go through the information flow, you get down to the point
10 where qualification is done by testing or analysis, and my
11 question is who makes that decision on how a particular piece
12 of equipment is in fact qualified, whether it is done by
13 testing or analysis, because on Table 1, there are several
14 options given. One is preferable, but who does in fact make
15 the decision? Does the vendor or the equipment qualification
16 team people?

17 MR. BINGHAM: Well, the vendor would make the decision
18 based on the particular piece of equipment. The review team
19 may not agree with that decision, and from there you would
20 develop into a final acceptable way of testing your particular
21 equipment. For example, if it was just impractical to run a
22 test, you would accept some other acceptable method.

23 MR. FREID: So it is basically the vendor who has
24 the initial cut?

25 MR. BINGHAM: The first shot at it, yes.



1 MR. FREID: The second part of that question, if you
2 take the arrow going to the left, you order the testing,
3 which is relatively simple, it is a go or no-go decision, I
4 presume, do you also audit the analysis if it was done by
5 analysis rather than testing or if it is done by a combination
6 of methods.

7 MR. BINGHAM: I suppose you could call it a form of
8 auditing. Actually, we review the calculations. For example,
9 in seismic areas, Bruce Linderman will do a detailed review
10 of the work that comes in to us.

11 MR. FREID: So then auditing is done on both testing
12 and analysis?


13 MR. BINGHAM: In that context, yes.

14 MR. VAN BRUNT: I would like to follow up on Shelly's
15 question, Bill. You indicate that the vendor makes the
16 choice. Specifically, what do the specifications say to the
17 vendor? Does it give him three or four options, tell him
18 that he has to comply with IEEE 323 or whatever it is, and
19 then he takes his best shot at what he thinks he can do?
20 Is that the way it works, or do you indicate in the specs
21 that you prefer type testing?

22 MR. BINGHAM: Ed, as I indicated before, the specifica-
23 tions were written long, long ago.

24 MR. VAN BRUNT: I understand.

25 MR. BINGHAM: What we are doing today is somewhat




1 different than what we did before. We did rely on IEEE 323-74,
2 which has a statement in it that type testing is preferred,
3 so the specifications in the early days didn't give the
4 kind of guidance that we might give in a set of specifications
5 today if we were to go out to a particular vendor.

6 MR. VAN BRUNT: Harold, you would like to ask a
7 question?

8 DR. DENTON: I have a follow-up question to the one
9 the panel just raised. When you mentioned you audit the
10 supplier, could you describe the nature and depth of that
11 audit? I am interested in how complete do you audit. Do you
12 look at their results of tests on every piece of equipment
13 or every tenth piece, or how do you decide the scope of your
14 audit of that?


15 MR. BINGHAM: Let me focus on the auditing for equip-
16 ment qualification, because we do audit for compliance to the
17 specifications in other areas. The point that we are trying
18 to focus on is when a testing lab says, "Here's your report,"
19 signs it off, gives it to you; the equipment is qualified.
20 How do you really know that that is the case? Did they run
21 the test at the proper cycles? Did they have the proper
22 measurement of temperature or pressure or whatever parameter
23 we are looking at? Did they record the information properly
24 and analyze it properly? Now, there really aren't too many
25 testing labs, I think as we all know, and some of them are



1 getting very busy right now, so I think it is even more
2 important for us to audit to the extent that we feel necessary.
3 First, is the testing group applying the principles that they
4 should properly, are they using the right equipment, has it
5 been calibrated so that the results that we get are proper,
6 and has the information been interpreted properly? We will
7 probably not do every one, but, as I indicated in the presen-
8 tation, we are focusing now on that particular issue, and if
9 it so comes out when we review a particular supplier that
10 things are not like we had hoped, then we will review more
11 until we are satisfied that the reports that we get do reflect
12 what we are told.


13 DR. DENTON: I guess I would phrase that one a bit finer,
14 if I might. Does this mean that you audit each supplier at
15 least once on each piece of equipment as opposed to auditing
16 the same piece of equipment several times? I guess I am
17 interested are there laboratories testing equipment for you
18 that you don't audit at all? I am trying to get you to define
19 in more detail the nature and scope of the audits that you do
20 so I can get a feel for what competence should be placed in
21 the word "audit."

22 MR. BINGHAM: I indicated that for equipment qualifica-
23 tion, we have yet to conduct one of our audits and that our
24 first audit would be toward the end of this year. We will
25 probably be looking in great detail at everything that goes



1 on. I might indicate for the board's benefit that that
2 testing will be on a piece of electrical equipment and it
3 will be conducted at Wyle's . Norco . Laboratory. We will
4 be looking in great detail at all the various aspects,
5 because we really haven't to date taken a look at, for
6 example, what has been done at Huntsville, except I might
7 mention that the engineers do witness from time to time
8 particular seismic tests to make sure that things are
9 reflected. That is about all we have done to date. We are
10 going to focus more diligently on the programs, and one of
11 the things that worries us is that when testing labs become
12 overloaded, as they might, that there might be a tendency to
13 not focus attention on the particular issues necessary, so
14 we probably will have a little more diligence on that equipment.

15 You asked a question about would we look at each
16 piece of equipment or would we look at selected equipment.
17 As the board knows, we have three identical units and some
18 of the equipment has already been shipped in order to maintain
19 our construction schedule and we have deemed it appropriate
20 to qualify equipment for Unit 2 or Unit 3 and to have that
21 qualification complete prior to the operating license or
22 prior to submitting the information for review by NRC. I
23 would guess when it comes to valves and valve operators, for
24 example, the Limitorque operators that we have, that that
25 would cover a broad spectrum. There has been a substantial




1 amount of work in the industry to assure that that
2 particular qualification is satisfactory, and I would expect
3 that we wouldn't spend as much time on that as perhaps we
4 would on qualification of some of the diesel generators where
5 there really haven't been extensive testing programs or
6 extensive work on some of the components such as the governors
7 and control systems, and it would be my expectation that we
8 would focus our attention on those particular areas during
9 the next several months.

10 MR. VAN BRUNT: Bill, if I can interrupt.


11 Harold, just to follow up on Bill's comments, as
12 the applicant is the person that is ultimately responsible
13 for the adequacy of all this equipment, we are going to be
14 looking very carefully at the testing laboratories to assure
15 ourselves that they are in fact doing the things we want them
16 to do, and, through our own quality assurance activities,
17 we will be auditing these facilities either with our own
18 forces or through the Bechtel QA organization, which we
19 utilize to do audits, and we will be setting up these programs
20 to audit the same as we do any other vendors to assure
21 ourselves that their programs are adequate. So independent
22 of how much auditing Bechtel may think is appropriate,
23 we will be doing that which we believe is necessary to
24 assure that the equipment is appropriate.

25 John.



1 MR. ROEDEL: Bill, you spoke of equipment qualification.
2 I would like to focus on commodity qualification to get a
3 little clarification and more explanation of what the word
4 "audit" means. For instance, what has been the involvement
5 in Bechtel, Bechtel Engineering, or Bechtel supplier quality
6 representatives in the qualification of Rockbestos cable?
7 Were they not present, were they not witnessing some of the
8 tests in the qualification of that material?

9 MR. BINGHAM: The answer to your question is yes, we
10 did, John. The area that I was trying to focus on was equip-
11 ment qualification and indicate to the members here that we
12 are just getting into the swing of our audits on that particu-
13 lar type of equipment, that particular area, and I am sure we
14 will use all the elements that we use in our other audits of
15 equipment. I also tried to indicate to Dr. Denton that we
16 believe there is even more emphasis in this particular area
17 that must be put on certain aspects of our review. I did not
18 indicate earlier that the engineers responsible for the
19 inspection plans, and our inspection plans are being updated
20 to include these elements. We set the criteria from an
21 engineering viewpoint and then we have individuals in our
22 auditing department, procurement department, that go out and
23 actually look and assure that our requirements are met. Then
24 we as an engineer might be there, also, as a follow-on, if you
25 will, the second layer.



1 MR. ROEDEL: That is why I brought up the difference
2 between the equipment qualification versus material qualifica-
3 tion, which we are now engaged in, and have been for some
4 time, so that we could qualify the material for installation in
5 containment. I just asked that question because I wanted to
6 make that clear.


7 MR. VAN BRUNT: Ed Sterling.

8 MR. STERLING: I want to follow up on Dr. Denton's
9 question. In your plan for audit, would you say that the
10 plan would be to take a look at procedures that a lab might
11 use? For example, if they make certain assumptions when
12 running an analysis, then that particular assumption or
13 analysis would be applicable to more than one piece of
14 equipment if they used it over and over again, are you satis-
15 fied through an audit that it was a satisfactory way to
16 proceed? The same thing with the type of test procedures
17 that they might use.

18 MR. BINGHAM: That's correct.

19 MR. VAN BRUNT: Are there other questions in this
20 particular area? Norm.

21 MR. HOEFERT: On Figure 7, I have a question. The
22 end of Figure 7 is qualification documentation, which then
23 goes to the PVNGS site records. There is going to be a large
24 quantity of qualification documentation, many reports, and
25 so forth. How are all the various tasks which have to be



1 performed throughout the life of the plant to maintain
2 qualification being identified and tabulated so that all
3 these tasks can be performed or will be performed in the
4 future.

5 MR. BINGHAM: Are you talking about once the equipment
6 becomes under the jurisdiction of APS operations? Is that
7 what you are focusing on?


8 MR. ALLEN: No. I think I can expand on his question
9 a little bit, Bill. Norm is talking about a requirement which
10 comes out of a qualification program that operations has to
11 check a breaker every 1,000 cycles. How is that information
12 going to be compiled and sent to operations so they can put
13 it in their maintenance procedures. Right, Norm?

14 MR. HOEFERT: That's right, that type of thing, and I
15 am particularly concerned is this going to be picked up in
16 the FSAR or tech spec or separate document. Just how will
17 this all get together?

18 MR. BINGHAM: Yes, it will probably be in several
19 different places. All the information will be compiled and
20 be given to APS engineering by us and that will be implemented
21 into the various procedures or tech specs, if that is the case,
22 or test specifications or maintenance documents.

23 MR. HOEFERT: Has it really been decided yet where
24 this information is going to go?

25 MR. BINGHAM: Again, I believe that I would have to



1 ask Ed for information from APS, but it is my understanding
2 that the principles are established, but perhaps the details
3 aren't yet totally worked out.

4 MR. ALLEN: That's correct. As far as specific
5 maintenance procedures, that will be taken out of the tech
6 manuals both by Bechtel and APS nuclear engineering and
7 identified to operations. As far as tech spec requirements,
8 we haven't gotten into the tech spec requirements on this
9 yet. We don't know exactly which portion of it will be tech
10 spec requirements and which won't.

11 MR. VAN BRUNT: Other questions? Dr. Rosztoczy.

12 DR. ROSZTOCZY: I have a few questions which
13 relate to some of the presentation and some of the answers
14 to questions, and then I would like to come back to some of
15 the basics. For details of the record, let me ask them one
16 by one and I would like to get them answered.

17 MR. VAN BRUNT: Sure, go right ahead.

18 DR. ROSZTOCZY: First, from one of your answers to
19 one of the questions, I understood that the environmental
20 specifications are being prepared by the contractors, Bechtel
21 or Combustion Engineering, then they are submitted to APS for
22 approval and APS approves them, so if we are going to audit,
23 let's say, a year or two years from now your files, then we
24 would find in each file environmental specifications that the
25 contractor prepared on a piece of paper that shows that APS

1 reviewed these and approved them, is this correct?

2 MR. BINGHAM: That is correct.

3 DR. ROSZTOCZY: The second question relates as a
4 follow-up on an earlier question. The question was asked
5 who makes the decision on what type of qualification is going
6 to be performed, whether it is going to be testing or
7 something else instead. Did I understand it correctly that
8 the vendor or supplier of the equipment makes a recommendation
9 of how he is planning to test this equipment and then this
10 recommendation is reviewed by the equipment qualification
11 team and it is approved by the equipment qualification team,
12 so again the files would have a piece of paper indicating that
13 the team reviewed this and made the decision that it is appro-
14 priate to go with analysis, for example, instead of testing?

15 MR. BINGHAM: There will be approval of the test plan,
16 that's correct.

17 DR. ROSZTOCZY: There is an approval for the test plan
18 for each piece of each type of equipment?


19 MR. BINGHAM: For each piece. Excuse me, the qualifica-
20 tion plan. The qualification plan may be test, analysis,
21 combination, whatever is appropriate for the particular
22 piece of equipment.

23 DR. ROSZTOCZY: Yes, and there will be an approval
24 for the selected approach, which might be a combination of
25 these.

1 MR. BINGHAM: Yes.

2 DR. ROSZTOCZY: The third one is maybe a follow-up on
3 Dr. Denton's question. You indicated that you are going to
4 audit this. I didn't get the clear answer whether you are
5 going to audit every type of equipment qualification or,
6 instead, you are going to audit only selected ones. For
7 example, if the vendor is going to go for qualification for
8 25 different types of equipment that are going into this
9 plant, then is it your intent to audit each of those or are
10 you going to pick only some selected ones? If you are going
11 with the selected equipment approach, then do you have a plan
12 how you make your selection? Have you already made those?
13 Do you know which one you are going to follow?

14 MR. BINGHAM: It has been pointed out to me there may
15 be a bit of confusion. We do review every report in detail
16 to make sure that it meets the established criteria, every
17 plan, every report that comes in from all of the vendors.
18 We probably will be selective in the audit. That is, we
19 will pick the equipment that we would expect a testing lab
20 to have difficulty with or we have heard from the industry or
21 NRC in some cases that there has been difficulty in qualifying.
22 When I responded to Dr. Denton, I was trying to portray that
23 we are in the early stages of really what should be considered
24 for a large nuclear project that is in our time frame, and if
25 that turns out to be that one needs to audit all of the




1 equipment, then we will audit all of the equipment. We
2 suspect from our review and our discussions with APS that
3 probably will not be necessary, and I cited one example that
4 I believe was a Limitorque motor operator, where we felt
5 that perhaps everything might be in order on that particular
6 one. I am sure that, as Ed indicated, APS will assure
7 themselves by asking appropriate questions of us that we have
8 done our job and that if we don't audit all of them, there
9 will be well documented reasons for not doing that.

10 DR. ROSZTOCZY: So the answer to my question is that
11 you don't have at this time a plan which will tell you
12 exactly which ones you are going to audit, you are developing
13 this as you go along, and you will assure that appropriate
14 amounts will be audited.

15 MR. BINGHAM: That's correct.


16 DR. ROSZTOCZY: Let me go now to another set of
17 questions, which are kind of basic and I think they kind of
18 relate to the beginning of your presentation. Could we have
19 Figure 2 up for a second? Figure 2 is a very general
20 portrayal for design criteria and it is not specific to
21 equipment qualification. It shows one line which indicates
22 that certain information is flowing into the design criteria
23 from the utility. Now let's go to Figure 3. When we go to
24 Figure 3, then the equivalent of this is not shown. I don't
25 see a clear block which would tell me that certain information



1 had been given to the environmental qualification team. My
2 questions relate to certain information which I think this
3 team should have, whether it has already been given to them
4 and in what form has it been given to them. The first
5 question is: Before you can start to go ahead with a program
6 qualifying the equipment, you have to know what equipment
7 needs to be qualified, so has APS prepared a list of safety-
8 related systems which need to be environmentally qualified
9 and has that list been supplied to all the appropriate people
10 like Bechtel, Combustion, and the team mentioned there?

11 MR. BINGHAM: Ed, maybe I should make a comment here.
12 First, the answer to your question is yes. The rest of the
13 presentation is structured to present the details of the
14 working of the organization, particularly Section IV, and I
15 wonder if maybe you might want Dr. Rosztoczy to indicate
16 his questions at this time and then as we go through the
17 presentation, those that remain unanswered we can deal with
18 when we go into Section IV.

19 MR. VAN BRUNT: Dr. Rosztoczy, this isn't the first
20 one of these that we have done and we have learned a little
21 bit as to the most expeditious way of getting from here to the
22 end. What I would suggest is that as you ask your questions
23 such as this one that if Bill knows that somewhere along
24 later in his presentation he is going to deal specifically
25 with that subject, he will identify that to you, and when he



1 comes to it, he will try and note it or certainly you will
2 note that you either got your answer satisfactorily or that
3 you did not rather than try and take it out of context. It
4 is the same reason I tried to hold the questions until the
5 end of a particular area. If that is agreeable to you, I
6 would like to proceed that way. We have found that that is
7 probably the most expeditious way of getting from one point to
8 another and it makes a little more orderly presentation.

9 DR. ROSZTOCZY: Yes, I think that would be fine.

10 So you say that yes, such a list has been prepared.
11 The next question is are we going to get a copy of that list
12 today?

13 MR. BINGHAM: I had not planned to give you a copy of
14 that list today, but I am sure that Ed and his people can
15 make it available.

16 MR. VAN BRUNT: We will send you a copy of the list.

17 DR. ROSZTOCZY: It is my observation from some of the
18 reviews that we are conducting for other plants that the
19 lists the different utilities are using are not uniform.
20 Certain systems are included on one utility's list and other
21 utilities are not including them. I think it will be for the
22 benefit of you as well as everybody else, including us, if
23 there would be an early agreement on that list that that list
24 is complete and nothing has been left off from it.

25 MR. BINGHAM: I think I can respond to that part of the


1 question. All of the equipment that we are talking about is
2 equipment that is flagged in the FSAR as safety-related and
3 the list of equipment is noted in Appendix 3E of the FSAR,
4 so that equipment has been listed and it ties back to our
5 basic qualification table. There is a meshing of the two
6 to make sure that we have covered it all.

7 DR. ROSZTOCZY: These lists have undergone certain
8 developments of Three Mile Island, and so on, so I would
9 like to have a clear understanding today of what it is
10 exactly that you are working with so we can take a look at
11 that list, and if we have any comments, we would feed it
12 back to you in a relatively short turn around so we could
13 have an early agreement on that list.

14 MR. VAN BRUNT: Bill, let me ask Terry and Gerry both
15 to put on the list -- I am aware of the list you are speaking
16 of and we will submit that list to you, but prior to
17 submitting it to you, we will review and be sure that it
18 complies with the present-day requirements or any new require-
19 ments that have come up since we submitted it the first time.

20 DR. ROSZTOCZY: I think what I am asking for is not
21 that this list be necessarily submitted to NRC, but to present
22 it to this board so the members of this board can see it and
23 kind of pass a judgment, including NRC representatives.

24 MR. VAN BRUNT: Let me deal with that part of the
25 question. Dr. Rosztoczy, the mechanics of what happens is ,



1 that this will be an open item for the board and that will be
2 a question that will be dealt with, and as a part of the
3 responses to that will be this particular list and that will
4 become a part of the overall documentation of this particular
5 meeting. So, in essence, in kind of a round about way, the
6 same thing that you have been asking will be accomplished.

7 DR. ROSZTOCZY: Thank you. That will be fine.


8 The second question is again along these lines and
9 the question is has APS prepared a list of environmental
10 parameters, various things like temperature, pressure, that
11 has to be considered in the qualification of the various
12 equipment? In some cases, of course, some are not applicable,
13 but they have to be considered, and are we going to receive
14 a copy of that list today?

15 MR. BINGHAM: The answer is yes. That is Item B.9. of
16 your agenda.

17 DR. ROSZTOCZY: Under Item B.9., we will see a copy?

18 MR. BINGHAM: We will see a copy of that.


19 DR. ROSZTOCZY: The third question is has APS identified
20 environmental zones for the plant? Have you divided the
21 plant into environmental zones and then established the
22 numerical values or time functions of these environmental
23 parameters for each of those time zones? Have you provided
24 this information to the contractors who are writing the
25 specifications for the various equipment?



1 MR. BINGHAM: Again let me respond. The answer is yes,
2 we have established them. You will hear them today under
3 Section B.9. One point that I tried to make earlier was that
4 we are in the process in some cases of backfitting the
5 requirements to have a complete understanding with some of
6 the very early suppliers where we might have had general or
7 envelope criteria. You are going to hear all about that
8 today when we get into the environmental qualification
9 criteria.

10 MR. VAN BRUNT: Dr. Rosztoczy, I would like to
11 interrupt for just a second just to clarify something. You
12 are directing your questions to APS, and that is perfectly
13 fine and I or my staff could answer these questions just as
14 well as Mr. Bingham could. However, we work so closely
15 together in our organizations the way that we have structured
16 these proceedings, at least as far as the interface workings
17 between our two organizations, Bill is prepared to answer
18 those questions. If you wish to ask APS a question about
19 how we process something within our organization, we will
20 directly answer that. In these areas where things are going
21 between us and Bechtel, Bill we have just designated as a
22 matter of convenience, since he is up here, to answer those
23 kinds of questions. I didn't want you to feel that we could
24 not answer these questions if we so desired.

25 DR. ROSZTOCZY: My main concern is whether these things



1 have been established and have been provided to all parties
2 involved, for example, Combustion Engineering or a third
3 party or fourth party involved, and have they received this
4 information.

5 MR. VAN BRUNT: All things that go through the
6 interface Bill is perfectly capable of answering, as we are,
7 but as a convenience, he will be answering. If you want to
8 get into the specifics that occur within the Arizona Public
9 Service Company organization itself, then one of my staff or
10 myself will be very happy to answer those questions.

11 MR. BINGHAM: In your handout, as you get back to
12 them, you will see the qualifications and the zones and
13 everything, so the material is your handout. We will get
14 into that.

15 DR. ROSZTOCZY: Let me then see those in the presenta-
16 tion. If I have anything more, I will ask it at that time.

17 MR. VAN BRUNT: Do you have any more questions?

18 DR. ROSZTOCZY: No. Thank you.

19 MR. NOONAN: I would like to go back to your earlier
20 statement of the purchase orders and I would like to ask
21 Bechtel as to given a particular piece of equipment that
22 will interface with your NSSS vendor, how are his requirements
23 integrated into your purchase order and what procedure is
24 followed.

25 MR. BINGHAM: If it is an interface, the criteria are

1 put in the purchase order. A draft is sent to Combustion
2 Engineering for review. They comment and send us back a
3 formal letter indicating their comments and acceptance or
4 request that we make some modifications and finally will
5 accept that we have interpreted the information and included
6 them properly. So there is a formal system that we have in
7 our house that not only covers the original requirements, but
8 any revisions that may happen thereto during the course of
9 the design.

10 MR. NOONAN: In this interchange of information, is
11 APS then kept informed of what is being done between Bechtel
12 and the NSSS vendor?

13 MR. BINGHAM: Yes, they are part of the process.

14 MR. NOONAN: They are part of the process. Okay. If
15 I could go to Figure 6, this is a question on the service
16 conditions. I notice you list temperature, pressure, radiation,
17 and chemical. I don't see aging. Is that to be discussed?

18 MR. BINGHAM: Yes, it will. This was just to present
19 an overview for the board's information of generally how the
20 program works. When we get into the detailed discussions, we
21 will be covering in particular the aging requirements.

22 MR. NOONAN: All right. I have a few more questions.
23 On Table 1, I look at the various safety-related equipment
24 categories, A, B, C, D, and particularly the one I am most
25 concerned about is the in-containment - possible harsh

1 environment. You indicated that you would allow Method 3
2 to be used to qualify equipment. Can you tell me where you
3 have documented operating experience for equipment exposed
4 to harsh environments.


5 MR. BINGHAM: We haven't done that yet, but we are
6 prepared to discuss that in detail later on, so if you could
7 hold that question until that time, I think we will cover it
8 properly.

9 MR. NOONAN: If I can go to Figure 7, I have two
10 questions. The first question is in this qualification team
11 review, I suspect that that team is to look at -- maybe it is
12 in the next block where you do the audit of testing, I am not
13 sure where, but, anyway, given that you have some anomalies
14 that occur during a test, how are those anomalies resolved
15 and, if they impact the NSSS supplier, how are they resolved
16 with him?

17 MR. BINGHAM: First of all, we will cover the process
18 in detail under Section IV later on. We resolve them in the
19 same manner as we resolve all of our problems with APS, very
20 carefully. Your question about Combustion Engineering, in
21 other areas, of course, we have extensive meetings and reviews
22 to resolve the particular issues.

23 I think, Ed, that you may want to respond on the
24 plans for Combustion Engineering in this particular case.

25 MR. ALLEN: Regarding how we handle Combustion




1 Engineering?

2 MR. BINGHAM: If there is an anomaly in what Combustion
3 is doing for testing as far as it relates to equipment
4 qualification, as I understand.

5 MR. ALLEN: So far as Combustion Engineering, we work
6 with Combustion Engineering very closely, as we do with
7 Bechtel. For example, we have seen some of their qualifica-
8 tion programs, we have commented on them, we have received
9 Bechtel's comments on some of their qualification programs
10 and some of our concerns, and then we transmit these to
11 Combustion Engineering and we periodically have meetings with
12 Combustion Engineering trying to resolve our differences, very
13 similar to how we handle them with Bechtel.

14 MR. NOONAN: So APS takes that function to make sure
15 that any anomalies that occur on either side in the testing
16 of equipment, that those anomalies are not detrimental to
17 safe shutdown of the plant?

18 MR. VAN BRUNT: Right. Mr. Noonan, there is no
19 question that we are ultimately responsible and we are going
20 to take what action is necessary, be it with Bechtel or be
21 it with Combustion or be it with any sub-vendor, to assure
22 ourselves that any anomalies are resolved to our satisfaction.
23 As far as Combustion is concerned, we work very closely with
24 Bechtel in reviewing those matters and then, of course, with
25 the Bechtel sub-suppliers, we are working very closely with




1 Bechtel to resolve those matters.

2 MR. NOONAN: I guess one of the things I am thinking
3 about is particularly on some of your seismic testing where
4 you might be testing a piece of equipment and you get some
5 spurious signals out of that equipment. Those signals might
6 be very minor and be very short-time based and a judgment
7 made on Bechtel's part that these would not cause any detri-
8 mental effects as far as that equipment is concerned, but
9 these types of signals could be fed into an NSSS piece of
10 equipment that could cause detrimental effects, and that is
11 what I am looking for, given you get these types of anomalies,
12 to make sure that this is integrated into the NSSS side to
13 assure that you are not going to have some malfunction occur
14 with some other piece of safety-related equipment.

15 MR. VAN BRUNT: Bill, let John make a comment.

16 MR. ALLEN: I would like to respond to that a little
17 bit about differences of opinion between us and Bechtel and
18 Combustion. Many times we have had and we have requested
19 that an outside consultant be brought in, an independent
20 consultant, to help us resolve problems. So if we have
21 gotten to where we couldn't come to an agreement, we request
22 an outside consultant come in for a third opinion.

23 MR. VAN BRUNT: This is exactly what we have done
24 recently. You heard before Mr. Roedel mention a specific
25 problem we have had with Rockbestos. We bought some



1 10 CFR 50-55(e) type material and what we did was bring in
2 an outside consultant, an expert in that area, to review the
3 whole matter and make recommendations to us as to what we
4 should do about these particular problems. So in our function
5 as the applicant and having the ultimate responsibility for
6 this plant, we will be assuring ourselves, be it through
7 Combustion or our own forces or through the Bechtel staff,
8 that anomalies such as you speak of or any other matters that
9 may be a problem with equipment qualification or any other
10 darn thing in the plant will in fact be resolved satisfactorily.

11 MR. ALLEN: In addition, I might say that in this
12 case with the Rockbestos, within APS, not necessarily inside
13 the nuclear engineering organization, we have Roger Clark's
14 people in generation engineering we want to help us out
15 on this problem. In addition to that, we have a cable expert
16 that we went to. So we have quite a large resource in that
17 area to help us resolve our problems.

18 MR. VAN BRUNT: I don't think there is any particular
19 cookbook method that I can outline to you as to how we could
20 take care of an anomaly. Each anomaly will have to be dealt
21 with as a particular problem and handled as appropriate for
22 that particular situation.


23 MR. NOONAN: I just wanted to be sure that it is
24 handled properly.

25 MR. VAN BRUNT: I assure you that it is.

1 MR. NOONAN: I have one last question, or I want to
2 comment. On Figure 7, I find it very difficult where you
3 leave the decision to test or do analysis up to your suppliers
4 or your vendors. In some cases, I guess the supplier maybe
5 has the capability of making that type of determination, but
6 there are probably some small type suppliers that really would
7 not have engineering capabilities of making these determina-
8 tions whether this equipment should be tested or should be
9 analyzed, and I don't understand that process at all. It
10 seems to me that Bechtel should have that responsibility of
11 determining whether the equipment should be tested or analyzed.

12 MR. BINGHAM: We share your concern, Mr. Noonan. I
13 think that probably the best thing to do is to listen to the
14 rest of the presentation, and at that time, let's have a
15 discussion on this particular issue so that we can portray
16 exactly how we are handling this and how the team is assuring
17 that the proper decision is made, because it is something
18 that we don't treat lightly.

19 MR. NOONAN: Then later on in your presentation, you
20 are going to talk about pieces of equipment. One thing I
21 would like you to address is how you handle the testing of
22 relays, since relays have been a problem not only in this
23 industry, but many other industries, and they are a constant
24 source of trouble, particularly under vibratory dynamic loads.
25 I would like to see later on a discussion on that.



1 MR. BINGHAM: We will do that. We will be pleased to
2 do that.

3 MR. VAN BRUNT: Do you have any other questions,
4 Mr. Noonan?


5 Any other board members have any questions at
6 this time?

7 DR. ROSZTOCZY: Mr. Chairman, going back to my previous
8 statement, I do have one question.

9 MR. VAN BRUNT: We'll let you get away with it.

10 DR. ROSZTOCZY: In the presentation, you have indicated
11 that for certain types of equipment, you have a preferred
12 mode of qualification. The preferred mode for many of them
13 was testing. Do you have a list of those cases where you have
14 decided not to follow the preferred mode of qualification and
15 are those cases and their reasons going to be discussed here
16 today?

17 MR. BINGHAM: Yes. In general, most of our in-containment
18 and perhaps all of our in-containment has type testing in
19 some form, and even equipment in Category B, which is outside-
20 possible harsh environment. Our biggest problem is that the
21 vendors are coming to us and saying that, for various
22 reasons, it can't be done, or it is not practical, or something
23 else of that nature. You will be hearing later when we get
24 into the problem areas the process that we have amongst us
25 wrestling with this particular problem. To date, we have




1 not backed down. If you could at the time that we get
2 through the presentation ask the questions what about this
3 equipment, what about that supplier, we would be more than
4 pleased to bring the board up to date on where we stand and
5 tell you how we are talking and what we hope the outcome will
6 be.

7 DR. ROSZTOCZY: What I am asking for, are you keeping
8 a list of those items where you are not following the
9 preferred one?

10 MR. BINGHAM: Yes.

11 DR. ROSZTOCZY: In other words, this is exceptional
12 items. This is supposed to be the short list rather than the
13 one where you follow it, and are you going to discuss the
14 reasons why did you decide not to perform testing for those
15 cases.

16 MR. BINGHAM: We don't believe that we are in the
17 position yet where we have had to accept other than what we
18 wanted, and that is the area that we will discuss with our
19 problem vendors. I think it is Section VIII of our agenda.
20 I guess what I am saying is the bottom line to you,
21 Dr. Rosztoczy, is that we don't give up easy, and we will
22 give the board a perspective of where we stand. I'm sorry, I
23 am corrected. It is in Section VII, Qualification Problem
24 Areas. We do not and we don't intend to give in on a type
25 testing unless it is demonstrated to be impractical.



1 DR. ROSZTOCZY: Then the answer is that up to date,
2 you have not given in on any of them?

3 MR. BINGHAM: To my knowledge, we have not. When we
4 get into the details, if there is one in there, we will
5 make sure that we flag it this afternoon.

6 DR. ROSZTOCZY: So it is a nice short list.

7 MR. VAN BRUNT: How many more questions have we got?
8 Karl, you've got one. Bill, you've got one. Carter's got
9 one. Why don't we take about a 15-minute break at this
10 point. We will get back here at about 25 after.

11 (Thereupon a brief recess was taken, after which
12 proceedings were resumed as follows:)

13 MR. VAN BRUNT: Bill, let me say a word before you
14 proceed.

15 As I indicated earlier in my opening remarks, I
16 have to leave and go out to Palo Verde, so I am going to turn
17 the Chair over to Mr. Allen. He will be handling the meeting
18 from now until the completion. So, John, if you would pick
19 up.

20 MR. ALLEN: Bill, I think some other people have some
21 questions. Bill Quinn.

22 MR. QUINN: On Figure 3, you indicated a box which
23 shows independent qualification programs that you are doing
24 for your recalcitrant suppliers. I am sure you are going to
25 touch on that later.

1 MR. BINGHAM: That's correct.

2 MR. QUINN: Can you just tell me, have all those
3 recalcitrant suppliers been identified to date?

4 MR. BINGHAM: Not completely.

5 MR. QUINN: Have the ones identified to date been
6 factored into your schedule on Figure 8?

7 MR. BINGHAM: We are including that in our schedule.

8 I think, John, before we go on with more questions,
9 there were a couple of clarifications I wanted to make. One
10 of these figures, Figure 7, says "Qualification Test Review."
11 That should be "Qualification Team Review." We will correct
12 that.


13 MR. ALLEN: Then that will become part of the record.

14 MR. BINGHAM: Yes. The second is that it has come
15 to my attention that there may be some misunderstanding on
16 exactly what we are doing with regard to type testing, and we
17 will make sure that we clarify that during the presentation
18 so you know exactly what is done with the various pieces of
19 equipment.

20 Are there any other questions from the board?

21 MR. ALLEN: Go ahead, Karl.

22 MR. KREUTZIGER: I have three questions which we might
23 cover later, so I will just state the questions. The first
24 question on Table 1 is the definition of harsh or possible
25 harsh environment. I would like to have a little explanation



1 either now or later, because I see a piece of electrical
2 equipment, a motor control center, listed in the examples
3 and I was wondering whether or not a possible harsh environ-
4 ment was limited to such events as high energy line breaks
5 or whether the harsh environment included other parameters.

6 MR. BINGHAM: Fine. We will answer that later on.

7 MR. KREUTZIGER: The second question I have refers to
8 Figure 6. In Figure 6, there is a qualification of IE
9 components on the left and qualification of other safety-
10 related components on the right. On a previous slide on
11 Figure 4, the examples of non-electrical equipment, the word
12 there is "non-electrical equipment." Where do such items as
13 valves fall with respect to qualifications of items like
14 limit switches or other items that might be considered
15 electrical in nature and, therefore, require to be qualified
16 to 323? Specifically, to clarify my question, as I see that
17 on the right-hand column on Figure 6, the only document that
18 you have for environmental qualification is IEEE 627-1980.
19 Was there or has there been any qualification of equipment,
20 since you indicated that most all of the equipment has been
21 purchased as to environmental qualification criteria for
22 non-class IE equipment.

23 MR. BINGHAM: We will be responding to that.

24 MR. KREUTZIGER: The last question I have is the role
25 of the qualification review team. My understanding is that

1 the number of people is comprised of five APS people
2 approximately and five Bechtel people doing coordination.
3 What is the definition and role of the individuals and how
4 does this team function with respect to their review?

5 MR. BINGHAM: We will cover that under Section IV.

6 MR. ALLEN: Are there any more questions? George.

7 MR. SLITER: With regard to Figure 5, your Qualifica-
8 tion Requirements Time Line, is it your intention to revise
9 the FSAR to eventually reflect the degree of compliance to
10 NUREG 0588?

11 MR. BINGHAM: I think I would have to refer that one
12 to APS.

13 MR. ALLEN: What was the question again?

14 MR. SLITER: Would you eventually revise your FSAR,
15 that's why I asked the question of Bechtel, to reflect the
16 degree of compliance with 0588?


17 MR. ALLEN: That's correct.

18 Any further questions on this before Bill moves on
19 to the next subject? Ed.

20 MR. STERLING: On Figure 8 at the bottom line, you
21 have these qualification review meetings with the 44 PO
22 vendors. Are you going to cover the scope of what you
23 accomplish with that later on?

24 MR. BINGHAM: Yes.

25 MR. STERLING: I will defer my questions, then.



1 MR. ALLEN: Go ahead, Bill, to the next subject.


2 MR. BINGHAM: With that lengthy introduction and
3 background, I would like to ask Bob Carson to continue the
4 presentation. There is a considerable amount of detail that
5 we will cover in the presentation. Generally what we will do
6 is break for questions at the end of III. A., Overview of
7 Design Criteria, and then when he gets into Section B.,
8 Environmental Qualification Criteria, we will break at the
9 end of each of those subheadings.

10 MR. ALLEN: Bill, if I may say something, lunch is
11 scheduled for 12:30. How is that going to fit into that
12 presentation? We have to eat right at 12:30.

13 MR. BINGHAM: Well, why don't we stop at 5 or 10
14 minutes prior to that time for our presentation. You can ask
15 questions until that time, break for lunch, and then continue.


16 MR. ALLEN: Okay, fine.

17 MR. CARSON: Exhibit IIIA-1 is an overview of the
18 design criteria having to do with environmental qualification.
19 First of all, a few definitions. Safety-related equipment
20 as it applies to the nuclear station is any item of equipment
21 which is necessary to mitigate the consequences of a design
22 basis accident and to allow the station to be brought to a
23 safe shutdown condition. This equipment is identified by
24 system and by item of equipment in the plant and the appropriate
25 qualifications are applied. Qualification is a demonstration




1 that the safety-related equipment items will perform properly
2 at the times when they are called upon to perform and mitigate
3 consequences of the accident and to allow the plant to be
4 brought to a safe shutdown. It is also a demonstration that
5 this performance can be accomplished at the times necessary
6 and under the conditions which prevail at the time of the
7 operation, and that would be normal operation, abnormal
8 conditions, design basis accident conditions, post-design
9 basis accident conditions, and in-service tests. Any time
10 the equipment is called upon to operate, that is demonstrated
11 by some qualification method. In answer to one of
12 Dr. Rosztoczy's questions, service conditions are determined
13 for each piece of equipment at its location in the plant.
14 Environmental zones are set down in this project by building,
15 and the environmental conditions which accrue at those locations
16 are determined by reference to information supplied by
17 engineering; for instance, by calculations made by the
18 project staff having to do with pressure and temperature and
19 radiation releases due to the design basis accidents.

20 Safety-related operational requirements have to do
21 with when the equipment is called upon to operate, what it has
22 to do, and methods for showing that this is proper. Various
23 criteria are involved having to do with the operational
24 requirements. Some are NRC requirements as listed in General
25 Design Criteria 1, 2, 4, and 23 of Appendix A, and Sections




1 III and XI of Appendix B to 10 CFR Part 50. IEEE Standard
2 323-1974 is the basic document having to do with acceptable
3 methods and criteria and procedures to follow for qualifying
4 primarily electrical or Class IE safety-related equipment,
5 but, as will be shown later, the principles and criteria of
6 that particular document are general enough and generic
7 enough that their application applies to all sorts of safety-
8 related equipment. A rather recent document, IEEE 627-1980,
9 which has been in preparation for several years, really
10 involves the principles of qualification for all types of
11 safety-related equipment and will be acting as an umbrella
12 document for qualification with reference to IEEE 323-74 as
13 the specific document for safety-related electrical equipment.
14 The principles and criteria contained in 627 are very, very
15 similar to 323, but their application is across the board for
16 safety-related equipment. Other requirements for qualification
17 appear in the several NRC regulatory guides, which are
18 interpretations and possibly modified requirements having to
19 do with IEEE documents having to do with qualification. The
20 indicated word here, "daughter" documents, is against 323. There
21 are a whole series of IEEE standards which have been and are
22 being developed which apply to specific items of electrical
23 equipment, and we will talk about those a little bit later,
24 but they cover particular items and the methods in the individual
25 IEEE standards all are aimed at providing successful qualification




1 in accordance with the basic 323 document.

2 This is Exhibit IIIA-2. The purpose of establish-
3 ing a qualified life for a safety-related piece of equipment.
4 Qualified life, first of all, is a time period based in
5 years or portions of years during which the equipment can
6 perform its safety-related function. Qualified life is that
7 time period after which it has experienced the rigors of
8 all the environmental parameters and is still able to do its
9 job when called upon when subjected to a design basis
10 accident. It may not be able to continue for a longer
11 period of time under normal operation, but it is demonstrated
12 that it will do its job for that length of time and still
13 be able to perform its function under a design basis
14 accident or any other condition accruing from a design basis
15 accident at that time. To establish an assumed end-of-life
16 condition by artificially or naturally aging the piece of
17 equipment is a part of the qualification process. There are
18 accepted aging mechanisms and methods which are used for
19 equipment to put it in an assumed end-of-life condition.
20 The qualified life that is always looked for hopefully is
21 the life of the plant, which is based on a 40-year life. We
22 would always like to have equipment of a 40-year qualified
23 life. Sometimes that is not possible. We age the equipment
24 artificially or naturally to that qualified life period, then
25 subject it to seismic events and design basis accident events




1 to show that it will still do its job.

2 Information required for each safety-related
3 equipment item. Again in answer to one of Dr. Rosztoczy's
4 questions, identification of the equipment and its safety-
5 related function, all safety-related systems and all items
6 within the system are identified and pieces of equipment are
7 indicated in the FSAR. The safety-related functions are
8 determined for each piece of equipment under the conditions
9 of the design basis events during which it must operate to
10 mitigate various consequences of those events. The operability
11 requirements are determined: When does it have to operate,
12 for how long does it have to operate, under what conditions
13 does it have to operate, and what does it do when it operates?
14 The range of service conditions during normal, abnormal,
15 design basis event, post-design basis accident, and test
16 conditions, all these service conditions are evaluated and
17 determined for that particular piece of equipment in its
18 location. Only a few were indicated on one of the previous
19 slides having to do with temperature, pressure, radiation.
20 The whole gamut of operating requirements has to be deter-
21 mined for that location. If an item, for instance, is subjected
22 to flooding or submergence or if it has a dust problem
23 involved in it during any one of its operating modes, that
24 is determined, it is indicated in the specification for the
25 equipment, and those things are taken account of during the



1 qualification process. The identification of components
2 and/or modules of equipment which must be subjected to aging
3 deterioration. Not everything in every piece of equipment
4 ages at the same rate and not every item of the equipment
5 in fact ages. You could have equipment, for instance, such
6 as metallic items which don't age on a time basis or through
7 temperature or through exposure to some of the conditions in
8 the plant. Metals, of course, rust if exposed to some
9 conditions. Allowances are made for this in the design of
10 the metallic items. Those items which age primarily due to
11 temperature or radiation would be organic materials such as
12 electrical insulation or plastics or other materials which
13 are used as portions of equipment. Those materials are
14 determined and, as a part of qualification, certain require-
15 ments will be attached to them. Certain methods will be used
16 to artificially age them as a portion of the qualification
17 process.

18 Exhibit IIIA-3. Documentation as to the methods
19 used for qualification must be provided and it must be
20 provided in an auditable form. Mr. Bingham indicated that
21 documents similar to this (indicating) and in many cases
22 considerably fatter items of documentation are involved in
23 a qualification program. Those documents include information
24 of what types of qualification methods are used, as agreed
25 upon by the vendor and Bechtel and APS, the procedures on how




1 the qualification is to be accomplished, reports of the
2 qualification process, the data that is taken, the use of the
3 data, and the reduction of the data into usable reports. This
4 information is all in auditable form; that is, it can be
5 looked at at any time by NRC personnel or others who have the
6 need to know, and it is kept by APS at various locations.
7 Documentation by vendors which is used to supplement the
8 qualification effort or which may be proprietary to that
9 vendor which he feels it is not in his best interest to allow
10 in public records is also available at the vendor's location
11 and in many cases at 'APS' location if that can be arranged.
12 The material in terms of the documentation has to be available
13 for the life of the plant. If the vendor chooses to say
14 something is proprietary and it will not be made available as
15 a portion of the program, it must be specifically identified,
16 its location has to be identified, and assurance given that
17 that documentation will be available for audit for the life
18 of the plant, the assumed 40-year period.

19 As mentioned, IEEE 323-1974 is the basic document
20 having to do with qualification of electrical safety-related
21 equipment, the so-called Class IE equipment. Other safety-
22 related equipment is covered under the general principles and
23 methods and criteria contained in that document as indicated
24 in NRC's Standard Review Plan Section 3.11, Revision 1. The
25 application of the 627 document, which is a very new one, and in

1 fact is not even available at this point for official
 2 distribution but is available to the industry, has to do with
 3 all types of safety-related equipment. It contains in
 4 general the same principles, the same criteria for qualifica-
 5 tion of safety-related equipment -- identification of the
 6 equipment, identification of the modes of operation, documen-
 7 tation, and such as that, as are in IEEE-323.

8 Exhibit IIIA-4 has to do with standardized
 9 environmental and seismic qualification specification
 10 appendices. The information to the vendor having to do with
 11 qualification indicating what needs to be qualified and how it
 12 is to be qualified is presented in regard to the several
 13 specifications by these standard appendices which are
 14 attached. You will notice there is quite a variety of these
 15 covering various types of equipment.

16 Exhibit IIIA-5 is additional appendices having to
 17 do with particular pieces of equipment. Down to Appendix 4U
 18 cover various seismic qualifications. Appendices 4V and 4Y
 19 have specifically to do with the Class IE electrical equipment
 20 and the safety-related control and instrumentation devices.
 21 In these, reference is made to the IEEE Standard 323 as to the
 22 basic general requirements for qualification, and if there are
 23 any other special requirements or a particular method which
 24 is mandatory for that piece of equipment, this would be
 25 specified in the appendix or in the specification for the



1 individual item of equipment.


2 MR. BINGHAM: Are there any questions?

3 MR. ALLEN: George.

4 MR. SLITER: On your No. 3) on Item III.A-2 is the
5 expression "Establish an assumed end-of-life condition."

6 Could you please elaborate on what you mean by the word
7 "assumed" here in this context?


8 MR. CARSON: Well, the end-of-life condition is
9 determined by the aging. The methods of aging we will discuss
10 a little bit later, but, for instance, in terms of organic
11 materials or electrical insulation, the Arrhenius method is
12 used extensively to determine by accelerated methods a life
13 that can be expected at an operating temperature. By using
14 the Arrhenius method, we could, for instance, say that an
15 electrical insulation system, when operated at a 90-degree C
16 ambient, will last for 50 years or more, or 40 years, or
17 20 years, depending upon the components and constituents
18 used in that system. The vendor when aging will use the
19 appropriate method to provide the aging and he will, of course,
20 try to get the longest age or the longest life that he can.
21 Some materials under the conditions existing in the plant
22 won't indicate a 40-year life, but the aging mechanisms
23 have to be determined, the aging methods used, to give what
24 is the assumed end of life, because we can't determine the
25 actual end of life. We are trying to demonstrate that this



1 equipment, based on its components, its constituents, under
2 the conditions when it has to operate would operate for that
3 period determined by the accelerated aging methods.

4 MR. ALLEN: Since we are on that slide, Bob, that last
5 bullet down there, Identification of Components and/or
6 Modules of the Equipment Which Are Subject to Aging Deteriora-
7 tion, what is the basis of determining whether they are
8 subject to aging deterioration or not? What is your criterion
9 for that?

10 MR. CARSON: The criterion for that is primarily based
11 on, first of all, determining whether the component, the
12 module, or the individual item is in fact safety related,
13 does that particular thing have to operate in order to mitigate
14 the consequences of the accident or have to operate to allow
15 the entire piece of equipment to function properly. Once
16 you determine that a piece of equipment, a module within it,
17 or an individual item within it has to operate, you then have
18 to determine whether that item has some aging mechanism. I
19 mentioned metals. Metals, for instance, don't age signifi-
20 cantly. They don't age at all, really, in regard to tempera-
21 ture or in terms of radiation for most of the magnetic
22 materials that are used, so you would say that metallic items
23 can be disregarded in terms of age deterioration mechanisms
24 for the parameters that we are worried about. But if you
25 look at organic material, plastics, electric cable insulation,



1 things like that, those are known to deteriorate due to the
2 effects of temperature, due to the effects of radiation,
3 possibly moisture in the humidity situation, and you need
4 to determine the materials, the components that age, and
5 once you determine what ages, you have to figure out the
6 mechanisms by which they age, determine the characteristics
7 of that material that you are looking for, and make a test,
8 make an analysis, or an analysis backed up by some testing
9 in order to determine what the aging is under the conditions
10 in which you are operating. That is the whole point of the
11 accelerated aging.

12 MR. BINGHAM: Any other questions?

13 MR. STERLING: Just to respond a second on what John
14 had indicated, who sets that criteria? Do you ask the
15 vendor to qualify his equipment and then he comes back with a
16 list of what he thinks ages or doesn't age with an analysis,
17 or do you or do APS and Bechtel set the criteria about what
18 they must test to or not?

19 MR. BINGHAM: John, again, some of these questions
20 would be more appropriate to answer at a later time, because we
21 will be hitting these issues during the next part of the
22 review, and I think I would ask to let us present some of our
23 material in this area and then we will, I am sure, answer
24 those particular questions.

25 MR. STERLING: I have another question, if I may, on

1 Exhibit IIIA-3. If you are going to hit this later, let me
2 know. You are calling for the supplier to maintain some
3 documentation. How do you plan to handle the supplier who
4 is going out of business or a loss of that documentation
5 because it is not in the utility?

6 MR. CARSON: We cover that in a later portion of the
7 presentation.

8 MR. STERLING: On the next page, IIIA-4, could you
9 clarify the difference between active and nonactive equipment
10 that are in the various appendices, the titles?

11 MR. CARSON: I would like to have Ken Schechter
12 answer that particular question, since those are involved
13 with seismic definitions.


14 MR. SCHECHTER: I will cover that later on in my
15 presentation.

16 MR. BINGHAM: We are covering that later on, also.

17 MR. ALLEN: Shelly, did you have a question?

18 MR. FREID: Yes. This rather extensive list of
19 appendices cover most of the principles brought forth, but
20 several times we refer to IEEE 627, which covers nonelectrical
21 equipment, and I don't see an appendix that covers the
22 environmental qualification of nonelectrical equipment. Are
23 you in the process of developing an appendix to cover those
24 areas?


25 MR. CARSON: Not specifically. As indicated, the 627



1 document is very new, 1980, but the principles of 627 read
2 very, very similarly to 323. It is an umbrella document
3 having to do with qualification. As well, I will indicate
4 a little bit later when we discuss the Standard Review Plan,
5 the principles of 323 have been asked for and have been made
6 requirements for the several vendors of nonelectrical
7 equipment specifically. We are asking them to use the
8 principals of 323 and apply them to those pieces of equipment
9 which are not specifically electrical.

10 MR. FREID: My question is how do you in your specifica-
11 tions make that clear. In all of these others, it is obvious
12 you append an appendix that defines exactly what they are to
13 do in these areas. In the case of nonelectrical equipment,
14 how do you let the supplier know what you intend him to do?


15 MR. CARSON: Previous to recently, within the past
16 year, vendors were not specifically advised that other than
17 electrical equipment was to be addressed in more detail than
18 to address the seismic problems. During the past year, we
19 have been in contact with all of our vendors and have
20 requested them and are requiring them to address their pieces
21 of equipment, no matter what they are, in regard to the
22 principles and criteria of the 323 document. Bill Bingham
23 mentioned earlier that we are having meetings with these
24 44 different vendors that we have involving these 59
25 different purchase orders that are involved. We are meeting



1 with each of these vendors. We are asking them to look at
2 their programs, identify those pieces of nonelectrical
3 equipment that have aging mechanisms that are safety related,
4 and give us information about the qualification status of
5 those items, give us aging mechanisms, deterioration modes,
6 look at these things so that we will have this information,
7 which is now being called for in the 627 document, but we
8 have looked at it and are looking at it in relation to the
9 principles of the 323 document.


10 MR. BINGHAM: Further questions, John?

11 MR. NOONAN: On Exhibit IIIA-2 under Paragraph 4),
12 you have a bullet there called Determination of Operability
13 Requirements. I mentioned this earlier, but it was brought
14 out during the break that maybe I was not being specific
15 enough to get my concern across. When Bechtel makes this
16 determination of operability requirements and looks back at
17 their test results to see whether or not they have passed
18 these test results, I was talking about anomalies and how
19 these anomalies are fed back to the utility or to the NSSS
20 supplier. I would like to give a specific example to show
21 my concern. Recently there was a test by another NSSS
22 vendor regarding a piece of electrical equipment. That
23 electrical equipment was monitored for output. Its output was
24 monitored to see whether or not it met the requirements of
25 what it was supposed to do under seismic environment. In



1 doing so, they found small type spurious signals coming out
2 of the piece of equipment that were not supposed to be there.
3 These were signals that were in duration about one millisecond,
4 but you would get a number of these occurring say within a
5 period of about a 100 millisecond duration. After
6 investigation, it was found out that, while this was not
7 particularly detrimental to the piece of equipment that the
8 NSSS supplier was providing, these signals did perform an
9 adverse function on a piece of balance of plant equipment.
10 That is what I am trying to get across. When you look at the
11 determination of operability requirements, do you consider
12 those requirements as to how they relate back to the NSSS
13 people?

14 MR. CARSON: In the specification for the particular
15 equipment item, we will indicate the acceptance criteria for
16 that particular piece of equipment, what does it have to do
17 under what conditions, and we hope that we have determined
18 everything involved in the operability that might cause a
19 problem. If during the testing some anomaly such as you
20 mention does come up and is identified, we would go back to
21 the responsible engineer and identify those anomalies. We
22 would go back into an analysis of the system in which this
23 piece of equipment operates to see whether it can be determined
24 whether such an anomaly would cause a problem. If it is
25 analyzed and determination is made that such a thing is




1 indicated as not causing a problem, then that would be
2 accepted. If it is determined that that would cause a
3 problem, we then will go back to the vendor and try to
4 eliminate that or possibly have a redesign of the equipment
5 to eliminate such anomaly that would cause detrimental effects.

6 MR. NOONAN: That procedure is in place between you
7 and the utility and the NSSS vendor? That's what I am
8 looking for, to make sure that procedure is in place.

9 MR. BINGHAM: Vince, that's true for everything that
10 we do. We use the same procedure. We have to do that in
11 order to assure that there is feedback in design. I think
12 what Mr. Carson said is once it is flagged, we don't neglect
13 it, we follow through, and we can cite other examples in the
14 balance of plant design.

15 MR. NOONAN: I would like to ask one other additional
16 question, or two additional questions, really. I am not
17 sure what paragraph this would fit under, but I think it
18 would fit under Paragraph 4) on the same slide. As you all
19 know, we have an IE Bulletin Statement 79-14, which for the
20 public is referred to as the as-built conditions. I see
21 nothing in here that shows me that when the plant is being
22 built and modifications are made out in the field, whether
23 those modifications are a change in mounting or change in
24 location, how that is fed back into the qualification of that
25 equipment and how are records kept of that so that those



1 things are noted, if they affect the qualification of the
2 equipment, it is so noted and something can be done about
3 it.

4 MR. BINGHAM: We can respond to that. What I would
5 like to do is to respond a little later, if I could, John.

6 MR. ALLEN: Okay. Gerry, do you want to make a note
7 of that?

8 MR. BINGHAM: Make a note of that.


9 MR. ALLEN: You want to make a phone call over lunch?

10 MR. BINGHAM: Yes.

11 MR. NOONAN: The final question would be on the next
12 page, IIIA-3 slide, on No. 5) where you talk about documen-
13 tation. Recently, there has been a Commission interim order
14 to staff on equipment qualification dated May 23. In that
15 Commission order, it directs the staff to make sure that
16 adequate documentation is being maintained at a central
17 location. The supplier in my estimation does not conform to
18 that requirement of keeping documentation in a central loca-
19 tion, and I guess I would like Dr. Rosztoczy to address that
20 in detail as to what we at NRC expect on that particular issue.

21 MR. BINGHAM: We would like to hear.

22 DR. ROSZTOCZY: The required documentation is that it
23 has to be maintained at a central location and it is the
24 responsibility of the licensee. Those are the two important
25 parts, the central location and the licensee. There are also



1 some clearly defined words which I believe permit, for
2 example, maintenance possibly at two places. One may be
3 at the utility's location for most of the plant documentation
4 and then the nuclear part at the Nuclear Steam Supply System
5 vendor location. Nevertheless, even in that case, the
6 responsibility for the maintenance of both of these files
7 rests with the licensee.


8 MR. BINGHAM: I think that is very helpful, John.

9 MR. NOONAN: One other point on the same thing. We
10 would like to discuss maybe very briefly here the subject of
11 replacement parts. Replacement parts documentation also has
12 to get into this package. I think you ought to address how
13 you are going to handle replacement parts, how you are going
14 to maintain documentation to assure us that if you go out and
15 replace a part with a different part that it has met all of
16 the qualification requirements of the previous part.

17 MR.. BINGHAM: John, I think that probably falls more
18 within the APS area, the replacement parts.

19 MR. ALLEN: That's correct. Presently Bruce Kaplan, of
20 John Roedel's department, is coming up with a corporate QA
21 manual which this type of issue is covered in, so maybe I
22 could ask John Roedel to comment a little bit about that and
23 then possibly Norm Hoefert, from operations.

24 MR. ROEDEL: To answer your question, we are developing
25 a system of purchasing that is based on the safety-related
aspect of that item and what is necessary to inform us to



1 assure that that item meets those requirements, so the
2 procurement activity will be directly associated with what
3 is necessary to assure us that the technical requirements are
4 met. If we can buy that as an off-shelf item and still
5 verify that the technical requirements are met, we will do it.
6 I am sure that if it is qualified electrical equipment, most
7 of it won't be bought that way, but some of it could be as
8 long as we can still verify its technical requirements and the
9 previous requirements as expressed in the purchase order for
10 its original purchase.

11 MR. NOONAN: And the documentation of the qualification
12 of that replacement part will be kept where?

13 MR. ROEDEL: Well, that will be available at the plant
14 site. We are documenting all our documents on a microfilm
15 system so that it will be available at different readouts in
16 the various parts of the plant or wherever the procurement
17 activity begins.

18 MR. ALLEN: I might clarify that, Vince, a little bit.
19 We intend to film every piece of documentation that we get
20 especially related to safety-related components and there
21 will be records kept both in the central engineering office
22 and the power plant, so it will be in two different locations,
23 identical records.

24 MR. NOONAN: So when your IE inspector comes out to the
25 site, he would have a set of records to look at?

1 MR. ALLEN: Right, or if he happens to be at the
2 engineering office, he will have the same records there.

3 Norm, would you like to respond on your procure-
4 ment of parts at all?

5 MR. HOEFERT: What specific area?

6 MR. ALLEN: On the procedures you have developed on
7 how you handle spare parts, or do you think John Roedel
8 covered it satisfactorily?

9 MR. HOEFERT: I think generally John covered it as far
10 as we will have documentation at the site of any quality
11 assurance requirements that are needed for each particular
12 part that is purchased.

13 MR. ALLEN: Any further questions?

14 DR. ROSZTOCZY: I have one question. In your presenta-
15 tion, you gave a verbal definition of safety-related equipment
16 and you tied it to the design basis accident. I hope that was
17 an oversight and what you really mean is all transients and
18 accidents that the plant might be exposed to.

19 MR. CARSON: Yes. As I indicated, the equipment must
20 operate whenever it is called upon to operate during any
21 period; normal, abnormal, design basis event, post-design
22 basis event, test, whatever. Any time period during the
23 operation of the plant during its life, under any conditions
24 that accrue at its location, for any operational mode of the
25 plant, that equipment must operate and has to be demonstrated

1 during the qualification phase that it will operate.

2 DR. ROSZTOCZY: Thank you.

3 MR. ALLEN: Any further questions? Carter.

4 MR. ROGERS: I would like to take Vince Noonan's first
5 question and turn it around just a little bit. Let's say
6 that we have a relay, for instance, that we are purchasing
7 through the balance of plant and that relay is tied to
8 Combustion Engineering's qualified equipment. The relay is
9 tested and it comes up with an anomaly. Are there procedures
10 in place which would ensure that Combustion Engineering is
11 notified of that anomaly and has a chance to review it for
12 acceptability or not?

13 MR. BINGHAM: Yes, there are.

14 MR. ALLEN: Any further questions? If not, Bill, why
15 don't you proceed.


16 MR. BINGHAM: Because of the time, I think probably we
17 would only be able to go through the first part of the next
18 section, which is III. B. Environmental Qualification Criteria,
19 Item 1, Standard Review Plan, and if we have time after that,
20 John, we will try to do the Design Criteria. Section 3 is
21 a very lengthy presentation, so I think that would be best
22 to hold until after lunch.

23 MR. CARSON: Figure 11 indicates the environmental
24 qualification criteria having to do with safety-related
25 equipment which would be applicable in the environmental

1 qualification program for the project. As we have indicated
2 earlier, we define Class IE or electrical safety-related
3 equipment and we identify other safety-related components or
4 nonelectrical equipment and indicate the principal sources of
5 qualification requirements for those types of equipment. The
6 box area here (indicating) represents the NRC's Standard
7 Review Plan for Qualification of Safety-Related Equipment
8 Section 3.11, Revision 1. All of these items within the box
9 are specifically referenced in the Standard Review Plan as
10 being applicable to qualification of equipment.

11 Exhibit IIIB-1, Section 3.11 of the Standard Review Plan.
12 For the following presentations where we talk about these
13 several items, we have only extracted certain portions of
14 these, those items that bear specifically on qualifica-
15 tion. I have not reproduced the entire document. The
16 Standard Review Plan indicates the same sorts of things that
17 we have talked about earlier. Safety-related equipment has
18 to be identified, its operational requirements determined.
19 Environmental design related mechanical and electrical
20 equipment has to be shown to meet all of its requirements.

21 Exhibit IIIB-2. The Standard Review Plan calls for
22 the applicability of 323-1974 and it indicates that, even
23 though 323 was specifically designed and put together for
24 electrical safety-related equipment, the criteria, the
25 methods, the sequential testing, the aging in that document



1 have to do generically with all types of safety-related
2 equipment.

3 On Exhibit IIIB-3 are various requirements having
4 to do with the application of 323 in regard to specific
5 types of electrical equipment called out in the daughter
6 documents to that standard having to do with electrical
7 penetrations IEEE 317, 334 for motors, 382 for valve
8 operators, 383 for wire and cable. As indicated, there are
9 a number of other specific IEEE documents either in place
10 or being prepared now covering other items of electrical
11 equipment.

12 Exhibit IIIB-4. In regard to the environment, one
13 of the parameters is chemical spray primarily involved with
14 in-containment chemicals during a design basis event. The
15 equipment has to be qualified for operation in that chemical
16 environment, and then the chemical requirement has to be that
17 which will accrue in the specific plant.

18 Radiation is also involved with the design basis
19 events. The equipment must be shown to be operable in the
20 radiation environment under any circumstances that will accrue
21 at its location.

22 Exhibit IIIB-5. Another one of the specific items
23 called out in the Standard Review Plan is General Design
24 Criterion No. 1 of 10 CFR 50, Appendix A, quality standards
25 having to do with structures, systems and components related


1 to safety or safety-related items. The project maintains
2 quality assurance requirements in accordance with Appendix B
3 of the 10 CFR 50 document.

4 Exhibit IIB-6, General Design Criterion No. 2,
5 design bases for protection against natural phenomena. All
6 safety-related equipment is designed and qualified to withstand
7 the effects of natural phenomena if such accrue at its
8 location.

9 Exhibit IIIB-7, General Design Criterion No. 4,
10 environmental and missile design bases. Again, safety-
11 related structures, systems and components must be designed
12 so that any environmental or missile conditions that accrue at
13 the location are taken care of. In addition, physical
14 independence and redundant equipment is provided throughout
15 the plant so that a single item of safety-related equipment
16 if it is somehow disabled will not prevent the safety function
17 from being performed.

18 Exhibit IIIB-8, General Design Criterion No. 23,
19 protection system failure modes. Safety-related equipment
20 has to be designed and qualified so that it will fail in a
21 safe manner. In the single-failure criterion, one piece of
22 equipment failing will not prevent the safety function from
23 being performed through the multiplicity of equipment provided.

24 MR. BINGHAM: I think, John, let's entertain questions
25 at this time for Sections 1 and 2.




1 MR. ALLEN: Any questions from the board?

2 DR. ROSZTOCZY: The last few slides that you presented
3 had a separate column for the Palo Verde position and there
4 were certain words indicated there. Maybe we can have the
5 first one up, which was IIIB-1. In the right-hand column,
6 there are words saying that that is in compliance. At the
7 present stage of your work, most of them have not yet been
8 tested, so you are obviously in no position to make any
9 conclusion that it is in compliance. You hope that by what
10 you are going to do in the next few months or the next year
11 that by the end of that work, you will arrive at this
12 conclusion. I think the slide in its present form is grossly
13 misleading and those words should be modified or eliminated
14 from them.

15 MR. BINGHAM: You are absolutely right. In my opening
16 remarks, I indicated that you might get that impression from
17 what we were presenting that we were in compliance with
18 the principles of the documents, and I had hoped that that
19 clarification would help. But that is true.

20 DR. ROSZTOCZY: Probably you should use words like
21 you intend to comply with this rule, something like that.

22 MR. CARSON: What we are really indicating is that we
23 are in agreement with the positions stated in the documents
24 and we are applying them to our qualification programs. We
25 are asking our vendors to provide qualification programs which



1 meet these criteria, and when we get all done with the total
2 programs, our qualifications will be in compliance with all
3 of the documents that we are discussing.

4 DR. ROSZTOCZY: Those words would be much better on the
5 slide, also.

6 MR. BINGHAM: John, we have followed the format of the
7 last two or three boards of review by using this presentation.
8 It apparently is confusing, and we can either qualify it for
9 the record that that is the case, as we have done, or if the
10 board would desire, we can modify the slides for the record
11 to make that statement.


12 MR. ALLEN: I think, like the slide indicates, it is
13 our intent to comply and we are not where we can say we comply
14 100%. I think as long as that is in the record, that should
15 be satisfactory.

16 MR. BARROW: I think, though, that it ought to be
17 explained, because, as his question suggests, quite a bit of
18 our testing might be still yet to come, or the vast majority
19 of our testing. It might be pointed out the percentage of
20 our equipment that has already undergone some or all of its
21 testing by the vendors. Could Bechtel indicate that?

22 MR. CARSON: Are you indicating environmental or
23 seismic, or both?

24 MR. BARROW: Environmental and/or seismic.

25 MR. CARSON: As I indicated, a great amount of the



1 equipment has had some qualification testing, analysis, or
2 combination programs performed on it. The earlier table
3 indicated that 15 programs had been considered complete prior
4 to the issuance of the 0588 document and only one now is
5 considered complete. Those programs that had been considered
6 complete are being reevaluated on the basis of the more
7 recent requirements. Those programs which are in process,
8 the new requirements are being applied to them. So they
9 will all eventually comply with all of these requirements
10 that we are talking about today. But, yes, a great number of
11 items have had some testing, analysis, or some qualification
12 applied to them.


13 MR. BARROW: In addition, isn't it true that the
14 balance, the other ones besides the 15, probably the majority
15 of them have had some testing done?

16 MR. CARSON: Yes, they are in process. As Bill
17 indicated, only a few items have not at this date been
18 purchased and these programs have been in operation and in
19 the testing and qualification process over the past years.
20 They are all at some state, but most of them are not fully
21 complete.

22 MR. BARROW: Thank you.

23 MR. ALLEN: John.

24 MR. ROEDEL: May I ask a question that maybe can
25 clarify these various slide presentations to me? Is not the



1 column on the left-hand side the acceptance/rejection criteria
2 for the various activities that are needed for either a system or
3 the testing of an article and the right-hand column is a
4 statement that this project is going to meet that requirement,
5 that was the acceptance or rejection criteria, and that the
6 implementation of the acceptance criteria has not been
7 accomplished yet? Is not that what you are saying?

8 MR. BINGHAM: John, that's true. This is a format
9 that we have adopted for this particular board of review to
10 not only state what we are doing, but to compare it with the
11 standard review plans and indicate where we stand as far as
12 the key elements in those standard review plans. An issue in
13 earlier boards of review that has come up is well, that's
14 all very nice; now we know what you are doing. The board
15 has wanted to know how does that compare with the regulations
16 or the criteria. The intent here is a little bit more
17 difficult for the board, I am sure, to understand, because it
18 is not a system like the aux feedwater system or the power
19 system that we have done. We have tried to take the same
20 format, because you are used to seeing it, and essentially
21 put the key elements on the left column and then indicate
22 more importantly those areas where we have exceptions or areas
23 that are just not practical as far as the regulations to
24 comply with on the right column.

25 MR. ALLEN: Do you have a better understanding of that

1 now or do you still have a problem with it?


2 DR. ROSZTOCZY: I think I understand it and I under-
3 stood, it from the beginning, but I think the wording on the
4 slides is not consistent with the present state. I just
5 intended to bring attention to that.

6 MR. ALLEN: Carter, did you have a question?

7 MR. ROGERS: John Roedel pretty well summarized what I
8 was thinking. Actually, maybe this is a poor example, but it
9 would be very difficult in my mind to say that there are three
10 criteria that are there and all must be met, and when reading
11 those criteria, I think that I would have difficulty finding
12 an acceptable exception to those whether it has been tested
13 or not, and I would think that equipment would meet this
14 position even after they are tested or otherwise they are not
15 acceptable. Maybe we've got a little time element question
16 here, but our position as I read this, and in my mind, too,
17 sitting on the safety board, is that we should be in compliance
18 with those three elements that are listed on this slide.

19 MR. ALLEN: Pete.

20 MR. NEWCOMB: I have two questions related to Exhibit
21 IIIB-7. Under the Palo Verde position statement, you state
22 that systems and components outside containment important to
23 safety are provided with redundancy. First of all, would you
24 explain why outside was chosen and what is done for
25 inside containment.



1 MR. CARSON: We are talking primarily here, as
2 Mr. Bingham indicated earlier, of the balance of plant
3 equipment, which is primarily located outside of the contain-
4 ment. Certainly all equipment having to do with safety-
5 related functions is provided where necessary in redundancy
6 both inside and outside. CE provides redundant equipment.
7 Balance of plant equipment is provided in redundancy. What
8 we are addressing here primarily is the balance of plant
9 equipment. That is why the distinction was made outside the
10 containment.

11 MR. NEWCOMB: So the Palo Verde position is in fact
12 both inside and outside?


13 MR. CARSON: Absolutely.

14 MR. NEWCOMB: Bechtel is primarily affected on the
15 outside containment.

16 MR. CARSON: That's right.

17 MR. NEWCOMB: The second question I have is you were
18 relating redundancy as a means evidently of meeting some of
19 the requirements of environmental effects. Could you explain
20 the basis for that? In other words, I read Criterion No. 4
21 to state that you must accommodate the effects of environmental
22 conditions. Where does redundancy relate to that requirement?

23 MR. CARSON: Well, what we are indicating here is that
24 the redundant equipment is provided and if, due to some
25 environmental action, a piece of safety-related equipment is



1 disabled, the arrangement is such that a single environmental
2 occurrence would not be involved with more than one piece of
3 equipment, so the other equipments which are redundant and
4 perform the same function would not be affected by a single
5 environmental occurrence.

6 MR. NEWCOMB: What you are saying then is that the
7 redundancy is also combined with physical independence or
8 positional independence?

9 MR. CARSON: Yes, the physical independence of the
10 equipment. The walls around the rooms in which the equipment
11 is located segregate one piece of equipment from another piece
12 of redundant equipment so that only one can be damaged
13 possibly in a given incident.


14 MR. BINGHAM: John, it is 12:30.

15 MR. ALLEN: I think we had better postpone any further
16 questions until after lunch, because they did ask that we have
17 lunch at exactly 12:30. Why don't we adjourn the meeting and
18 come back at 1:30.

19 (Thereupon the meeting was at recess.)
20
21

22 September 25, 1980
23 1:30 p.m.

24 MR. ALLEN: Bill, were you able to get any resolution
25 to any of those items?



1 MR. BINGHAM: Yes, we have some resolution and, as I
2 remember, before we broke, there was a question before the
3 board on how they wished us to respond to the modification of
4 the examples on the use of the words "in compliance."

5 MR. ALLEN: What I would like to find out from the
6 board is would anybody be opposed to changing that to wording
7 that would be more acceptable to Zoltan such as "intended
8 compliance," or do you have some words you would like?

9 MR. ROSZTOCZY: A number of different wordings have
10 been mentioned here. I think any of those would be fine.
11 My only concern was that the present wording kind of expressed
12 a past tense type of thing, that it already has been established
13 to be in compliance, and it is more like the future.


14 MR. ALLEN: "Future compliance," would that --

15 MR. BARROW: John, I suggest "in the process of
16 compliance" or to show that we are actually energetically
17 endeavoring to comply.

18 DR. ROSZTOCZY: I'm not sure if it is necessary to
19 pick the words right here. I think you've probably got the
20 message from the comments, and why don't we just leave it to
21 you to correct the words to whatever is appropriate.

22 MR. ALLEN: Bill Bingham, could I ask you then to go
23 back and correct those slides with some wording to show that
24 it is our intent to comply or some other words like that.

25 MR. BINGHAM: All right, we will correct them.



1 MR. KOPCHINSKI: All of them, I presume?

2 MR. BINGHAM: All of them.


3 MR. CLARK: Bill, I have a question concerning
4 equipment that meets the qualifications and then say ten years
5 down the road or five years or x years, is there anything
6 that states anywhere that you would require a requalification
7 and, if so, how is it documented or spelled out to Operations?

8 MR. BINGHAM: As I recall, John Allen touched on that
9 earlier. If there is a qualified life less than 40 years,
10 let's say 20 years or 10 years, that will be so noted and,
11 as John mentioned, it will become part of the maintenance
12 procedures to replace it. Generally that is how it is
13 handled.

14 MR. CLARK: Maybe a restatement of that is if we do
15 have equipment that has been qualified for 40 years life and
16 say it has operated 10 years, how do we prove that it still
17 has 30 years life left on that piece of equipment? Mainly
18 rotating machinery.

19 MR. BINGHAM: Well, I think the concept is that you
20 demonstrate prior to that that its qualified life is 40 years.
21 Of course, there will be periodic testing of all safety
22 equipment as required in the Tech Specs to assure that it is
23 still performing its function monthly or some other period as
24 determined by the Technical Specifications.

25 MR. ALLEN: Any further questions? Shelly.




1 MR. FREID: Could we go to Exhibit IIIB-8, please?
2 It doesn't seem that the PVNGS position addresses the Design
3 Criterion No. 23 for equipment qualification. It addresses
4 the position, but in particular for equipment qualification,
5 we qualify the system that it would not fail under adverse
6 conditions, postulated adverse environments, but more so
7 don't we qualify that the component if it fails will fail
8 as the design intends? What I mean is a valve is designed
9 to fail either closed or fail open or to fail as is and the
10 qualification program assures that it fails in that mode.

11 MR. BINGHAM: Yes, that's correct.

12 MR. ALLEN: Ed, did you have a question, or does George?

13 MR. SLITER: I think that brings up a more general
14 question about again your statement of position. You said
15 earlier, Mr. Bingham, that this was meant to mean not so much
16 in compliance, but in agreement, but this would be the
17 location in which you may bring up any exceptions to the
18 requirement. There may be an implication then that if the
19 words "in compliance" or "in agreement" are not here that
20 there may be an implied exception. I will assume in what I
21 have heard so far that in anything you have said, you have
22 not come up with any exceptions, and can I also assume that
23 if you had any exceptions, in future proceedings you would
24 be explicit about calling them exceptions?

25 MR. BINGHAM: That's correct, George. Our intent is to



1 inform the board exactly where we stand and it is our intent
2 to delineate all exclusions, all exceptions.

3 MR. SLITER: And there are none.

4 MR. BINGHAM: Only as indicated, that's right, and
5 again I must indicate to you this is our intent. If we run
6 up against a vendor that we have extreme difficulty with,
7 there may have to be some compromises, and, of course, NRC
8 and APS and all parties would have to be a party to that
9 particular compromise. But we really intended not to hide
10 anything or imply that anything is hidden in our presentation
11 today.

12 MR. ALLEN: Any further questions? Yes, sir.


13 MR. VOLLMER: I have a question on safety-related
14 equipment. Your definition "would prevent or mitigate the
15 consequences of an accident and provide for a cold shutdown,"
16 is that right?

17 MR. CARSON: To mitigate the consequences of an
18 accident and allow safe shutdown of the plant.

19 MR. VOLLMER: That is cold shutdown?


20 MR. BINGHAM: Yes.

21 MR. VOLLMER: Further, how do you intend to deal with
22 two things: One, the changing requirements in the action
23 plan which are identifying equipment that will be in the
24 future categorized as safety related and may not necessarily
25 currently be in your QA as safety related, and, also, the



1 changing requirements such as use of different source materials
2 on your balance of plant equipment, that is, higher radio-
3 activity content of fluid than you probably now normally
4 assume? I am wondering how the program deals with this and,
5 also, if you are dealing with in any way what are categorized
6 as systems and components that are not necessarily safety
7 related by the true definition, but are important to safety
8 in the context of the TMI lessons learned.

9 MR. BINGHAM: We are considering all those points and
10 will be discussing some of them, for example, the radiation,
11 and there are other points that you didn't mention. We know
12 that there are changes that are coming, or at least potential,
13 that we must consider. We work very close with APS with
14 input from meetings like this and other discussions we have
15 with NRC or other utilities. When we go through the details,
16 there will be appropriate places where we can respond to how
17 we are tackling what I might call escalation of present
18 criteria, at least as we know them. So if we have missed a
19 point, maybe at that time I would suggest to the board that
20 that be brought up so that we are sure to clarify it. The
21 overall response to your question is yes, we are aware of
22 them and we have them as part of our program and they would
23 be handled in the proper manner; that is, if they come in as
24 a requirement, they will be reviewed with the utility,
25 become part of the criteria, and be implemented in the plan.



1 MR. ALLEN: Any further questions before we move along?

2 Yes, sir.


3 DR. ROSZTOCZY: I am not sure if I get the gist as it
4 relates to single failure. On the left-hand side of the
5 slide, the question is what happens if it fails because of
6 some environmental condition. This would be kind of a
7 systematic failure. If you have four channels that have
8 safety components in them and if one of those components in
9 each of the channels fails because of environment, then the
10 indication is they do fail in the safe mode. On the right-
11 hand side, your position doesn't address this question.

12 MR. BINGHAM: Help me with the question again. I
13 thought we did cover it.

14 DR. ROSZTOCZY: The requirement quoted on the left-
15 hand side indicates that should there be a failure because
16 of environmental conditions, then that should be in the safe
17 state, to be given in such a way so that it falls into the
18 safe state. The right-hand side kind of ignores this problem
19 and instead talks about single failure. Environmental failures
20 typically are not single failures, but they are multiple
21 failures.

22 MR. CARSON: Dr. Rosztoczy, I think you are asking
23 what if the piece of qualified equipment experiences a
24 failure due to an environmental parameter?

25 DR. ROSZTOCZY: Right.



1 MR. CARSON: What we are indicating is that we
2 determine what environmental designator it is in and what the
3 range of those environmental parameters are for those
4 locations and we test all items or otherwise test the
5 equipment for that complete range of parameters, and we would
6 not anticipate that an item would fail because of some
7 environmental parameter, as you indicate, a common mode
8 failure. We are taking account of the total range of parameters.

9 DR. ROSZTOCZY: That's correct, and that meets an
10 earlier requirement which is not shown on this slide. This
11 requirement quoted on this slide goes a step further and it
12 says that, for example, you didn't predict the environment or
13 an unexpected environment somehow happens and should we fail,
14 then it should be designed to fail in the safe mode.


15 MR. CARSON: This is correct.

16 DR. ROSZTOCZY: The right-hand side does not address
17 this question. The right-hand side should say yes, you are
18 going to see to that, that if they fail because of high
19 temperature or because of something, that it falls into the
20 safe mode.

21 MR. CARSON: This is right, yes.

22 MR. BINGHAM: Yes, we meet that.

23 DR. ROSZTOCZY: Let me go back to the previous slide,
24 which is IIIB-7. Somebody asked some questions on this just
25 before lunch. I am not sure if I followed all the answers



1 to that. I might be somewhat repetitive, but let me try it
2 anyway. Here again the left-hand side emphasizes that the
3 equipment has to be designed to accommodate the environmental
4 conditions, and on the right-hand side, there is no answer to
5 that.

6 MR. CARSON: Again, as we have indicated, we design
7 the equipment and qualify the equipment for all of these
8 conditions. This is a further explanation. In addition to
9 qualifying it for the range of environmental conditions, we
10 also take these precautions to further prevent any problems.

11 MR. BINGHAM: We agree with you this response is a
12 little confusing, and I think what I would offer is that we
13 clarify it in the record, John.


14 MR. ALLEN: Okay, if someone would mark that down as
15 an open item then to be clarified, Exhibit IIIB-7.

16 DR. ROSZTOCZY: Is it your intention then to design
17 to meet the environmental conditions?

18 MR. BINGHAM: Yes.

19 MR. ALLEN: Any further questions on this? If not,
20 proceed with your presentation.

21 MR. BINGHAM: Before you start, I think there are two
22 things that we had left. The others we will discuss after the
23 break, John. First of all, with respect to Mr. Vollmer's
24 question on the qualification of perhaps not safety-related
25 equipment, we are not now looking at that in our present



1 plan, but we are aware of that potential.


2 The second thing is I wanted to make sure that we
3 had made the point that the positions on qualifications today
4 represent a project qualification in our work not only in this
5 area, but in all areas. We have positions that we do present
6 to our customers to start with and they may or may not follow
7 that particular position. So I wanted to make clear that
8 what you are seeing here today is a position that is for the
9 Palo Verde Project and you might see some different positions
10 on other jobs where Bechtel is involved.

11 With that, let's start into this next presentation,
12 John. This is a fairly long presentation. I just tell the
13 board that it will take somewhere in the neighborhood of a
14 half hour to 35 minutes, and, if you deem appropriate, we
15 can break in the middle, or if everybody is wide awake, we
16 can go on.

17 MR. ALLEN: I suggest that we hold the questions until
18 the end of the presentation to help us move along.

19 MR. CARSON: Exhibit IIIB-9 has to do with requirements
20 set forth in IEEE 279-1971, criteria for protection systems
21 having to do with test data and the range of transient
22 conditions which the equipment must operate under, and we are
23 in agreement with these positions in terms of the qualifying
24 program.

25 Exhibit IIIB-10, further on IEEE 279. Minimum




1 performance requirements to be documented. We are in
2 agreement with that requirement.

3 Exhibit IIIB-11, having to do with IEEE Standard
4 308, which has to do with the Class IE power systems which
5 are installed in the plant, the AC system, the DC system,
6 and vital instrumentation and control power systems. The
7 project provides such systems and those safety-related items
8 in the systems are qualified for use in the environments in
9 which they must operate.

10 Exhibit IIB-12, having to do with IEEE 317-1976
11 covering electrical penetrations. The penetration assembly
12 is a device whereby electrical circuits are passed through
13 the containment and provide for the safe and continued
14 passage of electric circuits for Class IE circuitry and also
15 serves as a pressure boundary for the container.

16 Exhibit IIIB-13. Design qualifications for the
17 penetrations have to be verified by material testing and
18 other methods to show that they are compatible with their use.
19 For the project, our specification EMO35A requires qualifica-
20 tion of penetrations under all postulated operating conditions.
21 Margins are to be applied as indicated and as suggested by
22 the IEEE 323 document. The project is in agreement with the
23 use or margins in qualification programs.

24 Exhibit IIIB-14 continues indication of margins
25 and the fact that conductors used in the penetrations must




1 meet the requirements of IEEE 383 having to do in part with
2 flame tests. The project is in agreement with that requirement.

3 Exhibit IIIB-15, having to do with the basic
4 qualification document, IEEE 323-1974, the capability of
5 Class IE equipment in regard to requirements that we have
6 previously mentioned. The equipment must be qualified to
7 operate under all conditions and allowances made for the
8 known potential failure modes. We agree with that position.

9 Exhibit IIIB-16, having to do with one method of
10 qualification under 323, ongoing qualification tests and
11 documentation for such testing. The project position is that
12 an ongoing qualification program as such is not encouraged.
13 We discourage such programs. We would like to have specific
14 qualified life established.

15 Exhibit IIIB-17, continuing on IEEE 323. There are
16 several methods, as we have indicated, for qualification and,
17 as Mr. Bingham indicated earlier in the discussion of Table
18 1, the methods of testing, documented analysis, documented
19 operating experience, combination of methods are agreed with.
20 As indicated, Class IE equipment is identified.

21 Exhibit IIIB-18, methods of qualification, we have
22 discussed previously. Operating experience is one method.
23 In Exhibit IIIB-18, the document indicates that type testing
24 is preferred for Class IE items in containment and other harsh
25 environments. Later in our presentation, we will further



1 describe what the harsh environments are in this plant.


2 Exhibit IIIB-19. Operating experience when success-
3 fully documented can be used as a method of qualification.
4 The project discourages the use of operating experience alone
5 as a method of qualification.

6 Exhibit IIIB-20. Analysis is another method
7 which can be used. The project discourages use of analysis
8 alone, but it is definitely of use in conjunction with type
9 testing or documented operating experience.

10 Exhibit IIIB-21. Ongoing qualification methods, as
11 indicated, are not encouraged as such, but if they are used,
12 we will only entertain programs which make use of equipment
13 which has some demonstrated qualified life, which is then
14 extended on a periodic basis through one of the methods
15 indicated, either removing portions of such equipment from
16 the main equipment periodically and retesting it under the
17 proper conditions or by installing completely redundant
18 equipment and removing it periodically for testing.

19 Exhibit IIIB-22, other methods, the combination of
20 any of the previous methods indicated. The project will allow
21 combination methods.

22 Exhibit IIIB-23, documentation having to do with
23 any qualification method must be complete, must be supplied,
24 and be in auditable form. The project agrees with that
25 position, but there is some problem with certain vendors who




1 refuse to provide on a regular basis what they consider to
2 be proprietary information, and we require that such informa-
3 tion be maintained at the supplier's or another facility in
4 auditable form for the life of the plant.

5 Exhibit IIIB-24 has to do with requirements of
6 IEEE 323 having to do with aging, sets forward the principle
7 of aging to put the equipment in the end-of-life condition
8 prior to exposing it to the design basis event. Aging has
9 to do with mechanisms of temperature, radiation, humidity,
10 seismic vibration, whatever would affect the equipment and
11 might cause it or some of its components to fail. The
12 project position is that aging must be considered no matter
13 what method of qualification is chosen and agreed upon.

14 Exhibit IIIB-25, talking about aging, is an
15 illustration having to do with organic materials, specifically
16 electric insulation materials, and the regression line method
17 or the Arrhenius methodology. If the so-called Arrhenius
18 methodology is used, the project position is that the
19 Arrhenius methodology is considered acceptable as a method
20 of addressing accelerated aging and that supporting data must
21 be provided to demonstrate that the Arrhenius plots are in
22 fact applicable to the materials being investigated.

23 Exhibit IIIB-26. 323-1974 sets down a specific
24 sequence in which the equipment is to be tested if the
25 qualification is achieved by type testing or the sequence that




1 should be considered if you are using analysis supported by
2 type testing or considering some other qualification method.
3 The project position is that type testing should be done in
4 the sequence as indicated and should be done on equipment that
5 is either identical or very, very similar to the equipment
6 being supplied for use in the plant. The first step in the
7 sequence is to inspect the item for form, fit and function prior
8 to doing the testing.

9 Exhibit IIIB-27, continuing the sequence, operate
10 the equipment under normal conditions to establish baseline data,
11 operate it under all of the extremes to find whether it will
12 do its job under extreme conditions in the plant. The project
13 is in agreement with the sequence of testing.

14 Exhibit IIIB-28. Equipment is to be aged prior to
15 exposing it to the design basis event. We concur with the
16 aging of the equipment.

17 Exhibit IIIB-29. The aged equipment is to be
18 exposed to mechanical vibration and seismic events that would
19 accrue in its lifetime in its position, and then is to be
20 operated while being exposed to radiation as part of the
21 aging. The project position is that aging and vibration are
22 to be incorporated in the qualification program and that
23 existing results that exist for such equipment can be used
24 to qualify equipment for the APS project.

25 Exhibit IIIB-30. The operated equipment is to be




1 exposed and operated during design basis event, after which
2 it is to be disassembled to inspect for any possible damage
3 to make sure that it is in fact capable of doing its job.
4 The project is in agreement with these requirements.

5 Exhibit IIIB-31. Margins are to be incorporated.
6 Margins take care of possible difficulties in establishing
7 exactly the parameters of the environment and take care
8 of manufacturing tolerances and other things. We want to
9 make sure that everything is going to operate over the range
10 of the parameters in the plant. Margins are to be included
11 in all programs.

12 Exhibit IIIB-32 gives some indication of the margins
13 that are suggested for test programs. The project concurs
14 with those margins.

15 Exhibit IIIB-33 gives additional margins and, as
16 indicated and in accordance with one of Dr. Rosztoczy's
17 questions, environmental transients are to be accounted for
18 during the qualification program. The project position is
19 that we will use plant specific profiles and environmental
20 conditions, and our profiles contain a single peak for
21 transients, not a double peak.

22 Exhibit IIIB-34, margin for vibration and the fact
23 that negative margins, if they are more severe, should be
24 included in the program. The project agrees with this
25 position.




1 Exhibit IIIB-35 has to do with another daughter
2 document for a specific item of electrical equipment,
3 electric motors, specifically continuous duty motors used in
4 the plant. The 1971 version of this document is included
5 in the Standard Review Plan. The 1971 version was specific
6 in that it related only to continuous duty motors inside the
7 containment. In that regard, the project notes that there
8 are no continuous duty BOP type motors which are provided.
9 We are also in agreement that the methods of 334 can be used
10 to qualify other continuous duty motors in the plant.

11 Exhibit IIIB-36 has to do with IEEE 379-1972, the
12 application of the single-failure criterion to the plant.
13 Single failure types are defined and our project position is
14 that other approaches are applicable, the things that we have
15 just talked about, making sure that common mode failures due
16 to environmental parameters are not going to affect the
17 equipment, the equipment will fail in a safe direction, and
18 that we are qualifying the equipment to all known environmental
19 parameters to preclude common mode failures.

20 Exhibit IIIB-37, continuing the definition of
21 failures and the definition of a common mode failure.

22 Exhibit IIIB-38, having to do with IEEE 382-1972,
23 the daughter standard having to do with valve operators,
24 safety-related valve operators, and indicating that a test
25 should be used to demonstrate compliance with the qualification.




1 The project is in agreement with this system and we note that
2 there is a recent version of IEEE 382 which will be
3 evaluated and recommendations made to the project.

4 Exhibit IIIB-39, additional requirements having to
5 do with qualification of valve operators corresponding to the
6 requirements in IEEE 323. The project is in agreement with
7 these requirements.

8 Exhibit IIIB-40, having to do with IEEE 383, the
9 daughter document specifying qualification methods for,
10 electric wire and cable to be used in safety-related systems,
11 including field splices and connections, and requirements for
12 such qualification programs. The project position is that we
13 agree with these requirements and, in addition, factory
14 repairs or manufacturing type splices must also be qualified
15 in addition to the long runs of cable. Flame tests are to
16 be accomplished in accordance with Section 2.5, the gas burner
17 method, rather than using the alternative method. The burners
18 must have at least 70,000 Btu input.

19 Exhibit IIIB-41 indicates the requirements for
20 testing field splices and for documentation in accordance
21 with 323, and the project is in agreement with the requirements.
22 All of these things have to do with methods of providing
23 qualification in accordance with the general requirements of
24 323.


25 Exhibit IIIB-42, another daughter document, this



1 time having to do with diesel generator equipment, the diesel
2 generator equipment as applied to the supply of power for
3 safety-related equipment. The items included are on Figure
4 387-1 and include the total scope of supply of the engine, the
5 generator, the auxiliary systems having to do with the engine
6 and generator and control system, and only exclude the
7 interfaces having to do with oil and water, electric power
8 necessary to flash the generator, or supply interfaces. The
9 project concurs with the scope of supply. The equipment is
10 rated either on a continuous or short-time basis.

11 Exhibit IIIB-43 calls for type qualification of the
12 equipment, and this is one type of equipment which has been
13 indicated as being impractical to provide complete type
14 testing for qualification. Therefore, qualification is done
15 by analysis and analysis based on type testing, some
16 reference made to operating experience well documented, and
17 the combination method of qualification. Tests will be
18 performed in the manufacturer's facility on the assembled
19 engine generator to make sure that it operates properly.
20 There is a specific number of tests, start tests, load tests,
21 load rejection tests, voltage tests, having to do with this
22 equipment, which are all provided prior to its delivery to the
23 site.

24 Exhibit IIIB-44 indicates again type testing and
25 qualification tests to be accomplished on the diesel generator



1 equipment and, following the successful completion, the
2 equipment is to be inspected and documentation provided.
3 The project is in agreement with all of these requirements.
4 There is a recent document, a version of 387, Draft 4, of
5 July 1, 1980, that has been proposed, which brings together
6 in one section of that document more specific requirements
7 for qualification based on 323: This document will be
8 reviewed and recommendations made to the project.

9 Exhibit IIIB-45 covers IEEE 535-1979 having to do
10 with qualification requirements for lead acid batteries of the
11 type used in the plant. The project is in concurrence that
12 the principles of 323 are to be concurred with.

13 Exhibit IIIB-36, again, talking about the principles
14 of qualification and indicating that the batteries and the
15 battery racks are to be qualified for use in the plant.
16 Type testing is to be used in regard to the batteries primarily
17 because analysis is extremely difficult. It is essentially
18 impossible to set up a realistic mathematical model of such a
19 piece of equipment. The project is in agreement with these
20 requirements.

21 Exhibit IIIB-47. Operating experience can be used
22 or previous qualification can be used in conformance with
23 this document. The project is in agreement with this position.


24 Exhibit IIIB-48. As indicated, analysis would
25 really not be justified for examination of such equipment.

1 Exhibit IIIB-49 indicates the accelerated aging
2 as set forth for the lead calcium type batteries being used
3 in this plant, and the vendor is currently embarked on an
4 accelerated aging program in which ten days of operation at a
5 temperature of 160 degrees F is equivalent to one year of
6 operation at the normal temperatures. The project is in
7 agreement with this testing program with the provision that
8 a specific differential voltage be maintained in regard to
9 the positive plate to electrolyte potential between the
10 normal operating condition and the accelerated aging tempera-
11 ture condition to prevent mousing of the plates. The
12 accelerated aging test is much more severe than actual opera-
13 tion at the normal temperatures and the test has to take this
14 into account to provide an acceptable method.

15 Exhibit IIIB-50. Documentation must be provided
16 and the user is to maintain the documentation file. The
17 project is in agreement with these requirements.

18 Exhibit IIIB-51. The recent document IEEE 627 having
19 to do with general qualification requirements for safety-
20 related or safety systems equipment contains information and
21 criteria and requirements very, very similar to IEEE 323.
22 The project is in agreement with the requirements of this
23 document.

24 Exhibit IIIB-52. It shall be demonstrated that the
25 equipment is to operate under all conditions. The project is




1 in agreement.

2 Exhibit IIIB-53, approaches to qualification.
3 Very similar to the requirements in IEEE 323. The project is
4 in agreement.

5 Exhibit IIIB-54. The pressure containment and
6 passive structures are to be handled in regard to various
7 ASME, AISC, or ACI codes to provide for their design. The
8 project is in agreement. Documentation is to be maintained.
9 The project is in agreement with this requirement.

10 Exhibit IIIB-55, having to do with IEEE 650-1979
11 describes methods for compliance with IEEE 323 aimed at
12 static battery chargers and inverters and contains methods
13 for qualification. The project is in agreement with use of
14 such methods and also feels that the 650 document is a
15 reasonable method for providing qualification of other types
16 of equipment or portions of equipment which contain solid
17 state electronic components and other electronic components.

18 Exhibit IIIB-56. The effect of aging is indicated
19 as being insignificant in the 40-year life of a plant for
20 certain types of electronic equipment. The project is in
21 agreement with this position, but requires that stress
22 calculations be provided showing that all such equipment is
23 used well within the manufacturer's ratings and that types
24 of equipment used are either Mil. Spec components or the
25 commercial equivalent of Mil. Spec components using the same



1 materials and processes in manufacture.


2 MR. BINGHAM: Are there any questions?

3 MR. ALLEN: Shelly.

4 MR. FREID: Yes, a few. If we go back to IIIB-19, 24,
5 and 51 through 54, basically the question relates to aging.
6 On 19, you indicate that use of experience alone is discouraged,
7 on 24 you indicate aging must be considered regardless of the
8 qualification method used, and in the discussion on 627, you
9 ignore the test for significance that is in 627 on aging.
10 I guess my question is are you going to do aging on everything
11 or are you going to use the test for aging that is in 627,
12 which for a great number of mechanical components will make
13 aging a nonessential component of the equipment qualification
14 program.

15 MR. CARSON: Aging always must be addressed. It might
16 be that when you address the aging, you find out that it is
17 insignificant, that the material, the piece of equipment, the
18 component does not age under the environmental parameters that
19 exist at its location, and, therefore, even though you have
20 addressed the aging, you found out that it doesn't matter.
21 But aging always must be addressed.

22 With regard to operating experience, we have
23 indicated that operating experience by itself is not considered
24 a reasonable method for qualification primarily on the basis
25 that documentation of operating experience is essentially



1 nonexistent. Very few people have reasonable records and
2 accurate records which will show that the equipment has
3 operated under certain conditions for certain periods of its
4 life which can be applied to the parameters under which we are
5 supposed to qualify this equipment. If someone has minute-
6 by-minute records over a 10, 20, 30, 40-year period which
7 would equal or be more severe than the requirements that we
8 have for a piece of equipment, that documentation when
9 verified could certainly be used as a basis for a qualification
10 program, but we have not seen anything like that.


11 MR. ALLEN: Carter.

12 MR. ROGERS: On Exhibit IIIB-12, when you were reading
13 the definition, you indicated that the electrical penetrations
14 were those that passed IE cables only, and I am not sure that
15 you intended to do that.

16 MR. CARSON: No, that is not correct. The penetrations
17 pass all electric circuits through the containment wall.
18 Some contain Class IE circuitry, some do not contain Class IE
19 circuitry, but in any case, each of the penetrations, no matter
20 what kind of circuitry it contains, must maintain pressure
21 integrity in the containment vessel.

22 MR. ROGERS: So all electrical containment penetrations
23 are subject to these criteria?

24 MR. CARSON: Oh, absolutely. All penetrations must
25 be qualified.




1 MR. ROGERS: Then on Exhibit IIIB-49, there is a figure
2 there that shows accelerated aging and you indicate in that
3 figure a certain number of test days at 160 degrees Fahrenheit
4 is equivalent to one year at 25 degrees centigrade or
5 77 degrees Fahrenheit.

6 MR. CARSON: Yes.

7 MR. ROGERS: In our program, do we correct the tempera-
8 ture, the 25 degrees centigrade or 77 degrees Fahrenheit,
9 to the expected temperature that the component is going to
10 see in the plant.

11 MR. CARSON: We maintain the temperature in the
12 battery rooms in the range which we will show a little bit
13 later in the discussion having to do with environmental
14 parameters in the plant, and this is a method that has been
15 agreed upon as being a method for showing that this equipment
16 will operate for the time period indicated by the qualified
17 life. A margin is applied. Currently, for instance, the
18 vendor who is doing this qualification program for the
19 Palo Verde batteries is using 11 days at 160 degrees of
20 temperature to equal one year rather than 10 days to account
21 for such things as the temperature not being exactly at the
22 77-degree level or for errors or inaccuracies in measurements,
23 or whatever, having to do with the program.

24 MR. ROGERS: I understand you to say then that for
25 these particular batteries, it is expected that the temperature



1 for aging would be at around 77 degrees Fahrenheit.

2 MR. CARSON: Not for aging. Temperature in normal
3 operation.

4 MR. ROGERS: For normal operation for 40 years?

5 MR. CARSON: It would be close in that range, yes,
6 and we will indicate the parameter on a later slide.

7 MR. ROGERS: Thank you.

8 MR. ALLEN: I have one. Bob, isn't it true in our
9 specifications on wire and cable on our flame test requirements
10 that we exceed 383 requirements?

11 MR. CARSON: For the bulk of the electric cables used
12 in the plant, a requirement of 210,000 Btu input, or three
13 times the minimum required by the specifications, is included.
14 For certain types of cable where it is not possible to obtain
15 such a requirement such as a coaxial cable, those are tested
16 to the 70,000 Btu input.

17 MR. ALLEN: Any further questions? George.

18 MR. SLITER: On Exhibit IIIB-13, you say that electric
19 penetration assemblies are now in progress of being tested.
20 Are these penetrations aged and, in the aging program, are
21 they thermally cycled before type testing, and I mean
22 thermally cycled with respect to operational and abnormal
23 conditions.

24 MR. CARSON: Yes. The vendor for these particular
25 types is the Conax Corporation, which supplies penetrations


1 for a number of nuclear power plant applications. They have
2 a continuing qualification program in which they have
3 qualified portions at earlier times, have made modifications
4 to their penetrations for additional requirements for
5 specific plants, they requalify on these bases. They have
6 performed all sorts of type testing having to do with
7 temperature, temperature excursions, short circuit, all of
8 the operational requirements of the penetration, and aging
9 is considered for all the materials used in the penetration.

10 MR. SLITER: So can I take it from your response that
11 this would be one of the types of equipment for which so much
12 has been done in the way of aging and testing that you perhaps
13 would not audit their actual tests for your equipment?

14 MR. CARSON: The equipment qualification programs to
15 be audited have not yet been determined.

16 MR. SLITER: My next question has to do with Exhibit
17 IIIIB-21. In terms of using ongoing qualification programs,
18 could you elaborate on the expression "having an identified
19 qualified life," that is, this identical equipment would have
20 an identified qualified life, and also what types of equipment
21 in the balance of plant have you already identified as having
22 a probable qualified life less than 40 years, some examples
23 of that, please.


24 MR. CARSON: For an ongoing qualification program,
25 an identified qualified life would be, for instance, something



1 that had either been type tested or it had been naturally
2 aged, had been used in a certain application equal or more
3 severe as in the project to a known life. For instance,
4 Foxboro Corporation has embarked on a program of using naturally
5 aged equipment of exactly the same type as will be used for
6 Palo Verde. They have had this equipment in operation in
7 their factories under conditions which are equal or more
8 severe than the project conditions for a period of four years.
9 They have used that equipment, tested it to the various other
10 requirements as applicable to this project, and on that basis
11 have established the qualified life of four years and are
12 currently extending that life to 10 years by additional
13 testing. There are a number of items which have qualified
14 lives indicated by tests of less than 40 years and those
15 equipments will be identified and, as John Allen indicated,
16 provisions made in the maintenance procedures to replace them
17 as required.

18 MR. SLITER: From what you know today, could you give
19 me some more examples of equipment that fall in that category?

20 MR. CARSON: At the present time, batteries, for
21 instance, are indicating a qualified life at the present
22 moment of eight years or so. The testing process is in
23 progress right now. Various gasket or seal materials on
24 certain mechanical equipments have been indicated as having
25 lives of four, five, ten years and would require periodic



1 replacement.

2 MR. SLITER: Another question has to do with Exhibit
3 IIIIB-26. Could you explain, please, what you mean by the
4 expression "type testing should be done in sequence on the
5 same item except if impractical?" Under what circumstances
6 would this be impractical?

7 MR. CARSON: The sequence indicated is to inspect,
8 operate at normal conditions, age, operate under vibration,
9 and such. If the piece of equipment, for instance, is so
10 very large that it is difficult to move it from this location
11 where it has been operated under normal conditions to a testing
12 laboratory to be operated under seismic conditions, we may
13 very well call for it to be operated under normal conditions,
14 aged, apply the DBA to it, and then seismically test it and
15 analyze the situation to show that the aging would not be
16 affected by the DBA or seismic, so that there would be no
17 necessity to do it strictly in the sequence indicated.

18 MR. SLITER: So you are indicating the sequence might
19 change, but it would be on the same item. Maybe the "except
20 as impractical" goes with a given sequence and not with the
21 same item. My point is that the type testing should indeed
22 always be done on the same item so that you would have a
23 cumulative effect, is that not true?


24 MR. CARSON: That may not be the case for certain
25 pieces of equipment. For instance, some manufacturers of

1 electrical equipment such as transformers or relays or
2 circuit breakers with repetitive manufacture of equipment
3 have done type testing on blocks of items and have done aging
4 tests on this group of items and they have done mechanical
5 wear tests on this group of items and they have done various
6 other tests on other groups of items of the same variety and
7 materials, and in that case, they have not specifically done
8 the whole series of tests on exactly the same piece of
9 equipment, but they have done tests on representative samples
10 of that equipment and have taken account of the total testing
11 program.

12 MR. SLITER: In terms of sequence of environments,
13 in the aging process and in the DBA, there are existing
14 various sequences of imposing radiation aging and thermal
15 aging and then thermal and radiation for your design basis
16 accidents. Are you aware of the latest thoughts on the
17 correct sequence of these environments such that it would
18 most closely represent the actual end point of the equipment?

19 MR. CARSON: The normal sequence that we have seen is
20 that equipment has been thermally aged and then has been
21 radiation aged either for a 40-year life period or for 40 years
22 plus DBA radiation all at one time prior to vibration,
23 mechanical aging, seismic, and then the application of the
24 actual design basis event.

25 MR. SLITER: I would like to point out for your



1 information that a recent study at Sandia in their qualifica-
2 tion testing evaluation program has uncovered some new data
3 on certain materials that point to the fact that the sequence
4 of environments is important and that for certain materials
5 you may want to alter your test plans based on their findings
6 on which sequence to put radiation and then thermal aging.

7 MR. CARSON: That will certainly be investigated.

8 MR. BINGHAM: Could we ask that that document be made
9 available, John?

10 MR. ALLEN: Certainly. Let's put that down as an
11 open item. We'll get that document.


12 MR. SLITER: That is the document that we discussed
13 back at the last EPRI meeting. It is one of the many documents
14 discussed. If you don't have it, I can make it available.

15 MR. ALLEN: Any more questions? I think, Ed, you had
16 one.

17 MR. STERLING: No, George asked my question, but I did
18 want to elaborate on just one point. On synergism, how are
19 we handling synergism in this sequence of events?

20 MR. CARSON: Synergistic effects as far as we know
21 received very little play in the testing programs principally
22 because it is so extremely difficult to apply temperature,
23 radiation, humidity, and all these other things at exactly the
24 same time except for certain items like electric cable.

25 MR. STERLING: I know there is some feeling that that.



1 is an important point. Are we going to have an analysis that
2 would show that there is no effect of synergism or how are we
3 going to deal with a resolution of the matter as far as
4 synergistic discounting.

5 MR. CARSON: Synergistic effects will be investigated.

6 MR. ALLEN: Is that all you had on that, Ed?

7 MR. STERLING: Yes.


8 MR. ALLEN: Norm.

9 MR. HOEFERT: I would like to know how the beginning
10 of a qualified life is determined for the different equipment:
11 If it is qualified for 40 years, when does the clock start for
12 that piece of equipment? When it is manufactured, when it
13 is installed, or when it is put in service?

14 MR. CARSON: The clock would start when the equipment
15 is installed as long as the storage prior to installation has
16 been in accordance with the manufacturer's recommendations
17 and the storage temperatures and other environmental conditions
18 are shown to not be detrimental to the equipment; that is,
19 not age the equipment unduly during that storage period.

20 MR. HOEFERT: Is that being done? Are there documents
21 from vendors which say that it is being stored under certain
22 conditions that don't affect its life?

23 MR. CARSON: Specifications for each item of equipment
24 require that the vendor specify storage condition for short
25 term up to six-month and for long-term more than six-month



1 periods and they must specify to us any special storage
2 conditions that must apply, humidity, temperature, whatever.

3 MR. HOEFERT: Would this apply to spare parts as well?
4 I am thinking of things that may be in the warehouse for many
5 years.

6 MR. CARSON: Yes, spare parts storage conditions are
7 required to be specified.

8 MR. ALLEN: John Barrow.


9 MR. BARROW: If the qualification period is considered
10 to start at the time of installation and the equipment is
11 installed a year and one-half before the unit goes into
12 commercial operation, does that mean that the equipment is
13 only qualified for 38½ years of plant operation?

14 MR. BINGHAM: The answer to your question is it is
15 qualified for 38 years of commercial operation.

16 MR. BARROW: Then at the end of that 38 years, you
17 would have to consider requalifying it for several years?

18 MR. BINGHAM: Perhaps.

19 MR. BARROW: The reason I asked the question was it
20 is conceivable that the equipment could be installed prior to
21 commercial operation but energized only sporadically and at
22 very low energy levels or something so that it would not see
23 its normal operating parameters until such time as it went
24 commercial. For the most part, it would be shut down except
25 during testing intervals and, consequently, you could make the



1 qualification interval not start until commercial operation.

2 MR. ALLEN: I had one question. We indicated that
3 IEEE 627 is just now being looked at. However, my memory
4 serves me that in the pump and valve operability tests, some
5 of those requirements are very similar and that was already
6 placed into the specifications. Isn't that correct?

7 MR. CARSON: That's correct.

8 MR. ALLEN: So, in a way, we have already imposed
9 some of those requirements of 627 in our early specifications.

10 MR. CARSON: That's correct, and, as indicated earlier
11 in regard to the Standard Review Plan that the principles and
12 criteria of 323 were applicable to all types of safety-related
13 equipment, all of the vendors for equipment for this project
14 have been contacted and asked to respond in regard to the
15 methods and criteria of 323, and, as indicated, that is the
16 basis of a series of meetings that have been held and are
17 being held with the several vendors to obtain such information.

18 MR. ALLEN: John.


19 MR. ROEDEL: Could I go back to the storage requirements
20 that we requested from the vendors for electrical equipment?
21 Do you feel that these storage requirements have in fact
22 considered environmental requirements relative to aging in
23 all cases or do we need to go back and look at some of the
24 equipment that has been on site for some time to assure
25 ourselves that the storage requirements we have from that

1 vendor in fact do address those items because we have had
2 those on the site for some time when we hadn't even started
3 the testing for qualification.

4 MR. BINGHAM: That's a good point, John. We have been
5 aware of that for not only this type of equipment, but other
6 equipment because of warranty problems that we see. I think
7 in general we are in relatively good shape. Of course, we
8 do recognize that we need to take a look at some of the
9 equipment to make sure that storage was adequate.

10 MR. ALLEN: Any questions? Karl.

11 MR. KREUTZIGER: With relationship to the storage or
12 qualified life again of equipment that has been installed in
13 the plant for a period of years prior to operation, is not the
14 qualification program based on design conditions which far
15 exceed that of normal operation? For example, electrical
16 insulation material is based upon an aging process of 90 degrees
17 C conductor temperature for the duration of the plant's life.
18 Other insulation materials are the same. Is this not
19 considered as a method in which to extend qualification beyond
20 the original qualified life and are there any plans to monitor
21 the environment in the Palo Verde Power Plant over the 35 or
22 40-year life in order to see that there are design margins
23 or actual conditions are considerably less than the design
24 basis conditions as a method to extend some of this qualified
25 life for whatever the additional storage years might be.




1 MR. CARSON: In regard to installation of equipment
2 and temperatures, we are aware of some plants in which
3 continuous monitoring equipment will be installed in various
4 areas where safety-related equipment is in place and the
5 time duration of temperatures will be used either to extend
6 or reduce qualified life. That method will be investigated
7 with APS.

8 MR. ALLEN: Shelly, did you have your hand up?

9 MR. FREID: Karl essentially asked my question, but I
10 would like to carry it a little further. In general, most
11 equipment does not operate at a design condition. There is
12 an operating condition which is generally much less than the
13 design condition. Inherently, you would expect that what you
14 would consider a qualified life in terms of that type of
15 aging has got to be very conservative and have lots of margin
16 in it. It seems to me that it would be intuitively obvious
17 in almost all cases that -- You know, the difference between
18 38½ years and 40 years is insignificant.

19 MR. BINGHAM: We agree, Shelly, that that is the case.
20 However, we are trying to respond to particular questions.
21 You are quite right, there is conservatism in it, and I am
22 sure that that is what will be used at the time you intend to
23 extend the life of the equipment, but at the present time,
24 what we are trying to do is to start with a qualified life,
25 whatever it might be, and then to indicate the parameters on



1 which it is based, and then I am sure there will be subsequent
2 programs that will be developed by APS to monitor in order to
3 assess how they might extend the qualified life at a later
4 date.

5 MR. KREUTZIGER: I would like to also add that I think
6 that I heard you say the reason the ongoing qualification was
7 discouraged was because of lack of documentation. I thought,
8 also, I heard -- this was something which kind of surprised
9 me -- that there was no minute-by-minute recording of
10 conditions. I would think that for the long term,
11 if that is the project's position, that it would be almost
12 imperative to provide in some areas temperature monitoring where
13 there might be a question about extending qualified life. A program that
14 determines what are your basic measurements would be useful if that is the
15 criterion that prevents you from using operating experience.


16 MR. BINGHAM: John, we are going to be considering that
17 point in our reviews with APS and I would expect that you want
18 to have that as an issue to respond to to the board.

19 MR. ALLEN: That's correct. I think it also was an open
20 issue that was addressed at the PVNGS Units 4 and 5 hearings,
21 too, regarding monitoring.

22 MR. BINGHAM: That's right.

23 MR. ALLEN: So if we could ask Terry to record that.

24 MR. QUAN: Could we have that rephrased by Karl so we
25 could get it down?



1 MR. KREUTZIGER: My concern was the utilization of
2 the method of ongoing qualification and the fact that the
3 project has discouraged as a general criterion its use. The
4 basis was the lack of documented evidence of what the prior
5 environmental conditions were, and the question was I would
6 take those two statements and conclude that in order to look
7 at this plant operating many years in the future it would be
8 advisable to seriously consider an environmental monitoring
9 system so that 10 or 15 or 20 years down the road you are not
10 faced with the dilemma of looking at something and saying,
11 "I do not know what the environment has been over this period
12 of time."

13 MR. QUAN: Okay, fine.

14 MR. ALLEN: Pete, I think you had a question.

15 MR. NEWCOMB: You have discussed impacts in some detail
16 as regards thermal and radiation aging. Could you discuss
17 your position regarding the effects long term of either high
18 or low humidity, or both, on the equipment under discussion.

19 MR. ALLEN: Off the record for a second. Why don't we
20 take a break.

21 MR. BINGHAM: Could I get that question repeated again,
22 I want to make sure we respond to it correctly, before you go
23 off the record?

24 MR. ALLEN: Do you want to repeat the question, please?

25 MR. NEWCOMB: The question is how do you, if at all,

1 respond to the conditions of long term high or low humidity,
2 or both, on the equipment that you are talking about here, the
3 long term aging effects due to humidity.

4 MR. ALLEN: Why don't we take about a 15-minute break.

5 (Thereupon a brief recess was taken, after which
6 proceedings were resumed as follows:)

7 MR. ALLEN: Are there any more questions on the last
8 subject matter before we proceed?


9 MR. STERLING: We haven't got the answer.

10 MR. BINGHAM: Humidity I believe was the question.

11 MR. ALLEN: That's right, back to humidity.

12 MR. CARSON: In regard to humidity, humidity certainly
13 is considered in the design of all these equipments.
14 Environmental parameters provided in the specification for
15 each item of equipment indicate the range of humidity under
16 which it is to operate and the vendors take this into account
17 in their design, and we make sure that items of equipment or
18 specifically materials that would be hydroscopic are not
19 included and that equipment that might be susceptible to
20 failure due to humidity or tracking due to moisture on surfaces,
21 terminal block spacing, electrical equipment spacing, or
22 terminal spacing within the equipment, is such that humidity
23 would not be a problem.

24 MR. NEWCOMB: One more follow-up. How does that
25 address the question more specifically of humidity aging as in



1 thermal aging?

2 MR. CARSON: We know of no method to do humidity
3 aging other than such things as spray tests or maintaining a
4 pool of water in the bottom of a test chamber when something
5 is being tested for temperature effects where the humidity
6 would be very high in that area.


7 MR. BINGHAM: John, are there any other questions?

8 MR. SLITER: On Exhibit III B-25, the Palo Verde position
9 is that Arrhenius methodology is considered an acceptable
10 method of addressing accelerated aging, but other methods are
11 possible. What are some of these other methods and is the
12 10-degree-C rule, for example, one of these methods and would
13 consider that acceptable?

14 MR. CARSON: The project endorses the Arrhenius
15 methodology in conjunction with the NRC's endorsement of the
16 same methodology as indicated in NUREG 0588. The 10-degree
17 rule as such was and is a primary electrical industry use of
18 an Arrhenius type methodology, and the project position is
19 that the indiscriminate use of that 10-degree-C rule of thumb
20 is not accepted without justification that in fact the
21 equipment does exhibit a 10-degree rule as indicated by an
22 Arrhenius plot.

23 MR. SLITER: Then other methods?

24 MR. CARSON: Other methods which might be acceptable
25 would be the TGA method or others that have been discussed,



1 but we have not as yet seen any vendor who has suggested
2 other methods than Arrhenius.


3 MR. SLITER: Thank you.

4 MR. ALLEN: Bob, as a follow-up on that, how about
5 Mil. Handbook 217? What is the project's position on the use
6 of it and its data?

7 MR. CARSON: Mil. Handbook 217 has to do primarily
8 with electronic type components and has been put together
9 through extensive data gathering by military systems oriented
10 companies, NASA, the Air Force, Bell Laboratories, various
11 other people, and has to do with factors of stress and
12 derating factors for various types of electronic components.
13 As indicated in the discussion of IEEE 650, the project's
14 position is that data from Mil. Handbook 217 would be
15 applicable to discussions of electronic equipment as long as
16 the equipment items used are in fact identical to those for
17 which the data in the handbook has been prepared or, as
18 indicated in the 650 document, are the commercial equivalent
19 of such Mil. standard components using the same materials and
20 the same manufacturing processes.

21 MR. ALLEN: Are there further questions by the board?

22 DR. ROSZTOCZY: Could we have Exhibit IIIB-13? We
23 have criticized various things here today and I think we
24 ought to give credit when it is appropriate. If you look at
25 this slide, the right-hand side, the position side, of this



1 slide is one of the better ones in the whole package. It
2 gives certain information to the reader. If I take Item 2)
3 as an example, then there are two pieces of information that
4 one learns from this. One of them is how it is going to be
5 enforced by saying you are going to enforce it through your
6 specifications. Every possible requirement we will have in
7 the specifications. The second piece of information given
8 there is where you stand right now as the testing is in
9 progress. In the cases where you are going to revise the
10 entries in this column, you can probably use this as an
11 example, and if you would provide the equivalent of these two
12 pieces of information, namely, how do you enforce it and where
13 do you stand with it, I think it will be very useful.

14 MR. CARSON: That information can be provided.

15 MR. ALLEN: Could I just ask could that be an item
16 to provide that information?


17 MR. QUAN: It would be part of the previous item. We
18 had an item to correct the slides which state "in compliance"
19 to wording which is appropriate.

20 MR. ALLEN: We will just add to use IIIB-13 as a guide.

21 MR. QUAN: As a guide, right.

22 MR. ALLEN: Do you have another question?

23 DR. ROSZTOCZY: Yes. Exhibit IIIB-23. In the right-
24 hand side column, there is a statement which says, "Proprietary
25 data may require audit in supplier's facility." I am aware of



1 this type of problems in the past and I was under the
2 impression that most of those have been resolved. There is
3 maybe one possibly outstanding at the present time, but that
4 would not affect you because of your water reactors. What
5 is the purpose for the sentence here? Do you have any
6 problems of this sort at the present time? Do you have any
7 supplier who is not willing to give you the proprietary
8 reports or test reports or whatever it is?

9 MR. CARSON: We are going to be covering that
10 particular item in our discussion of problems later in the
11 presentation, but, yes, we have had and are having problems
12 with vendors who refuse to supply data but will allow us to
13 audit. One case in point is the General Electric Company,
14 of San Jose, in qualification of motors. They have refused to
15 provide us with the specific data on which their qualifica-
16 tion is based. We know what the data is. It has been
17 identified for us specifically and we have audited that data
18 at their facility to determine that the data was in fact
19 applicable to the qualification and did correctly reflect the
20 positions taken in their qualification documents, but we are
21 not able to get that data. GE is not the only vendor for
22 which that situation exists.

23 DR. ROSZTOCZY: You do have other vendors, also?

24 MR. CARSON: Yes.

25 DR. ROSZTOCZY: GE is the one that I was formerly

1 aware of. I didn't know that you had components from them,
2 so that's why I said --


3 MR. CARSON: Westinghouse is another one.

4 DR. ROSZTOCZY: I suppose that has been resolved and
5 now they are complying.

6 MR. CARSON: We have had no such indication. We are
7 constantly asking them to provide this information. We have
8 had meetings with the vendors and they have flatly refused in
9 many cases to provide the data, and we have in fact asked
10 them to specifically identify the data so that it can be
11 audited by the NRC or by others who have a need to know.

12 MR. ALLEN: Do you have a further question?

13 DR. ROSZTOCZY: Yes. Exhibit IIIB-36. The requirement
14 talks about the single-failure criterion. The single-failure
15 criterion in itself is very complex. It is very complex
16 because it requires that you consider that, depending on what
17 is the purpose of your evaluation, the first single failure is
18 different. For example, if you are looking at the consequences
19 of a condenser cooler accident and if you are concerned about
20 the containment overpressurization, then you find the certain
21 single failure that gave you the worst or the highest contain-
22 ment pressure. If you are dealing with the very same accident,
23 but you ask the question whether the core is protected, then
24 you find that another failure is limiting in that sense that
25 gives the worst condition in terms of water level in the core



1 or whatever you are interested in. When we get to equipment
2 qualification, it becomes a lot more complex. There are many
3 different equipments and those equipments are being used for
4 different cases. Could you describe for me at least briefly
5 how do you use the single failure criterion for equipment
6 qualification? Could you explain it through an example?
7 For example, how did you select the single failure for
8 limiting the chemical environment and what single failure you
9 ended up with, which other ones did you consider?

10 MR. BINGHAM: John, we seem to have not quite a
11 unanimous approach on the answer that we want to give, so
12 what I would request is that at the next break, we will
13 caucus and come back with a correct example responding to the
14 particular question you had.

15 MR. ALLEN: Do you have that down, Terry?

16 MR. QUAN: Dr. Rosztoczy; could you repeat that
17 question?

18 DR. ROSZTOCZY: Let me just phrase the question in
19 brief terms and ask an explanation for it. I would like to
20 know how do you apply the single-failure criterion for
21 equipment qualification in general terms and then I would
22 like you to take an example and illustrate through this
23 example the application of the single-failure criterion. I
24 am suggesting as an example the selection of the single
25 failure for predicting the chemical environment. What

1 failures did you consider to predict what kind of chemicals
2 could come into the plant through the spray system or by
3 other means?

4 MR. ALLEN: Do you have additional questions?

5 DR. ROSZTOCZY: Yes. Exhibit IIIB-43. At the time
6 when this slide was presented, it was mentioned that this is
7 a case which will be done by the combination method. Earlier
8 today when I asked the question if there is any case where
9 you have already decided to use anything but the preferred
10 mode, which was type testing, the answer was you haven't
11 arrived at such a decision yet. If this is being done by
12 combination, then those two answers don't completely jibe, so
13 somewhere along the line, I would like to have an explanation.

14 MR. BINGHAM: Okay, we will provide that.

15 MR. ALLEN: I believe that is coming up in your
16 presentation.

17 MR. BINGHAM: Yes.


18 DR. ROSZTOCZY: That was my last question.

19 MR. ALLEN: Vince, I think you raised your hand a while
20 ago. You had a question?

21 MR. NOONAN: He already covered it.

22 MR. ALLEN: Are there further questions?

23 I have one question regarding qualification programs.
24 I think I know the answer before I ask the question, but I'll
25 ask it anyway. It is not project policy to accept



1 certification of qualification data, is that correct? In
2 other words, a vendor cannot send us a certification that
3 says, "I certify that this is qualified to your spec."

4 MR. CARSON: A certificate of certification by itself
5 is not acceptable. We require that the actual documentation
6 be provided.

7 MR. ALLEN: If no further questions, you can continue,
8 Bill.

9 MR. BINGHAM: We will now present Section B.4.,
10 equipment environmental qualifications, regulatory guides.

11 MR. CARSON: Another set of criteria having to do
12 with qualification, as indicated in the Standard Review Plan,
13 has to do with several NRC Regulatory Guides which provide
14 interpretation of various IEEE standards. Exhibit IIIB-57
15 has to do with Reg. Guide 1.32 in relation to IEEE 308 having
16 to do with Class IE electric systems for the plant. The
17 project concurs with the requirements of Reg. Guide 1.32 and
18 the equipment is qualified for the operational requirements
19 indicated.

20 Exhibit IIIB-58. Reg. Guide 1.40 has to do with
21 IEEE 334-1971, specifically for continuous duty motors inside
22 the containment. This Reg. Guide is not applicable for
23 BOP equipment, since no safety-related BOP machines are
24 provided inside the containment.

25 Exhibit IIIB-59, Reg. Guide 1.53, application of


1 single-failure criterion. Qualification requirements of
2 IEEE 379-1972 to be met. The project is in agreement with
3 that requirement.

4 Exhibit IIIB-60, Reg. Guide 1.63 having to do with
5 IEEE 317 covering electrical penetrations. The Reg. Guide
6 gives some guidance in terms of certain tests and values
7 which are to be used in the qualification program. The
8 project is in agreement with these requirements.

9 Exhibit IIIB-61, additional requirements for
10 electric penetrations. The project is in agreement. There
11 is an open item having to do with electric penetrations which
12 came up at the AC system review which is being studied and
13 response will be made at a later date.

14 Exhibit IIIB-62, Reg. Guide 1.73 having to do with
15 IEEE 382 covering electric valve operators used for valve
16 and various other equipment indicating that the auxiliary
17 equipment having to do with the valve is also to be qualified.
18 The project is in agreement with this requirement and equipment
19 suppliers are being required to qualify the entire equipment
20 for its use. Test sequence is to be used. The position
21 stated the project agrees with.

22 Exhibit IIIB-63 continues the discussion of Reg.
23 Guide 1.73 having to do with testing of valve operators and
24 the radiological source term which is to be used in accordance
25 with Reg. Guide 1.7. The project is in agreement with these




1 positions and the effect of Beta radiations is under review
2 for organic materials.

3 Exhibit IIIB-64, Reg. Guide 1.89, clarification of
4 Reg. Guide 323-1974 having to do with radiological source
5 terms and applicability of IEEE Standard 344 for seismic
6 testing. The equipment is being qualified in accordance
7 with the requirements of 1.89 with the exception that equip-
8 ment that had been seismically qualified prior to aging on
9 some of the older programs is being reevaluated to see that
10 aging will not cause a problem or will not have problems
11 caused by subsequent application of seismic events. This may
12 require some retesting.

13 Exhibit IIIB-65, again on Reg. Guide 1.89. The use
14 of thermal and vibrational techniques are difficult to apply
15 and are not valid or practical for many type tests. The
16 project agrees with the requirements of 1.89.

17 Exhibit IIIB-66, Reg. Guide 1.131 having to do with
18 IEEE Standard 383 for electric wire and cables. All design
19 basis events are to be considered, environmental service conditions
20 are to envelope plant specific conditions, and ongoing qualifica-
21 tion programs are to be used as a possibility for qualification.
22 The project is in agreement with the requirements and, as
23 indicated before, use of an ongoing program is discouraged.
24 All electric cable used in the project has been qualified
25 by type testing.



1 MR. BINGHAM: Are there any questions on the Reg.
2 Guides?


3 MR. ALLEN: Ed Sterling.

4 MR. STERLING: On Exhibit IIIB-64, and maybe Vince can
5 help me out on this, at the regional meeting in Dallas on
6 qualification, a question was raised by a gentleman from
7 SMUD that the source term calculations that were addressed
8 in 0588 were in conflict with the source term calculations
9 called for on the TMI lessons learned, and I guess my question
10 is what source terms are we using for Palo Verde, and I don't
11 have the answer to that question that the SMUD gentleman
12 asked.

13 Vince, you said you had those lists of questions.
14 If it has been determined, maybe you can shed some light on
15 what source terms were the ones that were applicable or the
16 most severe.

17 MR. NOONAN: I have a list of the questions, but I
18 think Dr. Rosztoczy can answer it very clearly.

19 DR. ROSZTOCZY: Basically, the question was raised.
20 what are the requirements for the use of source terms to
21 predict how much radiation a certain equipment is exposed to.
22 The basic ground rule is very simple. When you start to
23 apply it, it becomes a little bit more complex. The ground
24 rule is that following an accident, there are two possibilities.
25 One possibility is that you blow almost everything from the



1 primary system out into the containment, and in that case,
2 the activity is mainly in the containment. Another possibility
3 is that you have some core damage, but you terminate the
4 blow damage to the containment, so most of the activity stays
5 in the water in the coolant system and is being recirculated
6 in the system. The basic ground rule is you have to be
7 covered for both of these events, so when you look at a given
8 piece of equipment, then you have to ask the question how
9 much radiation would this equipment have if the activity was
10 blown into the containment and you have to ask the question
11 how much radiation would this equipment have if the activity
12 stayed within the coolant loops, including the RHR system.
13 Whichever gives the higher result, you have to qualify to
14 that value. Normally, the equipment within the containment
15 gets the higher dose if the activity was blown into the
16 containment. There could be some exceptions. If some equip-
17 ment is installed on the coolant loops or is very close to it,
18 it might get the higher dose when the activity stays in. When
19 you are talking about the equipment that is outside contain-
20 ment, then normally the second one is more limiting; namely,
21 the proximity of the coolant loop is what determines the
22 radiation rather than what is in the containment. You have
23 to be covered for both cases. The question then is have you
24 done this and, if you haven't, then we certainly would like
25 to bring it to your attention to do it.

1 There was some reference here or questions asked
2 at the regional meeting and responses to them. At the time
3 of the regional meetings, we promised that these would be
4 provided to all parties involved, including the utilities,
5 in written form. We have written up some of the most
6 important questions, we have provided written answers for
7 them, and those are presently being mailed out. I believe
8 they started to mail them out today. Somewhere in the very
9 near future, you are going to receive them in written form.
10 This was one of the questions and, basically, the same
11 answer what I gave you is in written form in that package.

12 MR. ALLEN: Additional questions?

13 MR. NOONAN: Yes.

14 MR. STERLING: We didn't get an answer.

15 MR. ALLEN: Bill, anything else to add to it?

16 MR. BINGHAM: As I understand, the question was have
17 we considered it. We are considering it. We have had
18 discussions with Dr. Rosztoczy on this very point and we are
19 looking at it to make sure that we have used the correct dose
20 for the limits.

21 MR. ALLEN: Anything else?

22 MR. NOONAN: On the same exhibit, IIIB-64, Part A here,
23 I wonder if you could walk me through that. I am not quite
24 sure what you are telling me here regarding the aging and the
25 seismic qualification question. Could you just briefly
describe your answer on Part A, just what you are talking

1 about.

2 MR. CARSON: We are addressing equipment that may have
3 been seismically qualified prior to an aging mechanism being
4 applied and indicating that for such equipment, aging is to
5 be considered to determine by analysis, if possible, that the
6 aging would not have resulted in a failure of such equipment
7 in the event that the aging had been accomplished prior to
8 seismic events. If no successful analysis can be made in
9 that regard, that is, if aging cannot be shown to be non-
10 existent or insignificant and, therefore, not affected by
11 seismic activity, as indicated, some additional supplemental
12 tests may be required.

13 MR. NOONAN: I guess as a personal opinion if you could
14 show that aging has no effect on equipment, then you are
15 probably in pretty good shape. If you cannot show that, then
16 I don't see how you can possibly do anything by analysis.


17 MR. CARSON: That is what we are indicating. If it
18 cannot be shown that aging is nonexistent for the material,
19 we would require additional testing to confirm the qualifica-
20 tion of the equipment.

21 MR. NOONAN: Okay, I understand. Thank you.

22 MR. ALLEN: Any further questions?

23 Seeing none, would you like to continue, Bill?

24 MR. BINGHAM: We next would like to cover under
25 Section B, Environmental Qualification Criteria, Items 5, 6,



1 7, and 8. That would be on Enclosure ii, Item 5, NUREG 0588,
2 Item 6, Commission Order CLI 80-21, Item 7, IE Bulletin 79-01B,
3 Item 8, 10CFR50 Appendix B. At that time, we will entertain
4 questions, John.

5 MR. CARSON: Exhibit IIIB-68 has to do with NRC NUREG
6 0588, which was issued earlier in 1980, and covers positions
7 which are involved with safety-related electrical equipment
8 specifically. The positions are applicable to plants in the
9 operating license stage, which is the PVNGS situation, and
10 indicates that the requirements set forth must comply with
11 one of two versions of 323, either the '71 or '74 version.
12 Because of the date of the construction permit for this
13 project in 1976, the requirements of 323-74 must be handled,
14 and those are covered in Category 1 of the NUREG. As indicated,
15 TMI type recommendations have not been addressed in this
16 document. The positions provide guidance for use in determin-
17 ing service conditions for qualification. Seismic qualifica-
18 tion is not covered. Equipment refers to safety-related
19 electrical equipment only. As indicated, PVNGS must conform
20 with Category 1 having to do with Item 323-74. As indicated
21 earlier, that is the basic document for qualification on this
22 project.

23 Exhibit IIIB-69. Calculations having to do with
24 temperature and pressure should use one of the computer codes
25 indicated. The project uses the COPATTA Code. Main steam

1 line breaks are to be calculated from plant specific model.
2 Plant specific parameters have been used. Chemical sprays
3 are to be addressed inside containment. The project addresses
4 chemical sprays in qualification of balance of plant equipment
5 located in the containment. Radiation environment should be
6 based on normal environment plus that associated with the accident,
7 and the project complies. As Dr. Rosztoczy just mentioned,
8 there is further guidance being indicated as to source terms
9 to be used.


10 Exhibit IIIB-70. Type testing is preferred and
11 it is indicated that type testing is essentially the only
12 method of qualification which will be accepted for any
13 equipment inside containment. The project is in agreement
14 with this method of qualification for in-containment equipment.
15 Temperatures are to be defined on or very near the surface
16 of the equipment being qualified by use of thermocouples,
17 The project indicates that separation precludes the failure
18 of redundant equipment, and the determination of temperature
19 on the surface of equipment is under study at this time.
20 Equipment that is required to operate within seconds or minutes
21 of the imposition of a design basis event, is called to
22 operate for at least one hour in addition to the actual
23 operating time. That requirement is under review. Aging
24 effects are to be considered. All of the qualification
25 programs for the project consider aging. The Arrhenius

1 methodology is considered an acceptable method of addressing
2 aging. The project agrees with that provision.

3 This is Exhibit IIIB-71. Periodic surveillance
4 testing under normal service conditions for ongoing qualifica-
5 tion, as indicated earlier, is discouraged as a principal or
6 prime method of qualification and, if used, is only endorsed
7 on the project using equipment which has some previously
8 demonstrated qualified life. Documentation requirements of
9 323-1974 are considered adequate. Documentation in accordance
10 with that standard is required for all programs. The
11 additional information required from Appendix E of the
12 0588 document has been worked into Table 3E-2 of the FSAR
13 and will be presented in a later amendment to that document.

14 Exhibit IIIB-72. Commission Order CLI-80-21 was
15 issued in late May of 1980 and has to do with operating
16 plants. At the workshops which were mentioned earlier by
17 Mr. Noonan and Dr. Rosztoczy, certain information having to
18 do with operating licensed plants, primarily the timetable for
19 review of qualification information, was given. The project
20 is using the requirements of 0588 in terms of qualification
21 programs and will follow the guidance of Category I of that
22 0588 document.

23 Exhibit IIIB-73. IE Bulletin 79-01B was issued
24 in early 1980 and has to do specifically with qualification
25 of the electrical safety-related equipment in operating



1 plants. It indicates that 0588 is to be used for operating
2 plants. It is indicated, also, for plants in the OL stages.
3 The FSAR service conditions are to be reviewed. The project
4 has reviewed all design basis accident conditions and these
5 are stated for equipment qualification programs. Beta and
6 Gamma radiation are to be considered and the 79-01B document
7 indicates that Beta doses less than 10% of Gamma doses need
8 not be further considered. Gamma doses are being investigated
9 and, as indicated, the FSAR reflects the TID 14844 sources.


10 Exhibit IIIB-74. Beta doses have not yet been
11 included in the FSAR. Effects of Betas are being reviewed
12 in relation to organic materials. Submergence is to be
13 addressed in regard to safety-related electrical equipment.
14 In the project, all safety-related electrical equipment has
15 been located such that it is not subjected to submergence.
16 Spray chemistry is to be addressed. Spray chemistry is
17 addressed in the design basis accident parameters.

18 Exhibit IIIB-75 having to do with 10 CFR 50
19 Appendix B, quality assurance criteria. The project maintains
20 a quality assurance program and fully meets the requirements
21 of Appendix B.

22 MR. BINGHAM: Are there any questions, John, at this
23 time?

24 MR. ALLEN: Ed Sterling.

25 MR. STERLING: Back on Exhibit IIIB-69, the radiation



1 environment. Part of that was the 10 to the fourth cutoff
2 limit for neglect of radiation. How has that been addressed?


3 MR. CARSON: We have indicated in the environmental
4 designators for the plant areas which are reflected in the
5 specifications the anticipated and calculated radiation
6 dosage for the areas in which the equipment is located. If
7 the area indicates doses less than 10 to the fourth, that is
8 indicated to the vendor and the vendor must respond to what-
9 ever doses are indicated in the specifications.

10 MR. STERLING: So you are not neglecting them?

11 MR. CARSON: We are not neglecting radiation. The
12 vendor may tell us that for materials in his equipment that
13 10 to the fourth or some other value of radiation is no
14 problem, but he must address the radiation specified.

15 MR. STERLING: Another question on the next exhibit,
16 IIIB-70, the second item. You talk about the temperature of
17 the thermocouple readings on or near the equipment surface,
18 and I have gone back. As you did in the previous exhibits,
19 this separation precludes failure. If you are qualifying to
20 have equipment not fail at all, not necessarily have one
21 fail and then, because another one is not in the same
22 environment, it would continue operating, you still have not
23 protected that piece of equipment from failure due to the
24 localized environment.

25 MR. CARSON: As we indicated, we are reinvestigating




1 temperatures to see if the programs that have been completed
2 or are in process can provide us with information specifically
3 on surface temperature and the type of equipment is being
4 analyzed on the basis of thermal mass and temperature gradient
5 to see if high temperatures for short periods of time will
6 affect such equipment.

7 MR. STERLING: I have one more question on Exhibit
8 IIIIB-74 on submergence. You have indicated that you are going
9 to locate electrical equipment above the flood level. Have
10 you also looked into localized submergence, something that
11 is not below the flood level, but due to sprayage might be
12 covered.

13 MR. BINGHAM: I think we will have Dennis Keith
14 respond to that particular question.

15 MR. KEITH: Let me just tie this in with the previous
16 question, also. Let me just add a little bit on that, because
17 it is my understanding that the concern about having the
18 thermocouples reading at the surface temperature is a
19 steam jet impingement concern, a steam jet impinging directly
20 on the piece of equipment. We do a high energy line break
21 analysis throughout the power block, and this also includes
22 moderate energy line breaks where the concern is flooding.
23 You can have certain failures. You can still take a single
24 failure and shut the plant down safely, so as part of that
25 analysis, we look at jet impingement, flooding



1 and all the effects from the pipe break, and that analysis
2 is very well along, as you know. We have not identified
3 anything that we cannot -- we either protect it from the
4 pipe break or, based on the equipment's function, we can
5 let it fail, and we have not identified anything where we
6 have had to environmentally qualify it for the effects of
7 jet impingement or submergence.

8 MR. BINGHAM: Thank you, Dennis.

9 Any other questions, John?

10 MR. ALLEN: Any further questions? George.


11 MR. SLITER: One of the requirements of NUREG 0588
12 that you did not highlight in your exhibits concerns
13 synergistic effects. You already said earlier in the proceed-
14 ing that synergistic effects will be considered. However,
15 0588 goes on to say investigation should be performed to
16 assure that no known synergistic effects have been identified
17 on materials that are included in the equipment being
18 qualified. What is your intended approach at this investiga-
19 tion? What is your interpretation of that?

20 MR. BINGHAM: That is still under review.

21 That could be an open item, John.

22 MR. ALLEN: Fine. Let's make that an open item to
23 determine how we are going to go about investigating the
24 synergistic effects.

25 MR. SLITER: Also, may I make the comment that NUREG




1 0588 is still out for comments and will be published in final
2 form at an early date, I understand.

3 DR. ROSZTOCZY: I would like to comment on that.
4 NUREG 0588 was issued in December of 1979 in a draft form.
5 Later on, through the Commission order issued May 23, 1980,
6 the draft version has been accepted by the Commission as an
7 interim requirement until a more permanent rule can be
8 generated through the normal rulemaking process. So the
9 draft version of NUREG 0588, which is presently the require-
10 ment, is the one that you have to work with until some new
11 regulation comes out. The new rule will be generated through
12 the normal rulemaking process, which will invite comments
13 from industry as well as anybody else. This process normally
14 takes a few years, so we don't expect that to be finished
15 earlier than maybe 1983 or so. In the meantime, it is
16 possible that we will reissue the NUREG, but we will not
17 change the requirements. The draft version is the required
18 version.

19 MR. ALLEN: Vince, you had a question?

20 MR. NOONAN: More of a comment. I guess it is really
21 not addressed to Bechtel, but it is addressed mostly to
22 Arizona Power. If you go back to your Exhibit IIIB-67,
23 Items 5, 6, and 7, which are addressing flame resistance,
24 fire tests, et cetera, if you have been following the recent
25 proceedings that are going on in the Commission in the




1 licensing of one of the plants, the question of hydrogen
2 burn has been raised. While it is more serious in certain
3 types of plants than it is in other types of plants, it is
4 getting quite a bit of Commission attention and the staff
5 has been asked to address the hydrogen burn question as it
6 affects equipment qualification. We are working on that
7 right now. It is not a requirement being placed on the
8 utilities at this point in time, but I think it would behoove
9 you to follow closely those proceedings to see what is being
10 done and what kind of requirements may fall out of that thing.
11 Since you are talking about two years to go before you load
12 fuel, you might be getting additional requirements in this
13 area, so I think it would be wise that you pay close attention
14 to the work that is being done back there in Washington on
15 this item and the types of questions that are being asked.

16 MR. ALLEN: Fine. Thank you.

17 Any additional questions?

18 MR. LaGOW: On IIIB-69, Item 2, you note for the main
19 steam line break that you are using plant specific parameters
20 to compute, I guess, pressure, temperature, and rate of
21 change of pressure. Are you going to provide that data or
22 show how the tests you are performing are relating to that?
23 Maybe that is coming up later.

24 MR. BINGHAM: You will see it in the environmental
25 parameters, but the answer is yes, we will provide that data.



1 MR. LaGOW: Do you do so testing for the rate of
2 change of pressure?

3 MR. BINGHAM: Yes, we do test to the ramps that
4 are shown. We will talk about that when we talk about
5 environmental qualification.

6 MR. ALLEN: Are there any further questions? Pete.

7 MR. NEWCOMB: I have two questions. One relates to
8 Exhibit IIIB-68. Item No. 2 states staff recommendations
9 resulting from review of the TMI are not included. What
10 precautions or what provisions have you taken in the set up
11 of your program to maintain enough flexibility to address new
12 requirements as they come along? Your previous discussion
13 clearly points out the sequential nature of testing where you
14 must do each thing in step and each thing must be properly
15 done before you move on to the next step. How do you address
16 a situation where an early part of the program may have to
17 be modified?

18 MR. BINGHAM: I believe, Pete, your question was how
19 flexible are we going to be.

20 MR. NEWCOMB: Is there flexibility in your program
21 set-up to accommodate additional requirements, for example,
22 coming from TMI concerns.

23 MR. BINGHAM: Generally, we always have some flexibility.
24 Of course, the closer you get to wanting to start the plant
25 up, the less flexibility you have. I would say in general

1 that our philosophy is to be aware of what is going on in
2 the industry and at the Commission and to try to assure
3 ourselves through our discussions with our customer that we
4 haven't precluded ourselves from later incorporation of at
5 least some escalation in requirements. However; our basic
6 goal is to get on with the job and get this done. If we
7 sat around and waited and "what if'd" ourselves, we could not
8 proceed.

9 MR. NEWCOMB: Well, as I understand, what you are
10 indicating is close communication with NRC regarding potential
11 future requirements.

12 MR. BINGHAM: And with the utilities, through all the
13 agencies, and the industry, that's correct.

14 MR. NEWCOMB: My second question is really in general.
15 One of the topics discussed in 0588 that you have not
16 discussed here, and it was brought up previously, is the
17 question of the nonsafety-related equipment. There is a
18 requirement in there where nonsafety-related equipment whose
19 failure could make events worse following an accident must be
20 qualified to show that it will not fail in an adverse mode.
21 How do you do that?

22 MR. CARSON: Nonsafety-related equipment is designed
23 in the plant in such a manner that its failure in any mode
24 will not affect safety-related equipment. It is placed, it
25 is supported, or it is barriered, or whatever, such that its

1 failure will not affect safety-related equipment. Another
2 way of saying this is that all safety-related equipment is
3 looked at in terms of its location, its support, and the
4 things around it to see if there are any nonsafety-related
5 equipment in the area whose failure could affect the safety-
6 related equipment.


7 MR. ALLEN: George.

8 MR. SLITER: Although you said that you are still
9 evaluating the effects of TMI on your program, to date was
10 any equipment reclassified as IE as a result of your
11 evaluation of TMI or were there any additional types of
12 equipment added to your plans as a result of TMI?

13 MR. BINGHAM: There have been some items. We did
14 discuss that at the board of review last month on the
15 auxiliary feedwater system that we were adding some Class I
16 or Class II flow meters. I am sure that there will be some
17 other items added as a result of TMI.

18 MR. ALLEN: Any further questions?

19 DR. ROSZTOCZY: Exhibit IIIB-68, ~~indicates the~~
20 time when 0588 was issued and the statement was made that
21 this does not include lessons learned from Three Mile Island.
22 Since that time, we had time to look at what possible
23 additional requirements are needed because of Three Mile
24 Island and the proposition that has been preferred is presently
25 under NRC management review. Whenever it is in final form,



1 I am sure it will be made available to the industry, including
2 yourself. I can't recall all the items mentioned in this
3 position paper, but I can recollect four of them, and there
4 aren't so many that four will probably represent most of
5 them. There could be one or two extra. I would like to
6 comment on those. One of them applies to new equipment that
7 has been installed on the plant because of the lessons learned
8 from Three Mile Island. This equipment in general are safety-
9 related equipment. That is why they had to be installed, and
10 they fall under the same rule as all other safety-related
11 equipment. It will qualify the same way as you are qualifying
12 the rest of the safety-related equipment, including instrumen-
13 tation that has to be installed for the benefit of the
14 operation of the equipment.

15 The second item mentioned is just simply the list
16 of safety-related equipment. We learned certain things in
17 Three Mile Island and now we are including on the list of
18 safety-related equipment certain equipment that was not
19 included prior to Three Mile Island. It would be important
20 that you review your own list and see if it has been updated
21 and if it includes all of those items that should be included
22 after Three Mile Island.

23 The third item is stratification both in terms of
24 radiation and temperature. It has been observed during the
25 Three Mile Island accident that rather high radiation doses showed

1 up in certain portions of the containment, higher elevations
2 in the containment, and this indicates a certain amount of
3 stratification, that one part of the containment might have
4 higher dose rates than an average dose rate would be calculated
5 for the completely distributed source. We don't know exactly
6 what is the best way to handle this, but we expect you to
7 take this into consideration at the time when you establish
8 your environmental zones. The same for temperatures. You
9 might elect to divide the containment into more than one
10 environmental zone and you might specify higher temperatures
11 and higher radiation levels, for example, for the higher
12 zones in the higher elevations in the containment and then
13 check if there is any different equipment at that location
14 and whether it is qualified for those higher zones. Normally,
15 the higher elevations in the containment don't have safety-
16 related equipment. However, if there is a possibility, it
17 should be kept in mind.

18 The fourth item which I recall from this position
19 paper relates to the hydrogen burn. I think Mr. Noonan
20 mentioned that earlier, so there is no need to discuss it
21 any further.

22 There could be one or two other things. If you are
23 interested, if you check with us, then we can check if there
24 is anything important for you.

25 MR. ALLEN: When do you think that paper is going to

1 be out?


2 DR. ROSZTOCZY: Well, I would expect it within a few
3 weeks, probably; maybe within a month. It is a two-page
4 type of thing, so it won't be very long.

5 MR. ALLEN: Do we have further questions from the
6 board before we proceed?

7 DR. ROSZTOCZY: The next one is Exhibit III B-70. The
8 third bullet down the line talks about the minimum one-hour
9 qualification requirement, if certain equipment is expected
10 to operate only for five minutes after the accident, it
11 should be qualified for one hour and five minutes. Under the
12 position column, I see the words that the requirement is
13 under review. Since this requirement exists on NRC's behalf
14 and since you are performing your tests, I am not sure what
15 these words mean. Are you performing the test to one hour
16 and five minutes for the example case or are you doing
17 something else? Time is running out on you. You can't
18 consider this requirement for too long. They have to be
19 in force, and there is no change in this. This is a require-
20 ment. We expect that it is going to stay this way, so the
21 recommendation would be that you should test all of your
22 equipment to this requirement.

23 MR. ALLEN: Does anyone want to comment on that?


24 MR. BINGHAM: Yes. The reason we put "in review" is
25 because we are having a great deal of difficulty understanding



1 the rationale of applying that criterion to some of the
2 equipment, and we have not yet had an opportunity to discuss
3 this in detail with APS or, indeed, with the NSSS vendor
4 or vendors throughout all the projects. We presently are
5 of the opinion that that may be a severe requirement for
6 qualification, and until we have our review completed, we
7 would not be in a position for those discussions. What I
8 understand that you have said is that regardless of the
9 rationale that the utility might provide, that still is the
10 requirement as far as NRC is concerned. Is that correct?

11 DR. ROSZTOCZY: Yes. In terms of the operating plants,
12 we are looking at what information is available, and so on,
13 and I am not sure exactly what the outcome might be for a
14 piece of equipment that wasn't qualified all the way up to
15 this time period, but for all new tests, we certainly would
16 expect that they will be performed to this time period. Now,
17 I am not sure what you meant when you indicated that this
18 might be a very severe requirement. Do you mean that it is
19 very severe in terms that the equipment might not be able to
20 withstand the environment for this long?

21 MR. BINGHAM: No, I did not mean that. What I was
22 referring to was the fact that the bulk of the equipment on
23 Unit 1 is installed and, therefore, would not be available for
24 that sort of testing. If I understand what you are saying,
25 it is that this criterion would be applicable to tests that




1 would be conducted or tests yet to come up and we would
2 conduct it in that manner. That puts a different perspective
3 on our interpretation of the requirement.

4 DR. ROSZTOCZY: I'm sorry, I didn't mean to imply
5 that. I meant to imply more in terms of the 1971 requirements
6 or the 1974 requirements. You fall under the '74 requirements.
7 You know this now for a number of years and we expect you
8 to meet this one hour plus test requirement. I am not sure
9 if I follow you in terms of the equipment which has already
10 been installed. The question is has this equipment already
11 been tested. If it has been tested, that includes tests
12 under the '74 requirements, meaning that you preaged it,
13 you preradiated it, you have shaken it, and then after that
14 you have underwent a blown core or appropriate environment
15 of that. This last portion of the testing should be performed
16 for this extended period, and if it wasn't followed, then you
17 might have a serious problem at hand.


18 MR. BINGHAM: I believe we understand your question
19 and Mr. Carson will respond.

20 MR. CARSON: In terms of BOP equipment, the primary
21 items would be isolation valves operated by Limitorque operators
22 for this project. Limitorque has provided qualification
23 which shows that they are capable of not only operating for
24 one hour in the accident environment, but throughout the
25 accident environment and post-accident, and this has been



1 demonstrated in their qualification programs. For other
2 equipment, it is still under study.

3 DR. ROSZTOCZY: Exhibit III B-73. Under Item 2)A, you
4 are talking about temperature and pressure steam conditions.
5 You didn't mention humidity. One of the concerns that we
6 have is that sometimes the humidity affects the test for the
7 equipment, whether the equipment will survive the test, and
8 it is not always clear whether the dry or the humid atmosphere
9 is more limiting or whether a combination of dry and humid is
10 more limiting than either the dry or the humid if it applied
11 as a single atmosphere. How did you assure that your
12 equipment will be tested for the most limiting conditions?
13 Let me give you an example. If you have some kind of equip-
14 ment, let's say electrical equipment, inside a box and the
15 box is sealed in such a way that humidity can't get to it,
16 then testing it at high temperature in a dry atmosphere could
17 fail the seal material. If after that it is exposed to a
18 humid atmosphere, the humidity penetrating into the box could
19 fail the electrical equipment inside. If this equipment
20 together with its box is being tested only in dry atmosphere,
21 there will be no failure. If it is tested only in a humid
22 atmosphere, there will be no failure again. But if it is
23 tested in a dry and then in a humid atmosphere, then it will
24 fail. What have you done to cover this type of cases and to
25 avoid the possibility of qualifying something at the same time



1 it might fail in the plant because of the combination of dry
2 and humid atmosphere.

3 MR. CARSON: In the specifications for equipment, as
4 indicated, the environmental parameters are stated including
5 the expected range of humidity at the location of the equip-
6 ment. The vendors' qualification programs are reviewed to
7 see that humidity has been considered. We have had programs
8 in which with large equipment, for instance, motor control centers or
9 switch gear or such as that, or relay cabinets, the vendors have
10 responded to humidity by actually putting open containers of
11 water in the equipment while it is run through temperature
12 ranges such that the humidity would vary over the appropriate
13 range and the operation of the equipment has been checked
14 under those conditions. As indicated earlier in another
15 discussion on humidity, humidity is primarily looked at by
16 the selection of the materials used to make sure that non-
17 hydroscopic materials are used and that the design of the
18 equipment would not provide surfaces on which humidity
19 condensation would provide for low tracking resistance or
20 for reduced insulation resistance.

21 DR. ROSZTOCZY: Have you specified for any of your
22 equipment testing at relatively elevated temperatures in a
23 dry atmosphere which would be followed by tests again in
24 elevated temperatures in a humid atmosphere?


25 MR. CARSON: We have not made any specific test

1 requirements in that specific sequence. As indicated, we
2 have indicated to the vendor the total range of parameters
3 which he must address and have made sure that the qualifica-
4 tion programs and the qualification testing have addressed
5 that range of parameters, but we have not been specific in
6 saying that you must closely follow a high temperature dry
7 operational period by a high temperature wet or a low
8 temperature wet operational period.

9 DR. ROSZTOCZY: I would like to recommend that you
10 review the qualification specifications for all of your
11 equipment that is exposed to this high temperature possibly
12 dry and humid environment and see if there is a need for such
13 a specification.

14 MR. ALLEN: We will take that down as an action item.

15 DR. ROSZTOCZY: Exhibit 73 and 74 together kind of
16 list the various environments that I assume you consider.
17 Here they are mentioned because they were mentioned in the
18 bulletin, but maybe this is an appropriate time to bring up
19 some other environments that have not yet been mentioned and
20 which should be considered. If you are planning to discuss
21 this later, then please just let me know and then I will wait
22 for that. Two items that are not mentioned here are, one,
23 what I would call a dynamic environment. This is an environ-
24 ment of expected vibrations created by the accident in
25 various portions of your plant or your system. For example,



1 if the expected course of the accident is that two-phase
2 flow is going to pass through pumps or valves, then you
3 expect to vibrate under this condition, as they did at
4 Three Mile Island. How do you account for this dynamic or
5 vibration environment and how do you represent this in your
6 specifications when you specify the environmental conditions?


7 MR. BINGHAM: Dr. Rosztoczy, we are not exactly sure
8 how we have covered that particular issue. We do look at some
9 vibratory motions, and what I would like to do is to check on
10 that particular issue and get back during this proceeding,
11 perhaps during Mr. Schechter's presentation, which I am sure
12 will touch a bit on it, but we will provide the answer.

13 MR. ALLEN: I would like to request that that be put on
14 the open items list.

15 MR. QUAN: Could we have that question repeated, your
16 concern?

17 DR. ROSZTOCZY: In the expected course of an accident
18 or event, various things can happen in the plant, including
19 vibrations or any kind of dynamic loads. How did you account
20 for these environments in your evaluation of the plant and
21 the specifications that you prepared for various equipment?

22 The other environment that is not mentioned in this
23 slide here is dust. I think earlier we mentioned sand storms.
24 Since Arizona is an area where this is kind of a more frequently
25 expected event than in other areas, are you going to discuss



1 sometime today or tomorrow how you handle dust and what kind
2 of specifications you have prepared for various equipment in
3 terms of dust?

4 MR. BINGHAM: Dust is near and dear to our hearts on
5 this project and we have through studies and actual measure-
6 ments at the site determined the dust loadings, for example,
7 that would affect the diesel generator, both intake and cool-
8 ing. There is a considerable amount of information available
9 and that has been presented as part of the licensing
10 document.

11 Dennis, help me on this.


12 MR. KEITH: I think it is primarily in Chapter 9 in
13 the ventilation.

14 MR. BINGHAM: Chapter 9 in the ventilation. There is
15 information there that discusses what we have given to the
16 manufacturers that would see dust environment. They have
17 responded back with a statement that their equipment is
18 satisfactory for the dust loadings that we would expect.

19 DR. ROSZTOCZY: Could you prepare a summary, let's say,
20 for tomorrow in terms of how did you handle dust, what kind
21 of equipment did you specify dust for, and give us some
22 examples of what was in the specifications?

23 MR. BINGHAM: Yes.

24 DR. ROSZTOCZY: I would like to include equipment,
25 for example, such as pump seals.



1 MR. BINGHAM: Pump seals?

2 DR. ROSZTOCZY: Yes.


3 MR. ALLEN: Dust effect on pump seals?

4 DR. ROSZTOCZY: Yes.

5 MR. ALLEN: Vince.

6 MR. NOONAN: I guess I would like to go back to IIIB-70,
7 the slide that Dr. Rosztoczy talked about before when he was
8 talking about the requirements out of NUREG 0588 including
9 testing at least one hour in excess of the time assumed for
10 the accident analysis. I don't find the answer that you gave
11 to be acceptable. I guess I would consider this to be an
12 open item. The requirement exists. It is a requirement out
13 of 0588. We are talking about a qualification test, we are
14 not talking about acceptance testing. You made a statement
15 you didn't quite understand where the requirement came from.
16 In qualification testing, you define tests in excess of
17 what you expect to see. I guess what I am trying to say is
18 that the requirement is there and it has to be met and the
19 answer that you gave I don't think was satisfactory.

20 MR. BINGHAM: I may have caused some confusion. I am
21 advised that for the balance of plant equipment that all of
22 the equipment that falls under this concern is or will be
23 qualified with that one-hour requirement. There was a
24 concern on our mind as at what time we were into the design
25 basis event and how to properly apply the one hour. Since



1 we seem to have things in order, let me say for this particular
2 issue that we will correct the record and the chart to reflect
3 compliance for balance of plant.

4 MR. NOONAN: That is acceptable.

5 MR. ALLEN: Did you get that, Terry?

6 MR. QUAN: Yes..

7 MR. ALLEN: Bill, again, that is strictly for BOP.

8 MR. BINGHAM: That is strictly for BOP.

9 MR. ALLEN: Any further questions?


10 If not, I had one. On Exhibit IIIB-74, Item C, it
11 seems to me that at one time we were discussing putting in
12 some submersible pumps in the safety-related sumps. Is that
13 not the case now?

14 MR. BINGHAM: John, Dennis Keith will respond to that
15 question.

16 MR. KEITH: John, we don't have any sump pumps in
17 the containment that are safety-related. However, as a
18 result of all the work that has been done post Three Mile
19 Island, we are looking at the possibility of getting
20 submersible sump pumps, but that evaluation has not been
21 completed.

22 MR. ALLEN: And if we do get them, then they will be
23 qualified for the flood levels?

24 MR. KEITH: They would be qualified, yes. That would
25 be the purpose of changing our design.



1 MR. NOONAN: John, when you answered me on that last
2 question, you made the statement for balance of plant when
3 he was talking about the one hour, but the requirement still
4 exists for Arizona Power for its plant.

5 MR. ALLEN: Right, I understand that, but what I
6 clarified that for was for the record of this system review,
7 which is balance of plant.

8 MR. NOONAN: I understand that, but I want to be sure
9 you understand what I was looking for.

10 MR. ALLEN: I understand it very well.


11 DR. ROSZTOCZY: One more comment on this last slide
12 in connection with the flood level. One lesson learned from
13 Three Mile Island is that maybe under some conditions, the
14 flood level will be higher than it showed for three years
15 ago or five years ago. Have you looked carefully at your
16 plant to see what is the maximum flood level that you would
17 be able to flood the containment to under extreme emergency
18 conditions?

19 MR. BINGHAM: We have looked very carefully at that
20 possibility. As I told you, we have everything on a very
21 large scale model, so we have reviewed to make sure that
22 needed equipment had a considerably safe margin that we added.

23 MR. ALLEN: Any further questions?

24 If not, continue with the presentation, Bill.

25 MR. BINGHAM: All right. That gets us to Section B.9,




1 PVNGS Environmental Classifications.

2 I would like to make one correction to the record,
3 John. Early in the presentation, I believe it was in
4 Section 5, Mr. Carson indicated that the CP date was 1966.
5 The date is 1976.

6 MR. CARSON: In Exhibit III B-76, we discuss the
7 environmental classification of the equipment, and this will
8 be in conjunction with some earlier questions raised at this
9 meeting. The parameter values which led to the environmental
10 conditions for all of the equipment are calculated using
11 appropriate conservative analyses. The values have been
12 grouped on the basis of plant arrangement and the maximum
13 values have been applied to the entire area that is identified.


14 Figure 12 shows an overall view of Unit 1, which is
15 exactly the same as Units 2 and 3, for the plant -- the main
16 buildings, the containment building, the main steam support
17 structure, auxiliary building, fuel building, radwaste building,
18 control building, diesel generator building, and the turbine
19 generator building. The areas of concern have been designated
20 with different environmental designators as shown on Exhibit 13.
21 The containment building is Environmental Designator I. These
22 parameters, as indicated in Table 2, are the parameters
23 associated with the containment building taken as a whole for
24 both normal and abnormal service and as a result of the
25 design basis accident with the design basis accident indicated.



1 In answer to an earlier question, the profile for
2 temperature and pressure has been indicated in terms of time
3 and the ramp rates for the various pressures indicated as
4 well as temperatures. Relative humidities have been specified,
5 integrated dose rates for the 40-year life and 40-year life
6 plus accident, chemicals indicated in the spray system for
7 the containment. These are all specified in the information
8 given the vendor for any equipment which must operate in this
9 atmosphere and the qualification will be handled accordingly.

10 The second area, the main steam support structure,
11 Environmental Designator II, is indicated in Table 3 with
12 the same sort of presentation: temperature, pressure,
13 humidity, radiation, chemicals for both normal and abnormal
14 operations plus the design basis accident, the LOCA main steam
15 line break, in which case temperatures above 100 elevation
16 in this building rise to a 300 degree level, pressure above 100
17 elevation only goes to 21 pounds, humidity specified,
18 radiation specified, again a higher level above 100 elevation,
19 and in this area, no chemicals are involved.


20 Designator III has to do with the auxiliary building
21 surrounding the containment. Shown in Table 4 is Designator
22 III indicating that conditions are the same under normal and
23 abnormal conditions and the effects of the LOCA with the
24 exception of radiation. Radiation in this area as a result
25 of circulating radioactive fluids would raise the value to



1 10 to the sixth power. No chemicals are involved in the
2 auxiliary building.

3 The control building, Environmental Area IV, is
4 shown in Table 5 with normal and abnormal and the conditions
5 which exist as a result of a LOCA or main steam-line break.
6 Of course, there is no main steam line break or LOCA applicable
7 to this area as such, but the effects of the LOCA or steam
8 line break in another portion of the plant will affect the
9 control building as indicated. We see that there are no
10 effects in normal or abnormal conditions and the accident
11 conditions are exactly the same for this area. As was
12 discussed previously in relation to the batteries, the
13 battery rooms are maintained at a temperature of between 60
14 and 85 degrees Fahrenheit, well within the operating range of
15 temperatures, which have a normal rated temperature of 77
16 degrees F.

17 The diesel generator building, Environmental
18 Area V, is shown on Table 6, the conditions for normal and
19 abnormal service. For the accident in another portion of the
20 plant, the same conditions apply with a slight bit of
21 increased radiation going from something lower than 10 to the
22 third rads to a 10 to the third rad level, which is not considered
23 detrimental to equipment and is being confirmed by tests and
24 analyses of all equipment in this area. In addition to the
25 parameters shown here, Mr. Bingham indicated that the dust



1 loadings applicable to the ventilation and combustion air
2 systems have been incorporated into the specifications for the
3 diesel generator.

4 The fuel building, Environmental Designator VI, is
5 shown in Table 7, conditions for normal and abnormal and the
6 accident environments with a slight increase in radiation,
7 which is taken into account for equipment located in that
8 area.

9 There is one other area, which is all of the outside
10 areas and is called Environmental Designator VII shown in
11 Table No. 8, indicating that there will be some slight
12 increase in radiation, and any safety-related equipment located
13 outside the actual plant buildings will be qualified
14 accordingly.

15 MR. BINGHAM: Are there any questions?

16 MR. ROGERS: On the last environmental area, the outside
17 area, are there any pumps or valves located outside of the
18 buildings shown that are safety-related?


19 MR. BINGHAM: There are pumps and valves for the
20 essential spray pond.

21 MR. ROGERS: Thank you.

22 MR. ALLEN: How about pumps and valves on the condensate
23 tank?

24 MR. BINGHAM: Yes, they are in the same designator.

25 MR. ALLEN: George.



1 MR. SLITER: Some of your tables for environmental
2 designators indicate normal and abnormal in a range. Is the
3 lower number normal and the upper abnormal? An additional
4 question would be what basis or what temperature profile do
5 you use for aging equipment in these environments? Is it a
6 combination of both, or what?

7 MR. CARSON: The range indicated is the range covering
8 both the normal and abnormal conditions. The lower temperature
9 is not the normal; the upper is not the abnormal. We have
10 taken the envelope of the entire normal/abnormal situation
11 and said this is the range of temperatures over which you
12 must operate. The vendor is required to respond to that and
13 they would normally envelope that condition with margin and
14 operate above the upper and below the lower indicated
15 temperatures, so they again operate over a wide range of
16 temperatures.


17 MR. SLITER: And the aging question. What value
18 normally would be used to age the equipment?

19 MR. CARSON: Normally, the value that would be used
20 would be the upper temperature.

21 MR. SLITER: The one with the margin in addition to
22 your upper value?

23 MR. CARSON: Yes.

24 MR. SLITER: This you recognize could be extremely
25 conservative in terms of aging.



1 MR. CARSON: Extremely conservative. Some programs
2 address an average temperature, but those are normally at
3 the higher levels, also.

4 MR. ALLEN: Norm, did you have a question?

5 MR. HOEFERT: Yes, I have a question on Table 8. You
6 stated the high range of the temperature for outside areas
7 is 116 degrees. Is any equipment that has to be qualified
8 being exposed to the sun and, if so, how do you justify the
9 116 degrees?


10 MR. CARSON: No equipment is exposed to sun. All is
11 in covered areas.

12 MR. HOEFERT: Does this include the ESF service
13 transformers?

14 MR. CARSON: ESF service transformers are not safety-
15 related items. All safety-related equipment in outside areas
16 are covered and are not exposed to sun.

17 MR. HOEFERT: It has been my understanding that they
18 are Class IE. Is that not correct?

19 MR. CARSON: The ESF service transformers are not
20 specifically Class IE. They are the preferred source of
21 power in the event of a design basis accident. Class IE
22 equipment is incorporated in the AC and DC systems, which
23 were reviewed earlier, and start really with the batteries
24 in the case of the DC system and the DC distribution equipment,
25 all of which is indoors, and start with the source of safety-
related AC power, which is the diesel generator and the



1 distribution system, again which is all indoors.

2 MR. HOEFERT: I have another question. On your tables,
3 for chemicals, you list none for I think all of those. Did
4 you consider chemicals which are used for firefighting?


5 MR. CARSON: Environmental qualification programs do
6 not cover the inadvertent actuation of firefighting systems
7 involving chemicals. The only chemicals used for such systems
8 in this plant are Halon in certain areas and carbon dioxide
9 in certain other areas. Other firefighting apparatus includes
10 water.

11 MR. HOEFERT: It would seem we could expect sometime
12 in the life of the plant to have these chemicals used --
13 Halon if that is the chemical. Must that be looked at on a
14 case-by-case basis or is there some justification that this
15 already --

16 MR. CARSON: We would expect not, since both Halon
17 and carbon dioxide are essentially inert gases and the selection
18 of Halon is made on the basis that it does not really affect
19 anything and, in fact, in the concentrations used, is not
20 harmful to human beings.

21 MR. HOEFERT: What about the temperature effects of
22 CO₂.

23 MR. CARSON: The temperature effects of CO₂ are not
24 involved, since CO₂ is not directed directly onto safety-
25 related equipment, but into the areas, and it would not be



1 expected to severely lower temperatures or impinge on the equipment and
2 cause freezing temperatures, for instance, that might damage
3 equipment.

4 MR. ALLEN: Vince, did you have a question?

5 MR. NOONAN: Following on the same question he is
6 bringing up here, it is pretty hard to believe that in the
7 40-year life of your plant that you would not expect to have
8 chemicals outside unless some particular procedure is in place
9 to make sure that this never happens. It is just hard for
10 me to believe that over 40 years of plant life that you will
11 not at some point in time find chemicals in outside areas.

12 MR. BINGHAM: We have looked at chemicals outside,
13 Vince, from time to time. All of this equipment is protected
14 from missiles, so that means it would be enclosed from direct
15 impingement, although there could be some leakage. One of
16 the major concerns was chlorine gas and we have opted on this
17 project to use sodium hyperchloride to do away with that
18 particular concern. I guess I would have to say that at
19 least to our knowledge, it is quite unlikely that this safety-
20 related equipment would experience direct impingement of
21 some chemical. Here I am assuming some chemical is outside.
22 If you have some examples that we should consider, please
23 state them so that we can assure ourselves that --

24 MR. NOONAN: I guess I don't really have an example,
25 but if you just think of things that happen over 40 years of

1 time, -- You are saying that there is no way that we are ever
2 going to get any chemicals in outside areas.

3 MR. BINGHAM: I am not saying no way. I said it is
4 unlikely.

5 MR. NOONAN: If I go to Table V, can you tell me how
6 the control building environment is controlled?

7 MR. BINGHAM: Yes, we can.

8 John, the reason we are taking a minute, this is a
9 little outside of the scope of this particular meeting. We
10 can take a minute and make sure we describe it properly to
11 Vince or we could in the morning if we are getting together
12 sometime later give you an exact description.

13 MR. NOONAN: Well, the point I am getting to, if you
14 have a control system here to control temperatures, and so
15 forth, inside the building and you lost that system, do you
16 have a redundant backup system?

17 MR. BINGHAM: Yes, we do.

18 MR. NOONAN: Okay, that's sufficient.

19 MR. BINGHAM: Is that sufficient?

20 MR. NOONAN: Yes.


21 MR. BINGHAM: All right, fine.

22 MR. ALLEN: Did you have a further question, Vince?

23 MR. NOONAN: No. Thank you.

24 MR. ALLEN: Ed Sterling, have you got one?

25 MR. STERLING: Yes. Dennis had answered before about



1 the impingement studies that you had done. Is there any other
2 case that you know of or have you addressed stratification
3 or local hot spots in any of these particular areas?

4 Dr. Rosztoczy had pointed out the fourth item in his list .
5 that stratification in the containment, but say in the other
6 buildings as well.

7 MR. BINGHAM: I believe this is an issue that is
8 coming up to assure that we have been covered, and when it
9 comes up, we will take a look at it.


10 MR. ALLEN: We will put that on the open item list,
11 stratification, and make sure we review it. We will have to
12 do it because of 0588 anyway.

13 MR. BINGHAM: Yes.

14 MR. NEWCOMB: On Table 3, which is the main steam
15 support structure environmental conditions, you identify a
16 300 degree temperature above 100 feet, 21 psi, et cetera,
17 above 100 feet. Is there anything below 100 feet? In other
18 words, you give a certain level in that structure a temperature
19 and pressure.

20 MR. BINGHAM: The auxiliary feedwater pumps are below
21 100 feet and, as we discussed at the last system review board
22 meeting, that is a contained area that is completely separate
23 from the upper portion of the main steam support structure.

24 MR. NEWCOMB: Do you address that environment? I mean
25 do you have an environment for that area, the auxiliary



1 feedwater pumps?

2 MR. BINGHAM: Yes, we do.

3 MR. NEWCOMB: Is it here somewhere and I missed it?

4 MR. CARSON: Well, it is this environment right here.

5 The only place where you have a possible problem is due to
6 the design basis event, which only occurs above 100 feet.

7 MR. NEWCOMB: There is no design basis event below
8 100 feet?

9 MR. CARSON: No.

10 MR. HOEFERT: Bill, wasn't there some discussion in
11 the meeting on the auxiliary feedwater system about a break
12 or leaks in the steam supply line to the turbine driven pump
13 and that Bechtel was going to look at that as far as the
14 effects on the equipment in that area.

15 MR. BINGHAM: Yes, there was.

16 MR. ALLEN: Are there any further questions on this
17 before we proceed? Karl.


18 MR. KREUTZIGER: I would like to refer to Table 4.
19 Under the radiation zone, the ion exchanger, is that correct,
20 2.7 times 10 to the ninth?

21 MR. BINGHAM: Yes.

22 MR. KREUTZIGER: Are there any electrical cables in
23 that area? What equipment is located in that area?

24 MR. BINGHAM: Just a moment. Let me check to be sure.

25 No, there is no electrical equipment in there.



1 There might be some pipes, of course, and valves.


2 MR. KREUTZIGER: My question is how does the project
3 preclude routing in these areas by the field since they do field routing of
4 conduit. How do you preclude anything from going through that
5 area? To the best of my knowledge, the cables that you have
6 purchased have not been qualified to this level, and my
7 question is how do you assure that something does not get
8 in there?

9 MR. BINGHAM: We may be confusing the board with this
10 particular issue. This is just a small compartment, it is
11 not safety-related, and I am not exactly sure why that is
12 put on as an example.

13 To answer your other question, we do review the
14 routing of the conduit by the field and make sure that we
15 don't have safety-related conduit and cable where it would exceed
16 its qualification.

17 MR. KREUTZIGER: My question is how do you assure that.
18 The electrical designer that might check the conduit route,
19 how does he know that the area is 2.7 times 10 to the ninth?
20 How is it assured in the review process?


21 MR. BINGHAM: There are reviews, Karl, of the model,
22 our ALARA reviews, separation reviews. All of the groups get
23 together, including the nuclear group, which is responsible
24 for the radiation, and that gives us some assurance that
25 somebody has not misapplied the criteria. I am advised that



1 this particular area really doesn't pertain to the issue at
2 hand and, if necessary, we could go into why the purification
3 ion exchanger would not fall in the category where we would
4 have to worry about a designer running some safety-related
5 conduit through that area.

6 MR. KREUTZIGER: Table 6, you have 140 degrees F in the
7 diesel generator area as a maximum temperature. This to my
8 knowledge is one of the few places on power plants, even on
9 other nuclear power plants, that have exceeded the level of
10 about 50 degrees C for normal operating temperatures. My
11 question is how do you assure that the design temperature has
12 been factored into the design of equipment ratings? For
13 example, we have a general temperature for cable derating.
14 Let's say that the cable that leaves a diesel generator
15 to go back to wherever the safety-related switch gear is
16 probably runs in trays. That cable is sized for an ambient
17 condition. Again I am bringing this point up because it is
18 the first time that I have ever seen an ambient condition
19 above 122 degrees F, which is 50 degrees C, and I would like
20 to know what assurance you have that if I were to look at the
21 cable sizing calculation, derating calculation for that
22 cable, how is it assured that the electrical engineer has
23 used for this area 140 degrees F?

24 MR. CARSON: In this particular area, safety-related
25 cables are run primarily in conduit which act partially as




1 heat sinks. The 140 degree temperature indicated is one
2 that is an extreme temperature and occurs only very periodically
3 and for short periods of time and is not a long-term
4 operational temperature. Cable sizing is done to accommodate
5 in these cases primarily the average temperature or above
6 average temperature which may occur in the area and the cables
7 are oversized to compensate for increased temperatures.

8 MR. KREUTZIGER: I would assume that these diesel
9 generators are assumed, at least, to operate for extended
10 periods of time during loss of off-site power in an accident
11 condition. Is this the temperature that comes from this
12 140 degrees F? My assumption is and my concern is that the
13 140 degrees F is occurring when the plant is requiring the
14 diesel generators for operation, which could be over a
15 relatively extended period of time on loss of off-site power.
16 Is that correct? Is my assumption correct that the 140 degrees
17 F does occur each and every time that the diesel generator
18 operates?

19 MR. BINGHAM: I am not sure that's correct.

20 Let me take care of two of the questions that you
21 had. One was how do we assure ourselves, and I think we
22 left that question open, that the designer includes the
23 information in the design. This information is part of the
24 design criteria and, as I have indicated before, there are
25 procedures and checks and balances to assure ourselves that



1 the designer is aware of it and has included it in the design.
2 The 140 degrees is based on the peak summer temperature that
3 you might see, so for a short period of time when the day
4 was the hottest and the diesel is operating, you would see
5 the 140 F.

6 MR. KREUTZIGER: But that 140 degrees F, were an
7 accident or the use of the diesel for loss of off-site power
8 to occur during the summer months -- I guess that would assume
9 during the day.

10 MR. BINGHAM: The heat of the day.

11 MR. KREUTZIGER: Then the temperature in that room
12 would be 140 degrees F?


13 MR. BINGHAM: It might be as high as 140.

14 MR. KREUTZIGER: The question was then the design
15 basis for cable derating is something less than that.

16 MR. BINGHAM: Based on the proper use of the criteria,
17 we would expect that that had been properly accounted for.

18 I cannot answer that question, John, without further
19 review. If you would like to have that as an open issue, we
20 will go back and confirm whether indeed we did cover that
21 properly.

22 MR. KREUTZIGER: I would like to have that as an
23 open issue, because there are other parts in here that we
24 show also 122 degrees as being the design temperature. The
25 same with things like the steam support structure. These



1 temperatures are higher than the normal derating that we
2 use in our designs. I think historically they have been
3 40 degrees -- well, 40 degrees C in the outside areas except
4 containment, which was 50, which equals 122 F. So I would
5 like to have confirmed that the parameters that have been
6 utilized in the design calculations have been properly
7 addressed.

8 MR. ALLEN: Okay.

9 John Barrow.


10 MR. BARROW: I want to clarify something. A couple
11 of times in this discussion, somebody has made reference to
12 140 degrees C. I want to make sure that it gets into the
13 record that we are talking about 140 degrees F.

14 MR. BINGHAM: Yes, that's right.

15 MR. CARSON: All temperatures listed in the tables are
16 degrees F.

17 MR. ALLEN: Further questions? Vince?

18 MR. NOONAN: I am going to really address this to
19 Arizona Power, and it is the same concern that I had earlier
20 when I raised the 79-14 bulletin of the as-built conditions,
21 and the question just asked on Table 4 about the purification
22 ion exchanger. Is there some quality assurance program that
23 you have in place to assure yourself that that plant that
24 sits out there is built like your drawings say they are built
25 and is it periodically going to be updated to assure yourself




1 that you don't five years from now run cables through some
2 of these areas where you have these very high radiation
3 levels?

4 MR. ALLEN: I think I would have to address that in
5 two parts, number one from our quality assurance standpoint
6 and the program that John Roedel has in effect, and then the
7 program that Bechtel has in effect at the present time to
8 make sure that the as built is actually like the design.

9 John, why don't you comment on your activities and
10 then I will have Bill say a few words on the Bechtel program.


11 MR. ROEDEL: Our whole quality assurance program which
12 filters down from Arizona Public Service Company all the way
13 down to Bechtel and all the way down to the subcontractors
14 is to assure that the plant is built in accordance with the
15 design requirements, and in that program, we have various and
16 very numerous management checks and balances to review
17 drawings and specifications to assure that we do accomplish
18 that fact. We also have quality control inspection at the
19 site. We have vendors' surveillance inspection at the shops,
20 and we have receiving inspections for articles at the plant
21 to then assure that that equipment and articles are installed
22 in accordance with the design criteria. Also, the design
23 criteria are expressed in the construction specifications.
24 They are again expressed in the work plan procedures/
25 quality control instructions, which is the document that



1 the quality control inspectors work from and the engineers
2 work from at the site. So I believe very strongly that our
3 program is sufficient to accomplish that objective. In the
4 six years that I have been on this project, we have verified
5 many times that the implementation of the design review
6 process at Bechtel for our project is functioning correctly.
7 That activity is covered by the EDP's, which is the engineering
8 department procedures, the project quality control program
9 manual, and in those documents, it describes how these
10 functions are carried out. That is a means by which the
11 engineering manager implements that program, and we have
12 many instances documented from reviews and from audits that
13 that is being implemented.


14 Now, if you will, let me answer the second part of
15 your question: What will we do in the operation of the
16 plant that we would not make a modification of that plant
17 that would preclude or interfere with the design criteria
18 that we installed the plant to? The corporate quality
19 assurance program has not yet been completed, although we are
20 working on that at the present time, and I will assure you
21 that we will have such management checks and balances to
22 assure ourselves that we do not violate our design criteria
23 when we perform major modifications of the plant. I guess
24 that's all I can say.

25 MR. NOONAN: I guess the only other comment I will have



1 on that subject is when we had Bulletin 79-14, and we started
2 getting the results of that bulletin in, industry as a whole
3 did not have a very good track record when it came to looking
4 at those plants and finding out that those plants were not
5 actually built according to the way they were designed and
6 we invalidated a number of particularly the seismic areas
7 because of displaced supports, wrong supports, things hung
8 completely different than what the drawings had shown. The
9 industry as a whole did not have a very good track record.
10 I would hope now that, based on that experience, that is
11 being taken into account and as these new plants come on line
12 that there is a gradual update of the as-built conditions to
13 show that you haven't done anything to that plant in either
14 modifications or field corrections during the building that
15 would invalidate this environmental program.


16 MR. ROEDEL: I would like to respond to that statement.
17 The design of this project has taken into consideration some
18 of those items. The design of this project precludes the use
19 of cinch anchors, concrete anchors commonly called cinch
20 anchors. You can't find one in our plant, because they are
21 not allowed to be used. We do have the caveat that you can
22 use one, but it takes engineering approval by Mr. Bingham and
23 APS to use one. Therefore, we have precluded that problem,
24 and there are some other designs that we have put into the
25 plant in controls to preclude some of those. For instance,



1 all the electrical cable for the plant is bought to the
2 Class IE requirements even though some of it is for the
3 balance of plant not safety-related. All the rebar is bought
4 to the same requirements, so, therefore, we don't have to
5 keep segregation of that. The weld rods the same way. All
6 the concrete is produced the same way.

7 Another feature that we might include here is that,
8 regardless of the qualification, the articles in the drawings
9 and the specifications for the most part are handled the
10 same way. Just because a specification happens to be for a
11 Quality Class Q item or a Quality Class S item, it is handled
12 the same way in Bill Bingham's shop with Bechtel Engineering
13 as it is in APS. Now, we may do some things different
14 relative to vendor inspection because of the quality classifi-
15 cation of that equipment, but the rest of it is handled the
16 same.

17 Now, the item in particular of as-built drawings,
18 I am glad you brought that question up, because I have a
19 packet right here of how we are studying to make sure that
20 the as-built drawings are going to actually depict the
21 condition of the plant and the plant is in fact built to the
22 drawing requirements. These happen to be quality control
23 records of how they had taken the drawing and gone through
24 and made sure that all the conditions on that drawing are
25 reflected in the plant. This one happens to be a weld status




1 log. All the welds on this isometric drawing, all the field
2 welds and all of the shop welds, are in fact in accordance
3 with the drawing and it shows that the actual weld is in fact
4 in accordance with the drawings requirement.

5 I can't say for certain that we will always be that
6 way, but we sure are making an attempt to be correct. Maybe
7 I might use our record for inspection by NRC as additional
8 proof that we have in fact done that. If I can remember the
9 numbers correctly, this year we have been inspected
10 approximately every four weeks, and that amounts to -- I am
11 having to guess, because NRC is two reports behind -- I would
12 say on the order of 650 manhours of actual NRC inspection at
13 the site verifying that we are in conformance with the drawings
14 and specifications. We have, and I might be one off, three
15 infractions and one deviation. In addition to that, we have
16 one resident inspector and his reports indicate to me now
17 that he has spent over 600 manhours of actual out in the field
18 inspection, and of the results of that, we have had one
19 infraction and no deviations, which I think, considering that
20 we have three units under construction at the same time, is
21 a fairly decent record.

22 MR. ALLEN: John, did you have a question?

23 MR. BARROW: I just wanted to add something specifically
24 in talking about Item 2 of that question, which was how can you
25 be sure after you go into operation that you are not going to



1 violate the environmental qualification by installing Class IB
2 equipment in high radiation areas or in areas where there is
3 a violation of the temperature, the specific example of that
4 one room that is 10 to the ninth rads and how can you be
5 sure later you are not going to install anything in it. Well,
6 once you get into operation for any period of time, your
7 health physics department is going to keep you from installing
8 anything in high radiation areas, because they are going to
9 be so hot you couldn't have a crew in there long enough to
10 install stuff. As far as the temperature areas, that's
11 different, but that room I don't think we have to worry about.

12 MR. ALLEN: Are there additional questions? Norm.


13 MR. HOEFERT: I just want to mention that we will have
14 a modification control program at the plant which Operations
15 will follow to be sure that all the design requirements for
16 modifications are met to prevent overlooking this type of
17 thing.

18 DR. ROSZTOCZY: Could we have Table 2 up on the screen?
19 Under the normal/abnormal temperature column, there are two
20 numbers, 50 and 120. The question was asked what do they
21 mean, and I believe the answer given was that both the normal
22 and the abnormal fall within this range. Then the question
23 was asked what value did you use for aging, and the answer
24 given was that you used the 120, which would mean to me that
25 every single piece of equipment that is going to be tested or

1 has been tested was preaged to the temperature of 120 degrees
2 for 40 years. Similarly when I go to the other zone. These
3 are generator areas. Then it was preaged to 140 degrees for
4 40 years; for example, the table which was discussed. If
5 that is the case, then you are certainly doing a conservative
6 job. If you are making any exceptions to that, I don't know
7 what exceptions you are making and I have no idea whether
8 the exceptions you are making are acceptable. I would like
9 to recommend that you include a separate column there and,
10 in addition to temperature, show aging right in there, the
11 excess value that you use for aging. If there is a certain
12 reason for it, it has to be explained somewhere.

13 MR. BINGHAM: Dr. Rosztoczy, this is a criteria table
14 and really isn't suitable for that information. The informa-
15 tion is presented in the data summary, which we will show
16 you later on in our presentation, and in the check-off lists
17 that we have for each of the qualification requirements, so
18 I would suggest that you take a look at that information and
19 then if there is still some benefit to the suggestion of
20 modifying this table, we will take that under advisement at
21 that time.

22 DR. ROSZTOCZY: I am looking at this table, but these
23 are the tables which tell me that a certain part of the plant
24 in a certain environmental zone, what are the conditions
25 that the equipment has to be qualified for if it is installed



1 in that zone, and since we mentioned earlier that we have
2 counted up to 10 different environmental parameters, I cannot
3 conduct a program or I cannot write the specifications
4 without having the values for all 10 of them. The slide
5 shown counts up to only 5 out of the 10, so, obviously,
6 information is missing which has to be provided to every
7 equipment supplier or everyone who is performing tests for
8 you in order to do his job.


9 MR. BINGHAM: Would you indicate the other five that
10 you have on your list, please?

11 DR. ROSZTOCZY: Flooding, which, for example, in this
12 case it would give the flood level for the containment indicating
13 that everything has to be located above the flood level;
14 otherwise it has to be qualified for submersion. Dynamic,
15 seismic, dust, and aging.

16 MR. BINGHAM: John, let's see if we can do something
17 this evening to clarify that particular issue. The information
18 is available and I do understand Dr. Rosztoczy's point.

19 MR. ALLEN: Fine, we will take that into consideration
20 tonight and see if we can't report back tomorrow on it.

21 DR. ROSZTOCZY: If I go to the last column or the
22 temperature column which gives the time for the LOCA and the
23 main steam line break environmental profiles, it ends at
24 42 hours. What is the value beyond 42 hours and what is the
25 time period that equipment has to be qualified for that you



1 are using on the long term after a given accident like, for
2 example, certain pumps which you rely on even a year after
3 the accident? What time period do they have to be qualified
4 for and to what temperature?


5 MR. BINGHAM: We would like to leave this one open.
6 I believe we can respond to it tomorrow on this particular
7 point.

8 MR. ALLEN: Why don't we take about a 15-minute break
9 and go off the record here. Before everybody breaks up, I
10 would like to discuss what we are going to do tomorrow.

11 (Thereupon a brief recess was taken, after which
12 proceedings were resumed as follows:)

13 MR. ALLEN: We have investigated where we could hold a
14 meeting tomorrow and we want to do the following things this
15 evening before we break. Number one, we want to finish any
16 questions we may have on the environmental qualifications
17 side before we go into the seismic. Number two, I believe we
18 have a couple of answers to questions that we can clear up
19 before we break. Number three, before we break, I want to
20 indicate where we will be meeting tomorrow and what time we
21 will be meeting tomorrow. Our intention is to finish this
22 up and adjourn the meeting for today and then reconvene
23 tomorrow morning at 8:00, so we can continue on with the
24 questions and get that first part of it out of the way.

25 Go ahead.



1 DR. ROSZTOCZY: We were talking about Table 2. Could
2 we have that back? The third entry is relative humidity, and
3 under the design basis accident column, it just says steam/air
4 mixture. This is maybe the part where you should spell out
5 more specifically the dry atmosphere as opposed to humid or
6 any combination of them if it is required, which we discussed
7 earlier. I think that should show up in this column.

8 The next entry is radiation. There is a normal/
9 abnormal part for radiation and then there is a design basis
10 accident radiation, and under the design basis accident, there
11 is a statement that it includes 40 year integrated. Does this
12 mean that the number in the right-hand column includes the
13 number in the left-hand column plus whatever is the result of
14 the accident?

15 MR. CARSON: Yes.

16 DR. ROSZTOCZY: I will come back to this in connection
17 with another table. In the accident column, there is one
18 single number given. This environmental zone is the contain-
19 ment building. Our expectation would be that in the contain-
20 ment building radiationwise, there would be more than one
21 environmental zone. I mentioned earlier the stratification
22 observed in Three Mile Island indicating that the dust blowout
23 carried more activity up to the top than somewhere else.
24 There could be an accumulation of activity in the sump. Some
25 equipment close to the sump would have a combination of

1 materials, one from the atmosphere of the containment and one
2 from the sump, so that might be a different environmental
3 zone. Then, finally, we discussed earlier the case when the
4 radioactivity stays in the system as opposed to going out
5 through the containment and being recirculated. Any equipment
6 close to those lines where it is being recirculated would
7 have a different environment or zone based on those. It is
8 also my expectation that some of these zones will have
9 numbers significantly higher than the one presently shown in
10 the accident column and then they will have to be qualified
11 at those higher values.

12 One more question on the radiation. What time
13 period was used to establish the radiation number in the
14 accident column? How much time after the accident?

15 MR. BINGHAM: Thirty days.

16 DR. ROSZTOCZY: How about equipment that has to operate
17 beyond 30 days?

18 MR. BINGHAM: Like 200?

19 DR. ROSZTOCZY: Well, one of my earlier questions was,
20 and you will answer it tomorrow, what is the time period that
21 you used as your design criterion, if you wish, for equipment
22 that is needed on the long term. Whatever that number is,
23 that should show up in this radiation column, also.

24 MR. BINGHAM: We will respond to that tomorrow.

25 DR. ROSZTOCZY: In connection with the chemicals, there

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

1 was a question earlier which asked you whether you considered
2 firefighting equipment and you provided some answer to that.
3 Basically, the answer was that you considered it and there
4 was no need to include those as a chemical atmosphere. My
5 question is how do you document the decision? How do you
6 document it in table form? For example, if I would pull out
7 the file on the environmental tables like this one, would
8 there be something in the file indicating that this other
9 chemical type of atmosphere was considered and the decision
10 was made that it is not needed for the following reasons,
11 giving the reasons? Would I find such a document there?

12 MR. CARSON: Not at this moment.

13 MR. BINGHAM: I don't believe at this point.

14 DR. ROSZTOCZY: It would be important to document
15 some of those decisions.

16 MR. BINGHAM: Let's note that comment.

17 MR. ALLEN: Terry, do you have that?

18 MR. BARROW: He's getting the previous one.

19 MR. BINGHAM: This next question was that it would
20 be important to document that we have considered other
21 chemical environments and have assured ourselves that the
22 qualification criteria are satisfactory.

23 MR. CARSON: Specifically, the firefighting chemicals.

24 DR. ROSZTOCZY: That there was no need to include that
25 in the environment because the chemicals weren't the type



1 which would have any effect.

2 Now could I have Table 4? Earlier, I asked on the
3 radiation what is the difference between the first column and
4 the second. If you look at the numbers in the first column,
5 they are not one number, there are about three numbers. On
6 the right-hand side column, there is only one number.
7 Obviously, if I follow the same principle that you described
8 before, then that one number cannot cover all three of these,
9 so something has to be done to this table to accomplish that.


10 MR. BINGHAM: We have to clarify that table. The
11 doses that you see here are in small compartments that are
12 around the purifiers or the ion exchangers, so we will clarify
13 that.

14 DR. ROSZTOCZY: But those small compartments exist
15 after the accident, also and they do have a dose rate, also,
16 so they probably should show up in the other column, also,
17 with the appropriate number. For example, a purifier might
18 accumulate a fair amount of radiation as a result of the
19 accident and if it needs to operate after the accident, then
20 the number would be a different number than present in the
21 left-hand side column.

22 MR. BINGHAM: That's correct.

23 MR. ALLEN: Terry, do you have that to clarify Table 4
24 regarding the dose rate?

25 MR. QUAN: Yes, I do have it.



1 DR. ROSZTOCZY: Mr. Chairman, I am finished with my
2 questions.

3 MR. ALLEN: Are there further questions on this issue?
4 I had one if no one else has any.

5 When we specify design values such as temperature
6 104 degrees, for example, we qualify the equipment to that,
7 but, as in any design, there is room for error. How do we
8 go back after the plant is in operation and verify that we
9 are maybe not seeing 120 degrees in there when we assumed it
10 would be 104?


11 MR. BINGHAM: I believe, John, that falls in the same
12 category as the question about continuous monitoring as a
13 benefit to extended qualified life and perhaps we should deal
14 with both those issues at that time.

15 MR. ALLEN: Norm has a question.

16 MR. HOEFERT: In line with your question, what do we
17 do if in plant operation we lose the heating and ventilating
18 system and exceed these numbers?

19 MR. BINGHAM: You will have to evaluate it, Norm, at
20 that time to assure that there has been no significant
21 degradation, and probably that again would tie in with the
22 question of do you have the data to know what happens so that
23 you can analyze it.

24 MR. HOEFERT: Are we covered by redundant heating and
25 ventilating systems in all these areas?



1 MR. BINGHAM: Yes.


2 MR. ALLEN: Are there any further questions?

3 MR. BINGHAM: We had one clarification, John.

4 MR. CARSON: I would like to clarify a question that
5 was asked by Mr. Kreutziger earlier as to what constituted
6 the harsh environment. If we could make reference again to
7 Figure 13, harsh environments are the inside of the contain-
8 ment building, the upper level of the main steam support
9 structure, and the accessible areas of the auxiliary building
10 as shown, for instance, here in Table 4 for the auxiliary
11 building and the accessible areas. The only thing that would
12 change is the radiation dose in the containment building,
13 and in the MSSS the parameters were indicated in the tables
14 and showed the difference between normal/abnormal and the
15 design basis event parameters. Those are the harsh environ-
16 mental areas.

17 MR. ROSZTOCZY: Could I ask a clarifying question
18 there? You described which part of the plant falls into the
19 harsh environment. If you use a definition for the harsh
20 environment saying that those parts of the plant which are
21 directly affected by the accident environment meaning steam,
22 humidity, pressure, temperature, radiation, those contain the
23 harsh environment, is the description that you just gave
24 consistent with that definition?

25 MR. CARSON: Yes, because the environment changes



1 due to the design basis event in those areas, as indicated
2 in the tables.

3 DR. ROSZTOCZY: And the design basis means not only
4 the loss-of-coolant accidents, but it also includes high
5 energy line breaks like feed line and steam line breaks?

6 MR. CARSON: Yes.

7 MR. ALLEN: Any further clarifications?

8 MR. BINGHAM: One thing I want to make sure, John, you
9 didn't mention it earlier, is that we have a review of the
10 open items from today.


11 MR. ALLEN: I intend to do that before we break.

12 MR. BINGHAM: That completes this part of our presenta-
13 tion.

14 MR. ALLEN: I guess, if the board agrees, we could
15 close that last item out off the open item list regarding the
16 definition of harsh environments.

17 Before we go any further, I guess this would be a
18 good time to go over the list of open items so we can try to
19 resolve as many as possible tonight and report on the resolu-
20 tion of them tomorrow, so I would like to ask Terry Quan to
21 read off the open items and make sure they are properly
22 closed.

23 MR. QUAN: Open Item No. 1 was to correct Figure 8 to
24 show the submittal of CENPD-255 to be July, 1980. That was
25 just a correction on those figures.



1 Open Item No. 2: Send to Dr. Rosztoczy a list of
2 equipment to be qualified taking into account any necessary
3 changes due to post-TMI concerns.

4 Open Item No. 3: Correct Figure 7 from Qualifica-
5 tion "Test" Review to Qualification "Team" Review.

6 Open Item No. 4: I&E Bulletin 79-14 be considered
7 in the qualification of equipment. This bulletin dealt with
8 as-built changes which may affect qualification, changes such
9 as change in location or position.

10 MR. BINGHAM: Excuse me, John. I believe that was one
11 that Mr. Noonan asked.

12 Is that question stated as you had intended?

13 MR. NOONAN: I guess I heard it from Arizona Power.
14 I don't think Bechtel had that.


15 MR. BINGHAM: But as he stated the open issue.

16 MR. NOONAN: The question, yes.

17 MR. QUAN: Open Item No. 5: Correct all slides which
18 state "in compliance" to more appropriate descriptive wording.
19 Use IIIB-13, Item 2, as a guide.

20 Open Item No. 6: Further clarify the PVNGS position
21 in Exhibit IIIB-7, which address General Design Criterion No.
22 4.

23 Open Item No. 7: Obtain through George Sliter the
24 Sandia qualification testing report dealing with testing
25 sequence effects and cumulative effects.



1 Open Item No. 8: Also, this incorporates John's
2 last concern on the environmental monitoring. Investigate
3 continuous environmental monitoring to determine if it should
4 be implemented to ensure design qualification parameters
5 were within reason and to supply historical environmental
6 data on which extension of qualification may be based.

7 Open Item No. 9: In general terms, how would single
8 failure criterion apply for equipment qualification?
9 Illustrate this application through example such as a single
10 failure used to determine the chemical environment.


11 Open Item No. 10: Investigate how a possible
12 synergistic effect as outlined in NUREG 0588 will be considered
13 in equipment qualification programs.

14 Open Item No. 11: Review the possibility of
15 including the test sequence of high temperature accompanied
16 by low humidity followed by high temperature accompanied by
17 high humidity in the equipment qualification procedures.

18 Open Item No. 12: How is vibration or dynamic fluid
19 flow from the event taken into consideration in the equipment
20 qualification plans.

21 Open Item No. 13: How does dust in the environment
22 affect equipment, especially pump seals.

23 Open Item No. 14: On Exhibit IIIB-70, the third
24 bullet is to be considered to show intent to comply with the
25 one-hour requirement.



1 MR. BINGHAM: Excuse me, John. I believe we responded
2 to that question.

3 MR. ALLEN: I think he closed that one out, Terry.

4 MR. KOPCHINSKI: We were asked to correct the slide.

5 MR. ALLEN: Oh, that's right, correct the slide.

6 MR. QUAN: Open Item No. 15: Was proper cable degrading
7 used for 140 degree environment.

8 MR. BARROW: Correction. That should be derated, I
9 think.

10 MR. ALLEN: Derated.

11 MR. CARSON: That was in regard to the diesel generator
12 building.

13 MR. ALLEN: I think that should be expanded on. I
14 think that was in general, too. Didn't Karl say in general?

15 MR. KOPCHINSKI: It was expanded to include the 122
16 degree areas.


17 MR. QUAN: Open Item No. 16: Add environmental
18 designators submergence, dust, seismic, dynamic, and aging.

19 I have a question. Was that in reference to the
20 tables?

21 DR. ROSZTOCZY: Yes.

22 MR. QUAN: On these next few, I've just got notes.
23 They are not quite complete.

24 MR. ALLEN: Why don't you go ahead on them and then
25 Gerry probably has some he can come up with.



1 MR. QUAN: Open Item No. 17 was in reference to the
2 table on containment environment designator. Investigate
3 LOCA temperature past 42 hours. Is that correct?

4 Open Item No. 18: Respond to time period assumed
5 for equipment required post LOCA on which the LOCA radiation
6 dose us based,

7 DR. ROSZTOCZY: That question is a little bit broader.
8 It asked for the time period that was used for equipment
9 qualification following an accident. It includes other
10 parameters like temperature, also.

11 MR. QUAN: Open Item No. 19: Verify documentation that
12 other chemical environments have been considered, specifically
13 fire protection chemicals.

14 Open Item No. 20: Clarify the radiation dose rate
15 in Table 4.


16 Gerry, do you have any others?

17 MR. KOPCHINSKI: The only other one I have is the
18 question of stratification. I am not sure if that was asked
19 twice or once.

20 MR. QUAN: I have that one.

21 MR. ALLEN: Vince, do you have an additional one?

22 MR. NOONAN: Yes. It is really not an open item, but
23 a reminder that sometime tomorrow when you start talking
24 about your equipment qualification and the environmental and
25 seismic, I want to include a discussion on relays.



1 MR. QUAN: To clarify that last open item, 21 was to
2 investigate the effect of temperature stratification in the
3 containment environmental designator per NUREG 0588.

4 MR. KEITH: It wasn't really radiation stratification,
5 was it?

6 MR. CARSON: Temperature, also.

7 MR. QUAN: Gerry, were there any others?

8 MR. KOPCHINSKI: No.

9 DR. ROSZTOCZY: I have two more items. One of them
10 I identified later, but it didn't show up in the list. I
11 asked for the treatment of dust relative to environmental
12 qualification.

13 MR. CARSON: Dr. Rosztoczy, that is No. 13.

14 DR. ROSZTOCZY: Oh, I'm sorry. The other one I believe
15 we didn't identify as an open item, but I think it would be
16 appropriate to identify it as an open item. It related to
17 the radiation source term. Questions were asked and the
18 answer was that, based on some discussion that we had, you
19 are looking at radiation source terms whether they have been
20 evaluated consistently with the approach that in an accident,
21 everything goes into the environment or it stays in the
22 recirculation system.

23 MR. BINGHAM: That's right.

24 DR. ROSZTOCZY: You said that one is presently ongoing.
25 I think it would be appropriate to put it on the open item



1 list.

2 MR. QUAN: Could you repeat that?

3 DR. ROSZTOCZY: Yes, an evaluation of the radiation
4 source terms in view of the two possible courses of the
5 accident, one being that the radiation is released to the
6 environment and the second possibility that it is retained
7 in the recirculation system.

8 MR. ALLEN: Bill Quinn.


9 MR. QUINN: I would like to go back to Item 2. Could
10 Terry read that one again?

11 MR. QUAN: Item 2 was send to Dr. Rosztoczy a list of
12 equipment to be qualified taking into account any necessary
13 changes due to post TMI concerns:

14 MR. QUINN: It seems to me that the open item should
15 be clarified slightly to review the particular table in
16 Appendix 3E and, if there are any changes, to provide those
17 changes. It would not seem necessary to provide something
18 that is already correct, since it is in the licensing
19 document. It, of course, would have to be upgraded.

20 MR. ROGERS: Furthermore, I think that we said that
21 that was to be submitted to the board, not just to Zoltan,
22 for the board's review.

23 DR. ROSZTOCZY: It should definitely be submitted to
24 the board, and let me maybe further clarify what it is I am
25 looking for there. In our presently ongoing reviews, we are



1 ending up with two lists. One list is the safety-related
2 systems list. This lists various systems that you depend on
3 for the treatment of the plant following certain accidents.
4 We have a second list that we call the displacement instrumen-
5 tation list. This lists instrumentation that are needed for
6 the operator to perform his action appropriately. All
7 equipment, every component in those systems listed in either
8 of those lists, has to be environmentally qualified. So I
9 am looking for these two lists or the combination of these two.
10 I will be very surprised if your FSAR's have a complete list
11 of that nature.

12 MR. ALLEN: Was the latter list you are talking about
13 the SPDS system?

14 DR. ROSZTOCZY: The latter list includes every instru-
15 ment that you include in your emergency procedures and use
16 for operator action.

17 MR. ALLEN: I understand.

18 Are there any additional items or questions that
19 anyone would like to ask before we adjourn for the evening?
20 If not, our plans are to reconvene tomorrow morning at 8:00
21 in the Valley National Building in downtown Phoenix.

22 (Thereupon a brief off-the-record discussion ensued,
23 after which proceedings were resumed as follows:)

24 MR. ALLEN: Are there any questions regarding tomorrow?
25 If not, I will declare the meeting adjourned until 8:00
tomorrow morning.

(Thereupon the meeting was at recess.)

