

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8108250513. DOC. DATE: 81/08/19 NOTARIZED: NO DOCKET #. 05000528  
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Public 05000529  
 STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Public 05000530  
 STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Public 05000530  
 AUTH. NAME: AUTHOR AFFILIATION  
 VAN BRUNT, E. E. Arizona Public Service Co.  
 RECIP. NAME: RECIPIENT AFFILIATION  
 KERRIGAN, J. NRC - No Detailed Affiliation Given

SUBJECT: Forwards responses to NRC structural audit questions asked at 810811-13 meeting. Meeting agenda, list of open items & completed audit forms encl. *See Reports for Encl's III*

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL: 1 SIZE: 500  
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: Standardized Plant. 1 cy: C Grimes 05000528  
 Standardized Plant. 1 cy: C Grimes 05000529  
 Standardized Plant. 1 cy: C Grimes 05000530

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL		ID CODE/NAME	LTR
ACTION:	A/D LICENSNG	1	0	LIC BR #3 BC	1	0
	LIC BR #3 LA	1	0	KERRIGAN, J. 04	1	1
INTERNAL:	ACCID EVAL BR26	1	1	AUX SYS BR 27	1	1
	CHEM ENG BR 11	1	1	CONT SYS BR 09	1	1
	CORE PERF BR 10	1	1	EFF TR SYS BR12	1	1
	EMRG PRP DEV 35	1	1	EMRG PRP LIC 36	3	5
	EQUIP QUAL BR13	3	3	FEMA-REP DIV 39	1	1
	GEOSCIENCES 28	2	2	HUM FACT ENG 40	1	1
	HYD/GEO BR 30	2	2	I&C SYS BR 16	1	1
	I&E 06	3	3	LIC GUID BR 33	1	1
	LIC QUAL BR 32	1	1	MATL ENG BR 17	1	1
	MECH ENG BR 18	1	1	MPA	1	1
	OELO	1	0	OP LIC BR 34	1	1
	POWER SYS BR 19	1	1	PROC/TST REV 20	1	1
	QA BR 21	1	1	RAD ASSESS BR22	1	1
	REAC SYS BR 23	1	1	REG FILE. 01	1	1
SIT ANAL BR 24	1	1	STRUCT ENG BR25	1	1	
EXTERNAL:	ACRS 41	16	16	LPDR 03	1	1
	NRC PDR 02	1	1	NSIC 05	1	1
	NTIS	1	1			

AUG 27 1981

*Limited Dist*

MAZ

TOTAL NUMBER OF COPIES REQUIRED: LTR 63 ENCL 58


*63* *58*  
*52* *51*

*26*

1949  
1950  
1951  
1952  
1953  
1954  
1955  
1956  
1957  
1958  
1959  
1960  
1961  
1962  
1963  
1964  
1965  
1966  
1967  
1968  
1969  
1970  
1971  
1972  
1973  
1974  
1975  
1976  
1977  
1978  
1979  
1980  
1981  
1982  
1983  
1984  
1985  
1986  
1987  
1988  
1989  
1990  
1991  
1992  
1993  
1994  
1995  
1996  
1997  
1998  
1999  
2000  
2001  
2002  
2003  
2004  
2005  
2006  
2007  
2008  
2009  
2010  
2011  
2012  
2013  
2014  
2015  
2016  
2017  
2018  
2019  
2020  
2021  
2022  
2023  
2024  
2025

1949  
1950  
1951  
1952  
1953  
1954  
1955  
1956  
1957  
1958  
1959  
1960  
1961  
1962  
1963  
1964  
1965  
1966  
1967  
1968  
1969  
1970  
1971  
1972  
1973  
1974  
1975  
1976  
1977  
1978  
1979  
1980  
1981  
1982  
1983  
1984  
1985  
1986  
1987  
1988  
1989  
1990  
1991  
1992  
1993  
1994  
1995  
1996  
1997  
1998  
1999  
2000  
2001  
2002  
2003  
2004  
2005  
2006  
2007  
2008  
2009  
2010  
2011  
2012  
2013  
2014  
2015  
2016  
2017  
2018  
2019  
2020  
2021  
2022  
2023  
2024  
2025


1949  
1950  
1951  
1952  
1953  
1954  
1955  
1956  
1957  
1958  
1959  
1960  
1961  
1962  
1963  
1964  
1965  
1966  
1967  
1968  
1969  
1970  
1971  
1972  
1973  
1974  
1975  
1976  
1977  
1978  
1979  
1980  
1981  
1982  
1983  
1984  
1985  
1986  
1987  
1988  
1989  
1990  
1991  
1992  
1993  
1994  
1995  
1996  
1997  
1998  
1999  
2000  
2001  
2002  
2003  
2004  
2005  
2006  
2007  
2008  
2009  
2010  
2011  
2012  
2013  
2014  
2015  
2016  
2017  
2018  
2019  
2020  
2021  
2022  
2023  
2024  
2025



August 19, 1981  
ANPP-18697 - JMA/WFQ

Ms. Janis Kerrigan  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Subject: Palo Verde Nuclear Generating Station  
(PVNGS) Units 1, 2 and 3  
Docket Nos. STN-50-528/529/530  
File: 81-056-026; G.1.10



Dear Janis:

A meeting with the NRC/NRR's Structural Engineering Branch (SEB) was conducted from August 11 to August 13, 1981. Prior to the meeting, we were requested to respond to 10 NRC questions and to complete typical SEB audit forms for our Category I structures.

In this regard, the following information is enclosed:

- Enclosure 1 . . . . . Meeting Agenda
- Enclosure 2 . . . . . List of Meeting Open Items
- Enclosure 3 . . . . . Completed Audit Forms
- Enclosure 4 . . . . . Responses to NRC Questions

Very truly yours,

E. E. Van Brunt, Jr.  
APS Vice President  
Nuclear Projects  
ANPP Project Director


EEVBJr/WFQ/pc

Enclosures

cc: S. Chan (NRC) w/encl.  
P. Hourihan w/encl.  
A. C. Gehr w/encl.

*Limited Distribution*  
*BOO1*  
*s*  
*1/1*


8108250513. 810819  
PDR ADOCK 05000528  
A PDR



Ms. Janis Kerrigan  
August 19, 1981  
Page Two


STATE OF ARIZONA )  
                          ) ss.  
COUNTY OF MARICOPA)

I, Edwin E. Van Brunt, Jr., represent that I am Vice President Nuclear Projects of Arizona Public Service Company, that the foregoing document has been signed by me on behalf of Arizona Public Service Company with full authority so to do, that I have read such document and know its contents, and that to the best of my knowledge and belief, the statements made therein are true.



Edwin E. Van Brunt, Jr.

Sworn to before me this 21<sup>st</sup> day of AUGUST, 1981.

  
Notary Public

My Commission expires:

June 24, 1983

1904  
JAN 15  
11 00 AM  
ST. LOUIS, MO.  
RECEIVED

AGENDA

NRC SER AUDIT MEETING  
STRUCTURAL ENGINEERING BRANCH

Week of August 10, 1981

- Monday:           Tour of Jobsite in Phoenix, Arizona
- Tuesday:           I. INTRODUCTION
- II. REVIEW OF STRUCTURAL AUDIT WORKSHEETS
- A. Brief Overview of Entire Plant.
- B. Containment Building
- Wednesday        C. Main Steam Support Structure
- D. Auxiliary Building
- E. Fuel Building
- F. Control Building
- Thursday           G. Diesel Generator Building
- H. Category I Tanks
- I. Spray Ponds
- J. Category I Structures
- III. REVIEW OF RESPONSES TO NRC QUESTIONS
- IV. SUMMARY

2025/01/10



DATE OF MEETING: August 11, 12, 13, 1981

LOCATION: Downey, California

ATTENDEES:

<u>APS</u>	<u>Bechtel</u>		<u>NRC/NRR/SEB</u>
W. Quinn	D. Gibson	G. Kopchinski	D. Jeng
W. Hurst	* R. Kosiba	* A. Hadjian	R. Lipinski
	O. Gurbuz	* S. Jain	S. Chan
	R. Peters	* G. Guevara	
	P. Wong	* W. Brandes	
	K. Schechter	* R. Senczyszyn	
	D. Keith	* R. Platoni	
	B. Bitner	* D. Niehoff	
	* B. Linderman	* W. Au	


\* Part time.

SUBJECT: SEB DRAFT SER

PURPOSE: Working meeting to resolve questions and provide requested information.


I. OPEN ITEMS FROM STRUCTURAL AUDIT WORKSHEETS.

- |   | <u>Date<br/>Information<br/>To Be<br/>Furnished</u> |
|---|---|
| 1. Provide justification for the use of 2 OBE seismic events in lieu of 5 OBE events with a minimum of 10 cycles each. Show that the intent of SRP 3.7.3.2 is met.  | 8/24/81   |
| 2. Provide a discussion of transferring both damping (material damping) and shear modulus values shown on Figure 3A-2 into actual determination of compliance functions used for seismic analysis of Category I structures. | 9/21/81   |




Date  
Information  
To Be  
Furnished

3. Provide live load sketches for Category I structures, noting that the absence of live load is considered to obtain the greatest loading. 8/24/81
4. NRC requests Bechtel provide an ultimate capacity assessment of the Containment Structure against internal pressure, accounting for the specific parameters in Attachment 1. (A sophisticated computer analysis is not required.) Not Applicable
5. Present a calculation showing that the liner system design satisfies all the loading requirements resulting from a negative pressure of 4 psig. 8/24/81
6. Bechtel will provide technical justification for the vertical analysis of the polar crane. This justification will account for the upward motion of the suspended mass, including the flexibility of the cable. 9/21/81
7. Provide technical justification, in the form of calculations, demonstrating that the accidental torsion applicable to the Containment Building (i.e., 5% of the size dimension multiplied by the maximum lateral force at the base) is properly accounted for in the containment shell and interior structure design. 9/21/81




	<u>Date Information To Be Furnished</u>
8. Bechtel will provide technical basis for deciding boundary and extent of the soil included in the 'FINEL' analysis.	8/24/81
9. Bechtel will provide: the angle of rotation for the Containment Building basemat, the actual calculation determining the factor of safety (FS) against overturning, and an additional calculation determining the FS against overturning using conventional methods.	8/24/81
10. Bechtel will elaborate upon the answer given on page 26, Item 5-B Containment Building; specifically, provide discussion on the procedure used by the applicant to meet the requirements of SRP 3.7.II.8. (Regarding non-Category I over Category I criteria)	8/24/81
11. Provide typical calculation (a paragraph) determining the fictitious temperature drop accounting for the effect of prestressing tendon (both orthogonal and draped tendons).	8/24/81
12. Provide a copy of the equipment hatch calculation (Sub-Section NE). [This will serve as the typical calculation procedure for the personnel hatch as well.]	8/24/81



Date  
Information  
To Be  
Furnished


13. Provide a calculation of the junction between the containment wall and mat according to the computer analysis results. Also, explain the method in which seismic forces are combined with nonseismic forces. 9/21/81
14. Provide a calculation for radial reinforcement to account for the delamination effect in the dome. 8/24/81
15. Provide calculations for the critical section of the primary shield around the hot and cold leg penetrations. 9/21/81
16. Bechtel will provide SEB with the results of the calculations checking the crane runway girder stability against D.L. + L.L. + SSE. Also provide calculations for the polar crane bracket. 10/6/81
17. Provide the calculations for the steam generator upper support lever arm and snubbers (Bechtel scope of work). 8/24/81
18. Bechtel will provide a typical calculation for the development of story stiffness parameters for MSSS. 8/24/81
19. Provide justification that the corridor building has been designed to meet SRP section 3.7.II.8: 12/11/81






Date  
Information  
To Be  
Furnished

- |  |         |
|--|---------|
| 20. Provide technical justification for one critical wall of the Auxiliary Building similar to that requested in Action Item #8.   | 9/21/81 |
| 21. Provide the mechanical properties of Rodofam II and EVERLASTIC Micro II.   | 8/24/81 |
| 22. Provide a conventional stability analysis against overturning of the Auxiliary Building.   | 8/24/81 |
| 23. Provide the design calculations for the concrete column at elevation 88'-0" in the Auxiliary Building. The column has an axial force of 1981 k and a moment of 203 ft-k.         | 8/24/81 |
| 24. Provide the calculation developing the hydrodynamic aspects of the Fuel Building seismic analysis model. (Lumped mass model)   | 8/24/81 |
| 25. Provide an accidental torsional effect analysis (i.e., 5% of the size dimension multiplied by the maximum lateral force at the base) for one critical wall of the Fuel Building. | 9/21/81 |
| 26. Provide the calculations for the west wall of the spent fuel pool to withstand the impact from a fuel cask drop.   | 8/24/81 |




Date  
Information  
To Be  
Furnished

- |  |         |
|--|---------|
| 27. Provide an accidental torsional effect analysis (i.e., 5% of the size dimension multiplied by the maximum lateral force at the base) for one critical wall of the Control Building.          | 9/21/81 |
| 28. Provide an approximate sum of the participation factors of 3 modes considered in the Diesel Generator Building seismic analysis as a percent of total response                               | 8/24/81 |
| 29. Provide an accidental torsional effect analysis (i.e., 5% of the size dimension multiplied by the maximum lateral force at the base) for one critical wall of the Diesel Generator Building. | 9/21/81 |
| 30. Provide calculations determining the soil pressure on the Diesel Generator Building foundation due to three directional seismic load.  | 9/21/81 |
| 31. Provide an impact assessment on the seismic response of the refueling water tank accounting for partial cracking of the concrete shell.  | 9/21/81 |
| 32. Provide calculations for considering tornado missile overall response for the roof and one wall of the Auxiliary Building.   | 9/21/81 |




Date  
Information  
To Be  
Furnished

33. Provide justification for not considering the soil structure interaction effect in the seismic analysis of the spray pond pump house. 8/24/81
34. Provide a calculation determining the loads used in the design of both the spray pond walls and pump house walls. 8/24/81
35. Provide an accidental torsional effect analysis (i.e., 5% of the size dimension multiplied by the maximum lateral force at the base) for one critical wall of the spray pond pump house. 9/21/81
36. Provide a calculation showing that the natural frequency of the floor/structure support is at least twice the frequency of the pump/motor unit. 8/24/81
37. Provide portions of calculation for Category I tanks, 13-CC-CT-015 (pages 1-53; Appendix pages F1-F18). 8/24/81
38. Provide justification on the procedure used in calculating the partial embedment versus total embedment effect (per BC TOP 4A - Rev. 3) on the compliance functions for the seismic analysis of the tanks. 9/21/81



Date  
Information  
To Be  
Furnished


39. Provide a discussion on how major cable tray test results were used in arriving at the 20% modal damping. The discussion should assure consistency of observed data and calculations used. 12/11/81
40. Why was cable tray test input loading applied at a 45° angle instead of simultaneous horizontal and vertical load input? What are the implications of this testing method upon the validity of the recommended 20% damping (e.g., with respect to statistical independency requirements of different directional inputs)? 12/11/81
41. Will sprayed-on fireproofing affect cable friction and thus the damping ratios? 12/11/81
42. The cable tray test conditions do not reflect the actual physical site situation. Provide the rationale for extending the test results to the actual design which is different from the test configuration. 12/11/81
43. Specify different conditions under which different modal damping ratios ranging from 7-20% are used. (cable tray) 12/11/81





Date  
Information  
To Be  
Furnished

44. It appears that the scope of the cable tray test and the number of tests may not support direct extension to APS cable tray design. Justify that the scope of test conducted is adequate for direct design application. 12/11/81
45. It appears that response to NRC Question 220.12 contains several deviations from draft Appendix A to Standard Review Plan Section 3.5.3. Indicate compliance with the above position or describe in quantitative terms the impact of any deviations from the above position. 9/21/81
46. Provide calculations for the design of electric duct banks, Category I manholes, and Category I buried piping. 9/21/81
47. CONDAM computer program will be added to the FSAR appendix 3B. 9/21/81



4. The space within the opening is sufficiently occupied by piping and pipe supports to preclude missile penetration.

The roof of the Main Steam Support Structure is elevated from the top of the walls to allow the escape of steam in the event of a major pipe break. The roof is cantilevered beyond the wall to provide the necessary missile protection.

Question 3A.14 (NRC Question 450.2) (3.5.1.4)

Describe the protection of the control room air intakes and diesel generator exhaust pipes from tornado-generated missiles.

RESPONSE:

- The control room air intakes are enclosed within a box structure located within the Control Building (See figure 3A-7). The wall sections exposed to tornado-generated missiles are designed to withstand such impact without adverse effect upon the system.
- The diesel generator exhaust pipes are enclosed within a 1'9" thick vertical, concrete chimney which is designed to withstand tornado-generated missile impact. A thick, steel pipe sleeve, also capable of withstanding tornado-generated missile impact, provides protection for the exhaust piping at the vent opening at the top of the chimney.

Question 3A.15 (NRC Question 220.11) (3.5.3)

The allowable displacement of reinforced concrete flexural members stated as Formula (3-2) in Appendix 3C to FSAR is inconsistent with the ACI 349-76 Code. Please correct this error.

RESPONSE: The response is contained in section 3C.3.1.2.

Question 3A.16 (NRC Question 220.12)

(3.5.3)

The ductility ratios listed in Table 3C.3-4 and used for design of missile barriers are not acceptable. It is the staff position that the permissible ductility ratio under impactive and impulsive loads be not greater than 10 unless it is justified by submitting applicable experimental evidence in the plant SAR. A copy of the draft Appendix A to Standard Review Plan Section (SRP) 3.5.3 is attached herewith for your reference (Attachment 1). Please also note that the ductility ratio for pressurization, a condition that BC-TOP-9A does not cover, remains 1. Express your intention to comply with this staff position.

*PVNGS complies with the staff position.*

RESPONSE: ~~A maximum ductility ratio of one has been used for pressurization.~~ Further information is contained in amended table 3C.3-4.

Question 3A.17 (NRC Question 220.13)

(3.7.4)

There are some deviations in seismic instrumentation from the requirements of Regulatory Guide (R.G.) 1.12 as stated in Sections 1.8 and 3.7.4 of the FSAR. Give reasons for such deviations and state whether the suggested alternatives would exceed the requirements or the intended functions in R.G. 1.12. Also, explain how and when the control room operator be notified of the occurrence of an OBE which is defined by the design response spectra of Figures 3.7-3 and 3.7-4 of the FSAR.

RESPONSE: Deviations from Regulatory Guide 1.12 are defined and explained in section 1.8. The seismic instrumentation provided meets or exceeds the intended functions of Regulatory Guide 1.12. The control room operator is notified of an safe shutdown earthquake (SSE) or an operating base earthquake (OBE) by audible and visual annunciation as defined by amended section 3.7.4.3.


200.123

Table 3C.3-4  
DUCTILITY RATIOS

Member Type and Load Condition	Maximum Allowable Value of $\mu$
<u>Reinforced Concrete</u>	
Flexure:	
Beams and one-way slabs	$\frac{0.10}{p-p'} \leq 10$
Slabs with two-way reinforcing	$\frac{0.10}{p-p'} \leq 10$
Axial compression:	
Walls and columns <sup>30</sup>	1.3
Shear, concrete beams and slabs in region controlled by shear:	
Shear carried by concrete only	1.3
Shear carried by concrete and stirrups	1.6
Shear carried completely by stirrups	2.0
Shear carried by bent-up bars	3.0
<u>Structural Steel</u>	
Columns and beams with uniform moment <sup>31</sup>	$\mu \leq \frac{14 \times 10^4}{F_y \left(\frac{KL}{r}\right)^2} + 1/2 \leq 10$
Beams with moment gradient	10
Shear	10
Axial tension and steel plates membrane tension <sup>32</sup>	$0.5 \frac{e_u}{e_y}$

Notes:

1. Based on information contained in references 9, 12, and 14 through 25.
2.  $p$  and  $p'$  are the positive and negative reinforcing steel ratios.
3. See figure 3C.3-2 for allowable ductility ratios where there is a beam-column action.
4.  $KL/r$  is the member slenderness ratio.  $F_y$  is the yield stress (ksi).
5.  $e_u$  and  $e_y$  are the ultimate and yield strains.  $e_u$  shall be taken as the ASTM specified minimum.



### 3.5.1.2.2 Pressurized Component Failure Missiles

#### A. Reactor Coolant System Pressure Boundary (RCPB)

The selection of potential missiles is based on the application of single-failure criteria to the normal retention features of plant equipment for which there is a source of energy capable of creating a missile in the event of the postulated removal of the normal retention features. Where redundancy is provided by the normal retention features, such that sufficient retention capability remains to prevent creation of a missile in the event of a postulated failure of a single retention feature, no potential missile is postulated. Table 3.5-4 presents the potential missiles postulated to originate from RCPB equipment, and summarizes their characteristics, <sup>AND LISTS PROVIDED</sup> ~~The provided~~ missile protection <sup>is presented in table 3.5-4.2</sup> ~~is presented in table 3.5-4.2~~

#### B. Non-RCPB Systems

<sup>(INCLUDING MISSILES FROM EQUIPMENT WITHIN THE C-E SCOPE OF SUPPLY).</sup>

A tabulation of missiles generated from failures of pressurized components, their sources and characteristics, and provided missile protection, is given in table 3.5-4. The bases for selection are identical to those described in section 3.5.1.1.2.

### 3.5.1.3 Turbine Missiles


#### 3.5.1.3.1 Turbine Placement and Orientation

The placement and orientation of the turbine generators is shown in figure 3.5-1.

#### 3.5.1.3.2 Missile Identification and Characteristics

Analysis has indicated that high-pressure turbine missiles and generator missiles would be retained by their respective

September 1981





✓ Question 3A.18 (NRC Question 220.14) (3.7.4)

Is instrumentation needed for measuring torsional input provided? If yes, describe type, numbers, and layout of the torsional instrumentation.

RESPONSE: Instrumentation for measuring torsional input has not been provided.

✓ Question 3A.19 (NRC Question 220.15) (3.8.1)

Provide the manufacturer's name or the name of the post-tensioned prestressing system used in the Palo Verde containment structures. Has this system been accepted by the NRC staff as indicated in R. G. 1.103?

RESPONSE: The PVNGS containment structures use a BBRV post-tensioned prestressing system. This <sup>system</sup> ~~method~~ is accepted by Regulatory Guide 1.103.

✓ Question 3A.20 (NRC Question 220.16) (3.8.1)

Has buckling been considered in design of containment building? Would it cause any problem in design?

RESPONSE: Buckling has not been considered as part of the design of the containment exterior concrete wall. The 4-foot-thick wall and geometry preclude buckling as a design factor in the containment design. Buckling has been considered in the liner plate design since the liner plate acts as the inside form for the containment shell. (Refer to BC-TOP1A, Rev 1, 1972.)

Question 3A.22 (NRC Question 220.19)

(3.8.4)

Are there any (a) intake structures, submerged pipes or tunnels, (b) structure-pile-soil medium systems, (c) spent or new fuel pool structures, used in Palo Verde plants? If yes, describe key dimensions, structure modeling, static and seismic analysis criteria, assumptions and computer codes used. A copy of "Minimum Requirements for Design of Spent Fuel Pool Racks" is enclosed for your reference (Attachment 3).

RESPONSE:

(a) Intake Structures: The Circulatory Intake Structure is a non-Category I structure.

Submerged Pipe: There are submerged pipes in the essential spray ponds and the spent fuel pool. In the spray ponds the pipes vary in diameter with the maximum dimension being 24 in. The pipes in the fuel pool are 16 in. in diameter. Both types of pipe are designed in accordance with sections 3.6 and 3.9.

Tunnels: There are two tunnels: the condensate tunnel and the essential pipe density tunnel. These tunnels are approximately 135 feet long. The condensate tunnel is 15 feet high and 15 feet wide with the top approximately at grade level. The essential pipe density tunnel is 15 feet high and 30 feet wide with the top approximately at grade level. Both are designed as Category I.

(b) There are no structure-pile-soil medium systems.

(c) The spent fuel pool and new fuel pit structures are discussed in section 3.8.4.1.2. The spent fuel racks are free-standing structures designed and supplied by Combustion Engineering, Inc. The design complies with NRC General Design Criteria 62 and Regulatory Guide 1.13.

✓ Question 3A.18 (NRC Question 220.14) (3.7.4)

Is instrumentation needed for measuring torsional input provided? If yes, describe type, numbers, and layout of the torsional instrumentation.

RESPONSE: Instrumentation for measuring torsional input has not been provided.

✓ Question 3A.19 (NRC Question 220.15) (3.8.1)

Provide the manufacturer's name or the name of the post-tensioned prestressing system used in the Palo Verde containment structures. Has this system been accepted by the NRC staff as indicated in R. G. 1.103?

RESPONSE: The PVNGS containment structures use a BBRV post-tensioned prestressing system. This <sup>system</sup> ~~method~~ is accepted by Regulatory Guide 1.103.

✓ Question 3A.20 (NRC Question 220.16) (3.8.1)

Has buckling been considered in design of containment building? Would it cause any problem in design?

RESPONSE: Buckling has not been considered as part of the design of the containment exterior concrete wall. The 4-foot-thick wall and geometry preclude buckling as a design factor in the containment design. Buckling has been considered in the liner plate design since the liner plate acts as the inside form for the containment shell. (Refer to BC-TOP1A, Rev 1, 1972.)

✓ Question 3A.21 (NRC Question 220.17) (3.8.1)

Provide an ultimate capacity analysis of the containment building in regard to hydrogen burning. The guideline and the staff position on this subject is enclosed (Attachment 2).

RESPONSE: The ultimate capacity of the containment is at least 90 psig.

Question 3A.22 (NRC Question 220.19) (3.8.4)

Are there any (a) intake structures, submerged pipes or tunnels, (b) structure-pile-soil medium systems, (c) spent or new fuel pool structures, used in Palo Verde plants? If yes, describe key dimensions, structure modeling, static and seismic analysis criteria, assumptions and computer codes used. A copy of "Minimum Requirements for Design of Spent Fuel Pool Racks" is enclosed for your reference (Attachment 3).

RESPONSE:

- (a) Intake Structures: The Circulatory Intake Structure is a non-Category I structure.

Submerged Pipe: There are submerged pipes in the essential spray ponds and the spent fuel pool. In the spray ponds the pipes vary in diameter with the maximum dimension being 24 in. The pipes in the fuel pool are 16 in. in diameter. Both types of pipe are designed in accordance with sections 3.6 and 3.9.

Tunnels: There are two tunnels: the condensate tunnel and the essential pipe density tunnel. These tunnels are approximately 135 feet long. The condensate tunnel is 15 feet high and 15 feet wide with the top approximately at grade level. The essential pipe density tunnel is 15 feet high and 30 feet wide with the top approximately at grade level. Both are designed as Category I.

- (b) There are no structure-pile-soil medium systems.
- (c) The spent fuel pool and new fuel pit structures are discussed in section 3.8.4.1.2. The spent fuel racks are free-standing structures designed and supplied by Combustion Engineering, Inc. The design complies with NRC General Design Criteria 62 and Regulatory Guide 1.13.

✓ Question 3A.23 (NRC Question 220.20)

(3.8.4)

Enclosed is a copy of staff interim criteria on safety-related masonry wall evaluation (Attachment 4). Identify any difference in requirements of materials, testing, analysis, design, construction and inspection related to safety-related concrete masonry walls between the Palo Verde design and the staff position. Modify your analysis and design, if necessary, to agree with this interim position. State and discuss your hardship, if any, of compliance.

RESPONSE: The design of masonry walls has been addressed in the response to Question 3A.12. The design of these non-structural concrete masonry walls meets the requirements of NRC SEB Interim Criteria for Safety Related Masonry Wall Evaluation.

✓ Question 3A.24 (NRC Question 220.22)

(3.8.4)

Prepare for the structural design audit scheduled for the week of August 10, 1981. A copy of requirements and guidelines for implementation of structural design audits is enclosed (Attachment 6).

RESPONSE: Preparations have been completed as required for the structural design audit scheduled for August 10, 1981.

*Close up space*

Question 3A.25 (NRC Question 220.23)

(3.5.3)

6 BC-TOP-9A does not cover design of barriers against turbine missiles. Barriers against turbine missiles should be designed in accordance with the requirements and criteria of R. G. 1.115. Address your commitment to comply with R. G. 1.115 or identify and justify all deviations and discrepancies that exist in your design. It is also the staff's position that for turbine missile barriers, penetration and scabbing predictions should be based on empirical equations such as the modified NDRC formula or the results of a valid test program. Other formulas which are supported by test data are acceptable and will be reviewed on a case-by-case basis.

RESPONSE: The response is contained in amended section 3.5.1.3.

### 3.7.4.2.3 Seismic Switches

One triaxial seismic switch with dual setpoint is installed adjacent to the SMA in the containment base slab. It is a backup device which actuates a visual and audible annunciator in the control room if either the SSE or OBE has been exceeded at the seismic switch location. The setpoints for the switch are:

OBE Horizontal = 0.18g	SSE Horizontal = 0.31g
OBE Vertical = 0.17g	SSE Vertical = 0.34g

### 3.7.4.2.4 Response Spectrum Analyzer

The response spectrum analyzer consists of a microprocessor-based computational unit and a printer unit. The computational unit is operated in conjunction with a playback system. The analyzer computes the response spectrum from the recorded data. The printer unit prints response acceleration versus frequency in a hard copy form.

### 3.7.4.2.5 System Control Panel

A panel located in the control room houses the recording, playback, and calibration units which are used in conjunction with the SMA sensors to produce a time-history record of the earthquake. It also contains signal conditioning and display equipment associated with the response spectrum analyzer, audible and visual annunciators associated with the seismic switch, audible and visual annunciators wired to display initiation of the SMA recorder, and the power supply components for the equipment contained within the panel.

### 220.13 3.7.4.3 Control Room Operator Notification

Activation of the seismic triggers causes an audible and visual annunciation in the control room to alert the plant

operator that an earthquake has occurred. This annunciation is initially set to occur at 0.01g horizontal and/or vertical acceleration on the containment tendon gallery or at 0.02g horizontal and/or vertical acceleration in the containment operating floor. These levels cause initiation of the SMA recording system at horizontal or vertical acceleration levels slightly higher than the expected background level, including induced vibrations from sources such as traffic, elevators, people, and machinery. These initial setpoints are based on experience in existing plants and may be changed once significant plant operating data have been obtained which indicate that a different setpoint would provide better SMA system operation. Audible and visual annunciators are provided in the control room to indicate if the SSE or OBE floor accelerations have been exceeded for the seismic switch location, as defined by the design response spectra of figures 3.7-3 and 3.7-4.

The peak acceleration level experienced on the containment tendon gallery is available immediately following the earthquake. This is obtained by playing back the recorded SMA data from this location and reading the peak value for this data from the printer unit.

Significant response spectra from the containment tendon gallery are available in the control room immediately following an earthquake on readout equipment suitable for comparing the measured response spectra with the OBE and SSE response spectra.

#### 3.7.4.4 Comparison of Measured and Predicted Responses

Initial determination of the earthquake level is performed immediately after the earthquake by comparing the measured response spectra from the containment tendon gallery with the OBE and SSE response spectra for the corresponding location.



PALO VERDE NUCLEAR STATION UNITS 1, 2, 3  
DESIGN ADEQUACY AUDIT

STRUCTURAL AUDIT OF CONTAINMENT BUILDING  
Part I - General Analysis

I. BASIC DESIGN CRITERIA

- (1) 'g' value - free field

	Seismic level based on construction permit license	Seismic level used in design of structures and equipment
SSE	0.20g	0.25g
OBE	0.10g	0.13g

Reference: FSAR, Section 3.7

- (2) Spectra (attach figs. for all damping values, ductilities)

A. zero period acceleration

SSE	0.25g
OBE	0.13g

(Pages 89-92)

Reference: FSAR, Figures 3.7-1--3.7-4, and Section 3.7.1.1

This is consistent with Reg. Guide 1.60

Frequency (or period) interval

Refer to BC-TOP-4A, Section 2.5.1 (c)

- (3) Damping

Refer to FSAR, Section 3.7.1.3

This consistent with Reg. Guide 1.61

Refer to FSAR Figures 3.7-5 and 3.7-6 (Pages 92A and 92B)

- (4) Artificial time history and corresponding spectra (attach figures)

A. original time history and its composition, i.e., rising time, strong motion and tail end.

Refer to FSAR, Section 3.7.1.2 and BC-TOP-4A, Section 2.5

8108250913

• 11. 10. 1971



- B. base line correction, check the integrated velocity and displacement time histories

The velocity and displacement time histories were checked and found to be satisfactory. In addition, only the acceleration time history was used as input in analysis.

- C. time interval - compatible with the highest frequency considered in the spectral calculation

0.005 seconds

- (5) Motion duration

24 seconds

Refer to FSAR, Section 3.7.1.2

- (6) components of motion including their relative motion amplitudes

Analysis was performed for the three principle directions with equal amplitudes.

- (7) Dead and live loads for various operating floors and base slab

~~Refer to Project Design Criteria Manual, Part II, Sections 3.5 and~~

~~Part III, Section 4.4.2.~~ Dead load includes all structures, major equipment load and 50 psf equivalent for small equipment  
Live load - See action item 3.

- (8) Internal pressure

Containment Shell: 60 psig design pressure

Reactor Shield Wall and Reactor Cavity: 110 psid design pressure

Steam Generator Compartment: 30 psid design pressure



27

28



(9) Ground water level

The groundwater design level is at plant El 70'-0". The actual water level is at approximately plant EL. 60'-0".

Reference: FSAR, Sections 2.4.13.2.4 and 2.4.13.5.

(10) Backfill earth pressure, wind, overpressure due to postulated external explosions (as applicable)

- 1) The backfill is 23' (The top of the containment basemat is located at elevation 77'-3" and plant grade is elevation 100'-0"). This occurs over about a 120° segment in plan.
- 2) The wind load is not a governing load for the containment structure.
- 3) The containment structure is designed for an external pressure of 4 psig.

Reference: FSAR, Section 6.2.1.1.3.6

(11) Other considerations

None



## II. ANALYSIS METHOD

## (1) Seismic Analysis

## A. Mathematical model-general description with sketch.

Three models were used for the seismic analysis:

- (1) Two planar lumped parameter models were used for a time history analysis to generate in-structure response spectra and determine seismic shear and bending moments for the containment shell design. Refer to FSAR, Figure 3.7-10 and Attachment A for sketches of the models  
(Page 96) (Page 64)
- (2) A 3 dimensional lumped parameter model that was coupled with CE's 3-D NSSS model to be used in their 3-dimensional analysis.
- (3) A finite element model that was used in a modal response spectrum analysis to analyze and design the internal structures. See Attachment B for a sketch of the model.

(a) (Pages 65-70)  
 parameters used

## (i) concrete modulus

$$E_c = 6.00 \times 10^6 \text{ psi} \quad \text{For } f'_c = 6000 \text{ KSI}$$

$$E_c = 5.50 \times 10^6 \text{ psi} \quad \text{for } f'_c = 5000 \text{ KSI}$$

Reference: Project Design Criteria

## (ii) rebar modulus and yield strength

$$E = 29 \times 10^3 \text{ KSI} \quad F_y = 60 \text{ KSI}$$

## (iii) Poisson's ratio

$$\nu = 0.24 \text{ for concrete}$$

## (iv) damping

Refer to FSAR, Section 3.7-1.3 and Table 3.7-1. (Page 88A)  
 This is consistent with Reg. Guide 1.61

## (v) structural steel modulus and yield strength

$$E_s = 29 \times 10^3 \text{ KSI}$$

$$F_y = 36 \text{ KSI}$$





(vi) properties of foundation materials.

- Shear modulus

Refer to FSAR, Figures 3.7-7, 3.7-8, 3.7-9  
(Pages 93-95)

- Subgrade reactions

~~Refer to Project Design Criteria, Part II,  
Section 3.4.5.4 for coefficient of subgrade  
reaction~~

Coefficient of subgrade reaction = 40-60 KIPS/FT<sup>2</sup>  
/FT

- Bearing capabilities

Refer to FSAR, Tables 2.5-15 and 2.5-16 (Pages 87-88)

(vii) other parameters

(Page 93)

Refer to FSAR, Figure 3.7-7 for mass density and  
Poisson's ratio for soil.

b. stiffness calculations

- (1) concrete shell method of incorporating different layers of materials (concrete, rebars, and slip surface). State the method used to account for containment shell cracking due to preoperational pressure tests.

Refer to FSAR, Section 3.7.2.3.2.



(ii) internals

Refer to FSAR, Section 3.7.2.3.2.

B. Method of Analysis

- (a) Method of analysis used (Time history, response spectrum methods, etc.) and consideration of torsional and translational response

Two planar lumped parameter models were used to generate in-structure response spectra from a time-history analysis.

(i) general description

Refer to FSAR, Section 3.7.2.3.2.

The soil structure interaction analysis method was used and compared against current NRC review position and this meets the intent of NRC soil structure interaction position (ii) findings and comments

(b) selection of number of masses and degrees of freedom

(i) general description

Data for the planar models are:

N-S Model: 42 DDOF 42 masses (horizontal)

E-W Model: 42 DDOF 42 masses (horizontal)

Vertical: 21 DDOF, 21 masses.



## (2) findings and comments

## c. number of modes considered

	SSE	OBE
Horizontal (E-W)	10 modes	10 modes
Horizontal (N-S)	12 modes	12 modes
Vertical	6 modes	6 modes

The frequencies of the highest modes considered were all greater than 33 cps.

## (1) general description

Refer to FSAR, Appendix 3A, Question 3A.6.

## (2) findings and comments



d. combining modal responses

This is not applicable for the time history analysis.

(1) actual procedures used

Refer to FSAR, Section 3.7.2.7

(2) general findings

e. consideration of three components of motion

(1) actual procedures used

Refer to FSAR, Section 3.7.2.6

(ii) It is consistent with Reg. Guide 1.92  
general findings





f. consideration of soil-structure interaction and interaction among adjacent buildings

Refer to FSAR, Section 3.7.2.4 for consideration of soil-structure interaction. The containment is separated from the surrounding buildings by means of a 6 inch gap above grade. There is Rodofam below grade which is a compressible material.

Structure-structure interaction is negligible.

(i) general description

See FSAR Section 3.7.2.4 for soil impedance calculation.

Soil Springs:

<u>SSE</u>	$K_X = 1.334 \times 10^6$ K/FT	$K_{XX} = 6.800 \times 10^9$ K-FT/RAD
	$K_Y = 1.911 \times 10^6$ K/FT	$K_{YY} = 9.160 \times 10^9$ K-FT/RAD
	$K_Z = 1.334 \times 10^6$ K/FT	$K_{ZZ} = 6.800 \times 10^9$ K-FT/RAD

<u>OBE</u>	$K_X = 1.720 \times 10^6$ K/FT	$K_{XX} = 8.700 \times 10^9$ K-FT/RAD
	$K_Y = 1.911 \times 10^6$ K/FT	$K_{YY} = 1.178 \times 10^{10}$ K-FT/RAD
	$K_Z = 1.720 \times 10^6$ K/FT	$K_{ZZ} = 8.700 \times 10^9$ K-FT/RAD

X: East - West direction  
Y: Vertical direction  
Z: North - South direction

(ii) findings and comments

g. decoupling criteria for subsystems

(i) general procedure

The mass of a subsystem may be lumped into the supporting structure mass if its mass is less than one-tenth that of the supporting mass. Otherwise, the subsystem must be modeled into the structural model.

Reference: BC-TOP-4A, Rev. 3

(ii) key examples

A lumped parameter model of the NSSS that provided an adequate representation of the mass and stiffness of this subsystem was furnished by Combustion Engineering. The NSSS was then coupled to the structural lumped parameter model. Mass of other major equipment was included in the analysis.

(iii) The other criteria pertaining to frequency ratio as defined in SRP 3.7.3.II.3.b are also met



iv

(iii)

general findings and comments



3. development of in-structure response spectra

Refer to FSAR, Section 3.7.2.5

a. general procedures

The "SPECTRA" program was used to compute the response spectra. Refer to FSAR Appendix 3B for a description and applications of this program.

(i) smoothing (describe specific smoothing method used)

The smoothened response spectra represent an envelope of the maximum peaks.

(ii) peak widening

$\pm 15\%$

Refer to FSAR, Section 3.7.2.9

b. typical results (attach figures)



(i) basemat spectra

Refer to FSAR, Figures 3D-23, -25x (Pages 149 and 150).

(ii) reactor supports spectra

Refer to FSAR, Figures 3D-13, -15, -17x (Pages 144-146).

(iii) steam generator supports

Refer to FSAR, Figure 3D-21x (Page 148).





(iv) Steam generator upper supports

Refer to FSAR, Figures 3D-7, -19x (Pages 141 and 147)

(v) reactor coolant pump support:

Refer to FSAR, Figures 3D-9, -11x (Pages 142 - 143)

(vi) pressurizer supports

Pages 151, 152 and 158 for  
Refer to Project Design Criteria Part IV,  
~~pp. IV-2-25, IV-2-27, IV-2-79~~

applicable response spectra



(vii) operating floor and crane support,  
Pages 156-157 for applicable  
Refer to ~~Project Design Criteria Part IV,~~  
~~pp. IV.2-67 and IV.2-75.~~  
response spectra

(viii) top of steam generator  
Refer to FSAR, Figure 3D-19 (Page 147)

(ix) base of fuel pool  
Pages 153-154 for applicable  
Refer to ~~Project Design Criteria Part IV,~~  
~~pp. IV.2-39 and IV.2-63.~~  
response spectra



- (x) interior floors key floors with floor elevations identified)

Pages 153-156 for applicable  
Refer to ~~Project Design Criteria Part IV,~~  
~~pp. IV.2-39, IV.2-63, IV.2-65, IV.2-67.~~  
response spectra.



**D. Vertical Dynamic Analysis****a. Mathematical Model - general description with sketch**

The vertical dynamic analyses utilized similar models and methods as used for the horizontal dynamic analyses.

(Page 96)

For sketches refer to FSAR, Figure 3.7-10 and Attachment A<sub>x</sub> (Page 64).

**b. Development of stiffnesses, including floor stiffness, as applicable.**

See answer to part (a) above.

**c. Method of Analysis**

See answer to part (a) above.

Description of method used as well as each subitem considered in the analysis

See answer to part (a) above.





E. Seismic Analysis for Polar Crane

a. Mathematical Model - general description with sketch

A lumped mass model was used in conjunction with the response spectrum analysis.

b. Stiffness calculations

c. Inputs

d. Key analysis results



**F. Seismic Analysis for Buried Piping and/or Electrical conduits****a. Method of Analysis**

Refer to Amended FSAR, Section 3.7.3.12 (see Attachment C for buried piping), Pages 70A-70GG, Appendix 3G of Amended FSAR

**b. Stiffness calculations****c. Inputs****d. Key analysis results.**



## 2. Stress Analysis

### A. containment shell

#### a. Mathematical model - general description w/sketch

Refer to FSAR, Section 3.8.1.4 and ~~Final Analysis Design Report~~ Figures A.1-1, A.1-2, A.1-3 (Pages 159-161)

#### b. Method of analysis--incorporation of torsion

The overall analysis of the containment for the application of axisymmetric loads were performed by Bechtel's nonlinear FINEL finite-element computer program.

For the seismic induced loads (non-axisymmetric loads), the analysis was performed by Bechtel's linear elastic ASHSD finite-element computer program. The torsional loads on the axisymmetric containment structure shell are negligible.

Refer to FSAR, Section 3.8.1.4.2.



## B. Containment Internals

## a. mathematical model - general description w/sketch

A three dimensional finite element BSAP model was developed for the analysis and design of the major concrete walls of the internal structures. Concrete slabs and major structural steel members were included in the model for ~~stiffness only~~ <sup>mass and determination</sup>. The structural steel, concrete slabs and other minor structures were analyzed and designed manually. See Attachment B for a sketch of the finite element model.

## b. Method of analysis - incorporation of torsion

A three dimensional finite element model of the containment internal structure was developed to obtain the stress distributions within the interior structure. For seismic induced loads, the response spectra technique was employed. Torsional effects are accounted for by modeling the structure three-dimensionally, inherently incorporating the actual eccentricity of the structure in the analysis. Accidental torsional effects will be addressed in the design.

## c. Load combinations

Refer to FSAR, Section 3.8.3.3. We are in compliance with the SRP

## d. key results (figures, etc.)

<sup>amended</sup>  
Refer to FSAR, Table 3.8-4A. (See Attachment K) (not included)





## C. Foundation mat including reactor pit

## a. mathematical model - description of boundary conditions

In both the ASHSD and <sup>FINEL</sup> ~~Final~~ finite-element analyses, elements were extended into the soil to account for the elastic nature of the soil material and its effect on the behaviour of the basemat.

Refer to FSAR, Section 3.8.1.4.2 and ~~Final Analysis Design Report~~,  
Figures A.1-1, <sup>A</sup> 1-2, A.1-3, and Attachment D<sub>x</sub> (Page 71).

(Pages 159-161)

## b. Method of analysis

The basemat and reactor pit were analyzed using the same methods as for the containment shell. Refer to page 19, part b.

## c. load combinations

Refer to FSAR, Table 3.8-1A<sub>x</sub> (Pages 97 and 98) We are in  
compliance with ASME, III, Div. 2, Subsection CC 3000  
and 8C TOP 5A.

## d. key results (figures, etc.)

Refer to FSAR, Table 3.8-1B<sub>x</sub> (Pages 99 - 107)



## (3) computer programs used in analysis

BSAP, SAP 1.9, ASHSD, OPTCON, FINEL, FOSIN, LUCON, TENDON, SUPER SMIS, CECAP, STICK, STRUDL-DYNAL, SPECTRA, CONDAM.

## A. Assumptions and limitations

See FSAR, Appendix 3B.

## B. applicability

Refer to FSAR, Appendix 3B and FSAR, Sections 3.8.1.4.2, 3.7.2.3, 3.7.2.

## C. Verification

\*Sensitivity study in case of numerical solutions (e.g., finite element analysis)

Refer to FSAR, Appendix 3B

## D. load input (include all cases)

- o Dead and live loads are inputted as gravity loads.
- o Prestressing loads are inputted as either equivalent pressure loads, external loads, or using pseudo thermal loads.
- o Pressure loads are inputted as surface pressure loads.
- o Seismic loads are inputted from the free-field design spectra or from floor response spectra.
- o Thermal loads are inputted as actual temperature differences or as thermal gradients.
- o Equipment reaction loads (including LOCA and seismic loads) are inputted as concentrated loads.



E. Output (include all cases)

See FSAR Appendix 3B.

F. Other discussions



## (4) overall stability

## A. forces and moments from seismic analysis

## ELASTIC FORCES &amp; MOMENTS

	Horizontal Force	Overturning Moment
OBE	24,143 K	$2.60 \times 10^6$ K-FT
SSE	39,600 K	$4.27 \times 10^6$ K-FT

## B. Various cases considered

Seismic event loading combinations considered SSE or OBE applied in the North-South, East-West, and vertical directions simultaneously.





- C. bearing pressure versus bearing capacity and safety factor against bearing failure

Refer to FSAR, Section 2.5.4.10 and Tables 2.5-15 and 2.5-16x (Pages 87 and 88),

- D. factors of safety

Refer to FSAR, Section 3.8.5.5 and Table 3.8-5x (page 111)

- a. sliding

Factor of Safety - 1.2 (SSE)

- b. overturning

Factor of Safety - 1200 (SSE)



(5) interaction of non-category I structures

A) identification of pertinent non-category I structures

None. There are no non-category I structures adjacent to the Containment Building.

B) consideration given to potential failure of non-category I systems on Category I systems

Yes. During a walkdown, those items whose failure will not affect any safety related equipment are left as they are. If they are judged that they might

C) general findings and comments

affect category I systems, they are designed to maintain their structural integrity under an SSE.



III. Conformance to Acceptable Criteria

(1) Identification of deviations, if any

None.

(2) justification of deviations and disposition of the deviations

(3) Comparison of reevaluation results with the original design bases and discussions.

(4) general comments



**PART II - AUDIT OF KEY DESIGNS**

For each key design area audited, the design calculations should be reviewed together with applicable drawings, sketches, etc. Also, key details and/or sections, as appropriate, in this audit report should be included.

**(1) Containment liner design**

conformance with Div. 2-Article CC-3000

The design of the liner plate system conforms to the provisions of "Containment Building Liner Plate Design Report," BC-TOP-1, Revision 1, Bechtel Power Corporation, San Francisco, CA, and "Additional Information Requested by the Atomic Energy Commission on BC-TOP-1, Revision 1, Containment Building Liner Plate Design Report," dated September 1973. *We are in compliance with ASME III, Div. 2, Article CC-3000.*  
specific check of key liner locations

**A. cylinder-base mat junction****(a) sketch**

See Attachment E (Page 72)

**(b) forces and displacement obtained from computer analysis**

Refer to FSAR, Tables 3.8-1A and 3.8-1B (Pages 97-107).





- (c) controlling stress, strain from analysis considering various load combinations

Refer to FSAR, Tables 3.8-1A and 3.8-1B (Pages 97-107),

- B. Anchorage between the liner and interior concrete slab

(Pages 119-120),

Refer to FSAR, Figures 3.8-12 and 3.8-13 and Attachment F (Page 73)

- C. liner anchor design (model, analysis, procedure, assumption)

See response on page 28, item (1)

- D. other embedment design

Polar Crane Bracket

Refer to FSAR, Figure 3.8-20 (Page 124)



E. key penetration design

Refer to FSAR, Figures 3.8-17, 3.8-18 and 3.8-19 (Pages 121-123).

For design, refer to BC-TOP-1 and BC-TOP-5A

F. preliminary audit findings



..  
.  
.  
.



.

.

.



(2) containment hatch design

A. design requirements and assumptions

The design requirements for the concrete portion of the containment equipment hatch are given in the FSAR, Section 3.8.1. The containment equipment hatch analysis used as input the resultant forces and moments obtained from the overall containment analysis..

The steel parts of the equipment hatch not backed by concrete were designed by W. J. Woolley Co. in accordance with the ASME B & PV Code, Section III, Division 1, Subsection NE.

B. model

The equipment hatch area is analyzed using a detailed finite element model. the model incorporates conditions, to account for Symmetrical and Non-Symmetrical Loading. The model has 1750 nodes, 1216 brick elements and 525 truss elements. Brick elements were used to model the concrete and truss elements were used to model the Post-Tensioning System.

(Page 74)

See Attachment G for a sketch of the model

C. analysis procedure and results

A three dimensional finite element model of the equipment hatch was prepared and analyzed by the use of the BSAP computer program. Forces and Moments from BSAP computer programs are used as input for the OPTCON computer program to optimize reinforcing steel.

The steel parts of the equipment hatch were designed manually by W. J. Woolley.



D. key controlling loads including appropriate load combinations

The key controlling loads are:

1.  $D + F + E + T$
2.  $D + F + 1.25P_a + 1.25E + T_a$
3.  $D + F + 1.5P_a + T_a$

D = Dead Load	E = OBE
F = Prestress	$T^o$ = Operating Temperature
$P_a$ = Accident Pressure	$T_a^o$ = Accident Temperature

E. key stresses and strains for section designs





- F. conformance to CC-3000  
concrete portion of the ASME III, DIV. 2, subsection  
The hatch design is in compliance with CC-3000.  
Reference: FSAR, Section 3.8.1.4

The steel hatch design is in compliance with ASME II,  
DIV. 1, subsection NE.

- G. general comments and preliminary audit findings



(3) foundation slab design

A. design requirements and model

The design requirements for the Containment Basemat are given in the FSAR, Section 3.8.1. Sketches of the finite-element computer models are shown in the ~~Containment Final Analysis Design Report~~, Figures A.1-1, A.1-2 and A.1-3x (Pages 159-161)

B. design loads (from general analysis)

Refer to FSAR, Section 3.8.1.3

C. forces and moments at key sections

Refer to FSAR, Tables 3.8-1A and 3.8-1B (Pages 97-107).




D. elastic deformation curve of the slab

See Attachment H (Page 75)

E. detailed design of rebar placement at key section

Refer to FSAR, Figures 3.8-1 and 3.8-2 (Pages 112-113)



F. conformance to CC-3000

ASME III, DIV. 2, subsection

The design of the basemat is in compliance with CC-3000.  
Reference: FSAR, Section 3.8.1.4

G. general comments and preliminary audit findings





(4) containment wall-base mat junction design

A. design requirements and model

See reply on page 34 for foundation slab design.

B. design loads (from general analysis)

Refer to FSAR, Section 3.8.1.3

C. forces and moments at key sections

Refer to FSAR, Tables 3.8-1A and 3.8-1B (Pages 97-107).



D. detailed design of rebar

Refer to FSAR, Figure 3.8-4 (Page 114).

E. Any waterstop membranes at the joint, their design considerations and installations.

(Page 113)

Refer to FSAR Figure 3.8-2. The waterstops are made of styrene - butadiene synthetic rubber. The water stops are used at construction joints below the design groundwater level.

F. Conformance to CC - 3000

ASME III, DIV 2, Subsection

The wall - basemat junction is in compliance with CC-3000.

Reference: FSAR, Section 3.8.1.4



G. general comments and preliminary audit findings



(5) general design for membrane shear forces

A. design requirements and model

Refer to FSAR Section 3.8.1.5.3.

B. design loads (from general analysis)

Refer to FSAR, Section 3.8.1.3

C. forces and moments at key sections

Appendix 3F of Amended FSAR, 75A  
Refer to ~~Appendix J, of the Containment Final Analysis Design~~  
~~Report.~~

(ATTACHMENT I, Pages 75A-75K)





D. detailed design of rebar

Refer to FSAR, Figure 3.8-4 (Page 114).

E. conformance to CC-3000


The ASME Section III, Division 2 Code presently has no tangential shear requirements. Refer to Amended FSAR, Section 3.8.1.5.3 (See Attachment I).

(, Pages 75A-75K, Appendix 3F of  
Amended FSAR

F. general comments and preliminary audit findings







(6) dome-to-cylinder junction design

A. design requirements and model

Refer to answer on page 34, item A.

B. design loads (from general analysis)

Refer to FSAR, Section 3.8.1.3

C. forces and moments at key sections

Refer to FSAR, Tables 3.8-1A and 3.8-1B (Pages 97-107).



D. detailed design of rebar placement at key sections

Refer to FSAR, Figure 3.8-6 (Pages 116 & 117)

E. conformance to CC-3000

subsection The dome-to-cylinder junction design is in compliance with ASME III, Div. 2, CC-3000.

F. general comments and preliminary audit findings





(7) primary shield wall-base mat junction

A. design requirements and model

The primary shield is intended to be the biological shield for the reactor vessel. It also serves as the support for the vessel under all loading conditions. A three dimensional finite element model was used for the analysis and design. See Attachment Jx (Pages 76-77).

B. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

C. forces and moments at key sections

Refer to Amended FSAR, Table 3.8-4A (See attachment K) (not included)



D. detailed design of rebar placement at key sections

Refer to FSAR, Figures 3.8-30, 3.8-31, 3.8-32, and 3.8-33

(Pages 131-134)

E. code jurisdiction boundary definition and anchor treatment at interface.

The boundary between the primary shield and the containment basemat is the containment leaktight boundary. The primary shield is anchored into the reactor pit basemat by means of B-Series Cadwelds welded to the top and bottom of the thickened liner plate. Reinforcing steel is then attached to the B-Series Cadwelds in the reactor pit.

F. conformance to SRP requirements

The design of the primary shield is in compliance with SRP requirements.



G. general comments and preliminary audit findings



(8) operating floor design

A. design requirements and model

The design requirements for the operating floor are given in FSAR, Section 3.8.3. The design of the operating floor was based on manual calculations. A plan of the operating floor is shown in Figures 3.8-35 and 3.8-36 of the FSAR (Pages 137-138)

B. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

C. forces and moments at key sections

Refer to Amended FSAR, Table 3.8-4A (See Attachment K) (not included)





(9) crane support design

A. design requirements and model

Refer to FSAR Section 3.8.3.4 for design requirements. The design of the supports were done manually. A sketch of the polar crane support girders is shown on Figure 3.8-38 of the FSAR (page 140),

B. design loads (from general analysis)

<u>Load Combination</u>	<u>Vertical Downward Load</u>	<u>Horizontal Load</u>
DL+LL+Impact	*563k	31k
DL+OBE	359	147k
DL+SSE	416k	240k

These loads are for each corner of the polar crane. Each corner has two trucks and each truck has two wheels.

C. forces and moments at key sections

For operating conditions

- Maximum moment at mid-span of support girder: 5867 in-k
- Maximum load onto a single polar crane bracket: 305 kips



- D. detailed design of rebar placement at key sections . . .

Refer to FSAR, Figure 3.8-3, 3.8-4 (Pages 113A and 114)

- E. Interface with containment shell, if applicable

For a sketch of the polar crane bracket and its interface with the containment shell, refer to FSAR, Figures 3.8-37 and 3.8-20x (Pages 124 and 139)

- F. conformance with SRP requirements and reevaluation criteria

The design of the crane supports is in compliance with SRP requirements.



G. general comments and preliminary audit findings



(10) reactor vessel support design

A. design requirements and model

The design requirements for all NSSS supports were furnished by Combustion Engineering. Bechtel manually designed the NSSS supports.

For a sketch of the reactor vessel supports, refer to FSAR Figures 3.8-23 and 3.8-24x (Pages 125-126)

B. design loads (from general analysis)

The design loads were furnished by Combustion Engineering.

C. forces and moments at key sections

See Attachment L (Pages 78-79)





D. detailed design of rebar

Refer to FSAR, Figures 3.8-30, -31, -32, -33 (Pages 131-134)

E. conformance with SRP requirements

The reactor vessel support design is in compliance with SRP requirements.

F. general comments and preliminary audit findings



(11) steam generator support design

A. design requirements and model

The design requirements for all NSSS supports were furnished by Combustion Engineering. Bechtel manually designed the NSSS Supports.

For a sketch of the steam generator support, refer to FSAR, figures 3.8-25 and 3.8-26 $\chi$  (Pages 127-128)

B. design loads (from general analysis)

The design loads were furnished by Combustion Engineering.

C. forces and moments at key sections

See Attachment M (Pages 80-82)



D. detailed design of rebar placement at key sections

See Attachment N (Pages 83-84)

E. conformance with SRP requirements

The steam generator support design is in compliance with SRP requirements.

F. general comments and preliminary audit findings



(12) coolant pump support design

A. design requirements and model

The design requirements for all NSSS Supports were furnished by Combustion Engineering. Bechtel manually designed the NSSS supports.

For a sketch of the reactor coolant pump supports, refer to FSAR, Figure 3.8-27 and 3.8-28x (Pages 129-130)

B. design loads (from general analysis)

The design loads were furnished by Combustion Engineering.

C. forces and moments at key sections

MAXIMUM TENSION IN ANCHOR BOLTS

	<u>DESIGN</u>	<u>ALLOWABLE</u>
Lower Supports	280 <sup>k</sup>	600 <sup>k</sup>
Lower Lateral Supports	242 <sup>k</sup>	600 <sup>k</sup>
Upper Lateral Support	256 <sup>k</sup>	600 <sup>k</sup>
Snubber Supports	204 <sup>k</sup>	600 <sup>k</sup>

Reference: FSAR, Figure 3.8-27, and 3.8-28 (Pages 129-130)





D. detailed design of rebar placement at key section

See Attachment 0 (Page 85)

E. conformance with SRP requirements

The reactor coolant pump support design is in compliance with SRP requirements.

F. general comments and preliminary audit findings



(13) secondary shield walls

A. design requirements and model

The design requirements for the secondary shield walls are given in FSAR, Section 3.8.3. See Attachment B, for sketches of the finite element model used in the analysis and design.

(Pages 65-70)

B. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3

C. forces and moments at key sections

Refer to Amended FSAR, Table 3.8-4A (See Attachment K) (not included)




D. detailed design of rebar placement at key section

Refer to FSAR, Figure 3.8-34 (Page 136)

E. conformance with SRP criteria

The design of the secondary shield walls are in compliance with SRP requirements.

F. general comments and preliminary audit findings



(13) other steel structures

A. design requirements and model

The design requirements for structural steel within the containment structure are given in the FSAR Section 3.8.3. The steel structures were designed by conventional hand calculations.

B. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3

C. forces and moments at key sections

Refer to FSAR, Table 3.8-4B (Pages 108-110)





D. detailed design

See Attachment P ( Page 86 )

E. conformance with SRP requirements

The steel design is in compliance with SRP requirements.

F. general comments and preliminary audit findings



(15) Post-Tensioning System and Anchorage

A. Post-Tensioning System

1. Tendon System used

The post-tensioning system used is the BBRV system. The tendons consists of 186-1/4 inch diameter, high strength wire in conformance with ASTM A421 Type BA. The wires are anchored by means of button heads. Reference: FSAR, Figure 3.8-7 (Page 115)

2. Prestressing force at transfer

Cylinder Hoop Tendons - 1495 kips per tendon (163.8 ksi)  
Dome Hoop Tendons - 1496 kips per tendon (163.9 ksi)  
Vertical  $\cap$  shaped tendons at top of dome - 1299 kips per tendon (142.3 ksi).

3. Tendon load under LOCA

Cylinder Hoop Tendons - 1237 kips per tendon (135.5 ksi)  
Dome Hoop Tendons - 1255 kips per tendon (137.5 ksi)  
Vertical  $\cap$  shaped tendons, at top of dome - 1055 kips per tendon (115.5 ksi). The forces and stresses given above are after all losses at the end of plant life.

4. Method used to calculate transfer losses:

a) Friction Calculated from the equation  $f_x = f_o e^{-(KL + \mu \alpha)}$  given in ACI-318-71, Chapter 18.

b) creep

Based on creep strain of  $500 \times 10^{-6}$  in/in at the end of plant life.

c) Concrete shrinkage.

Based on shrinkage strain of  $100 \times 10^{-6}$  in/in at the end of plant life.

5. Buttress Design

a) Maximum bursting stress in concrete

Refer to BC-TOP-7, "Full Scale Buttress Test for Prestressed Nuclear Containment Structures"



- b) Reinforcing provided to resist bursting stresses . .

(Page 115)

For a sketch of the reinforcement in the buttress, refer to the FSAR, Figure 3.8-5. The design of the tendon anchorage zones is based on two test programs conducted by Bechtel to demonstrate the adequacy of several reinforcing patterns for use in anchorage-zone concrete in the basemat and buttresses. The test results demonstrate satisfactory performance of the test anchorages. The design of the tendon anchorage zones is based on the results and recommendations of these tests. Refer to the FSAR, Section 3.8.1.4.4 for a description of the test programs.

- c) Stress under the anchor plate

3.5 ksi

- d) Allowable stresses

4.2 ksi

- e) Stress under the "  $\cap$  " tendons anchorage

3.5 ksi

- f) Method of calculation of stresses

The stresses were determined by a manual calculation


- g) Allowable stresses

4.2 ksi

3.6



DYNAMIC DEGREE OF FREEDOM	HORIZONTAL		VERTICAL	
	NODE DISPLACEMENT	DYNAMIC DEGREE OF FREEDOM	NODE DISPLACEMENT	DYNAMIC DEGREE OF FREEDOM
1	U <sub>1</sub>	U <sub>1</sub>	U <sub>1</sub>	V <sub>1</sub>
2	U <sub>2</sub>	U <sub>2</sub>	U <sub>2</sub>	V <sub>2</sub>
3	U <sub>3</sub>	U <sub>3</sub>	U <sub>3</sub>	V <sub>3</sub>
4	U <sub>4</sub>	U <sub>4</sub>	U <sub>4</sub>	V <sub>4</sub>
5	U <sub>5</sub>	U <sub>5</sub>	U <sub>5</sub>	V <sub>5</sub>
6	U <sub>6</sub>	U <sub>6</sub>	U <sub>6</sub>	V <sub>6</sub>
7	U <sub>7</sub>	U <sub>7</sub>	U <sub>7</sub>	V <sub>7</sub>
8	U <sub>8</sub>	U <sub>8</sub>	U <sub>8</sub>	V <sub>8</sub>
9	U <sub>9</sub>	U <sub>9</sub>	U <sub>9</sub>	V <sub>9</sub>
10	U <sub>10</sub>	U <sub>10</sub>	U <sub>10</sub>	V <sub>10</sub>
11	U <sub>11</sub>	U <sub>11</sub>	U <sub>11</sub>	V <sub>11</sub>
12	U <sub>12</sub>	U <sub>12</sub>	U <sub>12</sub>	V <sub>12</sub>
13	U <sub>13</sub>	U <sub>13</sub>	U <sub>13</sub>	V <sub>13</sub>
14	U <sub>14</sub>	U <sub>14</sub>	U <sub>14</sub>	V <sub>14</sub>
15	U <sub>15</sub>	U <sub>15</sub>	U <sub>15</sub>	V <sub>15</sub>
16	U <sub>16</sub>	U <sub>16</sub>	U <sub>16</sub>	V <sub>16</sub>
17	U <sub>17</sub>	U <sub>17</sub>	U <sub>17</sub>	V <sub>17</sub>
18	U <sub>18</sub>	U <sub>18</sub>	U <sub>18</sub>	V <sub>18</sub>
19	U <sub>19</sub>	U <sub>19</sub>	U <sub>19</sub>	V <sub>19</sub>
20	U <sub>20</sub>	U <sub>20</sub>	U <sub>20</sub>	V <sub>20</sub>
21	U <sub>21</sub>	U <sub>21</sub>	U <sub>21</sub>	V <sub>21</sub>
22	U <sub>22</sub>	U <sub>22</sub>	U <sub>22</sub>	V <sub>22</sub>
23	U <sub>23</sub>	U <sub>23</sub>	U <sub>23</sub>	V <sub>23</sub>
24	U <sub>24</sub>	U <sub>24</sub>	U <sub>24</sub>	V <sub>24</sub>
25	U <sub>25</sub>	U <sub>25</sub>	U <sub>25</sub>	V <sub>25</sub>
26	U <sub>26</sub>	U <sub>26</sub>	U <sub>26</sub>	V <sub>26</sub>
27	U <sub>27</sub>	U <sub>27</sub>	U <sub>27</sub>	V <sub>27</sub>
28	U <sub>28</sub>	U <sub>28</sub>	U <sub>28</sub>	V <sub>28</sub>
29	U <sub>29</sub>	U <sub>29</sub>	U <sub>29</sub>	V <sub>29</sub>
30	U <sub>30</sub>	U <sub>30</sub>	U <sub>30</sub>	V <sub>30</sub>
31	U <sub>31</sub>	U <sub>31</sub>	U <sub>31</sub>	V <sub>31</sub>
32	U <sub>32</sub>	U <sub>32</sub>	U <sub>32</sub>	V <sub>32</sub>
33	U <sub>33</sub>	U <sub>33</sub>	U <sub>33</sub>	V <sub>33</sub>
34	U <sub>34</sub>	U <sub>34</sub>	U <sub>34</sub>	V <sub>34</sub>
35	U <sub>35</sub>	U <sub>35</sub>	U <sub>35</sub>	V <sub>35</sub>
36	U <sub>36</sub>	U <sub>36</sub>	U <sub>36</sub>	V <sub>36</sub>
37	U <sub>37</sub>	U <sub>37</sub>	U <sub>37</sub>	V <sub>37</sub>
38	U <sub>38</sub>	U <sub>38</sub>	U <sub>38</sub>	V <sub>38</sub>
39	U <sub>39</sub>	U <sub>39</sub>	U <sub>39</sub>	V <sub>39</sub>
40	U <sub>40</sub>	U <sub>40</sub>	U <sub>40</sub>	V <sub>40</sub>
41	U <sub>41</sub>	U <sub>41</sub>	U <sub>41</sub>	V <sub>41</sub>
42	U <sub>42</sub>	U <sub>42</sub>	U <sub>42</sub>	V <sub>42</sub>



**LEGEND**

- RIGID MEMBER
- MASS POINT
- NODE POINT
- NA - TRANSLATIONAL SPRING
- ROTATIONAL SPRING
- MEMBER NUMBER

MODEL FOR N-S DIRECTION (PERPENDICULAR TO THE REACTOR HOT LEG)

ATTACHMENT A

<b>BECHTEL</b> LOS ANGELES	CONTAINMENT SEISMIC ANALYSIS	
	CONTAINMENT - INTERNAL BSS	
ARIZONA NUCLEAR POWER PROJECT PAJO VERDE NUCLEAR GENERATING STATION	10000 10000	SR C 275





This drawing is the property of Bechtel Inc. and is not to be distributed outside the project without the written consent of Bechtel Inc.

64





This drawing has been prepared in accordance with the standards and specifications of the American Institute of Steel Construction, Inc. and the American Institute of Mechanical Engineers, Inc. The design of the structure and the details thereof are the responsibility of the designer. The designer shall be held responsible for any errors or omissions. This drawing is not to be used for any other purpose without the written consent of the designer.



**NOTES**  
 1) THE LOCAL Z AXIS OF ALL SHELL ELEMENTS IS POINTING OUTWARD FROM THE PAPER.

- LEGEND**
- SHELL ELEMENT NO. (ELEMENT GROUP #3 UNB)
  - △ COLUMN ELEMENT NO. (ELEMENT GROUP #2)
  - BECK ELEMENT NO. (ELEMENT GROUP #4)
  - || BEAM ELEMENT NO. FOR SHELL AND AISC BEAMS (ELEMENT GROUP #6)



NO.	DESCRIPTION	DATE	BY	CHECKED

**BECHTEL**  
 LOS ANGELES  
 ARIZONA NUCLEAR POWER PROJECT  
 PAJO VERDE NUCLEAR  
 GENERATING STATION


SHEET NO. 117 OF 117  
 DATE: 11/15/68  
 SCALE: AS SHOWN









ISOMETRIC  
RESOURCES  
BEAMS (20-40-7)




PLAN VIEW - EL. 114 UNO.




PLAN VIEW - EL. 119



PLAN VIEW - EL. 125




PLAN VIEW - EL. 132 UNO.




PLAN VIEW - EL. 133


<p>RECNTEL 100 ANGELES</p> <p>ARIZONA NUCLEAR POWER PROJECT PAJO VERDE NUCLEAR GENERATING STATION</p>										<p>Sheet No. 110 of 3 of 6</p>	
---	--	--	--	--	--	--	--	--	--	------------------------------------	--

67







PLAN VIEW - EL 144





PLAN VIEW - EL 151




PLAN VIEW  
EL. 165  
GR. SCL. DIMENTS  
C=1.0 UNO.

PLAN VIEW - EL 155 UNO.



PLAN VIEW - EL. 160



UPPER CONTAINMENT SHELL

- 2009 EL. 189.11'
- 1997 EL. 169.11'
- 1995 EL. 178.11'
- 1993 EL. 173.11'
- 1991 EL. 184.11'
- 1989 EL. 159.11'
- 1987 EL. 159.11'
- 1985 EL. 159.11'

LOWER CONTAINMENT SHELL

ATTACHMENT B  
4 OF 6

**BECHTEL**  
LOS ANGELES

ARIZONA NUCLEAR POWER PROJECT  
PAJO VERDE NUCLEAR  
GENERATING STATION





03AP Containment Structure  
FROM PRELIMINARY WORK  
DATE: 11.11.80

8






This drawing is a reproduction of the original drawing and is not to be used for any other purpose than that for which it was prepared. The original drawing is the property of the Arizona Nuclear Power Project and is not to be reproduced without the written permission of the Project.



<b>BECHTEL</b> LOS ANGELES		Project: ARIZONA NUCLEAR POWER PROJECT Drawing: PALO VERDE NUCLEAR GENERATING STATION Title: SECURITY SHIELD WALLS Date: 11/1/77 Scale: AS SHOWN Drawing No.: 34776
Revision No. 1 Description Initials Date	Revision No. 2 Description Initials Date	Revision No. 3 Description Initials Date



THIS DRAWING IS THE PROPERTY OF BECHTEL INCORPORATED. IT IS TO BE USED ONLY FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED HEREIN. IT IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF BECHTEL INCORPORATED.



<b>BECHTEL</b> LOS ANGELES		DRAWING NUMBER: 111111 SHEET NUMBER: 1 OF 1	
<b>ARIZONA NUCLEAR POWER PROJECT</b> <b>PALO VERDE NUCLEAR</b> <b>GENERATING STATION</b>		DATE: 11/11/77 SCALE: AS SHOWN	

ATTACHMENT B 6 OF 6

70



PVNGS FSAR

OK 8/1/81  
REVIEW

EDIT. SECTION  
AUG 08 1981  
IN OUT

ATTACHMENT C

33 SHEETS

APPENDIX 3G  
SEISMIC STRESSES IN  
UNDERGROUND STRUCTURES

6

Jan 1981

08-06-81

Amendment  
70A

6



SEISMIC STRESSES IN UNDERGROUND STRUCTURES3G.1 SUMMARY

This section describes methods used for seismic analysis of buried structures such as conduits, tunnels, and well casings. The effects of earthquakes on buried structures may be broadly grouped into two classes: faulting and shaking. Faulting includes the direct, primary shearing displacement of bedrock which may carry through the overburden to the ground surface. Such direct shearing of the rock or soil is generally limited to relatively narrow zones of seismically active faults which may be identified by geological and seismological surveys. From a structural viewpoint, landsliding, ground fissuring, and consolidation of backfill soil have similar effects on buried structures. In general, it is not desirable to design structures to directly sustain such major soil displacements. However, design measures can be taken to mitigate the effects of the displacements and to identify and avoid areas prone to such displacements.

The effects of earthquake ground motion on underground conduits, in the absence of direct fault displacement or unstable soil conditions such as liquefaction, are:

1. Axial tension and compression due to traveling seismic wave
2. Shear and bending due to traveling seismic wave
3. Strain caused by dynamic differential movement at connections

Analytical procedures for evaluating these effects are described in the following sections. For very long structures, and procedures are based on the assumption that there is no relative motion between the flexible structure and the





## APPENDIX 3G

ground. Seismic stresses in the conduit are estimated from the calculated strains and curvature in the surrounding soil due to the passage of seismic waves. For short structures, slippage may occur between the conduit and the soil and the calculated axial stresses are proportionately less than those assuming the conduit strain equal to the soil strain. The effects of bends and differential displacement at connections to buildings are evaluated using procedures based on equations for beams on elastic foundations. The calculated seismic stresses must be combined with stresses from other loading conditions, including pressure and surcharge loading, for final design.

The interaction of stresses and strains due to seismic wave propagation and boundary displacements, both at bends and at structures, is a complicated problem. The conservative assumption can be made that the strains due to the several sources are additive and, hence, an SRSS combination may be used. In case these resultant stresses and strains are unacceptable, the problem can be circumvented by designing discontinuities to be flexible to allow for the resultant displacements.

### 3G.2 STRESSES IN STRAIGHT SECTIONS

#### 3G.2.1 GENERAL EQUATIONS FOR AXIAL AND BENDING STRAIN

The portions of a long, buried structure far from the ends and free of any external support other than the surrounding soil are assumed to be flexible and to follow essentially the displacements and deformations of the soil during seismic ground motion. Soil displacements due to the passage of shear, compression, and surface waves are calculated based on wave propagation velocities and the maximum ground particle acceleration and velocity due to the design earthquake.



## APPENDIX 3G

Stresses in the structure are calculated using the resulting strain, curvature, and modulus of elasticity of the structural material.

The assumption that relative motion between the buried structure and the surrounding soil is negligible has been shown by O'Rourke and Wang (1978) to be a valid assumption for most practical cases. For special situations where the relative motion is not negligible, and analysis techniques described by Hindy and Novak (1978) and O'Rourke and Wang (1978) can be used. Internal walls which may not follow the motion of the surrounding soil can be treated as simple oscillators subject to the design ground motion at the depth of burial.

The basic relations for calculating maximum longitudinal strain and curvature induced in a flexible, buried structure have been presented by Hall and Newmark (1978). For a compression wave propagating along the longitudinal axis of the buried structure

$$\epsilon_m = \pm \frac{v_{mp}}{C_p} \quad (3G-1)$$

and for a shear wave propagating along the longitudinal axis

$$\epsilon_m = \pm \frac{v_{ms}}{2C_s} \quad (3G-2)$$

$$K_m = \frac{a_{ms}}{C_s^2} \quad (3G-3)$$

where

- $\epsilon_m$  = maximum longitudinal strain
- $K_m$  = maximum curvature
- $v_{mp}$  = maximum compression wave particle velocity
- $v_{ms}$  = maximum shear wave particle velocity
- $a_{ms}$  = maximum shear wave particle acceleration



## APPENDIX 3G

$C_p$  = compression wave propagation velocity  
 $C_s$  = shear wave propagation velocity

The maximum strain as given by Eqs. 3G-1 and 3G-2 is an upper bound since it is limited by the pipe-soil interface friction. Slippage would occur if the computed axial force,  $\epsilon_m AE$ , exceeds the frictional resistance as given by Eq. 3G-21.

The appropriate particle acceleration ( $a_m$ ) for calculating maximum soil strain is the maximum ground acceleration. The maximum particle velocity should be selected for the corresponding wave type. For example, the maximum ground velocity for the compression wave portion of ground motion prior to arrival of the surface wave component is typically less than the maximum ground velocity associated with the surface wave component. Therefore, it may be unnecessarily conservative to take the maximum ground velocity in the entire ground motion when calculating maximum soil strain due to a compression wave.

The value of wave propagation velocity to be used when calculating maximum soil strain surrounding a buried structure is the effective velocity of the ground motion disturbance past the structure. For rock or very stiff and dense soils, the effective propagation velocity is equal to the in-situ wave propagation velocity as measured by field or laboratory tests. If the structure is embedded in a softer layer or at a shallow depth in uniform soils, the effective propagation velocity should be taken as the propagation velocity of the underlying competent soil or rock (Hall and Newmark, 1978). For example, the effective shear wave propagation velocity should not be taken as less than the shear wave velocity at a depth of 400 to 500 feet or, in any case, never less than about 2000 fps.



## 3G.2.2 MAXIMUM AXIAL AND BENDING STRESSES

Equations for calculating maximum axial and bending stresses as a function of angle of incidence of the various wave-types have been presented by Yeh (1974). For an oblique compression wave of amplitude  $A_p$  (Fig. 3G-1a).

$$\sigma_a = \pm \frac{E v_{mp}}{c_p} \cos^2 \theta \quad (3G-4)$$

$$\sigma_b = \pm \frac{E R a_{mp}}{c_p^2} \sin \theta \cos^2 \theta \quad (3G-5)$$

where

$\sigma_a$  = maximum axial stress

$\sigma_b$  = maximum bending stress

E = modulus of elasticity for the structure

$v_{mp}$  = maximum compression wave particle velocity

$a_{mp}$  = maximum compression wave particle acceleration

R = distance from the cross-sectional neutral axis of the structure to the extreme fiber

$\theta$  = angle of incidence of propagating wave from the structural axis

The maximum possible values of the axial and bending stresses due to an oblique compression wave are

$$\sigma_a = \pm \frac{E v_{mp}}{c_p} \quad \text{for } \theta = 0^\circ \quad (3G-6)$$

$$\sigma_b = \pm 0.385 \frac{E R a_{mp}}{c_p^2} \quad \text{for } \theta = 35^\circ 16' \quad (3G-7)$$

For an oblique shear wave of amplitude  $A_s$  (Fig. 3G-1b)

$$\sigma_a = \pm \frac{E v_{ms}}{c_s} \sin \theta \cos \theta \quad (3G-8)$$





REVIEW

## APPENDIX 3G

$$\sigma_b = \pm \frac{E v_{ms} a_{ms}}{2 C_s} \cos^3 \theta \quad (3G-9)$$

where

 $v_{ms}$  = maximum shear wave particle velocity $a_{ms}$  = maximum shear wave particle acceleration

The maximum possible values of the axial and bending stresses due to an oblique shear wave are

$$\sigma_a = \pm \frac{E v_{ms}}{2 C_s} \quad \text{for } \theta = 45^\circ \quad (3G-10)$$

$$\sigma_b = \pm \frac{E v_{ms} a_{ms}}{C_s^2} \quad \text{for } \theta = 0^\circ \quad (3G-11)$$

For an incident surface wave of amplitude  $A_R$ , the motion is equivalent to the combination of a compression wave of amplitude  $A_{Rp}$  and a shear wave of amplitude  $A_{Rs}$  (Fig. 3G-1c) and

$$\sigma_a = \pm \frac{E v_{mr}}{C_R} \cos^2 \theta \quad (3G-12)$$

$$\sigma_b = \pm \frac{E v_{mr} a_{mr}}{C_R^2} \sin \theta \cos^2 \theta \quad (3G-13)$$

for the compressional component

$$\sigma_b = \pm \frac{E v_{mr} a_{mr}}{C_R^2} \cos^2 \theta \quad (3G-14)$$

for the shear component

where

 $v_{mr}$  = maximum surface wave particle velocity $a_{mr}$  = maximum surface wave particle acceleration $C_R$  = surface wave propagation velocity



## APPENDIX 3G

The maximum possible values of the axial and bending stresses due to an incident surface wave are

$$\sigma_a = \pm \frac{Ev_{mr}}{C_R} \quad \text{for } \theta = 0^\circ \quad (3G-15)$$

$$\sigma_b = \pm 0.385 \frac{ERa_{mr}}{C_R^2} \quad \text{at } \theta = 36^\circ 16' \quad (3G-16)$$

for the compressional component

$$\sigma_b = \pm \frac{ERa_{mr}}{C_R^2} \quad \text{at } \theta = 0^\circ \quad (3G-17)$$

for the shear component

### 3G.2.3 WAVE TYPES AND COMBINATION OF STRESSES

The maximum ground velocity and acceleration for an earthquake motion contain contributions from compressional, shear, and surface waves. The choice of wave type to be used for design depends on the location and orientation of the structure to the earthquake source, as well as on the nature of the source and local geologic conditions along the travel path.

It is not presently possible, in general, to determine the relative contributions to the total motion of each of the various wave types. The axial and bending stresses should be maximized separately according to wave type and angle of incidence, and the resulting maximums for axial and bending stress should be combined by the SRSS method since the maximum values are unlikely to occur simultaneously.

The calculated axial and bending stresses are combined to provide the total seismic design stress. The combined stress is maximized for an incident angle between  $0^\circ$  and  $45^\circ$  for each wave type using the equations provided in section 3G.2.2. This combined stress for each wave type will always be less than the sum of the maximum possible values of axial and



## APPENDIX 3G

bending stress which are based on different angles of incidence and, therefore, do not occur simultaneously. The maximized values of axial and bending stress for each wave type are then combined using the SRSS method to give the total seismic design stress ( $\sigma_a + \sigma_b$ ) as follows:

$$\sigma_a = \pm \left[ (\sigma_{ap})^2 + (\sigma_{as})^2 + (\sigma_{ar})^2 \right]^{1/2} \quad (3G-18)$$

$$\sigma_b = \pm \left[ (\sigma_{bp})^2 + (\sigma_{bs})^2 + (\sigma_{br})^2 \right]^{1/2} \quad (3G-19)$$

where the subscripts p, s, and r identify the maximum axial and bending stresses due to a compressional, shear, and surface wave, respectively.

For buried piping of relatively small diameter (less than about 48 inches), the bending stresses are small compared to the calculated normal stresses. In this case, the maximum possible values of axial and bending stress for each wave type can be added directly without performing the maximizing procedure prior to combining. For buried structures of much greater dimensions, such as tunnels, and bending stress will be significant compared to the axial component and the maximizing procedure should be carried out.

If the calculated stresses exceed the allowable stresses, increasing the cross-sectional area of the structure is of no value since the stresses are due to an imposed strain. In this case, the solution may be to either articulate the structure to make it more flexible or to isolate the structure partially or completely from the surrounding soil.

#### 3G.2.4 SHORT SECTIONS

In case of a straight structural element embedded in soil, the transfer of soil strain as axial strain into the element depends on the end bearing of the element against the soil



## APPENDIX 3G

and the frictional resistance between the element surface and the soil. At the ends of a long, straight element, frictional resistance will develop for some length ( $\ell$ ) along which the element will displace relative to the surrounding soil due to strain incompatibility between the soil and the element (Fig. 3G-2a). Neglecting end bearing, the minimum length of structure ( $L$ ) required to develop full friction has been shown by Shah and Chu (1974) to be twice the maximum slippage length ( $\ell_m$ ) which is calculated as follows:

$$\ell_m = \frac{\epsilon_m AE}{f} \quad (3G-20)$$

where

- $\epsilon_m$  = maximum soil strain
- $A$  = structure cross-sectional area
- $E$  = structure modulus of elasticity
- $f$  = friction force per unit length

For buried structures where  $L < 2\ell_m$ , the calculated axial stresses will be proportionately less than those calculated assuming no relative slippage between the structure and the soil (Fig. 3G-2b).

The frictional force ( $f$ ) per unit length of a pipeline structure is given by

$$f = \pi D p_r \mu \quad (3G-21)$$

where

- $D$  = pipe diameter
- $p_r$  = average radial soil pressure on pipe
- $\mu$  = coefficient of friction

The average radial soil pressure on the pipe ( $p_r$ ) is approximated by

$$p_r = \left( \frac{1 + K_o}{2} \right) \gamma_{\text{soil}} H_d \quad (3G-22)$$





where

$K_0$  = coefficient of lateral stress at rest

$\gamma_{\text{soil}}$  = soil unit weight

$H_d$  = burial depth at pipe centerline

The parameters ( $\mu$ ) and ( $K_0$ ) are evaluated based on the type of structural material and soil conditions for a specific project. The coefficient of friction ( $\mu$ ) is typically in the range of 0.3 to 0.5 for a smooth pipe embedded in soil. The lateral stress coefficient ( $K_0$ ) typically ranges from 0.5 to 1.0.

### 3G.2.5 AXIAL DISPLACEMENT OF FREE END RELATIVE TO THE SOIL

Neglecting the effect of end bearing and considering the maximum soil strain to remain constant over the length of the structure, Shah and Chu (1974) give the longitudinal displacement of the ends of a structure relative to the soil as follows:

$$\Delta = \epsilon_m \ell_e - \frac{f \ell_e^2}{2AE} \quad (3G-23)$$

where

$$\Delta = \Delta(\text{soil}) - \Delta(\text{structure})$$

$\ell_e$  = effective slippage length (Fig. 3G-2b)

In the case of a short structure where  $L < 2\ell_m$ , the effective slippage length equals one-half the total length ( $\ell_e = L/2$ ) and

$$\Delta = \frac{\epsilon_m L}{2} - \frac{fL^2}{8AE} \quad (3G-24)$$

For a long structure,  $\ell_e = \ell_m$  and

$$\Delta = \frac{\epsilon_m \ell_m}{2} - \frac{\epsilon_m^2 AE}{2f} \quad (3G-25)$$



Provisions should be made in the design to accommodate this displacement at the intersection of long elements with massive embedded structures.

### 3G.2.6 SHEAR FORCE DUE TO AN AXIAL SHEAR WAVE

The basic relations for maximum longitudinal strain and curvature presented by Hall and Newmark (1978) can be extended to provide the rate of change of curvature of a buried structure due to a propagating shear wave. For a shear wave propagating with wave velocity ( $C_s$ ) along the x-axis, the particle displacement in the transverse (y) direction is

$$y = f(x - C_s t) \quad (3G-26)$$

The third derivative of equation (3G-26) with respect to x and t gives the following relation for the rate of change of curvature

$$\frac{\partial^3 y}{\partial x^3} = f'''(x - C_s t) = -\frac{1}{C_s^3} \left( \frac{\partial^3 y}{\partial t^3} \right) \quad (3G-27)$$

Defining (h) as the maximum derivative of the ground acceleration

$$h = \frac{\partial^3 y}{\partial t^3} \quad (3G-28)$$

and using the elementary beam relationship between the change in curvature and the shearing force (Q)

$$Q = -EI \left( \frac{\partial^3 y}{\partial x^3} \right) \quad (3G-29)$$

The shearing force in the buried structure is

$$Q = EIh/C_s^3 \quad (3G-30)$$



## APPENDIX 3G

The quantity (h) can be evaluated using the relationships between the maximum values of ground acceleration, displacement, and velocity where  $a_m d_m / v_m^2 = 6$  (Hall and Newmark, 1978, Table 1) and  $h v_m / a_m^2 = \beta a_m d_m / v_m^2$  (Newmark and Rosenblueth, 1971, p. 492). The coefficient ( $\beta$ ) accounts for uncertainties in the relationship between the various ground motion parameters, with a reasonable level of conservatism obtained by taking  $\beta = 1.5$ . Based on these assumptions

$$h = 9a_m^2 / v_m \quad (3G-31)$$

Combining equations (3G-30) and (3G-31) yields the following expression for the maximum shear force in the structure

$$Q = \frac{9EIa_m^2}{C_s^3 v_m} \quad (3G-32)$$

## 3G.2.7 CURVATURE

The maximum curvature ( $K_m$ ) at a point can be calculated using Eq. (3G-3). If the calculated curvature is equal to or less than the allowable value of  $M/EI$ , the structure can be assumed to follow the ground motion without overstress and no articulation is necessary. However, some rotational capability may be required in sections where the calculated curvature exceeds the allowable value of  $M/EI$  and in the vicinity of connections to structures. The angular distortion for a given length of structure (L) can be calculated using the relation

$$\phi = K_m L \quad (3G-33)$$

If sections of an underground structure are effectively isolated from the surrounding component soil, the angular distortion is a function of the relative motion of the support points. The maximum relative motion in the transverse



## APPENDIX 3G

direction between two points a distance (L) apart during an earthquake can be calculated according to Yeh (1974):

$$\Delta = \frac{v_{ms} L}{C_s} \quad (3G-34)$$

The angular distortion is then

$$\phi = \arcsin \frac{\Delta}{L} \quad (3G-35)$$

Sufficient rotational capability should be provided at joints and connections to permit the calculated angular distortion ( $\phi$ ) from the appropriate equation above.

### 3G.3 STRESSES AT BENDS

#### 3G.3.1 GENERAL PROCEDURE

The analysis of buried structures with bends or restrained ends is based on the equations for beams on elastic foundations derived by Hetenyi (1946). In the case of a bend, the transverse leg is assumed to deform as a beam on an elastic foundation due to the axial force in the longitudinal leg (Fig. 3G-3). The displacement ( $\Delta$ ) at the bend is defined by the overall spring constant at the bend (K) where

$$K = \frac{P}{\Delta} \quad (3G-36)$$

The spring constant at the bend depends on the stiffness of the longitudinal and transverse legs as well as the degree of fixity at the bend and at the far ends of the legs. The approximate deformed shapes for a number of typical combinations of leg stiffness and end condition are shown in Fig. 3G-5. The stiffness of the leg is classified according to Hetenyi (1946) as rigid ( $\lambda L < \pi/4$ ), intermediate ( $\pi/4 < \lambda L < \pi$ ), and flexible ( $\lambda L > \pi$ ) where

$$\lambda = \sqrt[4]{k/4EI} \text{ system characteristic}$$

$$L = \text{length of the leg}$$





## APPENDIX 3G

$k_s$  = modulus of subgrade reaction for structure of width (B)

$k = k_s(B)$  where B is width of the structure

Solutions for the bend spring constant (K) for some typical configurations (cases A through E) are shown in table 3G-1. Solutions for other configurations can be derived using the appropriate equations for beams on elastic foundations.

## 3G.3.2 EQUATIONS FOR STRUCTURE WITH RESTRAINED END

The configuration and deformed shape of a buried structure with a bend are shown in Fig. 3G-4. According to Shah and Chu (1974), the maximum axial force is

$$F_{\max} = Q + fl_e \quad (3G-37)$$

and

$$\Delta = \frac{Q}{K} \quad (3G-38)$$

Establishing displacement compatibility at the bend leads to the following expression:

$$\frac{fl_e^2}{2AE} + l_e \left( \frac{f}{K} - \frac{F_{\max}}{AE} + \epsilon_m \right) - \frac{F_{\max}}{K} = 0 \quad (3G-39)$$

If the structure is long ( $L_1$  or  $L_2 > l_e + l_m$ ),  $F_{\max} = \epsilon_m AE$  and equation (3G-39) reduces to

$$l_e = \frac{AE}{K} \left( \sqrt{1.0 + \frac{2\epsilon_m K}{f}} - 1.0 \right) \quad (3G-40)$$

In the case of a short structure ( $L_1$  or  $L_2 < l_e + l_m$ ),  $F_{\max} = f(L - l_e)$  and equation (3G-39) can be written in the form

$$\frac{fl_e^2}{2AE} + l_e \left[ \frac{f}{K} - \frac{f(L - l_e)}{AE} + \epsilon_m \right] - \frac{f(L - l_e)}{K} = 0 \quad (3G-41)$$



## APPENDIX 3G

Equation (3G-41) can be solved by trial and error for the effective slippage length ( $\ell_e$ ). Having the effective slippage length, the displacement ( $\Delta$ ) at the bend can then be calculated. With the displacement ( $\Delta$ ), the shear ( $Q$ ) and moment ( $M$ ) in the transverse leg can then be calculated for the appropriate configuration (cases A through E) in Table 3G-1. More complicated cases can be handled by discretizing the structure as described by Hindy and Novak (1978).

### 3G.4 STRESSES AT CONNECTIONS TO BUILDINGS

#### 3G.4.1 AXIAL MOVEMENT

Stresses are induced in buried structures at penetrations to buildings due to relative movement between the building and the soil. In the case of relative movement in the axial direction of an underground structure with the far end unrestrained, the maximum axial force ( $P$ ) in a long structure ( $L > \ell_e$ ) is given by Yeh (1974):

$$P = \sqrt{2EAf\Delta_x} \quad (3G-42)$$

where

$\Delta_x$  = relative movement between the building and soil in the axial direction.

$\ell_e$  =  $P/f$  effective slippage length

For a short structure ( $L < \ell_e$ ), the maximum axial force is limited to

$$P = fL \quad (3G-43)$$







11.7-7, 11.7-8 / REVIEW

Table 3G-1  
BEND CHARACTERISTICS

Case	Spring Constant At Bend (K)	Shear In Transverse Leg (Q)	Moment In Transverse Leg (M)	Remarks
(A)	$K = \frac{k}{2\lambda}$	$Q = \frac{k\lambda}{2\lambda}$	$M = \frac{0.1662k\lambda}{\lambda^2}$ $\theta X = \frac{\pi}{4\lambda}$	
(B)	$K = \frac{3k}{4\lambda}$	$Q = \frac{3k\lambda}{4\lambda}$	$M = \frac{k\lambda}{4\lambda^2}$	Equal moment of inertia (I) in longitudinal and transverse legs
(C)	$K = \frac{k}{\lambda}$	$Q = \frac{k\lambda}{\lambda}$	$M = \frac{k\lambda}{2\lambda^2}$	
(D)	$K = \frac{k}{\lambda C_1}$	$Q = \frac{k\lambda}{\lambda C_1}$	$M = \frac{k\lambda C_2}{\lambda^2 C_1}$	$C_1 = \frac{\sinh(2\lambda L) - \sin(2\lambda L)}{\cosh^2(\lambda L) + \cos^2(\lambda L)}$ $C_2 = \frac{\sinh(\lambda L)\cos(\lambda L) + \cosh(\lambda L)\sin(\lambda L)}{\cosh^2(\lambda L) + \cos^2(\lambda L)}$
(E)	$K = \frac{k}{\lambda \left(2C_1 - \frac{C_2^2}{C_3}\right)}$	$Q = \frac{k\lambda}{\lambda \left(2C_1 - \frac{C_2^2}{C_3}\right)}$	$M = \frac{k\lambda C_2}{2\lambda^2 \left(2C_1 - \frac{C_2^2}{C_3}\right)}$	$C_1 = \frac{\sinh(\lambda L)\cosh(\lambda L) - \sin(\lambda L)\cos(\lambda L)}{\sinh^2(\lambda L) - \sin^2(\lambda L)}$ $C_2 = \frac{\sinh^2(\lambda L) + \sin^2(\lambda L)}{\sinh^2(\lambda L) - \sin^2(\lambda L)}$ $C_3 = \frac{\sinh(\lambda L)\cosh(\lambda L) + \sin(\lambda L)\cos(\lambda L)}{\sinh^2(\lambda L) - \sin^2(\lambda L)}$

Note: See Fig. 3G-4 for definition of cases.

70 R





## APPENDIX 3G

If a bend in the underground structure is located near the penetration, the connection to the building will be influenced by this restraint. In this case, the following expression can be solved for the maximum axial force ( $F_{\max}$ ):

$$\Delta_x = \frac{F_{\max} L}{AE} - \frac{fL^2}{2AE} + \frac{F_{\max}}{K} - \frac{fL}{K} \quad (3G-44)$$

where K is evaluated for the appropriate configuration (Fig. 3G-4).

## 3G.4.2 LATERAL MOVEMENT

In the case of relative movement between the building and soil in the direction transverse to the buried structure, stresses are determined assuming the structure to be a semi-infinite beam supported on an elastic foundation with a fixed or hinged end at the connection to the building (Yeh, 1974).

For a fixed connection to the building:

$$\sigma_b = \pm \frac{KR}{2\lambda^2 I} (\Delta_y) \quad (3G-45)$$

$$\tau = \frac{\alpha K}{\lambda A} (\Delta_y) \quad (3G-46)$$

where

$\sigma_b$  = maximum bending stress at the connection

$\tau$  = maximum shear stress at the connection

$\Delta_y$  = relative movement between the building and soil in the transverse direction

$\alpha$  = shape factor for the structural cross section and is equal to 2 for a thin circular section



## APPENDIX 3G

For a hinged connection to the building:

$$\sigma_b = \pm 0.161 \frac{kR}{\lambda^2 I} (\Delta_y) \quad (3G-47)$$

$$\tau = \frac{\sigma k}{2\lambda A} (\Delta_y) \quad (3G-48)$$

where

$\sigma_b$  = maximum bending stress located at a distance  $\pi/4\lambda$  from the connection

$\tau$  = maximum shear stress at the connection

### 3G.5 DESIGN EXAMPLE

Given An underground steel pipeline connecting two buildings as shown in plan view in Fig. 3G-6. The properties of the pipe and supporting soil, and the earthquake motion are as follows:

<u>Pipe</u>	<u>Soil</u>	<u>Earthquake</u>
30-inch I.D.	$\gamma_{\text{soil}} = 118 \text{ pcf}$	$a_m = 120 \text{ in./sec}^2$
$t = 3/8\text{-inch}$	$C_p = 7500 \text{ fps}$	$v_{mp} = 5 \text{ in./sec}$
$I = 4130 \text{ in.}^4$	$C_s = C_R = 3000 \text{ fps}$	$v_{ms} = v_{mr} = 14 \text{ in./sec}$
$A = 35.8 \text{ in.}^2$	$K_o = 0.7$	
$E = 30 \times 10^6 \text{ psi}$	$H_d = 6.0 \text{ ft.}$	
$L_1 = 500 \text{ ft.}$	$\mu = 0.4$	
$L_2 = 100 \text{ ft.}$	$k_s = 98 \text{ lb/in.}^3$	



Find

- A. Seismic design stresses in the straight sections of the pipeline away from the bend and connections to the buildings.
- B. Design condition at the bend, including
- stresses in the pipeline if restrained at the bend
  - maximum axial displacement of the ends of the pipeline if unrestrained at the bend
  - maximum angular distortion at the bend.
- C. Design condition at the building connection, including
- stresses in the pipeline assuming a hinged or fixed connection and 0.5 in. relative movement in the axial or lateral direction
  - maximum axial displacement of the ends of the pipeline at the connections assuming no restraint
  - maximum angular distortion at the connections

Solution

Since the pipeline is of relatively small diameter, the maximum values of axial and bending stress for each wave type will be added directly without maximizing for angle of incidence as discussed in section 3G.2.3. The maximum axial and bending stresses due to individual compression, shear, and surface waves for a pipeline following the ground motion are determined from the appropriate equations of section 3G.2.2:



Compression wave

$$\sigma_a = \pm \frac{Ev_{mp}}{C_p} = \pm 1667 \text{ psi}$$

$$\sigma_b = \pm \frac{0.385 ERa_{mp}}{C_p^2} = \pm 2.6 \text{ psi}$$

Shear wave

$$\sigma_a = \pm \frac{EV_{ms}}{2C_s} = \pm 5833 \text{ psi}$$

$$\sigma_b = \pm \frac{ERa_{ms}}{C_s^2} = \pm 42.7 \text{ psi}$$

Surface wave

$$\sigma_a = \pm \frac{Ev_{mr}}{C_R} = \pm 11,667 \text{ psi}$$

$$\sigma_b = \pm \frac{ERa_{mr}}{C_R^2} = \pm 42.7 \text{ psi}$$

- (a) Seismic design stresses in the long, straight section ( $L_1$ ) are obtained from stresses for the individual wave types using the SRSS method:

$$\sigma_a = \pm \left[ (1,667)^2 + (5,833)^2 + (11,667)^2 \right]^{1/2}$$

$$= \pm 13,100 \text{ psi}$$

$$\sigma_b = \pm \left[ (2.6)^2 + (42.7)^2 + (42.7)^2 \right]^{1/2} = \pm 60 \text{ psi}$$





## APPENDIX 3G

Design stresses in the shorter section ( $L_2$ ) can be reduced to account for slippage between the pipeline and the soil as discussed in section 3G.2.4:

$$\epsilon_m = \frac{\sigma_a + \sigma_b}{E} = \frac{13,096 + 60}{30 \times 10^6} = 0.438 \times 10^{-3}$$

$$p_r = \left( \frac{1 + K_o}{2} \right) \gamma_{\text{soil}} (H_d) = 602 \text{ psf}$$

$$f = \pi D p_r \mu = 1935 \text{ lb/ft}$$

$$l_m = \frac{\epsilon_m AE}{f} = 243 \text{ ft.}$$

For the shorter section,  $L_2 < 2l_m$  and the seismic design stresses can be reduced in accordance with Fig. 3G-2b:

$$\sigma_a = \frac{f}{A} \left( \frac{L_2}{2} \right) = 2,700 \text{ psi}$$

- (b) If the pipeline is restrained at the bend by a rigid elbow or other structure, shear and bending stresses will be induced in the pipeline in addition to an axial stress as discussed in section 3G.3. For displacement at the bend in the east-west direction (axial force in  $L_1$ ):

$$\lambda = \left[ \frac{k_s B}{4EI} \right]^{1/4} = 8.83 \times 10^{-3}$$

Both pipeline sections ( $L_1$  and  $L_2$ ) can be considered as infinitely long for purposes of calculating the spring constant at the bend since both  $\lambda L_1$  and  $\lambda L_2 > \pi$ .



The appropriate spring constant at the bend is case (B) of Table 3G-1:

$$K = \frac{3k}{4\lambda} = 2.56 \times 10^5 \text{ lb/in.}$$

The effective slippage length along section  $L_1$  is calculated from Eq. (3G-40):

$$l_e = \frac{AE}{K} \left( \sqrt{1.0 + \frac{2\varepsilon_m K}{f}} - 1.0 \right) = 2291 \text{ in.}$$

The shear, moment, and transverse displacement induced in section  $L_2$  at the bend are:

$$Q_2 = F_{\max} - fl_e = \varepsilon_m AE - fl_e = 101,000 \text{ lb}$$

$$\Delta_2 = \frac{Q_2}{K} = 0.39 \text{ in.}$$

$$M_2 = \frac{k \Delta_2}{4\lambda^2} = 3.77 \times 10^6 \text{ in. lb}$$

For displacement at the bend in the north-south direction (axial force in  $L_2$ ), one-half the section length (600 in.) is less than the effective slippage length ( $l_e = 2291$  in.) calculated using Eq. (3G-40). In this case, Eq. (3G-41) must be solved for the effective slippage length by trial and error:

$$l_e = 470 \text{ in.}$$



## APPENDIX 3G

The shear, moment, and transverse displacement induced in section  $L_1$  at the bend are:

$$Q_1 = F_{\max} - fl_e = f(L_2 - l_e) - fl_e = 41,860 \text{ lb}$$

$$\Delta_1 = \frac{Q_1}{K} = 0.16 \text{ in.}$$

$$M_1 = \frac{k\Delta_1}{4\lambda^2} = 1.55 \times 10^6 \text{ in. lb}$$

If the pipeline is not restrained at the bend, the longitudinal displacement of the ends relative to the soil can be calculated by Eqs. (3G-23) and (3G-25). The displacement of the end of the long section ( $L_1$ ) is

$$\Delta_1 = \frac{\epsilon_m^2 AE}{2f} = 0.64 \text{ in.}$$

The displacement of the end of the short section ( $L_2$ ) is

$$\Delta_2 = \frac{\epsilon_m L_2}{2} - \frac{fL_2^2}{8AE} = 0.24 \text{ in.}$$

The angular distortion of the pipeline can be calculated by Eq. (3G-33):

$$\phi = K_m(L) = \frac{a(L)}{C_s^2}$$

For the long section ( $L_1$ ),  $\phi_1 = 0.03$  deg.; for the shorter section ( $L_2$ ),  $\phi_2 = 0.01$  deg.



## APPENDIX 3G

(c) Connection at Point (A)

The axial force induced in the longer section ( $L_1$ ) due to the design axial relative movement ( $\Delta_x$ ) of 0.5 in. is:

$$P_1 = \sqrt{2EAf\Delta_x} = 415,800 \text{ lb.}$$

for a long structure where  $L_1 = 500 \text{ ft.} > \frac{P}{F} = 215 \text{ ft.}$

Assuming a fixed connection, the maximum bending and shear stresses in the pipeline at the connection due to the design lateral relative movement ( $\Delta_y$ ) of 0.5 in. are:

$$\sigma_b = \pm \frac{kR}{2\lambda^2 I} (\Delta_y) = \pm 35,100 \text{ psi}$$

$$\tau = \frac{\alpha k}{\lambda A} (\Delta_y) = 9,500 \text{ psi}$$

Assuming a hinged connection, the maximum bending and shear stresses are:

$$\sigma_b = \pm \frac{0.161kR}{\lambda^2 I} (\Delta_y) = \pm 11,300 \text{ psi at a}$$

distance  $\frac{\pi}{4\lambda} = 89 \text{ in.}$  from the connection and

$$\tau = \frac{\alpha k}{2\lambda A} (\Delta_y) = 4,800 \text{ psi}$$

Connection at Point (C)

For the shorter section,  $L_2 = 100 \text{ ft.} < \frac{P}{F} = 215 \text{ ft.}$  and Eq. (6-44) can be solved to obtain the maximum axial force due to the design axial relative displacement ( $\Delta_x$ ) of 0.5 in.:

$$F_{\max} = 271,000 \text{ lb.}$$





012 8/18/81  
VIEW

## APPENDIX 3G

The maximum bending and shear stresses in the pipeline at the connection due to the design lateral relative movement ( $\Delta_y$ ) of 0.5 in. are the same as for the connection at point (A).

Angular Distortion

The design angular distortion at the connections is the same as for the bend:

$$\phi_1 = 0.03 \text{ deg.}$$

$$\phi_2 = 0.01 \text{ deg.}$$

The calculated seismic stresses and displacements at various locations along the pipeline must be combined with stresses due to all other loading conditions to obtain total design stresses (Goodling, 1978). If the total calculated stresses exceed the allowable stresses, the overstressed section can be made more flexible or isolated partially or completely from the surrounding soil. In the vicinity of the connections to the buildings, for example, a fixed connection would result in very high bending stresses which could be greatly reduced by use of a hinged connection.



APPENDIX 3G REFERENCES

Goodling, E. C., Jr., (1978) "Flexibility Analysis of Buried Pipe," ASME/CSME Pressure Vessels and Piping Conf., Montreal, Canada, June 25-30.

Hall, W. J., and Newmark, N. M., (1978) "Seismic Design for Pipelines and Facilities," Journal of the Technical Council on Lifeline Earthquake Engineering of ASCE, No. TC1, November, pp. 91-107.

Hetenyi, M., (1946) Beams on Elastic Foundation, Ann Arbor: The University of Michigan Press.

Hindy, A., and Novak, M., (1978) "Earthquake Response of Underground Pipelines," GEOT-1-1978, Faculty of Engineering Science, University of Western Ontario, London, Ontario, Canada.

Newmark, N. M., and Rosenblueth, E., (1971) Fundamentals of Earthquake Engineering, Englewood Cliffs, N.J.: Prentice-Hall.


O'Rourke, M., and Wang, L. R., (1978) "Earthquake Response of Buried Pipelines," Proceedings of the ASCE Geotechnical Engineering Division Specialty Conference on Earthquake Engineering and Soil Dynamics, Pasadena, California, June 19-21, pp. 720-731.

Shah, H. H., and Chu, S. L., (1974) "Seismic Analysis of Underground Structural Elements," Journal of the Power Division of ASCE, Vol. 100, No. P01, July, pp. 53-62.


Yeh, G. K., (1974) "Seismic Analysis of Slender Buried Beams," Bulletin of Seismological Society of America, Vol. 64, No. 5, October, pp. 1551-1562.




EDIT SECTION  
AUG 10 1981  
IN OUT



(a) COMPRESSIONAL WAVE




(b) SHEAR WAVE



(c) SURFACE WAVE

6

	<b>Palo Verde Nuclear Generating Station FSAR</b>
<b>AMPLITUDES OF COMPRESSIONAL, SHEAR AND SURFACE WAVES</b> Figure 3G-1	

September 1981

Amendment 6

08-06-81


70 CC




REVIEW

EDIT SECTION


AUG 10 1981



(a) LONG ELEMENT



(b) SHORT ELEMENT

 Palo Verde Nuclear Generating Station  
FSAR

---

AXIAL FORCE AND STRAIN IN  
IN STRAIGHT ELEMENT  
Figure 3G-2








REVIEW

EDIT SECTION

AUG 10 1981


IN OUT



(a)

(b)

6

	<b>Palo Verde Nuclear Generating Station</b> <b>FSAR</b>
	ELEMENT WITH BEND AND DEFORMATIONS AT A BEND Figure 3G-3

September 1981

Amendment 6

08-06-81

70 EE




REVIEW

TRANSVERSE LEG

EDIT SECTION

AUG 10 1981

LONGITUDINAL LEG



6

	<p>Palo Verde Nuclear Generating Station FSAR</p>
	<p>BEND CONFIGURATIONS Figure 3G-4</p>

September 1981

Amendment 6

08-06-81

70 FF



REVIEW

EDIT SECTION

AUG 10 1981

IN OUT



**EFFECT AT BEND (B)**

$\sigma_a = 1,170$ PSI	$\sigma_a = 2,820$ PSI
$\sigma_b = 14,000$ PSI	$\sigma_b = 5,770$ PSI
$\tau = 5,640$ PSI	$\tau = 2,340$ PSI
$\Delta_{NS} = 0.16''$ (RESTRAINED)	$\Delta_{EW} = 0.39''$ (RESTRAINED)
$\Delta_{NS} = 0.05''$ (FREE)	$\Delta_{EW} = 0.64''$ (FREE)
$\phi_2 = 0.01$ DEG.	$\phi_1 = 0.03$ DEG.

**LONG SECTION (L<sub>1</sub>)**

FREE-FIELD STRESSES:  
 $\sigma_a = 13,100$  PSI  
 $\sigma_b = 60$  PSI

**SHORT SECTION (L<sub>2</sub>)**

FREE-FIELD STRESSES:  
 $\sigma_a = 2,700$  PSI

**CONNECTION (A)**

$\sigma_a = 11,600$  PSI  
 $\phi_1 = 0.03$  DEG.

**CONNECTION (C)**

$\sigma_a = 7,600$  PSI  
 $\phi_2 = 0.01$  DEG.

**IF FIXED:**

$\sigma_b = 35,100$  PSI  
 $\tau = 9,500$  PSI

**IF HINGED:**

$\sigma_b = 11,300$  PSI  
 $\tau = 4,800$  PSI

**IF FREE:**

$\Delta_{NS} = 0.50 + 0.05 = 0.55''$

**IF FIXED:**


$\sigma_b = 35,100$  PSI  
 $\tau = 9,500$  PSI

**IF HINGED:**

$\sigma_b = 11,300$  PSI  
 $\tau = 4,800$  PSI

**IF FREE:**

$\Delta_{EW} = 0.50 + 0.64 = 1.14''$



6

**Palo Verde Nuclear Generating Station**  
**FSAR**

---


DESIGN EXAMPLE  
 Figure 3G-5



model Properties

SUBJECT:


CONTAINMENT STRESS ANALYSIS - ASHSD COMPUTER ANALY



EL 213.5'  
SPRINGLINE

- ASHSD MODEL FOR
- DEAD LOAD CASE
- PRESSURE LOAD CASE
- WIND LOAD CASE
- DYNAMIC LOAD CASE

156 NODES  
168 ELEMENTS





CIRCLED  
NODES ARE  
COMPLETELY  
FIXED

EL 0








LINER PLATE CYLINDER - BASE MAT JUNCTION






ALL CADWELD REBAR SPLICING SHALL BE "B" SERIES WITH MINIMUM 125 PERCENT YIELD STRENGTH OF THE REBAR SPLICED. ONE END OF THE SLEEVE SHALL HAVE J-GROOVE TO WELD WITH THICKENED LINER PLATE. ORIENTATION OF TAP HOLE ON CADWELD SLEEVES SHALL BE SUBMITTED BY FABRICATOR FOR ENGINEER'S APPROVAL.

ANCHORAGE BETWEEN LINER AND INTERIOR  
CONCRETE




SIG. M. HALL DATE 4/1/77 CHECKED S. F. J. M. DATE 4/1/77  
 PROJ. DUNGS JOB NO. UC-17-662  
 SURJ. STRESS ANALYSIS SHEET 9A OF 208 CALC. NO. 12-66-21-040  
**AND REINF. DESIGN**  
**AROUND EQUIP. HATCH**

SYMBOL	TYPE OF NODE	D.O.F.	NO. OF ELEM.	TOTAL D.O.F.
●	BRICK	3	1640	4920
⊙	BRICK-BRICK CONTACT SURFACE (CHALKS)	0	30	60
□	BRICK FIXED	0	80	0



**ATTACHMENT G**




**FIG. 2 DEVELOPED ELEVATION OF MATHEMATICAL MODEL OF EQUIPMENT HATCH OPENING**

1. DEVELOPED AT OUTSIDE RADIUS OF CONTAINMENT  $R=77'-0"$
2. EACH HORIZONTAL TRUSS ELEMENT REPRESENTS 4 HORIZONTAL TENDONS UNLESS NOTED OTHERWISE
3. EACH VERTICAL TRUSS ELEMENT REPRESENTS 2 VERTICAL TENDONS UNLESS NOTED OTHERWISE



ATTACHMENT H



PREDICTED DISPLACEMENTS DUE TO TEST PRESSURE ONLY





EDIT. SECTION

AUG-02 1981

IN OUT

ATTACHMENT I

1 OF 10

APPENDIX 3F

TANGENTIAL AND RADIAL SHEAR

6

6



TANGENTIAL AND RADIAL SHEAR

EDIT. SECTION

AUG 08 1981

IN ; OUT

3F.1 GENERAL

In this appendix tangential shear stresses are evaluated in detail. In the following subsections the critical loading combinations included in this Appendix are listed below:

$$\text{RLC \#1: } D + F_i + P_t + T_t$$

$$\text{RLC \#2: } D + F_i + T_t$$

$$\text{RLC \#3: } D + F + P_v + T_o$$

$$\text{RLC \#4: } D + F + E_o + T_o$$

$$\text{RLC \#11: } D + F + E_{ss} + T_o$$

$$\text{RLC \#15: } D + F + 1.5 P_a + T_a$$

$$\text{RLC \#18: } D + F + 1.25 P_a + 1.25 E_o + T_a$$

$$\text{RLC \#24: } D + F + P_a + E_{ss} + T_a$$

3F.2 TANGENTIAL SHEAR

There are no criteria in the Code for tangential shear in prestressed concrete containments. In the following paragraphs the tangential shear is evaluated using Bechtel's criteria.

A. Containment sections and governing loading combinations:

The only loading that incuces significant tangential shear (in-plane shear) in the structure is seismic loading. Also, tangential shear may be significant only in the shell. Furthermore, the effect of tangential shear is more significant when it occurs simultaneously with the internal pressure (postulated LOCA) because the shear capacity of a section decreases with reduced membrane compression, and internal pressure tends to reduce membrane compression due to prestressing and dead load.



OK 8/10/81 PL

For these reasons it will be sufficient to consider only three reference loading combinations. These combinations are: RLC Nos. 11, 18, and 24.

EDIT. SECTION

B. Section resultants:

AUG 08 1981

Horizontal and vertical membrane forces ( $N_h$  and  $N_v$ ) due to all loads other than earthquake are obtained from the FINEL analysis and are shown in table 3F.2-1.

OUT

Horizontal and vertical membrane forces ( $N_{he}$  and  $N_{ve}$ ) and tangential shear ( $V_u$ ) due to earthquake loads are also shown in table 3F.2-1.

C. Maximum applied shear:

Maximum applied tangential shear must not exceed  $V_u \leq 8.5bt \sqrt{f_c'} \approx 379$  k/ft. In the above equation  $b$  = width (12 inches).  $t$  = thickness (48 inches),  $f_c'$  = concrete strength (6000 psi). This limit is based on the ACI 318-77 code.

Table 3F.2-1 shows that the maximum allowable for each section.

*Tangential shear is limited to the maximum*

D. Shear carried by concrete:

If the section is under biaxial compression, the concrete is allowed to resist the following shear.

$$V_c = [(N_h + N_{he}) (\frac{N_v}{f_v} + \frac{N_{ve}}{f_{ve}})]^{1/2}$$

Assuming, conservatively, that the maximum membrane forces and tangential shear due to seismic loads occur at the same point, the concrete allowable shear force,  $V_c$ , is calculated using the above equation. These values are also shown in table 3F.2-1 for the given loading combinations.



## E. Evaluation of results:

Table 3F.2-1 shows that  $V_u$  exceeds  $V_c$  in only three cases. In accordance with the criteria 3F.1, whenever  $V_u > V_c$ , it is assumed that the shear carried by concrete is equal to zero. Thus, these three cases need further analysis as shown in the following paragraphs.

F. Further analysis of section with  $V_c = 0$ :

In this case a total equivalent membrane force is defined as follows:

$$N_{ht} = N_h + \left[ N_{he}^2 + v_u^2 \right]^{1/2}$$

$$N_{vt} = N_v + \left[ N_{ve}^2 + v_u^2 \right]^{1/2}$$

The section is then analyzed using these equivalent membrane forces and corresponding bending moments (table 3F.2-2). Results of these analyses are given in table 3F.2-3.

## G. Final results:

Table 3F.2-3 shows that, in the three cases where concrete shear capacity may, conservatively, be assumed to be zero, the resulting concrete and reinforcement stresses are within the allowable limits.

Thus, it is shown that, considering the effects of tangential shear, all the sections are adequate.

6



10/10/10





Table 3F.2-1  
MEMBRANE FORCES AND TANGENTIAL SHEAR IN THE SHELL  
(Sheet 1 of 2)

EDIT. SECTION

AUG 08 1981

IN OUT

Section	Ref. Loading Comb.	Hoop		Meridional		V <sub>c</sub> k/ft	V <sub>u</sub> k/ft	Remarks
		N <sub>h</sub> k/ft	N <sub>he</sub> k/ft	N <sub>v</sub> k/ft	N <sub>ve</sub> k/ft			
7	11	-469	22	-585	11	507	17	
	18	-88	16	-200	7	118	10	
	24	-164	22	-277	11	194	17	
16	11	-703	40	-578	35	600	56	
	18	-4	30	-194	25	86	34	
	24	-200	40	-271	35	194	56	
18	11	-765	17	-604	120	602	101	
	18	24	13	-220	89	0	61	See note 7
	24	-134	17	-297	120	144	101	
20	11	-516	15	-630	200	464	122	
	18	-76	10	-246	148	80	74	
	24	-154	15	-323	200	131	122	
21	11	-259	26	-636	217	312	121	
	18	-149	17	-253	161	110	73	
	24	-149	26	-329	217	117	121	See note 7
22	11	-221	36	-639	226	276	118	
	18	-162	26	-255	167	109	72	
	24	-135	36	-332	226	102	118	See note 7

Notes:

1. Notation:

N<sub>h</sub>, N<sub>v</sub> = hoop and meridional membrane forces due to other loads

N<sub>he</sub>, N<sub>ve</sub> = hoop and meridional membrane forces due to seismic loads

V<sub>c</sub> = shear carried by concrete alone

V<sub>u</sub> = applied tangential shear

2. V<sub>c</sub> is zero if either or both total membrane forces are positive (tension)

3. N<sub>h</sub>, N<sub>v</sub> are from FINEL analysis



Table 3F.2-1  
 MEMBRANE FORCES AND TANGENTIAL SHEAR IN THE SHELL  
 (Sheet 2 of 2)

EDIT. SECTION

AUG 0 1981

IN OUT

4.  $N_{he}$ ,  $N_{ve}$ ,  $V_u$  are from ASHSD analysis.
5. Whenever  $V_c > V_u$ , concrete shear capacity alone is adequate to carry tangential shear.
6. In all cases the calculated tangential shear force,  $V_u$ , is less than the total allowable shear on the section, 369 k/ft.
7. In these cases  $V_u > V_c$  and therefore further analysis is required considering tangential shear contribution to seismic membrane forces.

6



Table 3F.2-2(a)

AXIAL FORCE - MOMENT SETS WITH DUE CONSIDERATION TO TANGENTIAL SHEAR

Loading Combination	Section	Primary				Primary + Secondary			
		Meridional		Hoop		Meridional		Hoop	
		Axial	Moment	Axial	Moment	Axial	Moment	Axial	Moment
$D + F + 1.25 P_a + 1.25 E_o + T_a$	18	-112	-3	86	7	-112	430	91	346
$D + F + P_a + E_{ss} + T_a$	21	-81	-133	-25	-20	-81	424	-187	629
$D + F + P_a + E_{ss} + T_a$	22	-77	-398	-12	-67	-77	65	-224	618

Notes:

(a) Sign conventions are:

Axial forces (kips) . . . . . (+) tension . . . . . (-) compression

Moments (ft-kips) . . . . . (+) tension on outside face . . . (-) compression on outside face

EDIT SECTION  
 IN  
 AUG 08 1981  
 OUT


ATTACHMENT I  
 7 OF 10  
 REVIEW  
 APPENDIX 3F  
 4/28/81

Amendment 6

3F-6  
 08-06-81

September 1981

75 9



REVIEW  
DVG  
28/1/87

EDIT. SECTION

AUG 08 1981

IN OUT

Table 3F.2-3  
STRESS ANALYSIS RESULTS



1000



REVISED  
01/17/81

EDIT SECTION  
AUG 08 1981  
IN OUT  
J.P.P. T. 111 - F.2-3

BLE 3F,2-3, STRESS ANALYSIS RESULTS

Reference Loading Combination	Section	Concrete Stresses								Reinforcement Stresses								Liner Strains <sup>(b)</sup>			
		Meridional				Hoop				Meridional				Hoop				Meridional x 10 <sup>-6</sup> in/in	Hoop x 10 <sup>-6</sup> in/in		
		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary					
		MEM psi	MEM & BEN psi	MEM psi	MEM & BEN psi	MEM psi	MEM & BEN psi	MEM psi	MEM & BEN psi	MEM psi	MEM & BEN psi	Inside ksi	Outside ksi	Inside ksi	Outside ksi	Inside ksi	Outside ksi	Inside ksi	Outside ksi		
Allowable	Shell	-3600	-4500	-4500	-5100	-3600	-4500	-4500	-5100	±54	±54	±54	±54	±54	±54	±54	±54	±54	±54	±10000	±10000
16(c)	18	-194	-226	-194	-2696	(d)	(d)	(d)	-1518	-1.0	-1.2	-1.6	39.3	26.0	10.3	5.4	42.5	-519	-326		
24(c)	21	-141	-710	-141	-3138	-43	-86	-325	-2738	3.3	-2.7	-1.8	54.0 <sup>(e)</sup>	-1	-4	-4.8	28.6	-932	-640		
24(c)	22	-134	-2685	-134	-303	-21	-373	-389	-2872	46.4	-4.9	-1.3	-1	4.4	-1.1	-5.7	24.3	2317	-623		

- Notes:
- 1) Sign convention: Stress and strains . . . . (+) tensile . . . . (-) compressive
  - 2) Allowable liner strains shown are based on the lowest values from the ASME Code, Section III, division 2.
  - 3) The stresses were obtained from OPTCON computer output.
  - 4) A completely cracked section
  - 5) Reinforcement is assumed to yield at 54 ksi, the calculated strain is .00209 in./in.

75 I

ATTACHMENT I  
9 OF 10




## REFERENCES

1. "ASME Boiler and Pressure Vessel Code, Section III--Rules for Construction of Nuclear Power Plant Components, Division 2--Code for Concrete Reactor Vessels and Containments, "ASME Boiler and Pressure Vessel Committee, Subcommittee, Subcommittee on Nuclear Power, and ACI-ASME Joint Technical Committee, 1975 Edition.
2. BC TOP 5A, Revision 3, February, 1975, Prestressed Concrete Nuclear Reactor Containment Structures.


EDIT. SECTION  
AUG 06 1975  
IN OU




ANPP REACTOR CAVITY FINITE ELEMENT MODEL  
EAST WALL FROM NORTH-SOUTH CENTERLINE



SAP - PVNGS REACTOR CAVITY PRIMARY SHIEL  
D



ANPP REACTOR CAVITY FINITE ELEMENT MODEL  
WEST WALL FROM NORTH-SOUTH CENTERLINE




SAP-PVNGS REACTOR CAVITY PRIMARY SHIELD






# FORCES & MOMENTS AT KEY SECTIONS FOR REACTOR VESSEL LOWER SUPPORTS



78




# FORCES & MOMENTS AT KEY SECTIONS of REACTOR VESSEL UPPER LATERAL SUPPORTS






FORCES & MOMENT AT KEY :  
SECTIONS OF STEAM GENERATOR  
LOWER SUPPORTS







STEAM GENERATOR LEVER AND SNUBBER SUPPORTS





ATTACHMENT M

FOR ONE BOLT


$T_B = 274^k$ ,  $T_B(\text{ALLOW}) = 304^k$

$V_B = 226^k$ ,  $V_B(\text{ALLOW}) = 296^k$

FOR ONE PLATE . 3 OF 3

$T_P = 598^k$


$V_P = 218^k$




STEAM GENERATOR UPPER KEY SUPPORT









# REBAR PLACEMENT FOR STEAM GENERATOR UPPER SUPPORTS



**SECTION E**  
 3/16" = 1'-0"  
 552  
 THRU  
 559




**SECTION A**  
 3/16" = 1'-0"  
 552  
 553



**SECTION H**  
 3/16" = 1'-0"  
 553  
 555





# REBAR PLACEMENT FOR REACTOR COOLANT PUMP LATERAL SUPPORTS







# ATTACHMENT P



T.O. GRATING EL. 120'-0" (U.N.O.)  
T.O. STRUCT. STL. (SUPPORTING GRATING) EL. 119'-10 3/4" (U.N.O.)  
T.O. STRUCT. STL. (SUPPORTING CONC. SLAB) EL. 118'-1 7/8" (U.N.O.)



Table 2.5-15  
 STATIC BEARING CAPACITY OF CATEGORY I STRUCTURES

Structure	Average Static Design Load $q_s$ (k/ft <sup>2</sup> )	Ultimate Bearing Capacity $q_o$ (k/ft <sup>2</sup> )	Factor of Safety ( $q_o/q_s$ )
Containment Building	7.9	35.7	4.5
Auxiliary Building (deep section)	6.2	34.9	5.6
Main Steam Support Structure	7.1	64.8	9.1
Control Building	3.3	45.3	13.7
Fuel Building	5.3	54.9	10.4
Diesel Generator Building	3.1	79.5	25.6
Refueling Water Tank	4.4	90.4	20.5
Condensate Storage Tank	3.5	112.4	32.1



Table 2.5-16

## DYNAMIC BEARING CAPACITY OF CATEGORY I STRUCTURES (a)

Structure	Equivalent Uniform Vertical Stress $q_d$ (k/ft <sup>2</sup> )	Ultimate Bearing Capacity $q_o$ (k/ft <sup>2</sup> )	Factor of Safety ( $q_o/q_d$ )
Containment Building	16.1	32.2	2.0
Auxiliary Building (deep section)	10.3	25.8	2.5
Main Steam Support Structure	25.3	60.6	2.4
Control Building	9.8	39.8	4.1
Fuel Building	19.1	50.3	2.6
Diesel Generator Building	5.6	75.5	13.5
Refueling Water Tank	13.2	58.7	4.4
Condensate Storage Tank (b)	13.2	30.2	2.3

a. Based upon maximum dynamic loads derived from analyses described in section 3.7.

b. Condensate storage tank loads were conservatively chosen to be equal to the dynamic design load for the refueling water tank. Actual loads will be less.



Table 3.7-1  
DAMPING VALUES  
(PERCENT OF CRITICAL DAMPING)

Structure or Component	Operating Basis Earthquake	Safe Shutdown Earthquake
Equipment and large-diameter piping systems, pipe diameter greater than 12 in.	2	3
Small-diameter piping systems, diameter equal to or less than 12 in.	1	2
Welded steel structures	2	4
Bolted steel structures	4	7
Prestressed concrete structures	2	5
Reinforced concrete structures	4	7

The applicable allowable design levels are given in section 3.8 for the various loading combinations which include seismic loadings.

3.7.1.4 Supporting Media for Seismic Category I Structures

For purposes of the seismic analysis, the site is assumed to be a multi-layer system consisting of soil over bedrock. The approximate depth of soil deposit over bedrock for each unit at the site is as follows:


	<u>Unit 1</u>	<u>Unit 2</u>	<u>Unit 3</u>
Depth of Soil, ft	330	350	295




...










**Palo Verde Nuclear Generating Station**  
**FSAR**

---


**HORIZONTAL DESIGN SPECTRA**  
**FOR SSE 0.25 g**  
**Figure 3.7-1**








**Palo Verde Nuclear Generating Station**  
**FSAR**  
 VERTICAL DESIGN SPECTRA  
 FOR SSE 0.25 g  
 Figure 3.7-2







**Palo Verde Nuclear Generating Station**  
**FSAR**  
**HORIZONTAL DESIGN SPECTRA**  
**FOR OBE 0.13 g**  
**Figure 3.7-3**








**Palo Verde Nuclear Generating Station**  
**FSAR**  
 VERTICAL DESIGN SPECTRA  
 FOR OBE 0.13 g  
 Figure 3.7-4









**Palo Verde Nuclear Generating Station**  
**FSAR**

---

**DAMPING VS. STRAIN - CLAY**  
**FIGURE 3.7-5**





Palo Verde Nuclear Generating Station  
FSAR

DAMPING VS. STRAIN - SAND


FIGURE 3.7-6



AVERAGE PERCHED WATER LEVEL 44'

DEPTH (FT.)	LAYER DEPTH (FT.)	DESCRIPTION	LAYER THICKNESS	UNIT WEIGHT (PCF)	POISSON'S RATIO	IN-SITU SHEAR WAVE VELOCITY (FT/SEC)	LOW STRAIN SHEAR MODULUS (KSF)	LOW STRAIN P-WAVE VELOCITY (FT/SEC)
		SAND (2)	47'	123	.27	898 1118 1173	3720 4760 5260	1930 2090
	47'	CLAY (1)	23'	121	.44	1194	5450	3450
	70'	SAND (2)	3'	121	.48	1709	9500	4445
	73'	CLAY (1)	82'	123	.47	1253 1281	6000 6270	5260 5345
	155'	SAND (2)	10'	126	.465	1401 1329	7500	5362 5454
	165'	CLAY (1)	27'	127	.48	1308	8990	5844
	192'	SAND (2)	12'	127	.48			
	204'	CLAY (1)	20'	128	.45	1776	12350	5992
	224'	SAND (2)	10'	127	.44	1924	15630	6060
	234'	CLAY (1)	73'	128	.44	2048 2270	16480 20650	8293 8348
	301'	SAND (2)	23'	130	.44	2701	19270	8726
	311'	SAND (2)	23'	130	.44	2176	19130	6650
	334'	BEDROCK						

- NOTES: 1. LOW STRAIN SHEAR MODULI AT VARIOUS DEPTHS ARE AVERAGE VALUES.  
 2. SHEAR WAVE VELOCITY CALCULATED FROM  $V_s = (G/\rho)^{1/2}$   
 3. P-WAVE VELOCITY CALCULATED FROM  $V_p = V_s [(2 - \nu)/(1 - 2\nu)]^{1/2}$


**Palo Verde Nuclear Generating Station**  
**FSAR**

---

**SOIL PROFILE**  
**FIGURE 3.7-7**


September 1980


Amendment 2

CHANGE

93








**Palo Verde Nuclear Generating Station  
FSAR**  
 SHEAR MODULUS VS. STRAIN - CLAY  
 FIGURE 3.7-8









**Palo Verde Nuclear Generating Station**  
**FSAR**


---

**SHEAR MODULUS VS. STRAIN - SAND**  
**FIGURE 3.7-9**





LEGEND





**Palo Verde Nuclear Generating Station**  
**FSAR**  
 CONTAINMENT BUILDING  
 LUMPED MASS MODEL  
 FIGURE 3.7-10



Table 3.8-1A

LOADING COMBINATION FOR DESIGN AND FINAL ANALYSIS  
OF CONTAINMENT SHELL (Sheet 1 of 2)

Reference Loading (RLC)	PVNGS Project Criteria		ASME Sect III, Div. 2	BC-TOP-5A R-1	Final Analysis Performed	Remarks
	Category	Loading Combination				
1	Test	$D + L + P_1 + P_c + T_c$	Same	Same	Yes	$T_c$ is considered same as $T_0$ ; initial prestress is more critical
2	Construction	$D + L + P_1 + T_0$	Same	Same	Yes	Initial prestress case is more critical
3	Normal Operating Loads	$D + L + P + T_0 + E_0 + P_v$	Same	Same	Yes	$E_0$ is a local load
4	Severe Environment	$D + L + P + T_0 + E_0 + R_0 + P_v$	Same	Same	Yes	$E_0$ is a local load, $P_a$ is omitted conservatively
5	Severe Environment	$D + L + P + T_0 + W + E_0$	None	Same	No	Less severe than loading Combination #4
6	Severe Environment	$D + L + P + T_0 + W + E_0 + P_v$	Same	None	No	Less severe than loading Combination #5
7	Severe Environment	$D + 1.3L + P + T_0 + 1.5E_0 + R_0$	None	Same	No	Less severe than loading Combination #11
8	Severe Environment	$D + 1.3L + P + T_0 + 1.5W + R_0$	None	Same	No	Less Severe than loading Combination #7
9	Severe Environment	$D + 1.3L + P + T_0 + 1.5E_0 + R_0 + P_v$	Same	None	No	Less severe than loading Combination #7
10	Severe Environment	$D + 1.3L + P + T_0 + 1.5W + R_0 + P_v$	Same	None	No	Less severe than loading Combination #8
11	Extreme Environment	$D + L + P + T_0 + E_{ss} + R_0 + P_v$	None	Same	Yes	$E_{ss}$ is a local load; $P_v$ is omitted conservatively
12	Extreme Environment	$D + L + P + T_0 + W_t + E_0 + P_v$	None	Same	No	Less severe than loading Combination #11

Notation

- |   |  |
|---|--|
| D = Dead load   | $T_a$ = Design accident temperature  |
| L = Live Load   | $P_c$ = Test pressure (=1.15 $P_A$ )   |
| $P_1$ = Initial prestress   | $T_c$ = Test temperature (assumed equal to $T_0$ )                           |
| P = Final prestress   | $P_v$ = Design external pressure (vacuum)                                    |
| $T_0$ = Normal operating temperature                                  | $E_0$ = Operating basis earthquake   |
| $P_a$ = Design accident pressure                                      | $E_{ss}$ = Safe shutdown earthquake  |
| W = Wind Load   | $W_t$ = Tornado Loads (including differential pressure and tornado missiles) |
| $R_0$ = Pipe reactions during normal operating or shutdown conditions | $R_p$ = Local effects of containment due to postulated pipe breaks           |
| $R_b$ = Pipe reactions due to postulated break (including $R_0$ )     |  |



December 1980

3.8-20C

Amendment 3

13

88

Table 3.8-1A

LOADING COMBINATION FOR DESIGN AND FINAL ANALYSIS OF CONTAINMENT SHELL (Sheet 2 of 2)

Reference Loading (RLC)	PVNCS Project Criteria		ASME Sect III, Div. 2	BC-TOP-5A R-1	Final Analysis Performed	Remarks
	Category	Loading Combination				
13	Extreme Environment	$D + L + F + T_o + E_{ss} + P_o$	Same	None	No	Less severe than loading Combination #11
14	Extreme Environment	$D + L + F + T_o + W_t + P_o$	Same	None	No	Less severe than loading Combination #12
15	Abnormal	$D + L + F + 1.5P_a + T_a + R_a$	Same	Same	Yes	$R_a$ is a local load
16	Abnormal	$D + L + F + P_a + 1.25R_a$	None	Same	No	Less critical than loading Combination #17 in local analysis
17	Abnormal	$D + L + F + P_a + T_a + 1.25R_a$	Same	None	No	$R_a$ is a local load, less severe than loading Combination #15
18	Abnormal with Severe Environment	$D + L + F + 1.25P_a + T_a + 1.25E_o + R_a + R_r$	None	Same	Yes	$R_a$ and $R_r$ are local loads
19	Abnormal with Severe Environment	$D + L + F + 1.25P_a + T_a + 1.25W + R_a + R_r$	None	Same	No	Less severe than loading Combination #18
20	Abnormal with Severe Environment	$D + L + F + 1.25P_a + T_a + 1.25E_o + R_a$	Same	None	No	Same as loading Combination #18 without local loads
21	Abnormal with Severe Environment	$D + L + F + 1.25P_a + T_a + 1.25W + R_a$	Same	None	No	Less severe than loading Combination #19
22	Abnormal with Severe Environment	$D + L + F + T_o + E_o$	Same	None	No	Less severe than loading Combination #13
23	Abnormal with Severe Environment	$D + L + F + T_o + W$	Same	None	No	Less severe than loading Combination #14
24	Abnormal with Extreme Environment	$D + L + F + P_a + T_a + E_{ss} + R_a + R_r$	Same	Same	Yes	$R_a$ and $R_r$ are local loads

Notation

- D = Dead load
- L = Live Load
- F<sub>i</sub> = Initial prestress
- F = Final prestress
- T<sub>o</sub> = Normal operating temperature
- P<sub>a</sub> = Design accident pressure
- W = Wind Load
- R<sub>o</sub> = Pipe reactions during normal operating or shutdown conditions
- R<sub>a</sub> = Pipe reactions due to postulated break (including R<sub>o</sub>)
- T<sub>a</sub> = Design accident temperature
- P<sub>t</sub> = Test pressure (=1.15 P<sub>a</sub>)
- T<sub>t</sub> = Test temperature (assumed equal to T<sub>o</sub>)
- P<sub>v</sub> = Design external pressure (vacuum)
- E<sub>o</sub> = Operating basis earthquakes
- E<sub>ss</sub> = Safe shutdown earthquake
- W<sub>t</sub> = Tornado Loads (including differential pressure and tornado missiles)
- R<sub>r</sub> = Local effects of containment due to postulated pipe breaks

Note: Local loads are not considered in the overall analysis but are taken into account in local design. Also the live load has a negligible effect on the pressure boundary and thus is not included in the final analysis.

3

PVNCS FSAR  
CATEGORY I STRUCTURES  
DESIGN OF





Table 3.8-1B(a)  
STRESS ANALYSIS RESULTS (Sheet 1 of 9)

Reference Loading Combinations:  $D + F_1 + F_c T_c$  (SI from Table 3.8-1A)

Portion	Section (Shown in Figure 3.8-23A)	Concrete Stresses								Reinforcement Stresses								Liner Strains (b)		Deflection (c) (Primary Loads) (in)
		Meridional				Hoop				Meridional				Hoop				Meridional $\times 10^{-6}$ in/in	Hoop $\times 10^{-6}$ in/in	
		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary				
		MEM (psi)	MEM & BEN (psi)	MEM (psi)	MEM & BEN (psi)	MEM (psi)	MEM & BEN (psi)	MEM (psi)	MEM & BEN (psi)	inside ksi	Outside ksi	inside ksi	Outside ksi	inside ksi	Outside ksi	inside ksi	Outside ksi			
Allowable	Shell	-1800	-2700	-2700	-3600	-1800	-2700	-2700	-3600	±30	±30	±40	±40	±30	±30	±40	±40	±4000	±4000	-
	Basemat	-1500	-2250	-2250	-3000	-1500	-2250	-2250	-3000											
Dome	2	-338	-327	-315	-916	-328	-330	-320	-906	-1.5	-1.7	-2.7	6.3	-1.5	-1.7	-2.6	6.3	-376	-366	-0.24
	7	-592	-627	-585	-1360	-365	-403	-384	-1085	-2.4	-1.9	-3.7	2.8	-1.6	-1.3	-3.0	6.6	-284	-428	-0.16
Wall	16	-549	-554	-549	-1401	-467	-424	-451	-1211	-2.9	-2.6	-5.2	4.4	-1.9	-1.8	-3.8	5.5	-440	-449	-0.06
	18	-594	-564	-594	-1408	-342	-326	-338	-1064	-3.2	-3.2	-5.6	3.7	-1.3	-1.2	-2.9	6.4	-429	-448	-0.04
	20	-639	-680	-639	-1315	-387	-362	-357	-1048	-3.1	-4.0	-5.7	1.6	-1.3	-1.4	-2.9	6.4	-358	-452	-0.03
	21	-650	-1049	-650	-1069	-303	-358	-196	-814	-2.2	-6.4	-5.2	-0.3	-1.0	-1.0	-1.7	7.5	-238	-450	-0.03
	22 (a)	-676	-2214	-658	-941	-218	-527	-135	-560	0.1	-13.0	-4.1	-5.3	-0.3	-0.3	-1.6	6.0	636	-368	-0.01
Basemat Slab	23	27	-244	-37	-333	-6	-132	-29	-352	12.6	-0.5	2.0	0.5	-0.9	3.9	-3.4	8.3	516	-462	-0.01
	25	-40	-769	-129	-1212	-16	-336	-58	-695	-3.8	11.1	-7.6	14.5	-1.0	3.7	-3.2	8.3	-869	-450	-0.37
	26	-11	-380	-73	-705	16	-159	-29	-355	-2.4	7.5	-5.6	11.0	-0.5	1.0	-2.5	6.3	-650	-348	-0.48
Reactor Cavity	27	-177	-195	-98	-132	5	-13	79	(d)	-1.0	-1.3	-1.1	-1.0	0.3	0.2	2.7	4.9	13	-90	0.00
	28	92	-83	67	-104	52	91	107	(d)	6.6	0.7	2.8	10.4	0.6	0.6	0.8	9.6	-320	-372	-0.48

PVNGS FSAR  
 DESIGN OF  
 CATEGORY I STRUCTURES



Table 3.8-1B  
STRESS ANALYSIS RESULTS (Sheet 2 of 9)

Footnotes:

- (a) Sign Conventions are:  
Stresses and strains . . . . (+) tensile . . . . (-) compressive  
Deflections . . . . . (+) outward . . . . (-) inward
- (b) Allowable liner strains shown are based on the lowest values from the ASME Code, Section III, division 2.
- (c) All deflections shown are normal to the given surface.
- (d) Completely cracked sections; partially cracked sections are not indicated.
- (e) The stresses for section 22 were determined from a more detailed analysis, in addition to the FINEL analysis.
- (f) The stresses were obtained from OPTCON computer output.
- (g) Membrane stress is greater than 200 psi and thus the section is assumed cracked.
- (h) Reinforcement is assumed to yield at 54 ksi, the calculated strain is 0.00300 in/in.

3  
4  
3

PVNGS FSAR

DESIGN OF  
CATEGORY I STRUCTURES

May 1981

3.8-20E

Amendment 4

3

100



3  
Amendment 3

3.8-20F

December 1980

161

Table 3.8-1B (a)  
STRESS ANALYSIS RESULTS (Sheet 3 of 9)

Reference Loading Combination:  $D + P_1 + T_0$  (82 from Table 3.8-1A)

Portion	Section (Shown in Figure 3.8-22A)	Concrete Stresses								Reinforcement Stresses								Liner Strains (b)		Deflection (c) (Primary Loads) (in)
		Meridional				Hoop				Meridional				Hoop				Meridional $\times 10^{-6}$ in/in	Hoop $\times 10^{-6}$ in/in	
		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary				
		MEM (psi)	MEM & BEN (psi)	MEM (psi)	MEM & BEN (psi)	MEM (psi)	MEM & BEN (psi)	MEM (psi)	MEM & BEN (psi)	Inside ksi	Outside ksi	Inside ksi	Outside ksi	Inside ksi	Outside ksi	Inside ksi	Outside ksi			
Allowable	Shell	-1800	-2700	-2700	-3600	-1800	-2700	-2700	-3600	130	130	140	140	130	130	140	140	14000	14000	-
	Basemat	-1500	-2250	-2250	-3000	-1500	-2250	-2250	-3000											
Dome	2	-1062	-990	-1050	-1811	-1040	-1005	-1039	-1830	-5.1	-5.1	-7.4	1.7	-5.2	-5.2	-7.5	1.6	-382	-373	-0.67
	7	-1234	-1259	-1232	-2154	-1000	-1053	-996	-1946	-4.7	-4.2	-6.5	.5	-5.1	-4.8	-7.4	2.0	-309	-430	-0.49
Wall	16	-1161	-1128	-1161	-2092	-1469	-1274	-1464	-2265	-5.6	-5.3	-8.6	1.9	-6.8	-6.5	-9.8	-.3	-432	-462	-0.21
	18	-1207	-1150	-1207	-2130	-1604	-1459	-1598	-2446	-5.6	-5.6	-8.6	.8	-7.9	-7.6	-11.0	-1.4	-429	-463	-0.24
	20	-1252	-1365	-1252	-1795	-1054	-960	-895	-1704	-5.8	-7.7	-8.6	-2.4	-4.8	-4.5	-6.4	2.9	-399	-460	-0.16
	21	-1264	-1535	-1263	-2261	-497	-560	-332	-1152	-8.1	-4.4	-11.4	4.7	-1.6	-1.5	-1.9	7.4	-778	-451	-0.05
	22(a)	-1247	-1978	-1237	-3356	-401	-592	-348	-1298	-6.3	-5.0	-8.6	11.7	-.6	-.6	-1.5	6.1	-981	-366	-0.02
Basemat Slab	23	-23	-365	-116	-468	-57	-334	-121	-444	-.9	3.8	-3.6	7.5	-.5	.4	-3.5	4.2	-434	-300	-0.16
	25	-28	-225	-155	-777	-28	-111	-90	-464	-1.1	.7	-5.5	4.3	-.4	.2	-3.1	4.1	-383	-283	-0.21
	26	-19	-93	-129	-542	-21	-56	-40	-328	-.6	.8	-4.5	4.1	-.3	.1	-2.7	4.2	-339	-271	-0.22
Reactor Cavity	27	-80	-84	40	-42	-19	-22	63	(d)	-.3	-.5	-.2	.5	-.1	-.1	2.0	4.2	-30	-88	0.00
	28	13	-48	98	-87	11	13	31	27	.1	.2	-.4	9.2	.1	.1	-.9	7.2	-401	-340	-0.22

3

CATEGORY I STRUCTURES

DESIGN OF

PVNGS FSAR



Table 3.8-1B(a)  
STRESS ANALYSIS RESULTS (Sheet 4 of 9)

Reference Loading Combination:  $D + F + T_0 + P_v$  (S) from Table 3.8-1A)

Portion	Section (Shown in Figure 3.8-22A)	Concrete Stresses								Reinforcement Stresses								Linear Strains <sup>(b)</sup>		Deflection (c) (in) (Primary Loads)
		Meridional				Hoop				Meridional				Hoop				Meridional $\times 10^{-6}$ in/in	Hoop $\times 10^{-6}$ in/in	
		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary				
		MEM (psi)	MEM & BEM (psi)	MEM (psi)	MEM & BEM (psi)	MEM (psi)	MEM & BEM (psi)	MEM (psi)	MEM & BEM (psi)	Inside Rel	Outside Rel	Inside Rel	Outside Rel	Inside Rel	Outside Rel	Inside Rel	Outside Rel			
Allowable	Shell	-1800	-2700	-2700	-3600	-1800	-2700	-2700	-3600	±30	±30	±40	±40	±30	±30	±40	±40	±4000	±4000	-
	Basemat	-1500	-2250	-2250	-3000	-1500	-2250	-2250	-3000											
Dome	2	-947	-993	-916	-1777	-926	-921	-888	-1762	-4.7	-4.7	-7.0	2.6	-4.8	-4.8	-7.1	2.0	-403	-375	-0.63
	7	-1088	-1145	-1085	-2086	-877	-949	-899	-1875	-4.3	-3.8	-6.3	8.6	-4.6	-4.3	-7.2	2.3	-631	-429	-0.46
Wall	16	-1030	-1027	-1030	-2030	-1264	-1127	-1259	-2193	-5.2	-4.8	-8.3	1.1	-5.9	-5.7	-9.2	0.3	-433	-440	-0.18
	18	-1075	-1048	-1075	-2065	-1383	-1291	-1375	-2317	-5.2	-5.2	-8.4	1.0	-7.0	-6.7	-10.2	-0.7	-429	-462	-0.21
	20	-1120	-1241	-1120	-1769	-921	-860	-797	-1667	-5.3	-7.0	-8.3	-1.7	-4.2	-4.8	-6.4	3.0	-321	-440	-0.14
	21	-1131	-1432	-1131	-2636	-451	-518	-377	-1210	-7.6	-4.1	-11.1	5.0	-1.3	-1.4	-2.3	7.0	-784	-452	-0.05
	22 <sup>(a)</sup>	-1136	-2147	-1136	-3660	-388	-601	-399	-1427	-5.9	-4.6	-8.5	12.3	-0.6	-0.6	-2.1	5.4	-1003	-367	-0.02
Basemat Slab	23	-15	-329	-88	-442	-67	-134	-191	-534	-0.6	1.3	-3.3	6.1	-0.5	0.2	-4.2	3.0	-372	-286	-0.16
	25	-6	-57	-70	-377	-55	-112	-176	-604	-0.1	0.2	-2.9	2.0	-0.7	0.1	-4.9	3.2	-193	-316	-0.20
	26	6	-46	-34	-316	-73	-142	-200	-712	-0.1	0.6	-2.3	4.8	-1.0	-0.1	-5.8	3.0	-279	-343	-0.22
Reactor Cavity	27	-57	-117	-68	-217	-23	-39	96	189	-0.6	-0.1	-1.9	0.5	-0.1	-0.1	0.5	2.9	-97	-99	0.00
	28	20	-54	-75	-361	17	31	-57	-331	-0.1	0.4	-3.1	5.3	0.1	0.2	-2.9	2.7	-355	-232	-0.24





Table 3.8-1B (a)  
 STRESS ANALYSIS RESULTS (Sheet 5 of 9) (f)

Reference Loading Combinations: D + F + T <sub>o</sub> + E <sub>o</sub> (ff from Table 3.8-1A)																				
Portion	Section (Shown in Figure 1.8-22A)	Concrete Stresses								Reinforcement Stresses								Liner Strains (b)		Deflection (c) (Primary Loads) (in)
		Meridional				Hoop				Meridional				Hoop				Meridional X 10 <sup>-6</sup> in/in	Hoop X 10 <sup>-6</sup> in/in	
		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary				
		MEM (psi)	MEM & SEN (psi)	MEM (psi)	MEM & SEN (psi)	MEM (psi)	MEM & SEN (psi)	MEM (psi)	MEM & SEN (psi)	Inside ksi	Outside ksi	Inside ksi	Outside ksi	Inside ksi	Outside ksi	Inside ksi	Outside ksi			
Allowable	Shell	-1800	-2700	-2700	-3600	-1800	-2700	-2700	-3600	±30	±30	±40	±40	±30	±30	±40	±40	±4000	±4000	-
	Basemat	-1500	-2250	-2250	-3000	-1500	-2250	-2250	-3000											
Dome	2	-907	-930	-869	-1859	-887	-880	-869	-1868	-5.1	-5.5	-9.6	.6	-5.1	-5.2	-9.9	.3	-425	-419	-
	7	-1049	-1065	-1045	-2054	-826	-858	-844	-1814	-6.3	-6.0	-10.5	-6	-5.0	-4.6	-8.6	.6	-433	-416	-
Wall	16	-969	-986	-969	-2167	-1179	-1091	-1174	-2274	-5.8	-5.6	-10.6	-1	-6.5	-6.4	-10.7	-5	-480	-486	-
	18	-925	-942	-925	-2107	-1309	-1279	-1302	-2448	-5.4	-5.6	-10.2	.2	-7.7	-7.5	-12.0	-1.7	-473	-500	-
	20	-899	-1062	-889	-1694	-892	-870	-757	-1808	-4.6	-6.0	-8.0	-1.6	-5.0	-5.2	-7.7	1.3	-312	-439	-
	21	-880	-1211	-880	-2829	-425	-489	-307	-1439	-6.3	-3.6	-11.1	9.5	-2.6	-1.9	-4.0	8.0	-995	-580	-
	22 (a)	-877	-1346	-877	-3617	-347	-465	-354	-1926	-6.7	-3.0	-12.2	23.7	-2.3	-1.3	-4.5	7.6	-1740	-587	-
Basemat Slab	23	9	-295	-69	-723	-49	-233	-177	-782	-1.1	5.8	-3.6	7.8	-1.2	1.5	-4.4	4.6	-448	-351	-
	25	24	-329	-48	-824	-38	-254	-161	-908	-1.2	6.7	-4.0	10.0	-1.3	1.8	-5.1	5.8	-548	-426	-
	26	31	-337	-14	-673	-57	-272	-191	-1085	-1.2	7.4	-3.0	9.6	-1.5	1.3	-6.1	7.1	-495	-518	-
Reactor Cavity	27	-34	-249	-44	-448	-1	-25	105	(d)	-1.1	2.5	-1.8	9.6	-1	.4	6.5	4.9	-302	63	-
	28	48	-174	-36	-687	61	(d)	-39	-526	.9	10.6	-1.8	12.1	4.5	8.1	-1.6	8.2	-584	-410	-

PVNGS FSAR

DESIGN OF  
 CATEGORY I STRUCTURES

3  
 Amendment 4

3.8-20H

May 1981

163



Table 3.8-1B (a)  
STRESS ANALYSIS RESULTS (Sheet 6 of 9) (f)

Reference Loading Combination:  $S + F + E_o + E_{so}$  (all from Table 3.8-1A)

Portion	Section (Shown in Figure 3.8-22A)	Concrete Stresses								Reinforcement Stresses								Liner (b) Strains		Deflection (c) (Primary Loads) (in)
		Meridional				Hoop				Meridional				Hoop				Meridional $\times 10^{-6}$ in/in	Hoop $\times 10^{-6}$ in/in	
		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary				
		MEM (psi)	MEM & BEM (psi)	MEM (psi)	MEM & BEM (psi)	MEM (psi)	MEM & BEM (psi)	MEM (psi)	MEM & BEM (psi)	Inside ksi	Outside ksi	Inside ksi	Outside ksi	Inside ksi	Outside ksi	Inside ksi	Outside ksi			
Allowable	Shell	-1600	-4500	-4500	-5100	-3600	-4500	-4500	-5100	154	154	154	154	154	154	154	154	110000	110000	-
	Basemat	-1000L	-3750	-3750	-4250	-3000	-3750	-3750	-4250											
Dome	2	-901	-924	-863	-1035	-879	-873	-861	-1062	-5.1	-5.5	-9.5	.6	-5.1	-5.2	-9.9	.4	-426	-420	-
	7	-1040	-1056	-1036	-2046	-810	-841	-828	-1003	-6.3	-5.9	-10.4	-5	-6.9	-4.5	-8.6	.8	-434	-418	-
Wall	16	-843	-965	-943	-2150	-1151	-1065	-1146	-2234	-5.7	-5.5	-10.4	.2	-6.6	-6.2	-10.6	-.3	-489	-497	-
	18	-840	-859	-840	-2060	-1299	-1269	-1292	-2430	-4.0	-5.1	-9.7	1.2	-7.7	-7.5	-12.0	-1.6	-499	-499	-
	20	-747	-1010	-747	-1475	-870	-856	-745	-1807	-3.4	-5.5	-6.8	-1.1	-6.9	-5.1	-7.6	1.5	-276	-445	-
	21	-727	-1064	-727	-3225	-605	-474	-206	-1460	-5.3	-2.7	-9.3	23.6	-2.5	-1.0	-3.8	9.0	-1600	-621	-
	22(a)	-717	-1192	-717	-3950	-321	-442	-329	-1544	-5.7	-2.1	-10.1	40.0	-2.2	-1.1	-4.3	0.7	-2430	-630	-
Basemat Slab	23	19	-267	-39	-706	-44	-201	-171	-827	-.9	6.3	-3.4	0.2	-1.4	2.7	-4.5	5.6	-456	-399	-
	25	30	-400	-33	-977	-32	-313	-155	-966	-1.7	10.1	-4.6	13.3	-1.6	3.0	-5.3	6.9	-703	-478	-
	26	63	-631	-2	-770	-82	-320	-107	-1137	-1.5	9.7	-3.4	11.9	-1.7	2.2	-6.4	0.0	-600	-565	-
Reactor Cavity	27	-12	-342	-22	-530	2	-30	109	(4)	-1.1	5.9	-1.0	9.0	-.1	.7	6.5	5.2	-441	53	-
	28	63	-250	-22	-784	86	(4)	-14	-555	1.1	14.4	-1.0	15.0	6.6	11.2	-1.2	11.2	-730	-521	-

3

PVNGS FSAR

CATEGORY I STRUCTURES  
DESIGN OF



Table 3.8-1B(a)  
STRESS ANALYSIS RESULTS (Sheet 7 of 9)

Reference Loading Combination:  $D + P + 1.5P_o + T_o$  (SIS From Table 3.8-1A)

Portion	Section (Shown in Figure 3.8-22A)	Concrete Stresses								Reinforcement Stresses								Liner (b)		Deflection (c) (Primary Loads) (in)
		Meridional				Hoop				Meridional				Hoop				Meridional $\times 10^{-6}$ in/in	Hoop $\times 10^{-6}$ in/in	
		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary				
		MEM (psi)	MEM & BEN (psi)	MEM (psi)	MEM & BEN (psi)	MEM (psi)	MEM & BEN (psi)	MEM (psi)	MEM & BEN (psi)	Inside ksi	Outside ksi	Inside ksi	Outside ksi	Inside ksi	Outside ksi	Inside ksi	Outside ksi			
Allowable	Shell	-3600	-4500	-4500	-5100	-3600	-4500	-4500	-5100	154	154	154	154	154	154	154	154	110000	110000	-
	Basemat	-3000	-3750	-3750	-4250	-3000	-3750	-3750	-4250											
Dome	2	29	-89	170	-120	31	60	120	82	.3	.1	15.0	20.5	.3	.1	19.5	31.6	-232	-498	0.66
	7	-222	-277	-210	-1519	-22	-49	-99	-770	-1.1	-0.8	5.3	11.1	.2	.3	14.3	23.7	-255	-422	0.71
Wall	16	-204	-249	-204	-1572	123	(d)	-281	-1055	-1.0	-1.6	8.3	16.4	4.1	4.0	12.2	21.0	-370	-425	0.12
	18	-250	-359	-250	-1731	(g)	(d)	(g)	-494	-1.0	-0.8	6.0	17.3	16.9	16.4	16.7	25.3	-401	-410	0.52
	20	-295	-319	-295	-2419	77	(d)	-130	-1760	-1.9	-1.5	7.2	20.9	4.2	4.1	8.3	17.2	-661	-435	0.15
	21	-305	-1301	-305	-987	-226	-186	-439	-2702	9.7	-7.9	8.5	-2.0	-0.9	.9	.7	10.0	852	-453	-0.02
	22 (e)	-310	-2410	-310	-2878	-454	-1019	-559	-2033	42.4	-10.9	25.6	-13.9	-2.0	-1.4	-1.4	6.5	3020	-385	-0.06
Basemat Slab	23	22	-570	5	-570	-51	-403	-72	-404	29.5	.7	26.4	4.6	-2.7	10.6	-6.6	12.0	1131	-401	0.00
	25	11	-017	-9	-069	-119	-913	-142	-1100	-4.4	10.3	-5.6	10.3	-5.2	9.6	-7.7	12.5	940	-790	-0.16
	26	10	-022	4	-003	-219	-946	-270	-1213	-4.4	10.3	-5.5	10.4	-5.5	5.9	-0.4	9.0	-939	-710	-0.63
Reactor Cavity	27	-223	-350	-309	-805	49	(d)	107	(d)	-5.0	0.0	-4.5	5.6	2.4	2.9	4.5	7.1	-012	-209	0.02
	28	114	-110	72	-140	112	114	71	134	.7	.9	-0.1	0.0	.7	.0	-0.1	7.0	-343	-322	-0.69



Table 3.8-1B<sup>(a)</sup>  
 STRESS ANALYSIS RESULTS (Sheet 8 of 9)<sup>(f)</sup>

Reference Loading Combination:  $D + P + 1.25P_a + T_a + 1.25P_o$  (S18 from Table 3.8-1A)

Portion	Section (Shown in Figure 3.8-22A)	Concrete Stresses								Reinforcement Stresses								Liner (b) Strains		Deflection (c) (Primary Loads) (in)
		Meridional				Hoop				Meridional				Hoop				Meridional $\times 10^{-6}$ in/in	Hoop $\times 10^{-6}$ in/in	
		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary				
		MEM (psi)	MEM & BEM (psi)	MEM (psi)	MEM & BEM (psi)	MEM (psi)	MEM & BEM (psi)	MEM (psi)	MEM & BEM (psi)	Inside ksi	Outside ksi	Inside ksi	Outside ksi	Inside ksi	Outside ksi	Inside ksi	Outside ksi			
Allowable	Shell	-2600	-4300	-4300	-5100	-2600	-4300	-4300	-5100	254	254	254	254	254	254	254	254	110000	110000	-
	Basemat	-3000	-3750	-3750	-4250	-3000	-3750	-3750	-4250											
Dome	2	-119	-145	18	-1334	-113	-133	-52	-1162	-1.6	-1.8	2.4	50.0	-1.5	-1.7	-1.4	20.6	-2034	-1227	-
	7	-450	-404	-344	-2173	-130	-166	-203	-1642	-2.2	-1.7	-3.0	24.6	-1.9	-1.6	-2.5	23.3	-1332	-1153	-
Wall	16	-293	-345	-293	-2762	-76	-97	80	-1722	-1.9	-1.5	-3.2	44.1	-1.5	-1.3	.4	20.2	-2167	-1345	-
	18	-227	-250	-227	-2639	64	(d)	73	-1611	-1.2	-1.4	-2.4	35.5	10.3	6.9	3.1	33.7	-1730	-1570	-
	20	-170	-210	-170	-3164	-115	-135	-260	-2434	-1.2	-1.7	-1.6	52.3	-1.7	-1.5	-2.3	31.1	-2566	-1637	-
	21	-160	-1331	-160	-1740	-229	-296	-464	-2527	12.5	-3.9	1.3	31.6	-1.0	-1.6	-6.5	18.5	-1467	-1217	-
	22 (e)	-153	-3264	-153	-1397	-236	-429	-317	-2406	50.0	-0.1	14.3	-3.9	-1.7	-2.2	-7.1	15.7	2054	-1110	-
Basemat Slab	23	34	-430	33	-354	-19	-532	-55	-823	17.3	1.9	12.4	1.2	-1.9	11.2	-3.4	14.7	606	-711	-
	25	38	-1000	11	-1261	-84	-892	-112	-1270	-4.6	19.6	-5.7	20.0	-4.6	9.0	-6.6	13.6	-1041	-794	-
	26	46	-1002	22	-1194	-172	-834	-208	-1351	-4.5	20.2	-5.2	20.5	-4.0	6.6	-7.6	10.3	-1011	-703	-
Reactor Cavity	27	-220	-912	-223	-688	145	(d)	91	(d)	-3.0	.3	-3.0	2.0	7.3	0.3	3.0	6.1	-239	-94	-
	28	117	(d)	77	-175	335	(d)	84	(d)	5.1	19.2	1.0	19.4	11.2	16.0	4.5	13.0	-590	-356	-

December 1980

3.8-20K

Amendment 3

13/106

PVNGS FSAR

CATEGORY I STRUCTURES

DESIGN OF





Table 3.8-1B(a)  
STRESS ANALYSIS RESULTS (Sheet 9 of 9) (F)

Reference Loading Combination:  $D + P + P_a + T_a + E_{ab}$  (224 from Table 3.8-1A)

Portion	Section (Shown in Figure 3.8-22A)	Concrete Stresses								Reinforcement Stresses								Liner (b)		Deflection (Primary Loads) (in)
		Meridional				Hoop				Meridional				Hoop				Meridional $\times 10^{-6}$ in/in	Hoop $\times 10^{-6}$ in/in	
		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary		Primary		Primary and Secondary				
		MEM (psi)	MEM & BEM (psi)	MEM (psi)	MEM & BEM (psi)	MEM (psi)	MEM & BEM (psi)	MEM (psi)	MEM & BEM (psi)	Inside ksi	Outside ksi	Inside ksi	Outside ksi	Inside ksi	Outside ksi	Inside ksi	Outside ksi			
Allowable	Shell	-3600	-4500	-4500	-5120	-3600	-4500	-4500	-5100									±10000	±10000	-
	Basemat	-3000	-3750	-3750	-4250	-3000	-3750	-3750	-4250	±54	±54	±54	±54	±54	±54	±54	±54			
Dome	2	-272	-298	-353	-1977	-262	-279	-210	-1735	-1.4	-1.7	-3.1	40.3	-1.4	-1.6	-5.3	24.5	-1826	-1219	-
	7	-482	-528	-476	-2476	-257	-292	-324	-2066	-3.0	-2.9	-8.1	22.6	-1.6	-1.3	-4.7	23.7	-1344	-1275	-
Wall	16	-410	-459	-410	-3160	-270	-270	-153	-2195	-2.5	-2.1	-5.0	44.2	-1.5	-1.4	-3.3	24.1	-2392	-1320	-
	18	-307	-337	-307	-3165	-203	-214	-196	-2304	-1.6	-1.9	-3.0	41.0	-1.2	-1.0	-2.6	20.9	-2094	-1500	-
	20	-214	-294	-214	-3460	-241	-247	-377	-2713	-1.0	-1.6	-1.2	34.0 <sup>(h)</sup>	-1.4	-1.3	-4.4	29.4	-2676	-1647	-
	21	-194	-617	-194	-2904	-214	-241	-495	-2677	.7	-2.7	-.1	50.7	-1.0	-1.3	-7.0	19.7	-2460	-1302	-
	22(a)	-184	-2610	-184	-347	-172	-315	-540	-2612	30.0	-6.0	-1.5	-.4	-.9	-1.6	-7.5	16.9	2174	-3104	-
Basemat Slab	23	87	-439	32	-219	-23	-471	-87	-297	17.5	2.0	9.1	1.1	-1.0	9.1	-3.7	10.0	609	-569	-
	25	46	-834	18	-1135	-30	-693	-101	-1125	-3.3	10.3	-5.0	19.2	-3.3	0.4	-5.8	11.0	-350	-693	-
	26	45	-830	35	-1109	-89	-640	-180	-1230	-3.3	16.1	-4.7	19.0	-4.4	0.1	-6.7	10.7	-360	-688	-
Reactor Cavity	27	-163	-430	-156	-764	63	(d)	70	(d)	-2.4	.7	-3.0	9.4	2.7	6.1	3.1	9.3	-376	-92	-
	28	111	-130	86	-434	135	(d)	100	(d)	3.0	20.8	.4	16.0	10.4	17.9	9.3	17.1	-739	-496	-

3

PVNGS FSAR  
CATEGORY I STRUCTURES  
DESIGN OF



Table 3.8-4B

CONTAINMENT INTERNAL STRUCTURES SUMMARY OF GOVERNING COMBINED STRESS RATIOS FROM THE BEAM/COLUMN INTERACTION EQUATION FOR PRINCIPAL STRUCTURAL STEEL MEMBERS (Sheet 1 of 3)

Description of Principal Members	Location of Principal Members	Governing Load Combination Number	Combined Stress Ratio (<1.0)
W 18 X 35 Beam	El. 100'-0" @ Column #1	2 (a)	0.94
W 21 X 55 Beam	El. 100'-0" between Columns #2 and #3	2 (a)	0.85
W 33 X 130 Beam	El. 100'-0" between Columns #3 and #4	2 (a)	0.38
W 24 X 84 Beam	El. 100'-0" between Columns #4 and #5	2 (a)	0.99
W 21 X 55 Beam	El. 100'-0" @ Column #4	2 (a)	0.78
W 30 X 108 Beam	El. 100'-0" @ Column #6	2 (a)	0.69
W 30 X 108 Beam	El. 100'-0" between Columns #6 and #7	2 (a)	0.58
W 24 X 84 Beam	El. 100'-0" @ Column #10	2 (a)	0.31
W 30 X 172 Beam	El. 100'-0" between Columns #14 and #15	2 (a)	0.41
W 30 X 99 Beam	El. 100'-0" @ Column #16	2 (a)	0.68
W 36 X 135 Beam	El. 120'-0"	4 (b)	0.5
W 33 X 130 Beam	El. 120'-0"	4 (b)	0.41
W 36 X 300 Beam	El. 120'-0" @ Column #8	4 (b)	0.32

a. Refer to section 3.8.3.3.3.A(1) for description of load combination number.

b. Refer to section 3.8.3.3.3.B(1) for description of load combination number.

PVNGS FSAR

3

DESIGN OF  
CATEGORY I STRUCTURES

3 | Amendment 3

3-8-86D

December 1980

108



December 1980

3.8-86E

Table 3.8-4B

CONTAINMENT INTERNAL STRUCTURES SUMMARY OF GOVERNING COMBINED STRESS RATIOS FROM THE BEAM/COLUMN INTERACTION EQUATION FOR PRINCIPAL STRUCTURAL STEEL MEMBERS (Sheet 2 of 3)

Description of Principal Members	Location of Principal Members	Governing Load Combination Number	Combined Stress Ratio (<1.0)
W 36 X 182 Beam	El. 120'-0" @ Column #8	4 (b)	0.28
W 36 X 182 Beam	El. 120'-0" @ Column #7	4 (b)	0.41
W 30 X 99 Beam	El. 120'-0" between Columns #6 and #7	2 (a)	0.42
W 21 X 55 Beam	El. 120'-0" @ Column #5	2 (a)	0.87
W 14 X 43 Beam	El. 120'-0" @ Equipment Hatch	2 (a)	0.80
W 33 X 130 Beam	El. 120'-0" between Columns #4 and #5	2 (a)	0.34
W 21 X 55 Beam	El. 120'-0" between Columns #2 and #3	2 (a)	0.88
W 18 X 35 Beam	El. 120'-0" between Columns #1 and #2	2 (a)	0.78
W 21 X 55 Beam	El. 120'-0" between Columns #1 and #2	2 (a)	0.86
W 30 X 99 Beam	El. 120'-0" @ Column #1	2 (a)	0.71
W 36 X 300 Beam	El. 140'-0" between Columns #8 and #9	2 (a)	0.49
W 36 X 245 Beam	El. 140'-0" between Columns #9 and #10	4 (b)	0.21
W 36 X 300 Beam	El. 140'-0" between Columns #7 and #8	2 (a)	0.67
W 24 X 84 Beam	El. 140'-0" @ Column #8	2 (a)	0.96
W 24 X 55 Beam	El. 140'-0" @ Column #6	2 (a)	0.80
W 30 X 210 Beam	El. 140'-0" between Columns #14 and #15	2 (a)	0.26
W 24 X 68 Beam	El. 140'-0" between Columns #12 and #13	2 (a)	0.48
W 30 X 108 Beam	El. 140'-0" @ Column #17	2 (a)	0.61

3

CATEGORY I STRUCTURES

PVNGS FSAR

DESIGN OF

Amendment 3

3

109



Table 3.8-4B

CONTAINMENT INTERNAL STRUCTURES SUMMARY OF GOVERNING COMBINED STRESS RATIOS FROM THE BEAM/COLUMN INTERACTION EQUATION FOR PRINCIPAL STRUCTURAL STEEL MEMBERS (Sheet 3 of 3)

Description of Principal Members	Location of Principal Members	Governing Load Combination Number	Combined Stress Ratio (<1.0)
W 24 X 31 Beam	El. 140'-0" between Columns #15 and #16	2 (a)	0.73
W 24 X 84 Beam	El. 140'-0" @ Column #16	2 (a)	0.78
W 24 X 55 Beam	El. 140'-0" between Columns #17 and #18	2 (a)	0.81
W 14 X 150 Column	Column #1 between El. 100'-0" and 120'-0"	2 (a)	0.64
W 14 X 150 Column	Column #2 between El. 96'-6" and 120'-0"	2 (a)	0.79





3.8.5.5 Structural Acceptance Criteria



The foundations of Seismic Category I buildings are designed to meet the same structural acceptance criteria as the buildings themselves. These criteria are discussed in sections 3.8.1.5, 3.8.3.5, and 3.8.4.5. The limiting conditions for the foundation medium, together with a comparison of actual capacity and estimated structure loads, are found in sections 2.5.4.10 and 2.5.4.11. Computed factors of safety against overturning, sliding, and flotation for Category I structures are given in table 3.8-5.

Table 3.8-5  
COMPUTED FACTORS OF SAFETY

Structure	Overturning		Sliding		Flotation
	OBE	SSE	OBE	SSE	
Auxiliary	3200	830	2.2	1.3	4.7
Containment	3400	1200	1.7	1.2	4.5
Control	1500	420	1.6	1.2	4.8
Diesel Generator	1200	400	2.2	1.1	NA <sup>(a)</sup>
Fuel	1600	400	1.9	1.1	NA
Main Steam Support	340	91	1.6	1.1	NA
Condensate Storage and Refueling Water Tanks	500	150	1.7	1.4	NA


a. Not applicable





NOTE:  
 1. SEE DRAWING 13-C-103 FOR THE  
 2. THE REINFORCEMENT SHALL BE PLACED IN THE  
 3. THE REINFORCEMENT SHALL BE PLACED IN THE  
 4. THE REINFORCEMENT SHALL BE PLACED IN THE

13-C-103 REV. 0


 Palo Verde Nuclear Generating Station  
 FSAR

CONTAINMENT BUILDING  
 BASE MAT REINFORCING PLAN-BOTTOM LAYERS  
 AREAS CAA, CAB, CAC & CAD

Figure 3.8-1

112





13-C-ZCS-104 REV 13


**Palo Verde Nuclear Generating Station  
FSAR**

CONTAINMENT BUILDING  
BASE MAT REINFORCING  
SECTIONS AND DETAILS

Figure 3.8-2

113





**Palo Verde Nuclear Generating Station  
FSAR**

**CONTAINMENT BUILDING  
WALL REINFORCING  
SECTIONS AND DETAILS**


**Figure 3.8-4**

p11







TIP WALL REINFC  
SEE LOCATIONS  
FOR WALLS C-10  
(NOT TO SCALE)




SECTION A-A  
6'-0"




DETAIL (1)  
FOR (C-10) HTS




SECTION K-K  
12'-0"




SECTION B-B  
12'-0"




SECTION C-C  
12'-0"




WALL PENETRATION REINFC @ FUEL TRANSFER TUBE (LOOKING FROM OUTSIDE)  
12'-0"




SECTION D-D  
12'-0"




SECTION E-E  
12'-0"



TYPICAL ELECTRICAL PENETRATIONS  
SECTION F-F  
12'-0"



SECTION G-G  
12'-0"



TYPICAL MECHANICAL PENETRATIONS  
SECTION H-H  
12'-0"

FOR WALLS SEE SEE REINFC  
THEY ARE NOT TO BE REINFC  
WITH REINFC OR REINFC  
AT INTERIOR OR EXTERIOR SURFACE  
AND THE REINFC IS TO BE  
REINFC WITH REINFC  
BEFORE TREATMENT


**Palo Verde Nuclear Generating Station  
FSAR**

CONTAINMENT BUILDING  
WALL REINFORCING  
SECTIONS AND DETAILS

Figure 3.8-5

115






REV 1, 26-773

13-C-2CS-123 REV 1

	<b>Palo Verde Nuclear Generating Station</b> <b>FSAR</b>
	<b>CONTAINMENT BUILDING</b> <b>DOME REINFORCING</b> (Sheet 1 of 2)
	<b>Figure 3.8-6</b>





13-C-ZCS-122 REV 2


**Palo Verde Nuclear Generating Station  
FSAR**

**CONTAINMENT BUILDING  
DOME REINFORCING  
(Sheet 2 of 2)**


**Figure 3.8-6**

117





TYPE	A	B	C	D	E	F
186 WIRE	10-1/2 IN DIA	11 IN SQ	24 IN	4 IN	4-1/4 IN	5 FT 7-3/4 IN




**Palo Verde Nuclear Generating Station  
FSAR**

**TENDON END ANCHORS**  
Figure 3.8-7







- KEY**
- 2" THICK 1/4" LINER PLATE
  - 2" THICK 1/2" LINER PLATE
  - 2" THICK 1" LINER PLATE
  - 2" THICK 2" LINER PLATE
  - 2" THICK LINER PLATE JOINT
  - 2" THICK LINER PLATE JOINT
- NOTES**
1. SEE DIMENSIONS AND TOLERANCES ON SHEET 13-C-ZC6-200 REV 3
  2. FOR LINER PLATE, SEE SHEET 13-C-ZC6-200 REV 3
  3. SEE DIMENSIONS AND TOLERANCES ON SHEET 13-C-ZC6-200 REV 3
  4. FOR LINER PLATE, SEE SHEET 13-C-ZC6-200 REV 3
  5. SEE DIMENSIONS AND TOLERANCES ON SHEET 13-C-ZC6-200 REV 3

13-C-ZC6-200 REV 3

**Palo Verde Nuclear Generating Station**  
FSAR



---

CONTAINMENT BUILDING  
BASE MAT LINER PLATE-FLOOR PLAN  
AREAS CAA, CAB, CAC & CAD

Figure 3.8-12

511





Containment Building







1. On location only if 1/2" or less in size  
 2. All other items shall be shown as noted

13-C-203-201 REV 4

	<b>Palo Verde Nuclear Generating Station</b> <b>FSAR</b>
	<b>CONTAINMENT BUILDING</b> <b>BASE MAT LINER PLATE-INSERTS PLAN</b> <b>AREAS CAA, CAB, CAC &amp; CAD</b> <b>Figure 3.8-13</b>

120





1. DETAILS OF WALL AND OF TOP AND BOTTOM FLANGES SHALL BE AS SHOWN UNLESS OTHERWISE SPECIFIED IN THE DRAWING.


13-C-2CS-211 REV B

**Palo Verde Nuclear Generating Station  
FSAR**

**CONTAINMENT BUILDING  
WALL LINER PLATE  
SECTIONS AND DETAILS**

**Figure 3.8-17**





13-C-208-219 REV 6

**Palo Verde Nuclear Generating Station  
FSAR**

---




**CONTAINMENT BUILDING  
WALL LINER PLATE  
SECTIONS AND DETAILS**

Figure 3.8-18

122














**ANCHOR & GUSSET SCHEDULE**

TYPE	1"	2"	3"	4"	6"
M	1/2"	3/4"	1"	1 1/4"	1 1/2"
N	1/2"	3/4"	1"	1 1/4"	1 1/2"
GUSSET B	1/2"	3/4"	1"	1 1/4"	1 1/2"
SPACING	1/2"	3/4"	1"	1 1/4"	1 1/2"
ANCHOR RING B	1/2"	3/4"	1"	1 1/4"	1 1/2"
THICKEN B	1/2"	3/4"	1"	1 1/4"	1 1/2"
ANCHOR SLOTT	1/2"	3/4"	1"	1 1/4"	1 1/2"
GUSSET B	1/2"	3/4"	1"	1 1/4"	1 1/2"
WELD SIZE	1/8"	1/8"	1/8"	1/8"	1/8"
R	0.0"	0.0"	0.0"	0.0"	0.0"



1. SEE SECTION 472 FOR PENETRATION SCHEDULE
2. SEE SECTION 472 FOR PENETRATION SCHEDULE
3. SEE SECTION 472 FOR PENETRATION SCHEDULE
4. SEE SECTION 472 FOR PENETRATION SCHEDULE
5. SEE SECTION 472 FOR PENETRATION SCHEDULE
6. SEE SECTION 472 FOR PENETRATION SCHEDULE
7. SEE SECTION 472 FOR PENETRATION SCHEDULE
8. SEE SECTION 472 FOR PENETRATION SCHEDULE
9. SEE SECTION 472 FOR PENETRATION SCHEDULE
10. SEE SECTION 472 FOR PENETRATION SCHEDULE

13 C-205-213 REV 10




**Palo Verde Nuclear Generating Station**  
**FSAR**

CONTAINMENT BUILDING  
 WALL LINER PLATE  
 SECTIONS AND DETAILS

Figure 1.8-19

123






SEE NOTES, SEE DWG NO. G-120.100

12-C-208-218 REV 3

	<b>Palo Verde Nuclear Generating Station</b> <b>FSAR</b>
	<b>CONTAINMENT BUILDING</b> <b>WALL LINER PLATE</b> <b>SECTIONS &amp; DETAILS</b> <b>Figure 3.8-20</b>





- NOTE:** ALL ANCHORS & STIFFERS, AS SHOWN ON DRAWINGS, SHALL BE WELDED TO THE CONTAINMENT VESSEL.
1. ALL WELDS SHALL BE MADE IN ACCORDANCE WITH THE WELDING PROCEDURE SPECIFICATION (WPS) AND QUALIFICATION RECORD (QTR) FOR THE WELDING PROCESS AND MATERIALS TO BE USED.
  2. ALL WELDS SHALL BE MADE BY A WELDER WHO IS QUALIFIED IN ACCORDANCE WITH THE WELDING PROCEDURE SPECIFICATION (WPS) AND QUALIFICATION RECORD (QTR) FOR THE WELDING PROCESS AND MATERIALS TO BE USED.
  3. ALL WELDS SHALL BE MADE BY A WELDER WHO IS QUALIFIED IN ACCORDANCE WITH THE WELDING PROCEDURE SPECIFICATION (WPS) AND QUALIFICATION RECORD (QTR) FOR THE WELDING PROCESS AND MATERIALS TO BE USED.
  4. ALL WELDS SHALL BE MADE BY A WELDER WHO IS QUALIFIED IN ACCORDANCE WITH THE WELDING PROCEDURE SPECIFICATION (WPS) AND QUALIFICATION RECORD (QTR) FOR THE WELDING PROCESS AND MATERIALS TO BE USED.
  5. ALL WELDS SHALL BE MADE BY A WELDER WHO IS QUALIFIED IN ACCORDANCE WITH THE WELDING PROCEDURE SPECIFICATION (WPS) AND QUALIFICATION RECORD (QTR) FOR THE WELDING PROCESS AND MATERIALS TO BE USED.
  6. ALL WELDS SHALL BE MADE BY A WELDER WHO IS QUALIFIED IN ACCORDANCE WITH THE WELDING PROCEDURE SPECIFICATION (WPS) AND QUALIFICATION RECORD (QTR) FOR THE WELDING PROCESS AND MATERIALS TO BE USED.
  7. ALL WELDS SHALL BE MADE BY A WELDER WHO IS QUALIFIED IN ACCORDANCE WITH THE WELDING PROCEDURE SPECIFICATION (WPS) AND QUALIFICATION RECORD (QTR) FOR THE WELDING PROCESS AND MATERIALS TO BE USED.
  8. ALL WELDS SHALL BE MADE BY A WELDER WHO IS QUALIFIED IN ACCORDANCE WITH THE WELDING PROCEDURE SPECIFICATION (WPS) AND QUALIFICATION RECORD (QTR) FOR THE WELDING PROCESS AND MATERIALS TO BE USED.
  9. ALL WELDS SHALL BE MADE BY A WELDER WHO IS QUALIFIED IN ACCORDANCE WITH THE WELDING PROCEDURE SPECIFICATION (WPS) AND QUALIFICATION RECORD (QTR) FOR THE WELDING PROCESS AND MATERIALS TO BE USED.
  10. ALL WELDS SHALL BE MADE BY A WELDER WHO IS QUALIFIED IN ACCORDANCE WITH THE WELDING PROCEDURE SPECIFICATION (WPS) AND QUALIFICATION RECORD (QTR) FOR THE WELDING PROCESS AND MATERIALS TO BE USED.

13-C ZCS 600 REV 6

**Palo Verde Nuclear Generating Station**  
**FSAR**


---

**CONTAINMENT INTERNALS**  
**REACTOR VESSEL SUPPORTS**

Figure 3.8-23

125





13-C-2CS-601 REV 8

**Palo Verde Nuclear Generating Station  
FSAR**

---

**CONTAINMENT 'INTERNALS  
REACTOR VESSEL SUPPORTS**


**Figure 3.8-24**

March 1989 Amendment 1

126








- REVISIONS**
1. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  2. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  3. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  4. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  5. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  6. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  7. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  8. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  9. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  10. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  11. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  12. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  13. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  14. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  15. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  16. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  17. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  18. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  19. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  20. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  21. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  22. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  23. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  24. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  25. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  26. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  27. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  28. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  29. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  30. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  31. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  32. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  33. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  34. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  35. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  36. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  37. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  38. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  39. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  40. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  41. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  42. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  43. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  44. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  45. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  46. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  47. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  48. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  49. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:
  50. REVISE DRAWING TO REFLECT THE FOLLOWING CHANGES:

13-C-2CS-006 REV D



**Palo Verde Nuclear Generating Station**  
**FSAR**

**CONTAINMENT INTERNALS**  
**STEAM GENERATOR LOWER SUPPORTS**  
**SECTIONS AND DETAILS**

**Figure 3.8-25**


Amendment 1

122











KEY PLAN—VERTICAL SUPPORTS  
REACTOR COOLANT PUMPS



SECTION A-A



SECTION B-B

1. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE IN INCHES AND DECIMALS THEREOF.
2. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE SHAFT OR THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
3. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
4. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
5. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
6. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
7. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
8. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
9. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
10. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
11. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
12. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
13. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
14. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
15. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
16. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
17. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
18. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
19. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.
20. ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE TO BE TAKEN TO THE CENTER OF THE HOLES UNLESS OTHERWISE SPECIFIED.

13-C-2CS-602 REV 6



**Palo Verde Nuclear Generating Station  
FSAR**

---

**CONTAINMENT INTERNALS  
COOLANT PUMP SUPPORTS**

Figure 3.8-27





**DETAIL UPPER LATERAL SUPPORT 4-RIGID**

1. The upper lateral support is a rigid structure that supports the upper portion of the pump assembly. It is designed to withstand the full weight of the pump and any seismic loads. The support is attached to the containment structure via a series of anchor bolts and a base plate. The base plate is welded to the containment structure and the anchor bolts are secured with nuts and washers. The support is designed to be 4-rigid, meaning it is fixed at all four corners.

2. The support is made of stainless steel and is designed to be compatible with the containment structure. It is designed to be easy to inspect and maintain. The support is designed to be able to be removed and replaced if necessary.

3. The support is designed to be able to be used in a variety of configurations. It can be used to support a single pump or multiple pumps. It can be used to support pumps of different sizes and weights. The support is designed to be able to be used in a variety of orientations.

4. The support is designed to be able to be used in a variety of environments. It can be used in a variety of temperatures and pressures. It is designed to be able to be used in a variety of locations within the containment structure.

5. The support is designed to be able to be used in a variety of ways. It can be used to support a pump, a motor, or a control panel. It can be used to support a variety of other equipment. The support is designed to be able to be used in a variety of ways.

6. The support is designed to be able to be used in a variety of ways. It can be used to support a pump, a motor, or a control panel. It can be used to support a variety of other equipment. The support is designed to be able to be used in a variety of ways.

7. The support is designed to be able to be used in a variety of ways. It can be used to support a pump, a motor, or a control panel. It can be used to support a variety of other equipment. The support is designed to be able to be used in a variety of ways.

8. The support is designed to be able to be used in a variety of ways. It can be used to support a pump, a motor, or a control panel. It can be used to support a variety of other equipment. The support is designed to be able to be used in a variety of ways.

9. The support is designed to be able to be used in a variety of ways. It can be used to support a pump, a motor, or a control panel. It can be used to support a variety of other equipment. The support is designed to be able to be used in a variety of ways.

10. The support is designed to be able to be used in a variety of ways. It can be used to support a pump, a motor, or a control panel. It can be used to support a variety of other equipment. The support is designed to be able to be used in a variety of ways.

13 C ZCS 603 REV 3

**Palo Verde Nuclear Generating Station**  
**FSAR**






---

**CONTAINMENT INTERNALS**  
**COOLANT PUMP SUPPORTS**

Figure 3.8-28







- NOTES:
1. SEE THE FORMS DRAWING ON SHEET D-10-100 FOR THE FORMS.
  2. REINFORCING BARS SHALL BE OF THE TYPE AND SIZE AS SHOWN ON THIS PLAN. THE BARS SHALL BE DEVELOPED TO THE LENGTH AS SHOWN ON THIS PLAN.
  3. ALL REINFORCING BARS SHALL BE OF THE TYPE AND SIZE AS SHOWN ON THIS PLAN.
  4. THE REINFORCING BARS SHALL BE DEVELOPED TO THE LENGTH AS SHOWN ON THIS PLAN.
- NOTE: THE REINFORCING BARS SHALL BE DEVELOPED TO THE LENGTH AS SHOWN ON THIS PLAN.


13-C-208-348 REV 4


**Palo Verde Nuclear Generating Station**  
FSAR

**CONTAINMENT INTERNALS**  
**REINFORCED CONCRETE**  
**PRIMARY SHIELD**

Figure 3.8-30









	<b>Palo Verde Nuclear Generating Station</b> <b>FSAR</b>
	<b>CONTAINMENT INTERNALS</b> <b>REINFORCED CONCRETE</b> <b>PRIMARY SHIELD</b> <b>Figure 3.8-31</b>

132





13-C-PCS-347 REV 8






	<b>Palo Verde Nuclear Generating Station</b> <b>FSAR</b>
	<b>CONTAINMENT INTERNALS</b> <b>REINFORCED CONCRETE</b> <b>PRIMARY SHIELD</b>
<b>Figure 3.8-32</b>	












- KEY:
- 1. SEE THE SHEET FOR THE LOCATION OF THE REIN.
  - 2. SEE THE SHEET FOR THE LOCATION OF THE REIN.
  - 3. SEE THE SHEET FOR THE LOCATION OF THE REIN.
  - 4. SEE THE SHEET FOR THE LOCATION OF THE REIN.

13-C-ZCS-368 REV 4

	<b>Palo Verde Nuclear Generating Station</b> <b>FSAR</b>
	<b>CONTAINMENT INTERNALS</b> <b>REIN. CONC. - SHIELD WALLS</b> <b>SECTIONS AND DETAILS</b> (Sheet 1 of 2) <b>Figure 3.8-34</b>


135





ELEVATION LOOKING FROM OUTSIDE

ELEVATION LOOKING INTERIOR




13 C-ZCS-358 REV 5

	<b>Palo Verde Nuclear Generating Station</b> <b>FSAR</b>
	<b>CONTAINMENT INTERNALS</b> <b>REINFORCING CONCRETE</b> <b>WEST SECONDARY SHIELD WALLS</b> (Sheet 2 of 2) Figure 3.0-34

136





**Palo Verde Nuclear Generating Station**  
**FSAR**

CONTAINMENT INTERNALS  
 PARTIAL CONCRETE PLAN AT  
 EL 140'-0" AREAS C3A & C3B


Figure J.8-15

March 1980

Amendment 1

137





13C 203 207 REV 6

**Palo Verde Nuclear Generating Station**  
**FSAR**

CONTAINMENT - INTERNALS  
 PARTIAL CONCRETE PLAN AT  
 EL. 140'-0" AREAS C1C & C3D


Figure 3.8-16


March 1990 Amendment 1

138









 Palo Verde Nuclear Generating Station  
 PSAR -  
 POLAR CRANE SEISMIC  
 RETAINER BRACKET  
 Figure 3.8-37

2  
 135





1. THE CRANE GIRDER SHALL BE SUPPORTED BY THE CRANE BEAMS AS SHOWN IN THE PLAN VIEW.
2. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
3. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
4. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
5. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
6. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
7. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
8. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
9. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
10. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
11. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
12. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
13. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
14. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
15. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
16. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
17. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
18. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
19. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.
20. THE CRANE GIRDER SHALL BE WELDED TO THE CRANE BEAMS AS SHOWN IN THE SECTION VIEWS.


13C 2CS 620 REV 7


**Palo Verde Nuclear Generating Station  
FSAR**

**CONTAINMENT INTERNALS  
POLAR CRANE SUPPORT GIRDER  
SECTIONS AND DETAILS**

**Figure 3.8-JB**







**Palo Verde Nuclear Generating Station**  
**FSAR**


---

CONTAINMENT BUILDING  
 SSE HORIZ (E-W) ACC. RESPONSE SPECTRA  
 EL. 143.5 FT, STEAM GENERATOR SNUBBERS

Figure 3D-7







**Palo Verde Nuclear Generating Station**  
**FSAR**  
 CONTAINMENT BUILDING SSE HORIZ (E-W)  
 ACC. RESPONSE SPECTRA EL. 119.5 FT,  
 R.C. PUMP UPPER HORIZ SUPPORTS  
 Figure 3D-9





ACCELERATION (G'S)




Palo Verde Nuclear Generating Station  
FSAR


CONTAINMENT BUILDING SSE HORIZ (E-W)  
ACC. RESPONSE SPECTRA EL. 97.7 FT,  
R.C. PUMP LOWER HORIZ SUPPORTS

Figure 3D-11



ACCELERATION (G'S)





 Palo Verde Nuclear Generating Station  
FSAR

CONTAINMENT BUILDING SSE HORIZ (E-W)  
ACC. RESPONSE SPECTRA EL. 97.6 FT,  
R.V. COL. UPPER HORIZ GUIDES

Figure 3D-13








**Palo Verde Nuclear Generating Station  
FSAR**

CONTAINMENT BUILDING SSE HORIZ (E-W)  
 ACC. RESPONSE SPECTRA EL. 78.0 FT,  
 R.V. COL BASES & LOWER KEYS

Figure 3D-15








**Palo Verde Nuclear Generating Station**  
**FSAR**  
 CONTAINMENT BUILDING SSE VERTICAL ACC.  
 RESPONSE SPECTRA  
 EL. 78.0 FT, R.V. COLUMN BASES  
 Figure 3D-17











**Palo Verde Nuclear Generating Station  
FSAR**  
 CONTAINMENT BUILDING SSE HORIZ (N-S)  
 ACC. RESPONSE SPECTRA EL. 150.9 FT,  
 STEAM GENERATOR UPPER KEYS  
 Figure 3D-19







**Palo Verde Nuclear Generating Station  
FSAR**  
 CONTAINMENT BUILDING SSE VERTICAL  
 ACC. RESPONSE SPECTRA  
 EL. 96.7 FT, STEAM GENERATOR BASES  
 Figure 3D-21








**Palo Verde Nuclear Generating Station  
FSAR**

CONTAINMENT BUILDING SSE VERTICAL  
 ACC. RESPONSE SPECTRA, CONTAINMENT  
 SHELL AND INTERIOR STRUCTURE

Figure 3D-23






**Palo Verde Nuclear Generating Station**  
**FSAR**

CONTAINMENT BUILDING SSE  
 HORIZONTAL ACC. RESPONSE SPECTRA  
 EL. 73.5 FT, BASE MAT  
 Figure 3D-25








ARIZONA NUCLEAR POWER PROJECT  
PALO VERDE NUCLEAR  
GENERATING STATION  
UNITS 1, 2, AND 3

CONTAINMENT BUILDING  
SSE HORIZ. (E-W) ACC. RESPONSE SPECTRA  
EL. 108.3 FT., PRESSURIZER BASE

PREPARED: <i>JPI/MC/R.C.</i>	REVIEWED: <i>ROF JFO'S</i>	APPROVED: <i>FWB</i>
JOB NO. 10407	PAGE NUMBER: IV.2-25	REV. A DATE <i>1-12-76</i>








ARIZONA NUCLEAR POWER PROJECT  
PALO VERDE NUCLEAR  
GENERATING STATION  
UNITS 1, 2, AND 3

CONTAINMENT BUILDING  
SSE HORIZ. (N-S) ACC. RESPONSE SPECTRA  
EL. 108.3 FT., PRESSURIZER BASE

PREPARED: <i>JP/MC/R.C.</i>	REVIEWED: <i>RBF JFO'S</i>	APPROVED <i>FWB</i>
JOB NO. 10407	PAGE NUMBER: <i>IV.2-27</i>	REV. <i>A</i> DATE <i>11/27/76</i>



152






ARIZONA NUCLEAR POWER PROJECT  
PALO VERDE NUCLEAR  
GENERATING STATION  
UNITS 1, 2, AND 3

CONTAINMENT BUILDING  
SSE VERTICAL ACC. RESPONSE SPECTRA  
CONTAINMENT SHELL AND INTERIOR STRUCTURE

PREPARED: <i>J.P./M.C./K.C.</i>	REVIEWED: <i>RBF JFO'S</i>	APPROVED <i>H WSP</i>
JOB NO. 10407	PAGE NUMBER: IV.2-39	REV. B DATE 11-15-77








ARIZONA NUCLEAR POWER PROJECT  
PALO VERDE NUCLEAR  
GENERATING STATION  
UNITS 1, 2, AND 3

CONTAINMENT BUILDING  
SSE HORIZONTAL ACC. RESPONSE SPECTRA  
FLOOR SLAB AT ELEVATION 100.0 FT.

PREPARED: <i>J.P./m.c./rc</i>	REVIEWED: <i>RBF JFO'S</i>	APPROVED: <i>JH WGB</i>
JOB NO. 10407	PAGE NUMBER: IV.2-63	REV. B      DATE 11-15-77










ARIZONA NUCLEAR POWER PROJECT  
PALO VERDE NUCLEAR  
GENERATING STATION  
UNITS 1, 2, AND 3

CONTAINMENT BUILDING  
SSE HORIZONTAL ACC. RESPONSE SPECTRA  
FLOOR SLAB AT ELEVATION 120.0 FT.

PREPARED: <i>J.P./m.c./rc</i>	REVIEWED: <i>RBF JFO'S</i>	APPROVED: <i>[Signature]</i>	<i>WGB</i>
JOB NO. 10407	PAGE NUMBER: IV.2-65	REV. B	DATE. 11-15-77








ARIZONA NUCLEAR POWER PROJECT  
PALO VERDE NUCLEAR  
GENERATING STATION  
UNITS 1, 2, AND 3

CONTAINMENT BUILDING  
SSE HORIZONTAL ACC. RESPONSE SPECTRA  
FLOOR SLAB AT ELEVATION 140.0 FT.

PREPARED: <i>J.P./m.c./r.c.</i>	REVIEWED: <i>RBF JFO'S</i>	APPROVED <i>WGB</i>
JOB NO. 10407	PAGE NUMBER: IV.2-67	REV. B DATE 11-15-77








ARIZONA NUCLEAR POWER PROJECT  
PALO VERDE NUCLEAR  
GENERATING STATION  
UNITS 1, 2, AND 3



CONTAINMENT BUILDING  
SSE VERTICAL ACC. RESPONSE SPECTRA  
EL. 213.5 FT., POLAR CRANE

PREPARED: <i>JP/MC/R.C.</i>	REVIEWED: <i>ii</i>	APPROVED: <i>wab JB</i>
JOB NO. 10407	DRAWING NO.: IV.2-75	REV. A      DATE: 7/5/76








ARIZONA NUCLEAR POWER PROJECT  
PALO VERDE NUCLEAR  
GENERATING STATION  
UNITS 1, 2, AND 3



CONTAINMENT BUILDING  
SSE VERTICAL ACC. RESPONSE SPECTRA  
EL. 110.0 FT., PRESSURIZER BASE


PREPARED: <i>JP/mc/r.c.</i>	REVIEWED: <i>W.C.</i>	APPROVED: <i>TH HPP</i>
JOB NO. 10407	DRAWING NO.: IV.2-79	REV. A DATE 7/27/76







This drawing has been prepared by Bechtel and is the work of its independent contractors. It is not intended to be used for any other purpose than that for which it was prepared.



**LEGEND**


	REINFORCEMENT ELEMENT
	REINFORCEMENT-EMBEDMENT
	PRESTRESSED ELEMENT
	SIMPLE PLATE ELEMENT
	CONCRETE ELEMENT
	SOIL ELEMENT
	DIRECTION OF ELEMENT NUMBERS

FIGURE A.1-1

159


	 <b>BECTEL</b> LOS ANGELES	<b>CONTAINMENT SHELL</b> <b>FINEL COMPUTER MODEL</b> 2/12 1541 <b>SKC-277 A</b>
ARIZONA NUCLEAR POWER PROJECT PAJO VERDE NUCLEAR GENERATING STATION		







This drawing has been prepared by Bechtel and is the property of the ARCHITECT-ENGINEER CONTRACTOR. It is to be used only for the project and site named herein and for no other purpose without the written consent of Bechtel.



**LEGEND**

	REINFORCEMENT ELEMENT
	REINFORCEMENT (IN BACK) ELEMENT
	PIERS ELEMENT
	LINER PLATE ELEMENT
	CONCRETE ELEMENT
	SOIL ELEMENT
	DIRECTION OF ELEMENT NUMBERING

FIGURE A.1-2

	 <b>BECHTEL</b> LOS ANGELES	<b>CONTAINMENT SHELL</b> <b>FINE COMPUTER MODEL</b> <b>SHT 2</b>				
	ARIZONA NUCLEAR POWER PROJECT PALO VERDE NUCLEAR GENERATING STATION	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;"></td> <td style="width: 50%;"></td> </tr> <tr> <td style="text-align: center;">3X-C-278</td> <td style="text-align: center;">A</td> </tr> </table>			3X-C-278	A
3X-C-278	A					



PALO VERDE NUCLEAR STATION UNITS 1, 2, 3  
DESIGN ADEQUACY AUDIT

STRUCTURAL AUDIT OF MAIN STEAM SUPPORT STRUCTURE  
Part I - General Analysis

I. BASIC DESIGN CRITERIA

A. 'g' value - free field

	Seismic level based on construction permit license	Seismic level used in design of structures and equipment
SSE	0.20g	0.25g
OBE	0.10g	0.13g

Reference: FSAR, Section 3.7

B. Spectra (attach figs. for all damping values, ductilities)

1. zero period acceleration

SSE	0.25g
OBE	0.13g

(Pages 213-216)

Reference: FSAR, Figures 3.7-1 --3.7-4 and Section 3.7.1.1  
This is consistent with Reg. Guide 1.60

Frequency (or period) interval

Refer to BC-TOP-4A, Section 2.5.1 (c)

C. Damping

Refer to FSAR, Section 3.7.1.3

This is consistent with Reg. Guide 1.61

Refer to FSAR Figures 3.7-5 and 3.7-6 (Pages 216A and 216B)

D. Artificial time history and corresponding spectra (attach figures)

1. original time history and its composition, i.e., rising time, strong motion and tail end.

Refer to FSAR, Section 3.7.1.2 and BC-TOP-4A, Section 2.5





2. base line correction, check the integrated velocity and displacement time histories

The velocity and displacement time histories were checked and found to be satisfactory. In addition, only the acceleration time history was used as input in analysis.

3. time interval - compatible with the highest frequency considered in the spectral calculation

0.005 seconds

E. Motion duration

24 seconds

Refer to FSAR, Section 3.7.1.2

F. components of motion including their relative motion amplitudes

Analysis was performed for the three principle directions with equal amplitudes.

G. Dead and live loads for various operating floors and base slab

~~Refer to Project Design Criteria Part II, Section 3.0 and Part III, Section 4.0~~

Dead load - includes all structures, major equipment load and 50 psf equivalent for small equipment.

Live load - see 'action item' 3



H. Ground water level

The groundwater design level is at plant El 70'-0". The actual plant level is at approximately plant EL. 60'-0".

Reference: FSAR, Sections 2.4.13.2.4 and 2.4.13.5.

I. Backfill earth pressure, wind, overpressure due to postulated external explosions (as applicable)

~~Refer to Project Design Criteria Part II, Sections 3.4.5.3 and 3.5.3 for lateral earth pressure, wind, and tornado loads.~~

For lateral earth pressure see Pages 208A - 208D.  
Wind does not govern.

J. Other considerations

All penetrations in roof and exterior walls that expose safety related equipment have tornado missile protection. Concrete covers or steel plate shields to prevent missile perforation are provided.



II. ANALYSIS METHOD

A. Seismic Analysis

1. Mathematical model-general description with sketch.

Two planer lumped parameter models were used.

Refer to FSAR Section 3.7.2.3.3 and attachment Ax (Page 207)

a. (1) concrete modulus

$$E_c = 3.83 \times 10^6 \text{ psi for } f'_c = 4000 \text{ psi}$$

$$E_c = 4.03 \times 10^6 \text{ psi for } f'_c = 5000 \text{ psi}$$

(2) rebar modulus and yield strength

$$E = 29 \times 10^3 \text{ KSI } F_y = 60 \text{ KSI}$$

(3) Poisson's ratio

$$\nu = 0.20 \text{ for concrete}$$

(4) damping

(Page 212)

See FSAR, Section 3.7.1.3 and Table 3.7-1 and response to NRC Question 220.2 (Q 3A-4).

This is consistent with Reg. Guide 1.61



(5) properties of foundation materials

- shear modulus

Refer to FSAR, Figures 3.7-7, -8, -9 (Pages 217-219)

- subgrade reactions

~~Refer to Design Criteria Manual Part II, Section 3.4.5.4 for coefficient of subgrade reaction~~

Coefficient of subgrade reaction = 40-60 KIPS/FT<sup>2</sup>/FT

bearing capabilities

(Pages 209-210)

Refer to Tables 2.5-15 and 2.5-16 of the FSAR.

(6) other parameters

b. stiffness calculations

(1) exterior walls

Stiffness calculations were performed manually using standard engineering methods.

(2) interior walls

Same as exterior walls.



12



2. method of Analysis

- a. method of analysis used (time history, response spectrum methods, etc.) and consideration of torsional and translational response

Time history analyses were performed to derive in-structure response spectra.

(1) general description

Two planar, lumped parameter models were used in the analysis. Soil structure interaction was incorporated into the model by adding to the fixed-base system discrete soil springs based on elastic half-space theory.

The soil structure interaction analysis method was used and compared against current NRC review position and this meets the intent of NRC soil structure interaction position

(2) findings and comments

- b. selection of number of masses and degrees of freedom

(1) general description

For horizontal direction the model consisted of 6 nodes and 12 degrees of freedom.

For vertical direction, the model consisted of 6 nodes and 6 degrees of freedom.



(2) findings and comments

c. number of modes considered

	<u>SSE</u>	<u>OBE</u>
Horizontal (E-W)	4 Modes f = 26.9 cps	4 Modes f = 26.9 cps
Horizontal (N-S)	5 Modes f = 30.2 cps	5 Modes f = 30.3 cps
Vertical	1 Mode f = 5.85 cps	1 Mode f = 6.26 cps

Frequencies shown above are for the highest mode considered.

(1) general description

~~See Attachment.~~

Refer to FSAR, Appendix 3A, Question 3A.6.

(2) findings and comments



d. combining modal responses

(1) actual procedures used

Refer to FSAR, Section 3.7.2.7

(2) general findings

e. consideration of three components of motion

(1) actual procedures used

Refer to FSAR, Section 3.7.2.6

It is consistent with Reg. Guide 1.92

(2) general findings



f. consideration of soil-structure interaction

Soil Springs

$$K_x = 4.67 \times 10^5 \text{ K/FT} \quad K_{xx} = 2.89 \times 10^8 \text{ K-FT/RAD}$$

SSE  $K_y = 6.57 \times 10^5$

$$K_z = 4.67 \times 10^5 \quad K_{zz} = 2.89 \times 10^8$$

$$K_x = 6.07 \times 10^5 \text{ K/FT} \quad K_{xx} = 3.75 \times 10^8 \text{ K-FT/RAD}$$

OBE  $K_y = 7.78 \times 10^5$

$$K_z = 6.07 \times 10^5 \quad K_{zz} = 3.75 \times 10^8$$

x: North-south direction  
y: Vertical direction  
z: East-West direction

(1) general description

Refer to FSAR, Section 3.7.2.4.

(2) findings and comments

g. decoupling criteria for subsystems

(1) general procedure

Refer to BC-TOP-4A, Section 3.2

The other criteria pertaining to frequency ratio as defined in SRP 3.7.3.II.3.b are also met.

(2) key examples





(3) general findings and comments

h. modeling of hydrodynamic effects in spent fuel pool

Not applicable.

i. modeling of spent fuel pool <sup>a</sup>wells and interior floor  
slabs and equipment thereof

Not applicable.



3. development of in-structure response spectra

Refer to FSAR, Section 3.7.2.5

a. general procedures

The "SPECTRA" program was used to compute the response spectra. Refer to FSAR Appendix 3B for a description and applications of this program.

(1) smoothing (describe specific smoothing method used)

The smoothed floor response spectra represent an envelope of the maximum peaks.

(2) peak widening

$\pm 15\%$

Reference: FSAR, Section 3.7.2.9

b. typical results (attach figures)

Refer to FSAR, Figures 3D-37, -38, -39<sub>x</sub> (Pages 223 - 225 )



B. Stress Analysis

1. shear walls and floors

a. mathematical model - general description w/sketch

Shear wall and floor stresses were computed by performing standard manual calculations. Vertical loads were distributed in the structure by conventional methods. Lateral loads were calculated by multiplying lumped mass and seismic acceleration obtained from floor spectra at each level. These lateral loads were then distributed among the shear walls according to their relative stiffness and location.

b. method of analysis--incorporation of torsion

The minimum torsion moment was taken as the total seismic force times 5% of the long dimension (47') of the building. Geometric eccentricity is insignificant.

c. load combinations

Refer to FSAR, Section 3.8.3.3.



1. foundation mat

a. mathematical model - description of boundary conditions

The foundation mat was designed as a one-way slab. The slab had fixed boundaries at the junction of the walls with the basemat.

b. method of analysis

The analysis was done manually.

c. load combinations

Refer to FSAR, Section 3.8.3.3.

*This is in compliance with SRP*

d. key results (figures, etc.)

$$M_u = 597 \text{ Ft-K/Ft}$$
$$V_u = 210 \text{ K/Ft}$$





3. Material to protect against structure - structure interaction

Below grade (EL 100'-0") Rodofam II (WR Grace and Co.) or EVERLASTIC Micro II (Williams Products, Inc.) may be left in place in seismic joints between structures. Above grade gaps between walls were left open, typically 6" between Category I structures.

- a. mechanical properties
- b. additional pressure on walls
- c. findings and comments



4. vertical dynamic analysis

a. mathematical model - general description with sketch

The planer lumped parameter model consisted of one beam founded on a rigid mat, representing the exterior and interior walls.

b. development of stiffnesses, including floor stiffness, as applicable

Stiffnesses were calculated manually using standard engineering methods.

c. method of analysis

The model described above was used for acceleration time-history analysis using Fosin.



C. Computer Programs Used in Analysis

LUCON, SMIS, FOSIN, SPECTRA

1. assumptions and limitations

Refer to FSAR, Appendix 3B.

2. applicability

Refer to FSAR, Appendix 3B.

3. verification

- sensitivity study in case of numerical solutions (e.g., finite element analysis)

Refer to FSAR, Appendix 3B.

4. load input (include all cases)

PROGRAM	INPUT
SMIS	Mass matrix, stiffness matrix, damping values.
SPECTRA	In-structure time histories, frequency or periods and damping values.
FOSIN	Free-field time history, damping values, frequency.
LUCON	Shear modules, damping values.



5. output (include all cases)

-- Refer to FSAR, Appendix 3B.

6. other discussions





D. Overall Stability

1. forces and moments from seismic analysis

Elastic forces and moments

Horizontal Force

Overturning Moment

OBE

SSE

OBE

SSE

4270<sup>K</sup>

6160<sup>K</sup>

241,900 K-FT

348,800 K-FT

2. various cases considered

Seismic loading combinations considered an SSE or OBE applied in the North-South, East-West and vertical directions simultaneously.



3. bearing pressure versus bearing capability and safety factor against bearing failure

-- Refer to FSAR, Section 2.5.4.10 and Tables 2.5-15, -16x (Pages 209-210)

4. factors of safety

Refer to FSAR, Section 3.8.5.5 and Table 3.8-5 (Page 222)

- a. sliding

Factor of Safety = 1.1 (SSE)

- b. overturning

Factor of Safety = 91 (SSE)



E. Interaction of Non-category I Structures with the Structure Considered

1. identification of pertinent non-Category I structures

The Corridor and Turbine Buildings are adjacent to the Main Steam Support Structure.

2. consideration given to potential failure of non-Category I systems on Category I systems

The ~~Corridor and Turbine Buildings~~<sup>is</sup> are designed to preclude structural failure of building or parts thereof that could damage the Main Steam Support Structure and its Category I systems. Within the Main Steam Support Structure, non-Category I systems which potentially could affect Category I systems, are designed for structural integrity under SSE equivalent loads. *During a walkdown, those items whose failure will not affect any safety \**  
Reference: FSAR, Section 3.8.4.4

3. general findings and comments

\* related equipment are left as they are. If they are judged that they might affect category I systems, they are designed to maintain their structural integrity under SSE.



F. Design Consideration for Tornado Missiles

1. design requirements

Refer to FSAR, Sections 3.5.1.4 and 3.5.3, and Table 3.5-8x (Page 211)

2. models for

a. local damage

Refer to FSAR, Section 3.5.3.

b. overall response

Refer to FSAR, Section 3.5.3.

3. load combinations

Refer to FSAR, Section 3.8.3.3.

4. forces

The governing structural members are of sufficient thickness to preclude perforation by postulated missiles and maintain structural integrity.





Main Steam Support Structure

-22-

6. general comments and preliminary audit findings



III. CONFORMANCE TO ACCEPTABLE CRITERIA

A. Identification of deviations, if any

None.

B. Justification of deviations and disposition of the deviations

D. general comments



Part II Audit of Key Designs

A. Exterior Shear Walls

1. design requirements

The walls were designed to satisfy structural functions as bearing walls, shear walls, resistance to external and internal pressures, and protection against tornado missiles.

2. design loads (from general analysts)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Refer to FSAR, Table 3.8-4L<sub>x</sub> (Page 220) This table is being amended.

4. detailed design of rebar placement at key sections

See Attachment B<sub>x</sub> (Pages 202-208)

5. general comments and preliminary audit findings



B. Interior Shear Walls

1. design requirements

Same as exterior walls.

2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Refer to FSAR, Table 3.8-4Lx (Page 220)

*This table is being amended*

4. detailed design of rebar placement at key sections

See Attachment Bx (Pages 202-208)

5. general comments and preliminary audit findings





C. Main Floors and Roofs

1. design requirements

The main floor and roof were primarily designed for vertical dead, live and seismic loads, ~~as defined in the Project Design Criteria.~~  
The roof were also designed to satisfy minimum thickness to preclude perforation by tornado generated missiles.

2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Refer to FSAR, Table 3.8-4Lx (Page 220)

This table is being amended.

4. detailed design of rebar placement at key sections

See Attachment B<sub>1</sub> (Pages 202-208)



5. general comments and preliminary audit findings



D. Steel Structural Bracing Systems (if any)

- 1. design requirements

The main steam support structure roof is elevated above the top of the walls by a structural steel frame. The frame was designed for dead, live, seismic and accident pressure, ~~per the Project Design Criteria~~

2. design loads

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Refer to FSAR, Table 3.8-4M<sub>x</sub> (page 221)

6. general comments and preliminary audit findings



E. Foundation Mat

1. design requirements

Refer to FSAR, Section 3.8.5.4.2 and 3.8.5.5

2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

$$M_u = 597 \text{ Ft-K/Ft}$$

$$\sqrt{X}_u = 210 \text{ K/Ft}$$

4. detailed design of rebar placement at key sections

See Attachment B<sub>x</sub> (Pages 202-208)

5. general comments and preliminary audit findings





F. Main Frame Concrete Column Design (Key Columns)

1. design requirements

Not applicable. There are no concrete columns in the main steam support structure.

2. design loads (from general analysis)

3. forces and moments at key sections

4. detailed design of rebar placement at key sections

5. general comments and preliminary audit findings



G. Secondary Floors

1. design requirements

The Main Steam Support Structure has steel grating platforms spanning between the concrete walls. The structural steel is designed for dead, live, seismic and pipe support loads.

2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Refer to FSAR, Table 3.8-4M<sub>x</sub> (Page 221)

4. detailed design of rebar placement at key sections

See Attachment B<sub>x</sub> (Pages 202-208)

5. general comments and preliminary audit findings



H. Detailing at Floor-Wall Joints

- 1. design requirements

As per ACI 318-71 Code, Chapters 6 and 17.

2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Moment = 103.5 K-FT/FT (positive & negative)

Shear = 191.3 psi/FT stirrups are provided

4. detailed design of rebar placement at key sections

See Attachment B<sub>x</sub> (Pages 202-208)

5. general comments and preliminary audit findings



I. Dynamic Effects Applied to Floors and Walls by Machinery

1. design requirements

Dynamic effects from machinery are negligible.

2. design loads (from general analysis)

3. forces and moments at key sections

4. detailed design

5. general comments and preliminary audit findings





J. Crane & Support

1. design of bents (columns and roof trusses)

Not applicable. There are no cranes in the MSSS.

a. design requirements

b. design loads (from general analysis)

c. forces and moments at key sections

d. detailed design



Main Steam Support Structure

-35-

- e. general comments and preliminary audit findings



2. design of girders supporting crane rails

Not applicable.

a. design requirements

b. design loads (from general analysis)

c. forces and moments at key sections

d. detailed design



Main Steam Support Structure

-37-

e. general comments and preliminary audit findings





3. design of spent fuel bridge

Not applicable.

a. design requirements

b. design loads (from general analysis)

c. forces and moments at key sections

d. detailed design

e. general comments and preliminary audit findings




K. Fuel Pool Liner Design

- Not applicable.


1. stresses and strain controls
2. conformance to code requirements
3. analysis procedure and results
4. consideration of accidental drop of crane loads
5. corrosion effects (e.g., pitting) on liner integrity
6. preliminary findings of audit results





MAIN STEAM SUPPORT STRUCTURE.






AT TANGENT POINTS  
(SEE PLAN)

2-LAYERS #10 @ 12 BOT. 7 SPACING CV & OF  
2-LAYERS #10 @ 12 TOP CONTAINMENT

MAIN STEAM SUPPORT STRUCTURE EXTERIOR SHEAR WALL








MAIN STEAM SUPPORT STRUCTURE ... INTERIOR SHEAR WALL

SECTION

A  
700






MAIN STEAM SUPPORT STRUCTURE PRIMARY FLOOR

204






REINFORCING PLAN @ EL. 166'-11"  
 1/4" = 1'-0"

PLAN OF ROOF

MAIN STEAM SUPPORT STRUCTURE





FOUNDATION PLAN T.O.C. EL. 81'-0"


MAIN STEAM SUPPORT STRUCTURE

206





W12.31 TYP. UNO.



T.O.G. EL. 120'-0" T.O.S. EL. (-1 1/2") U.M.O.


MAIN STEAM SUPPORT STRUCTURE SECONDARY FLOOR

LADDER 8' 3"

LADDER 7' 8"

ATTACHMENT B 6 OF 7





MAIN STEAM SUPPORT STRUCTURE

TYPICAL WALL - FLOOR JUNCTION

7 OF 7

ATTACHMENT B

202



### Lateral Earth Pressure

The total lateral earth pressure on foundation and retaining walls shall be based on the sum of the appropriate static and dynamic lateral forces. Static forces shall be based either on the active case ( $P_A$ ) for the case of a retaining wall free to rotate and translate, or on the compacted backfill case ( $P_B$ ) for the case of a rigid foundation wall. Dynamic forces shall be based on the dynamic increment for a level backfill condition ( $P_{AE}$ ) plus the surcharge effect ( $P_{AES}$ ), if applicable.

#### A. Static conditions:

Equivalent Fluid Unit Weight (lb/ft<sup>3</sup>)  
(Horizontal Backfill)

<u>Case</u>	<u>Above Water Table</u>	<u>Below Water Table</u>
Active ( $P_A$ )	36	19
Passive ( $P_P$ )	228	118
Backfill ( $P_B$ )	90	47

The increment of lateral pressure due to adjacent surcharge for the case of a rigid foundation wall shall be computed using Figure 1.

The increment of lateral pressure due to adjacent surcharge for the case of a retaining wall free to rotate and translate shall be computed using Figure 2.


#### B. Dynamic conditions:

The dynamic lateral force increment due to seismic effects shall be computed in accordance with Figure 3.

The total dynamic lateral force increment,  $P_{AE}$  or  $P_{AE} + P_{AES}$ , shall be added to the lateral force calculated for either the active case or the compacted backfill case. The lateral force is calculated in the usual manner and includes hydrostatic pressure if a water table is present. The dynamic lateral force increments are independent of the water table.



- q = SURCHARGE PRESSURE (PSF)
- b = WIDTH OF SURCHARGE (FT)
- $\sigma_s$  = AVERAGE UNIFORM HORIZONTAL PRESSURE DUE TO SURCHARGE (PSF)
- H = DEPTH OF WALL BELOW ADJACENT SURCHARGE (FT)





AVERAGE LATERAL PRESSURE DUE TO ADJACENT SURCHARGE FOR RIGID RETAINING WALL

Figure. 1





- $\sigma_s$  = AVERAGE UNIFORM HORIZONTAL PRESSURE DUE TO SURCHARGE (PSF)
- $q$  = SURCHARGE PRESSURE (PSF)
- $b$  = WIDTH OF SURCHARGE (FT)
- $H$  = HEIGHT OF WALL (FT)
- $K_a = 0.28$ , ACTIVE PRESSURE COEFFICIENT
- $A_r$  = RATIO OF ACTIVE EARTH PRESSURE CAUSED BY SURCHARGE OF FINITE WIDTH TO SURCHARGE OF INFINITE WIDTH




AVERAGE LATERAL PRESSURE DUE TO ADJACENT SURCHARGE FOR RETAINING WALL FREE TO ROTATE

Figure 2



Level Backfill Condition



$$P_{AE} = 0.5 k_v K_A \gamma_t H^2 + 0.3(1 + k_v) k_h \gamma_t H^2$$

where:  $P_{AE}$  = dynamic lateral force increment due to seismic effects (lb)


$K_A$  = 0.28, coefficient of active lateral earth pressure.

$k_h = k_v = 0.25$  under SSE conditions, and  
0.13 under OBE conditions

$H$  = wall height (ft)

$\gamma_t$  = total unit weight (129 lb/ft<sup>3</sup>)

Surcharge Effect



where:  $P_{AES}$  = dynamic lateral force increment due to adjacent surcharge loading (lb)

$q$  = Surcharge pressure (lb/ft<sup>3</sup>)

$H$  = Depth of wall below adjacent surcharge (ft)

$K_A$  = 0.28

$k_h = k_v = 0.25$  under SSE conditions, and  
0.13 under OBE conditions

DYNAMIC LATERAL FORCE INCREMENT DUE TO SEISMIC EFFECTS

Figure 3



Table 2.5-15  
 STATIC BEARING CAPACITY OF CATEGORY I STRUCTURES

Structure	Average Static Design Load $q_s$ (k/ft <sup>2</sup> )	Ultimate Bearing Capacity $q_o$ (k/ft <sup>2</sup> )	Factor of Safety ( $q_o/q_s$ )
Containment Building	7.9	35.7	4.5
Auxiliary Building (deep section)	6.2	34.9	5.6
Main Steam Support Structure	7.1	64.8	9.1
Control Building	3.3	45.3	13.7
Fuel Building	5.3	54.9	10.4
Diesel Generator Building	3.1	79.5	25.6
Refueling Water Tank	4.4	90.4	20.5
Condensate Storage Tank	3.5	112.4	32.1

PVNGS FSAR

GEOLOGY AND SEISMOLOGY



March 1980

2.5-163

Amendment 1

Table 2.5-16

DYNAMIC BEARING CAPACITY OF CATEGORY I STRUCTURES (a)

Structure	Equivalent Uniform Vertical Stress $q_d$ (k/ft <sup>2</sup> )	Ultimate Bearing Capacity $q_o$ (k/ft <sup>2</sup> )	Factor of Safety ( $q_o/q_d$ )
Containment Building	16.1	32.2	2.0
Auxiliary Building (deep section)	10.3	25.8	2.5
Main Steam Support Structure	25.3	60.6	2.4
Control Building	9.8	39.8	4.1
Fuel Building	19.1	50.3	2.6
Diesel Generator Building	5.6	75.5	13.5
Refueling Water Tank	13.2	58.7	4.4
Condensate Storage Tank (b)	13.2	30.2	2.3

- a. Based upon maximum dynamic loads derived from analyses described in section 3.7.
- b. Condensate storage tank loads were conservatively chosen to be equal to the dynamic design load for the refueling water tank. Actual loads will be less.

PVNGS FSAR

GEOLOGY AND SEISMOLOGY





Table 3.5-8

## TORNADO-GENERATED MISSILES CONSIDERED IN DESIGN OF SAFE SHUTDOWN STRUCTURES

Description	Weight (lbs)	Impact Area (ft <sup>2</sup> )	Maximum Velocity (ft/s)	Kinetic Energy (ft-lbs)
(A) A 12-foot wood plank, 4 x 12 inches in cross-section, traveling end on at a speed of 240 mi/h.	200	0.333	352	$3.85 \times 10^5$
(B) A steel pipe, Schedule 40, 3 inches in diameter by 10 feet long, traveling end on at 120 mi/h.	78	0.063	176	$3.75 \times 10^4$
(C) A steel rod, 1 inch in diameter, 3 feet long, traveling end on at 180 mi/h.	8	0.005	264	$8.66 \times 10^3$
(D) A steel pipe, Schedule 40, 6 inches in diameter by 15 feet long, traveling end on at 120 mi/h.	285	0.24	176	$1.37 \times 10^5$
(E) A steel pipe, Schedule 40, 12 inches in diameter by 15 feet long, traveling end on at 120 mi/h.	743	0.886	176	$3.57 \times 10^5$
(F) A utility pole, 13-1/2 inches in diameter, 35 feet long, traveling end on at 120 mi/h.	1490	0.994	176	$7.17 \times 10^5$
(G) An automobile of 4,000 pounds weight, striking the structure at 60 mi/h.	4000	20.0	88	$4.81 \times 10^5$

3.5-34

PVNGS FSAR

MISSILE PROTECTION



Table 3.7-1  
DAMPING VALUES  
(PERCENT OF CRITICAL DAMPING)

Structure or Component	Operating Basis Earthquake	Safe Shutdown Earthquake
Equipment and large-diameter piping systems, pipe diameter greater than 12 in.	2	3
Small-diameter piping systems, diameter equal to or less than 12 in.	1	2
Welded steel structures	2	4
Bolted steel structures	4	7
Prestressed concrete structures	2	5
Reinforced concrete structures	4	7


The applicable allowable design levels are given in section 3.8 for the various loading combinations which include seismic loadings.

3.7.1.4 Supporting Media for Seismic Category I Structures

For purposes of the seismic analysis, the site is assumed to be a multi-layer system consisting of soil over bedrock. The approximate depth of soil deposit over bedrock for each unit at the site is as follows:

	<u>Unit 1</u>	<u>Unit 2</u>	<u>Unit 3</u>
Depth of Soil, ft	330	350	295







**Palo Verde Nuclear Generating Station  
FSAR**

**HORIZONTAL DESIGN SPECTRA  
FOR SSE 0.25 g**

**Figure 3.7-1**







**Palo Verde Nuclear Generating Station  
FSAR**


---

**VERTICAL DESIGN SPECTRA  
FOR SSE 0.25 g  
Figure 3.7-2**










**Palo Verde Nuclear Generating Station**  
**FSAR**  
 HORIZONTAL DESIGN SPECTRA  
 FOR OBE 0.13 g  
 Figure 3.7-3








**Palo Verde Nuclear Generating Station  
FSAR**

---

VERTICAL DESIGN SPECTRA  
 FOR OBE 0.13 g  
 Figure 3.7-4








**Palo Verde Nuclear Generating Station  
FSAR**

**DAMPING VS. STRAIN - CLAY**  
**FIGURE 3.7-5**






**Palo Verde Nuclear Generating Station**  
**FSAR**

---


**DAMPING VS. STRAIN - SAND**  
**FIGURE 3.7-6**





DEPTH (FT.)	LAYER DEPTH (FT.)	DESCRIPTION	LAYER THICKNESS	UNIT WEIGHT (PCF)	POISSON'S RATIO	SHEAR WAVE VELOCITY (FT/SEC)	LOW STRAIN SHEAR MODULUS (KSF)	LOW STRAIN P-WAVE VELOCITY (FT/SEC)
AVERAGE PERCHED WATER LEVEL 44'	47'	SAND (2)	47'	123	.27	996	3790	
						1116	4760	1990
						1173	5260	2090
	70'	CLAY (1)	23'	121	.44	1194	5450	3650
						1209	5500	4445
	105'	CLAY (1)	82'	123	.47	1253	6000	5268
						1281	6270	5386
						1401	7500	6502
	158'	SAND (2)	10'	125	.465	1389		5454
	163'					1308	8980	6544
	196'	SAND (2)	12'	127	.46			
	206'	CLAY (1)	20'	126	.45	1776	12350	9992
228'	SAND (2)	10'	127	.44	1934	15630	6060	
234'					2040	16880	6293	
285'	CLAY (1)	73'	128	.44	2270	20650	6348	
					2701	19270	6726	
					2176	19130	6450	
311'	SAND (2)	23'	130	.44				
334'	BEDROCK							

- NOTES: 1. LOW STRAIN SHEAR MODULI AT VARIOUS DEPTHS ARE AVERAGE VALUES.  
 2. SHEAR WAVE VELOCITY CALCULATED FROM  $V_s = (G/\rho)^{1/2}$   
 3. P-WAVE VELOCITY CALCULATED FROM  $V_p = V_s [(2 - 2\nu)/(1 - 2\nu)]^{1/2}$




Revised 1980


Amendment 2

CHANGE

212








**Palo Verde Nuclear Generating Station  
FSAR**

---

**SHEAR MODULUS VS. STRAIN - CLAY**  
**FIGURE 3.7-8**






**Palo Verde Nuclear Generating Station**  
**FSAR**

---

**SHEAR MODULUS VS. STRAIN - SAND**  
**FIGURE 3.7-9**



Table 3.8-4L

**MAIN STEAM SUPPORT STRUCTURE SUMMARY OF GOVERNING LOAD INTERACTIONS FOR  
PRINCIPAL REINFORCED CONCRETE MEMBERS**

Description of Principal Member	Location of Principal Member	Governing Load Combination Number (a)	Calculated Axial Load ( $P_u$ ) and Flexural Load ( $M_u$ )		Maximum Flexural Interaction Capacity ( $M_u$ ), Given Axial Load ( $P_u$ ) (b) (c)	Calculated Shear Load ( $V_u$ ) (b)	Maximum Shear Capacity ( $V_u$ ) (b)
			$P_u$ (b)	$M_u$ (c)			
3'-6" thick wall - vertical reinforcement	Exterior north wall El. 81'-0" to 100'-0"	5	+600	97,480	$2.76 \times 10^6$	2,433	6,384
3'-6" thick wall - vertical reinforcement	Interior wall El. 81'-0" to 100'-0"	3	+600	144	637	37.2	48.1
3'-6" thick wall - vertical reinforcement	Exterior south wall El. 100'-0" to 156'-0"	5	+1,200	67,300	$2.76 \times 10^6$	2,037	15,900
Variable wall thickness vertical reinforcement	Exterior west wall El. 100'-0" to 156'-0"	5	+545	93,460	$3.08 \times 10^6$	3,536	25,400
3'-6" thick slab	El. 100'-0"	3	0	103.5	264	94.3	100.9
2'-5-1/4" thick slab	El. 166'-7"	3	0	34	100	34.7	41.4

- a. Refer to Section 3.8.3.3.2.b for description of load combination number.  
b.  $P_u$  and  $V_u$  are in kips; sign convention for  $P_u$ : Compression (-), Tension (+).  
c.  $M_u$  is in ft-k/ft for slabs and ft-k for walls.

PVNGS FSAR

3

CATEGORY I STRUCTURES

DESIGN OF





Table 3.8-4M

MAIN STEAM SUPPORT STRUCTURE SUMMARY OF GOVERNING COMBINED  
STRESS RATIOS FROM THE BEAM/COLUMN INTERACTION EQUATION  
FOR PRINCIPAL STRUCTURAL STEEL MEMBERS

Description of Principal Members	Location of Principal Members	Governing Load Combination Number	Combined Stress Ratio (<1.0)
C 10 X 30 Beam	El. 88'-11-1/2"	2 (a)	1.0
W 16 X 15.5 Column	El. 88'-11-1/2"	1 (a)	1.0
W 24 X 76 Beam	El. 120'-0"	2 (a)	0.94
W 12 X 31 Beam	El. 120'-0"	2 (a)	0.96
W 12 X 40 Beam	El. 132'-0"	2 (a)	0.89
W 18 X 77 Beam	El. 129'-8"	2 (a)	0.60
W 18 X 106 Beam	El. 129'-8"	2 (a)	0.42
W 18 X 97 Beam	El. 140'-0"	2 (a)	0.96
W 14 X 176 Beam	El. 140'-0"	2 (a)	1.0
W 12 X 40 Beam	El. 140'-0"	2 (a)	0.51
W 8 X 40 Beam	El. 149'-0"	2 (a)	0.87
W 16 X 77 Beam	El. 164'-6-1/4"	5 (b)	0.96
W 30 X 132 Beam	El. 164'-6-1/4"	5 (b)	0.96
W 16 X 40 Beam	El. 164'-6-1/4"	5 (b)	0.97
W 14 X 120 Column	El. 164'-6-1/4"	5 (b)	1.0

- a. Refer to section 3.8.3.3.3.A(1) for description of load combination number.
- b. Refer to section 3.8.3.3.3.B(1) for description of load combination number.

3




3.8.5.5 Structural Acceptance Criteria


The foundations of Seismic Category I buildings are designed to meet the same structural acceptance criteria as the buildings themselves. These criteria are discussed in sections 3.8.1.5, 3.8.3.5, and 3.8.4.5. The limiting conditions for the foundation medium, together with a comparison of actual capacity and estimated structure loads, are found in sections 2.5.4.10 and 2.5.4.11. Computed factors of safety against overturning, sliding, and flotation for Category I structures are given in table 3.8-5.

Table 3.8-5  
COMPUTED FACTORS OF SAFETY


Structure	Overturning		Sliding		Flotation
	OBE	SSE	OBE	SSE	
Auxiliary	3200	830	2.2	1.3	4.7
Containment	3400	1200	1.7	1.2	4.5
Control	1500	420	1.6	1.2	4.8
Diesel Generator	1200	400	2.2	1.1	NA <sup>(a)</sup>
Fuel	1600	400	1.9	1.1	NA
Main Steam Support	340	91	1.6	1.1	NA
Condensate Storage and Refueling Water Tanks	500	150	1.7	1.4	NA
a. Not applicable					







**Palo Verde Nuclear Generating Station**  
**FSAR**  
 MAIN STEAM SUPPORT STRUCTURE  
 SSE VERTICAL  
 ACCELERATION RESPONSE SPECTRA  
 Figure 3D-37








**Palo Verde Nuclear Generating Station**  
**FSAR**  
 MAIN STEAM SUPPORT STRUCTURE  
 SSE HORIZONTAL (E-W)  
 ACCELERATION RESPONSE SPECTRA  
 EL 81'-0", BASE MAT  
 Figure 3D-38








**Palo Verde Nuclear Generating Station**  
**FSAR**  
 MAIN STEAM SUPPORT STRUCTURE  
 SSE HORIZONTAL (E-W)  
 ACCELERATION RESPONSE SPECTRA  
 EL 164'-0", ROOF  
 Figure 3D-39



PALO VERDE NUCLEAR STATION UNITS 1, 2, 3  
DESIGN ADEQUACY AUDIT

STRUCTURAL AUDIT OF AUXILIARY BUILDING  
Part I - General Analysis

I. BASIC DESIGN CRITERIA

A. 'g' value - free field

	Seismic level based on construction permit license	Seismic level used in design of structures and equipment
SSE	0.20g	0.25g
OBE	0.10g	0.13g

Reference: FSAR, Section 3.7

B. Spectra (attach figs. for all damping values, ductilities)

1. zero period acceleration

SSE	0.25g
OBE	0.13g

Reference: FSAR, Figures 3.7-1 - 3.7-4 and Section 3.7.1.1  
(Pgs. 270, 1, 2, 3)

*This is consistent with Reg. Guide 1.60.*

Frequency (or period) interval

Refer to BC-TOP-4A, Section 2.5.1 (c)

C. Damping

Refer to FSAR, Section 3.7.1.3

*This is consistent with Reg. Guide 1.61*

*Refer to FSAR Figures 3.7-5 and 3.7-6 (Pages 92A, 92B)*

D. Artificial time history and corresponding spectra (attach figures)

1. original time history and its composition, i.e., rising time, strong motion and tail end.

Refer to FSAR, Section 3.7.1.2 and BC-TOP-4A, Section 2.5



2. base line correction, check the integrated velocity and displacement time histories

The velocity and displacement time histories were checked and found to be satisfactory. In addition, only the acceleration time history was used as input in analysis.

3. time interval - compatible with the highest frequency considered in the spectral calculation,

0.005 seconds

E. Motion duration

24 seconds

Refer to FSAR, Section 3.7.1.2

F. components of motion including their relative motion amplitudes

Analysis was performed for the three principle directions with equal amplitudes.

G. Dead and live loads for various operating floors and base slab

~~Refer to Project Design Criteria Part II, Sections 3.5.1 and 3.5.2, and Part III, Section 1.4.1.~~

Dead Load - includes all structures, major equipment load  
and 50 psf equivalent for small equipment  
Live load - see action item 3



## H. Ground water level

The groundwater design level is at plant El 70'-0". The actual water level is at approximately plant El. 60'-0". A portion of the building extends down to El. 40'-0". Buoyancy effects have been considered in the design.

Reference: FSAR, Sections 2.4.13.2.4 and 2.4.13.5.

## I. Backfill earth pressure, wind, overpressure due to postulated external explosions (as applicable)

~~Refer to Project Design Criteria Part II, Sections 3.4.5.3 and 3.5.5 for lateral earth pressure, wind, and tornado loads.~~

*For lateral earth pressure see pages 208A & 208B, 208C,  
Wind does not govern 208D*

## J. Other considerations

All penetrations in roof and exterior walls that expose safety related equipment have tornado missile protection. Concrete covers or steel plate shields to prevent missile perforation are provided.





## II. ANALYSIS METHOD

## A. Seismic Analysis

## 1. Mathematical model-general description with sketch.

Two planar lumped parameter models were used.

Refer to FSAR, Figure 3.7-11 and Section 3.7.2.3.

## a. (1) concrete modulus

$$\begin{array}{ll} E = 3.64 \times 10^6 \text{ psi} & \text{For } F'_c = 4000 \text{ psi} \\ E = 4.07 \times 10^6 \text{ psi} & \text{For } F'_c = 5000 \text{ psi} \end{array}$$

## (2) rebar modulus and yield strength

$$E = 29 \times 10^3 \text{ KSI}$$

$$F_y = 60 \text{ KSI}$$

## (3) Poisson's ratio

$$\nu = .24 \text{ for concrete}$$

~~Reference: Project Design Criteria, Part II, Section 3.5.7~~

## (4) damping

Refer to FSAR Section 3.7.1.3 and ~~response to NRC~~  
~~Question 220.2 (Q3A-4)~~ and Table 3.7-1 (Page 88A)

This is consistent with Reg. Guide 1.61.



## (5) properties of foundation materials

- shear modulus

Refer to FSAR, Figures 3.7-7, -8, -9. (Pages 274, 5.6)

- subgrade reactions

~~Refer to Project Design Criteria, Part II,  
Section 3.4.5.4 for coefficient of subgrade  
reaction~~

Coefficient of subgrade reaction = 40-60 kips/ft<sup>2</sup>/ft

- bearing capabilities

Refer to Tables 2.5-15 and 2.5-16 of the FSAR. (Pages 266 & 267)

## (6) other parameters

## b. stiffness calculations

## (1) exterior walls

Exterior walls and interior walls stiffness calculations were performed manually using standard engineering methods.

## (2) interior walls

Same as exterior walls except for concrete masonry walls (fire barrier walls) and plaster walls which were neglected.



## 2. method of Analysis

- a. method of analysis used (time history, response spectrum methods, etc.) and consideration of torsional and translational response

The models described above were used for acceleration time history and modal response spectrum analyses. The time history analysis was performed using FOSIN. The modal response spectrum analysis was performed using SAP 1.9.

### (1) general description

The Auxiliary Building analysis used two planar lumped parameter models. Soil structure interaction was incorporated into the model by adding to the fixed-base system discrete soil springs based on elastic half-space theory.

*The Soil structure interaction analysis method was used and compared against current NRC review position and this meets the intent of NRC Soil structure interaction position*

### (2) findings and comments

- b. selection of number of masses and degrees of freedom

### (1) general description

For horizontal direction earthquake, the model consisted of 6 nodes and 12 degrees of freedom.

For vertical direction earthquake, the model consisted of 6 nodes and 6 degrees of freedom.



## (2) findings and comments

## c. number of modes considered

	SSE	OBE
Horizontal (N-S)	5 modes 37.9 cps	5 modes (37.6 cps)
Horizontal (E-W)	5 modes 40.0 cps	5 modes (39.7 cps)
Vertical	3 modes 69.1 cps	3 modes (68.7 cps)

Frequency shown above are for the highest mode considered.

## (1) general description

Refer to FSAR, Table 3.7-4, for modal frequencies and participation factors. (Page 279)

## (2) findings and comments





d. combining modal responses

(1) actual procedures used

Refer to FSAR, Section 3.7.2.7.

(2) general findings

e. consideration of three components of motion

(1) actual procedures used

Refer to FSAR, Section 3.7.2.6.

*This is consistent with Reg Guide 1.92*

(2) general findings



## f. consideration of soil-structure interaction

## Soil Springs

## OBE

North-South	$K_x = 2.87 \times 10^6 \text{ K/ft}$	$K_{xx} = 1.158 \times 10^{10} \text{ K-ft/Rad}$
East-West	$K_y = 2.755 \times 10^6 \text{ K/ft}$	$K_{yy} = 2.975 \times 10^{10} \text{ K-ft/Rad}$
Vertical	$K_z = 3.905 \times 10^6 \text{ K/ft}$	

## SSE

North-South	$K_x = 2.206 \times 10^6 \text{ K/ft}$	$K_{xx} = 8.902 \times 10^9 \text{ K-ft/Rad}$
East-West	$K_y = 2.117 \times 10^6 \text{ K/ft}$	$K_{yy} = 2.286 \times 10^{10} \text{ K-ft/Rad}$
Vertical	$K_z = 3.00 \times 10^6 \text{ K/ft}$	

## (1) general description

Refer to FSAR, Section 3.7.2.4.

## (2) findings and comments

## g. decoupling criteria for subsystems

## (1) general procedure

Refer to BC-TOP-4A, Section 3.2.

## (2) key examples

(3) The other criteria pertaining to frequency ratio as defined in SRP 3.7.3.II.3.6 are also met.



(3) general findings and comments

h. modeling of hydrodynamic effects in spent fuel pool

Not applicable. The Spent Fuel Pool is located in the Fuel Handling Building.

i. modeling of spent fuel pool wells and interior floor slabs and equipment thereof

Not applicable.



## 3. development of in-structure response spectra

Refer to FSAR, Section 3.7.2.5

## a. general procedures

The "SPECTRA" program was used to compute the response spectra. Refer to FSAR, Appendix 3B for a description and applications of this program.

## (1) smoothing (describe specific smoothing method used)

The smoothed floor response spectra represent an envelope of the maximum peaks.

## (2) peak widening

$\pm 15\%$

Reference: FSAR, Section 3.7.2.9

## b. typical results (attach figures)

Refer to FSAR, Figures 3D-1, -2, -3. (Pgs. 283, 4, 5)





**B. Stress Analysis****1. shear walls and floors****a. mathematical model - general description w/sketch**

Shear wall and floor stresses were computed by performing standard manual calculations. Vertical loads were distributed in the structure by conventional methods. Lateral loads were calculated by multiplying lumped mass and seismic accelerations obtained from floor spectra at each level. These lateral loads were then distributed among the shear walls according to their relative stiffness and location.

**b. method of analysis--incorporation of torsion**

The torsional moment was determined by resolving the couple due to eccentricity between the center of mass and the center of rigidity at each floor. Shear derived from this torsional moment was added directly to the forces considered for the individual shear walls.

**c. load combinations**

Refer to FSAR, Section 3.8.3.3.



1. foundation mat

a. mathematical model - description of boundary conditions

Calculation was performed manually.

b. method of analysis

Pressure loading is obtained from equivalent static analysis considering total dead load, live load and its eccentricity and three directional earthquake forces. The basemat at El. 40' and 70' were designed as rigid mats, using soil pressure as loading and walls as supports. ~~Due to lack of rigid walls in the penetration area at El. 77'-0" this mat was designed as a plate on elastic foundation.~~

c. load combinations

Refer to FSAR, Section 3.8.3.3.

*We are in compliance with the SRP.*

d. key results (figures, etc.)

Refer to FSAR, Table 3.8-4D. (Page 279)



3. Material to protect against structure - structure interaction

Below grade (EL 100'-0") Rodofam II (WR Grace and Co.) or EVERLASTIC Micro II (Williams Products, Inc.) may be left in place in seismic joints between structures. Above grade gaps between walls were left open, typically 6" between Category I structures.

- a. mechanical properties
- b. additional pressure on walls
- c. findings and comments



#### 4. vertical dynamic analysis

##### a. mathematical model - general description with sketch

The planar lumped parameter model consisted of one vertical beam on a rigid mat which represents the exterior and interior walls.

Reference: FSAR, Figure 3.7-11. (Page 277)

##### b. development of stiffnesses, including floor stiffness, as applicable

The model consists of lumped nodal masses representing floor mass tributary to the mass point and of axial elements representing vertical stiffnesses of walls with vertical degrees of freedom only. Stiffnesses of the walls were calculated manually.

##### c. method of analysis

The models described above were used for acceleration time history and modal, response spectrum analyses was performed by using SAP 1.9 computer program. The time history analysis was performed using FOSIN. The modal response spectrum analysis was performed using SAP 1.9.





## C. Computer Programs Used in Analysis

SAP 1.9, SPECTRA, FOSIN, LUCON

## 1. assumptions and limitations

Refer to FSAR, Appendix 3B.

## 2. applicability

Refer to FSAR, Appendix 3B.

## 3. verification

- sensitivity study in case of numerical solutions (e.g., finite element analysis)

Refer to FSAR, Appendix 3B.

## 4. load input (include all cases)

PROGRAM	INPUT
SAP 1.9	Finite element model (modes and elements), loading (pressure, nodal loads), response spectra.
SPECTRA	In-structure time histories, frequency or periods and damping values.
FOSIN	Free-field time history, damping values, frequency.
LUCON	Shear modulus, damping values



5. output (include all cases)

Refer to FSAR, Appendix 3B.

6. other discussions



D. Overall Stability

1. forces and moments from seismic analysis

Refer to FSAR, Figure 3.7-16. (Page 278)

2. various cases considered

Seismic event loading combinations considering SSE or OBE applied in North-South, East-West and vertical directions simultaneously.



3. bearing pressure versus bearing capability and safety factor against bearing failure

Refer to FSAR, Section 2.5.4.10 and Tables 2.5-15, -16. (Page 266, 7)

4. factors of safety

Refer to FSAR, Section 3.8.5.5 and Table 3.8-5. (Page 282)

- a. sliding

Factor of Safety = 1.3 (SSE).

- b. overturning

Factor of Safety = 830 (SSE).





E. Interaction of Non-category I Structures with the Structure Considered

1. identification of pertinent non-Category I structures

The Radwaste Building and Corridor Building are adjacent to the Auxiliary Building.

2. consideration given to potential failure of non-Category I systems on Category I systems

The Radwaste ~~and Corridor~~ Buildings <sup>was</sup> were designed to preclude structural failure of building or parts thereof that could damage the Auxiliary Building and its Category I systems. Within the Auxiliary Building, non-Category I systems which potentially could affect Category I systems, were designed for structural integrity under SSE loads.

Reference: FSAR, Section 3.8.4.4.

3. general findings and comments

During a walk down those items <sup>it</sup> whose failure will not affect any safety related equipment are left as they are. If they are judged that they might affect category I systems, they are designed to maintain their structural integrity under an SSE.



## F. Design Consideration for Tornado Missiles

## 1. design requirements

Refer to FSAR, Table 3.5-8. (Pg. 268)

## 2. models for

## a. local damage

Refer to FSAR, Section 3.5.3.

## b. overall response

Refer to FSAR, Section 3.5.3.

## 3. load combinations

Refer to FSAR, Section 3.8.3.3.

## 4. forces

The governing structural members are of sufficient thickness to preclude perforation by postulated missiles and maintain structural integrity.



6. general comments and preliminary audit findings



III. CONFORMANCE TO ACCEPTABLE CRITERIA

A. Identification of deviations, if any

None.

B. Justification of deviations and disposition of the deviations

D. general comments





Part II Audit of Key Designs

## A. Exterior Shear Walls

## 1. design requirements

The exterior walls were designed to satisfy structural function as bearing walls, shear walls, and protection against tornado missiles.

## 2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

Refer to FSAR, Table 3.8-4D. (Pg. 279)

## 4. detailed design of rebar placement at key sections

See Attachment A. (Pg. 265)

## 5. general comments and preliminary audit findings



**B. Interior Shear Walls****1. design requirements**

The interior walls were designed to satisfy structural function as bearing walls and shear walls.

**2. design loads (from general analysis)**

Same as exterior walls except that plaster and concrete masonry walls (fire barrier walls) were neglected for the strength of the building but were designed to resist the loads due to their own weight (Dead Load plus seismic) in order to preclude damage to safety related equipment.

**3. forces and moments at key sections**

Refer to FSAR, Table 3.8-4D. (Pg. 279)

**4. detailed design of rebar placement at key sections**

See Attachment A. (Pg. 265)

**5. general comments and preliminary audit findings**



## C. Main Floors and Roofs

## 1. design requirements

Main floors and roof slabs were primarily designed for vertical dead, live and seismic loads, ~~as defined in the Project Design Criteria~~. Roofs were also designed to satisfy minimum thickness to preclude perforation by tornado generated missiles.

## 2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

Refer to FSAR, Table 3.8-4D. (Pg. 279)

## 4. detailed design of rebar placement at key sections

See Attachment A. (Pg. 265)



5. general comments and preliminary audit findings





D. Steel Structural Bracing Systems (if any)

1. design requirements

In general, steel beams are designed for two functions:

- a) To support dead load of wet concrete and construction loads
- b) To support piping and cable trays and other miscellaneous equipment loads.

For penetration area, floors are supported on structural steel beams, girders and columns which are designed for dead, live and seismic loads.

2. design loads

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Refer to FSAR, Table 3.8-4E. (Pg. 280)

6. general comments and preliminary audit findings



## E. Foundation Mat

## 1. design requirements

Refer to FSAR, Sections 3.8.5.4.2 and 3.8.5.5.

## 2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

Refer to FSAR, Table 3.8-4D. (Pg. 279)

## 4. detailed design of rebar placement at key sections

See Attachment A. (Pg. 265)

## 5. general comments and preliminary audit findings



## F. Main Frame Concrete Column Design (Key Columns)

## 1. design requirements

The concrete columns were primarily designed for vertical loading due to dead, live and seismic loads. The columns were not used as lateral-load-resisting elements.

## 2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

	<u>Axial Force</u>	<u>Moment</u>
1) Column at El. 40'0"	1022 K	282 Ft-K
2 /) Column at El. 88'0"	1981 K	203 Ft-K
3 /) Column at El. 120'0"	999 K	460 Ft-K

## 4. detailed design of rebar placement at key sections

See Attachment A. (Pg. 265)

## 5. general comments and preliminary audit findings



**G. Secondary Floors****1. design requirements**

Same as main floors. Refer to page 26.

**2. design loads (from general analysis)**

Refer to FSAR, Section 3.8.3.3.

**3. forces and moments at key sections**

Refer to FSAR, Table 3.8-4D. (Pg. 279)

**4. detailed design of rebar placement at key sections**

See Attachment A. (Pg. 265)

**5. general comments and preliminary audit findings**





## H. Detailing at Floor-Wall Joints

## 1. design requirements

As per ACI 318-71 Code, Chapter 6 and 17.

## 2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

Refer to FSAR, Table 3.8-4D. (Pg. 279)

## 4. detailed design of rebar placement at key sections

See Attachment A. (Pg. 265)

## 5. general comments and preliminary audit findings



**I. Dynamic Effects Applied to Floors and Walls by Machinery****1. design requirements**

Dynamic effects from machinery are negligible. Major pumps are located on the basemat. HVAC units are mounted with isolation pads.

**2. design loads (from general analysis)****3. forces and moments at key sections****4. detailed design****5. general comments and preliminary audit findings**



J. Crane & Support

1. design of bents (columns and roof trusses)

Not applicable. There are no cranes located in this building.

a. design requirements

b. design loads (from general analysis)

c. forces and moments at key sections

d. detailed design



e. general comments and preliminary audit findings





2. design of girders supporting crane rails

Not applicable.

a. design requirements

b. design loads (from general analysis).

c. forces and moments at key sections

d. detailed design



e. general comments and preliminary audit findings



## 3. design of spent fuel bridge

Not applicable.

- a. design requirements
- b. design loads (from general analysis)
- c. forces and moments at key sections
- d. detailed design
- e. general comments and preliminary audit findings



## K. Fuel Pool Liner Design





Not applicable.

1. stresses and strain controls
2. conformance to code requirements
3. analysis procedure and results
4. consideration of accidental drop of crane loads
5. corrosion effects (e.g., pitting) on liner integrity
6. preliminary findings of audit results





ATTACHMENT "A"



AUXILIARY BUILDING  
TYP. WALL & COLUMN SECTS. & DETS.

265



Table 2.5-15  
 STATIC BEARING CAPACITY OF CATEGORY I STRUCTURES

Structure	Average Static Design Load $q_s$ (k/ft <sup>2</sup> )	Ultimate Bearing Capacity $q_o$ (k/ft <sup>2</sup> )	Factor of Safety ( $q_o/q_s$ )
Containment Building	7.9	35.7	4.5
Auxiliary Building (deep section)	6.2	34.9	5.6
Main Steam Support Structure	7.1	64.8	9.1
Control Building	3.3	45.3	13.7
Fuel Building	5.3	54.9	10.4
Diesel Generator Building	3.1	79.5	25.6
Refueling Water Tank	4.4	90.4	20.5
Condensate Storage Tank	3.5	112.4	32.1



March 1980

Table 2.5-16

DYNAMIC BEARING CAPACITY OF CATEGORY I STRUCTURES (a)

Structure	Equivalent Uniform Vertical Stress $q_d$ (k/ft <sup>2</sup> )	Ultimate Bearing Capacity $q_o$ (k/ft <sup>2</sup> )	Factor of Safety ( $q_o/q_d$ )
Containment Building	16.1	32.2	2.0
Auxiliary Building (deep section)	10.3	25.8	2.5
Main Steam Support Structure	25.3	60.6	2.4
Control Building	9.8	39.8	4.1
Fuel Building	19.1	50.3	2.6
Diesel Generator Building	5.6	75.5	13.5
Refueling Water Tank	13.2	58.7	4.4
Condensate Storage Tank (b)	13.2	30.2	2.3

a. Based upon maximum dynamic loads derived from analyses described in section 3.7.

b. Condensate storage tank loads were conservatively chosen to be equal to the dynamic design load for the refueling water tank. Actual loads will be less.

2.5-163

Amendment 1

167

GEOLOGY AND SEISMOLOGY

PVNGS FSAR



Table 3.5-8

## TORNADO-GENERATED MISSILES CONSIDERED IN DESIGN OF SAFE SHUTDOWN STRUCTURES

Description	Weight (lbs)	Impact Area (ft <sup>2</sup> )	Maximum Velocity (ft/s)	Kinetic Energy (ft-lbs)
(A) A 12-foot wood plank, 4 x 12 inches in cross-section, traveling end on at a speed of 240 mi/h.	200	0.333	352	$3.85 \times 10^5$
(B) A steel pipe, Schedule 40, 3 inches in diameter by 10 feet long, traveling end on at 120 mi/h.	78	0.063	176	$3.75 \times 10^4$
(C) A steel rod, 1 inch in diameter, 3 feet long, traveling end on at 180 mi/h.	8	0.005	264	$8.66 \times 10^3$
(D) A steel pipe, Schedule 40, 6 inches in diameter by 15 feet long, traveling end on at 120 mi/h.	285	0.24	176	$1.37 \times 10^5$
(E) A steel pipe, Schedule 40, 12 inches in diameter by 15 feet long, traveling end on at 120 mi/h.	743	0.886	176	$3.57 \times 10^5$
(F) A utility pole, 13-1/2 inches in diameter, 35 feet long, traveling end on at 120 mi/h.	1490	0.994	176	$7.17 \times 10^5$
(G) An automobile of 4,000 pounds weight, striking the structure at 60 mi/h.	4000	20.0	88	$4.81 \times 10^5$

3.5-34

PVNGS FSAR

MISSILE PROTECTION





Table 3.7-4  
 AUXILIARY BUILDING NATURAL FREQUENCIES (a)


4


		Mode	Frequency (Hz)
Horizontal (N-S)	OBE	1	3.6
		2	7.9
		3	18.8
		4	26.1
		5	37.6
	SSE	1	3.2
		2	7.0
		3	18.4
		4	26.3
		5	37.9
Horizontal (E-W)	OBE	1	3.9
		2	7.9
		3	16.1
		4	28.0
		5	39.7
	SSE	1	3.5
		2	7.0
		3	15.9
		4	28.1
		5	40.0
Vertical	OBE	1	5.2
		2	33.5
	SSE	1	4.6
		2	33.5

a. See figure 3.7-21 for mode shapes and participation factors.

4







 Palo Verde Nuclear Generating Station  
FSAR


HORIZONTAL DESIGN SPECTRA  
FOR SSE 0.25 g  
Figure 3.7-1







**Palo Verde Nuclear Generating Station**  
**FSAR**  
 VERTICAL DESIGN SPECTRA  
 FOR SSE 0.25 g  
 Figure 3.7-2








**Palo Verde Nuclear Generating Station  
FSAR**  
 HORIZONTAL DESIGN SPECTRA  
 FOR OBE 0.13 g  
 Figure 3.7-3







 Palo Verde Nuclear Generating Station  
FSAR


VERTICAL DESIGN SPECTRA  
FOR OBE 0.13 g  
Figure 3.7-4



DEPTH (FT.)	LAYER DEPTH (FT.)	DESCRIPTION	LAYER THICKNESS	UNIT WEIGHT (PCF)	POISSON'S RATIO	IN SITU SHEAR WAVE VELOCITY (FT/SEC)	LOW STRAIN SHEAR MODULUS (KSF)	LOW STRAIN P-WAVE VELOCITY (FT/SEC)
AVERAGE PERCHED WATER LEVEL 44'		SAND (2)	47'	123	.27	956	3790	
	50					1116	4760	1990
	47'					1173	5760	2090
	70'	CLAY (1)	23'	121	.44	1194	5450	3860
	77'	SAND (2)	2'	121	.48	1209	5500	4445
	100					1253	6000	5268
	150	CLAY (1)	82'	123	.47	1281	6270	5388
	153'					1401	7500	6502
	163'	SAND (2)	19'	125	.465	1389		5454
	186'	CLAY (1)	27'	127	.48	1308	8980	8544
	206'	SAND (2)	12'	127	.46			
	228'	CLAY (1)	20'	128	.45	1776	12350	5992
	238'	SAND (2)	10'	127	.44	1984	15830	6060
	250					2040	18990	6293
300	CLAY (1)	73'	128	.44	2270	20650	6348	
311'					2701	19270	6726	
334'	SAND (2)	23'	130	.44	2176	19130	6450	
350		BEDROCK						

- NOTES: 1. LOW STRAIN SHEAR MODULI AT VARIOUS DEPTHS ARE AVERAGE VALUES.  
 2. SHEAR WAVE VELOCITY CALCULATED FROM  $V_s = (G/\rho)^{1/2}$   
 3. P WAVE VELOCITY CALCULATED FROM  $V_p = V_s [(2 - \nu)/(1 - 2\nu)]^{1/2}$

00  
2



Palo Verde Nuclear Generating Station  
FSAR

---

SOIL PROFILE  
FIGURE 3.7-7


---


September 1990

CHANGE

274






 Palo Verde Nuclear Generating Station  
FSAR

SHEAR MODULUS VS. STRAIN - CLAY  
FIGURE 3.7-8






Palo Verde Nuclear Generating Station  
FSAR


SHEAR MODULUS VS. STRAIN - SAND

FIGURE 3.7-9









 <p><b>Palo Verde Nuclear Generating Station FSAR</b></p>
<p><b>AUXILIARY BUILDING LUMPED MASS MODEL</b></p> <p><b>FIGURE 3.7-11</b></p>






HORIZONTAL (OBE)



HORIZONTAL (SSE)

 <p>Palo Verde Nuclear Generating Station FSAR</p>
<p>AUXILIARY BUILDING DESIGN RESPONSE</p> <p>FIGURE 3.7-16</p>



Amendment 3

3.8-95C

December 1980

274

Table 3.8-4D

AUXILIARY BUILDING SUMMARY OF GOVERNING LOAD INTERACTIONS FOR PRINCIPAL REINFORCED CONCRETE MEMBERS (Sheet 2 of 2)

Description of Principal Member	Location of Principal Member	Governing Load Combination Number (a)	Calculated Axial Load ( $P_u$ ) and Flexural Load ( $M_u$ )		Maximum Flexural Interaction Capacity ( $M_u$ ), Given Axial Load ( $P_u$ ) (b) (c)	Calculated Shear Load ( $V_u$ ) (b)	Maximum Shear Capacity ( $V_u$ ) (b)
			$P_u$ (b)	$M_u$ (c)			
2' - 2-1/2" x 19'-4" wall - vertical and horizontal reinforcement	Interior wall at El. 88'-0"	2	-559	52,153	115,314	1,537	2,093
3'-0" x 22'-3" wall - vertical and horizontal reinforcement	Interior wall at El. 100'-0"	2	-1,544	65,440	94,008	1,706	2,417
3'-0" x 6'-9" wall - vertical and horizontal reinforcement	Exterior wall at El. 100'-0"	2	-301	7,258	7,702	247	686
2'-9" thick slab - N-S or E-W reinforcement	El. 70'-0"	2	(d)	128	181	(d)	<del>274</del>
1'-6" thick slab - E-W reinforcement	El. 88'-0"	2	-	43	51	-	-
2'-0" thick slab - N-S reinforcement	El. 88'-0"	2	-	65	73	-	-
2'-9" thick slab - N-S or E-W reinforcement	El. 88'-0"	2	-	112	131	-	-
2'-9" thick slab - N-S reinforcement	El. 100'-0"	2	-	84	104	-	-
1'-3" thick slab - N-S or E-W reinforcement	El. 120'-0"	2	-	21	26	-	-
6'-0" thick basemat - E-W reinforcement	El. 40'-0"	2	-	326	544	-	-
6'-0" thick basemat - E-W reinforcement	El. 70'-0"	2	-	933	1,031	-	-

3

PVNGS FSAR  
 DESIGN OF  
 CATEGORY I STRUCTURES



Table 3.8-4E

AUXILIARY BUILDING SUMMARY OF GOVERNING COMBINED STRESS RATIOS FROM THE BEAM/COLUMN INTERACTION EQUATION FOR PRINCIPAL STRUCTURAL STEEL MEMBERS (Sheet 1 of 2)

Description of Principal Members	Location of Principal Members	Governing Load Combination Number (a)	Combined Stress Ratio (<1.0)
W 16 X 36	Floor Beam @ El. 51'-6"	1	0.88
C 10 X 25	Floor Beam @ El. 51'-6"	2	0.82
W 14 X 78	Floor Beam @ El. 51'-6"	2	0.82
W 21 X 49	Floor Beam @ El. 70'-0"	1	0.85
W 18 X 60	Floor Beam @ El. 88'-0"	1	0.94
W 12 X 27	Top Chord of Truss @ El. 88'-0"	2	0.96
W 14 X 184	Column @ El. 77'-3"	2	0.73
W 14 X 158	Column @ El. 120'-0"	2	0.66
W 14 X 84	Bottom Chord of Truss @ El. 88'-0"	2	0.83
W 27 X 177	Main Girder @ El. 100'-0"	2	0.80
W 21 X 73	Main Girder @ El. 120'-0"	2	0.94
W 16 X 64	Floor Beam @ El. 120'-0"	2	0.93
W 27 X 94	Floor Beam @ El. 140'-0"	2	0.99
W 27 X 177	Main Girder @ El. 140'-0"	2	0.95
W 27 X 114	Main Girder @ El. 140'-0"	2	0.95
W 21 X 55	Floor Beam @ El. 156'-4"	2	0.81

a. Refer to section 3.8.3.3.3.A(1) for description of load combination number.





Table 3.8-4E

AUXILIARY BUILDING SUMMARY OF GOVERNING COMBINED STRESS RATIOS FROM THE BEAM/COLUMN INTERACTION EQUATION FOR PRINCIPAL STRUCTURAL STEEL MEMBERS (Sheet 2 of 2)

Description of Principal Members	Location of Principal Members	Governing Load Combination Number(a)	Combined Stress Ratio (<1.0)
C 10 X 15.3	Staircase Stringer (typ.)	2	0.71
C 10 X 15.3	Platform Channel @ El. 43'-6"	2	0.95
W 8 X 28	Platform Beam @ El. 110'-0"	2	0.98

PVNGS FSAR

3

DESIGN OF  
CATEGORY I STRUCTURES

281



DESIGN OF  
CATEGORY I STRUCTURES


3.8.5.5 Structural Acceptance Criteria


The foundations of Seismic Category I buildings are designed to meet the same structural acceptance criteria as the buildings themselves. These criteria are discussed in sections 3.8.1.5, 3.8.3.5, and 3.8.4.5. The limiting conditions for the foundation medium, together with a comparison of actual capacity and estimated structure loads, are found in sections 2.5.4.10 and 2.5.4.11. Computed factors of safety against overturning, sliding, and flotation for Category I structures are given in table 3.8-5.

Table 3.8-5  
COMPUTED FACTORS OF SAFETY

Structure	Overturning		Sliding		Flotation
	OBE	SSE	OBE	SSE	
Auxiliary	3200	830	2.2	1.3	4.7
Containment	3400	1200	1.7	1.2	4.5
Control	1500	420	1.6	1.2	4.8
Diesel Generator	1200	400	2.2	1.1	NA <sup>(a)</sup>
Fuel	1600	400	1.9	1.1	NA
Main Steam Support	340	91	1.6	1.1	NA
Condensate Storage and Refueling Water Tanks	500	150	1.7	1.4	NA
a. Not applicable					








**Palo Verde Nuclear Generating Station**  
**FSAR**

**AUXILIARY BUILDING**  
**SSE VERTICAL ACCELERATION**  
**RESPONSE SPECTRA**

Figure 3D-1








**Palo Verde Nuclear Generating Station  
FSAR**  
**AUXILIARY BUILDING  
SSE HORIZONTAL ACCELERATION  
RESPONSE SPECTRA EL 40'-0"**  
 Figure 3D-2

284.








**Palo Verde Nuclear Generating Station**  
**FSAR**  
 AUXILIARY BUILDING  
 SSE HORIZONTAL ACCELERATION  
 RESPONSE SPECTRA EL 156'-0", ROOF  
 Figure 3D-3

285.



PALO VERDE NUCLEAR STATION UNITS 1, 2, 3  
DESIGN ADEQUACY AUDIT

STRUCTURAL AUDIT OF FUEL BUILDING  
Part I - General Analysis

I. BASIC DESIGN CRITERIA

A. 'g' value - free field

	Seismic level based on construction permit license	Seismic level used in design of structures and equipment
SSE	0.20g	0.25g
OBE	0.10g	0.13g

Reference: FSAR, Section 3.7

B. Spectra (attach figs. for all damping values, ductilities)

1. zero period acceleration

SSE	0.25g
OBE	0.13g

*(Pages 332, 3, 4, 5)*

Reference: FSAR, Figures 3.7-1 - 3.7-4<sub>x</sub> and Section 3.7.1.1

*This is consistent with Reg. Guide 1.60*

Frequency (or period) interval

Refer to BC-TOP-4A, Section 2.5.1 (c)

C. Damping

Refer to FSAR, Section 3.7.1.3

*This is consistent with Reg. Guide 1.61*

*Refer to FSAR figures 3.7-5 and 3.7-6 (Pages 92A, 92B)*

D. Artificial time history and corresponding spectra (attach figures)

1. original time history and its composition, i.e., rising time, strong motion and tail end.

Refer to FSAR, Section 3.7.1.2 and BC-TOP-4A, Section 2.5



2. base line correction, check the integrated velocity and displacement time histories

The velocity and displacement time histories were checked and found to be satisfactory. In addition, only the acceleration time history was used as input in analysis.

3. time interval - compatible with the highest frequency considered in the spectral calculation,

0.005 seconds

E. Motion duration

24 seconds

Refer to FSAR, Section 3.7.1.2

F. components of motion including their relative motion amplitudes

Analysis was performed for the three principle directions with equal amplitudes.

G. Dead and live loads for various operating floors and base slab

~~Refer to Project Design Criteria Part II, Section 3.0 and Part III, Section 4.0~~

Dead Load - includes all structures, major equipment load and 50 psf equivalent for small equipment.

Live Load - See action item 3



## H. Ground water level

The groundwater design level is at plant El 70'-0". The actual water level is at approximately plant El. 60'-0".

Reference: FSAR, Sections 2.4.13.2.4 and 2.4.13.5.

## I. Backfill earth pressure, wind, overpressure due to postulated external explosions (as applicable)

~~Refer to Project Design Criteria Part II, Sections 3.4.5.3 and 3.5.5 for lateral earth pressure, wind and tornado loads.~~

For lateral earth pressure see pages 208 A & 208 B, 208 C, 208 D  
Wind does not govern.

## J. Other considerations

All penetrations in roof and exterior walls that expose safety related equipment have tornado missile protection. Concrete covers or steel plate shields to prevent missile perforation are provided.





## II. ANALYSIS METHOD

## A. Seismic Analysis

## 1. Mathematical model-general description with sketch.

Two planar lumped parameter models were used.

Refer to FSAR, Sections 3.7.2.3.3 and Figure 3.7-13.

A three dimensional finite element model was used for final verification of design.

## a. (1) concrete modulus

$$E_c = 3.64 \times 10^6 \text{ psi for } F'_c = 4000 \text{ psi}$$

$$E_c = 4.07 \times 10^6 \text{ psi for } F'_c = 5000 \text{ psi}$$

## (2) rebar modulus and yield strength

$$E = 29 \times 10^3 \text{ Ksi}$$

$$F_y = 60 \text{ Ksi}$$

## (3) Poisson's ratio

$$\nu = 0.17 \text{ for concrete.}$$

Reference: "Theory of Plates and Shells" 2nd edition  
by Timoshenko, Woinowsky, Kreiger p. 97.

## (4) damping

Refer to FSAR, Section 3.7.1.3 and ~~response to NRC  
Question 220.2 (Q3A-4).~~

*This is consistent with Reg. Guide 1.61*



## (5) properties of foundation materials

- shear modulus

Refer to FSAR, Figure 3.7-7, -8, -9.

- 

subgrade reactions

~~Refer to Project Design Criteria Part II,  
Section 3.4.5.4 for coefficient of subgrade  
reaction.~~

Coefficient of subgrade reaction = 40-60 kips/ft<sup>2</sup>/ft

- 

bearing capabilities

Refer to Tables 2.5-15 and 2.5-16 of the FSAR.

## (6) other parameters

## b. stiffness calculations

## (1) exterior walls

Exterior and interior walls stiffness calculations were performed manually using standard engineering methods.

## (2) interior walls

Same as exterior walls.



## 2. method of Analysis

- a. method of analysis used (time history, response spectrum methods, etc.) and consideration of torsional and translational response

Two planar lumped parameter mathematical models were used for an acceleration time history analyses to generate in-structure response spectra and to perform a response spectrum analysis.

### (1) general description

The Fuel Handling Building analysis used two planar lumped parameter models. Soil structure interaction was incorporated into the model by adding to the fixed base system discrete soil springs based on elastic half space theory. The three dimensional finite element model was used for a response spectrum analysis to determine seismic stresses within the structure to verify the design.

*Based on the results of 4 cat. I structures by the comparison of lumped model & finite element model, the NRC SSI intent is met.*

### (2) findings and comments

- b. selection of number of masses and degrees of freedom

### (1) general description

Data for the planar lumped parameter model are as follows:

For horizontal direction earthquake, the model consisted of 12 nodes and 37 degrees of freedom.

For vertical direction earthquake, the model consisted of 5 nodes and 5 degrees of freedom.

Refer to FSAR, Figure 3.7-13. (Pg. 339)



(2) findings and comments

c. number of modes considered

The time history analyses performed for the lumped parameter model considered all modes since the direct integration method was utilized. The response spectrum analysis used in the finite element model verification of design considered 66 modes.

(1) general description

Refer to FSAR, Table 3.7-6 for modal frequencies and participation factors. (Pg. 331)

(2) findings and comments





## d. combining modal responses

## (1) actual procedures used

Refer to FSAR, Section 3.7.2.7.

## (2) general findings

## e. consideration of three components of motion

## (1) actual procedures used

Refer to FSAR, Section 3.7.2.6.

*this is consistent with Reg Guide 1.92*

## (2) general findings



## f. consideration of soil-structure interaction

East-West  $K_x = \frac{5.6}{4.507} \times 10^5 \text{ K/ft}$   $K_{xx} = 2.363 \times 10^9 \text{ K-Ft/Rad}$

OBE North-South  $K_y = 6.222 \times 10^5 \text{ K/ft}$   $K_{yy} = 1.490 \times 10^9 \text{ K-Ft/Rad}$

Vertical  $K_z = 7.046 \times 10^5 \text{ K/ft}$

East-West  $K_x = \frac{4.507}{5.6} \times 10^5 \text{ K/ft}$   $K_{xx} = 1.902 \times 10^9 \text{ K-Ft/Rad}$

SSE North-South  $K_y = 5.008 \times 10^5 \text{ K/ft}$   $K_{yy} = 1.199 \times 10^9 \text{ K-Ft/Rad}$

Vertical  $K_z = 5.672 \times 10^5 \text{ K/ft}$

(1) general description

(2) findings and comments

## g. decoupling criteria for subsystems

(1) general procedure

Refer to BC-TOP-4A, Section 3.2.

(2) key examples

(3) The other criteria pertaining to frequency ratio as defined in SRP 3.7.3.D.3.2 are also met.



## (3) general findings and comments

## h. modeling of hydrodynamic effects in spent fuel pool

The spent fuel pool water was coupled into the model using the concepts of US AEC TID 7024, Nuclear Reactors and Earthquakes.

## i. modeling of spent fuel pool wells and interior floor slabs and equipment thereof



## 3. development of in-structure response spectra

Refer to FSAR, Section 3.7.2.5

## a. general procedures

The "SPECTRA" program was used to compute the response spectra. Refer to FSAR, Appendix 3B for a description and applications of this program.

## (1) smoothing (describe specific smoothing method used)

The smoothed floor response spectra represent an envelope of the maximum peaks.

## (2) peak widening

$\pm 15\%$

Reference : FSAR, Section 3.7.2.9

## b. typical results (attach figures)

Refer to FSAR, Figures 3D-31, -32, -33. (Pages 343, 4, 5)



5



**B. Stress Analysis****1. shear walls and floors****a. mathematical model - general description w/sketch**

Shear wall and floor stresses were computed by performing standard manual calculations. Vertical loads were distributed in the structure by conventional methods. Lateral loads were calculated by multiplying lumped mass and seismic accelerations obtained from floor spectra at each level. These lateral loads were then distributed among the shear walls according to their relative stiffness and location.

A three dimensional finite element model was used for verification of the design.

**b. method of analysis--incorporation of torsion**

The torsional moment was determined by resolving the couple due to eccentricity between the center of mass and the center of rigidity at each floor. Shear derived from this torsional moment was added directly to the forces considered for the individual shear walls.

The three dimensional finite element model was used for stress analysis considering all loads including the response spectrum analysis for seismic loads.

**c. load combinations**

Refer to FSAR, Section 3.8.3.3.



## 1. foundation mat

## a. mathematical model - description of boundary conditions

The original design was based on manual calculations. The three dimensional finite element model was used for verification.

## b. method of analysis

## c. load combinations

Refer to FSAR, Section 3.8.3.3.

*This is in compliance with the SRP*

## d. key results (figures, etc.)

Refer to FSAR, Table 3.8-4F. (Pg. 340)



3. Material to protect against structure - structure interaction

Below grade (EL 100'-0") Rodofam II (WR Grace and Co.) or EVERLASTIC Micro II (Williams Products, Inc.) may be left in place in seismic joints between structures. Above grade gaps between walls were left open, typically 6" between Category I structures.

a. mechanical properties

b. additional pressure on walls

c. findings and comments



#### 4. vertical dynamic analysis

##### a. mathematical model - general description with sketch

The planar lumped parameter model consisted of one vertical beam on a rigid mat which represents the exterior and interior walls.

##### b. development of stiffnesses, including floor stiffness, as applicable

Stiffnesses of the walls were calculated manually.

##### c. method of analysis

The model described above was used for acceleration time history and modal response spectrum analyses. The time history analysis was performed using super-SMIS. The modal response spectrum analysis was performed using super-SMIS and SPECTRA.

The three dimensional finite element model was also used to perform vertical dynamic analysis.





## C. Computer Programs Used in Analysis

## 1. assumptions and limitations

SAP1.9, SUPER SMIS, SPECTRA, OPTCON, LUCON, BSAP

## 2. applicability

Refer to FSAR, Appendix 3B.

## 3. verification

• sensitivity study in case of numerical solutions (e.g., finite element analysis)

Refer to FSAR, Appendix 3B.

## 4. load input (include all cases)


<u>PROGRAM</u>	<u>INPUT</u>
SAP1.9	Finite Element Model (Modes and Elements), Loading (Pressure, Nodal loads), Response Spectra, Time History.
SPECTRA	In-structure Time Histories, Frequency of Periods and Damping Values.
LUCON	Shear Modulus, Damping Values
SUPER SMIS	Mass Matrix, Stiffness Matrix, Response Spectra, Time History, Damping Matrix
OPTCON	Design Loads and Stresses



5. output (include all cases)

Refer to FSAR, Appendix 3B.

6. other discussions



D. Overall Stability

1. forces and moments from seismic analysis

SSE

$P_x$	$1.80 \times 10^4$	K
$P_y$	$1.59 \times 10^4$	K
$P_z$	$1.35 \times 10^4$	K
$M_x$	$7.93 \times 10^5$	FT-K
$M_y$	$5.82 \times 10^5$	FT-K

x: North-South  
 y: East-West  
 z: Vertical

EAST - WEST

$P = 1.59 \times 10^4$  K  
 $M = 5.82 \times 10^5$  FT-K

NORTH - SOUTH


$P = 1.80 \times 10^4$  K  
 $M = 7.93 \times 10^5$  FT-K

VERTICAL

$P = 1.35 \times 10^4$  K

2. various cases considered

Seismic event loading combination considered OBE or SSE applied in the East-West, North-South and vertical directions, simultaneously.



3. bearing pressure versus bearing capability and safety factor against bearing failure

Refer to FSAR, Section 2.5.4.10 and Tables 2.5-15, -16. (Pages 328, 9)

4. factors of safety

Refer to FSAR, Section 3.8.5.5 and Table 3.8-5. (Pg. 342)

- a. sliding

Factor of Safety = 1.1 (SSE)

- b. overturning

Factor of Safety = 400 (SSE)





E. Interaction of Non-category I Structures with the Structure Considered

1. identification of pertinent non-Category I structures

None: There are no non-Category I structures adjacent to the Fuel Building

2. consideration given to potential failure of non-Category I systems on Category I systems

Within the Fuel Building, non-Category I Systems which potentially could affect Category I Systems were designed for structural integrity under SSE loads.

3. general findings and comments

During a walk-down those items whose failure will not affect any safety related equipment are left as they are. If they are judged that they might affect Category I systems, they are designed to maintain their structural integrity under an SSE.



## F. Design Consideration for Tornado Missiles

## 1. design requirements

Refer to FSAR, Table 3.5-8. (Pg. 330)

## 2. models for

## a. local damage

Refer to FSAR, Section 3.5.3.

## b. overall response

Refer to FSAR, Section 3.5.3.

## 3. load combinations

Refer to FSAR, Section 3.8.3.3.

## 4. forces

The governing structural members are of sufficient thickness to preclude perforation by postulated missiles and maintain structural integrity.



6. general comments and preliminary audit findings



III. CONFORMANCE TO ACCEPTABLE CRITERIA

A. Identification of deviations, if any

None.

B. Justification of deviations and disposition of the deviations

D. general comments





Part II Audit of Key Designs

## A. Exterior Shear Walls

## 1. design requirements

The exterior walls are designed to satisfy structural function as bearing walls, shear walls, and protection against tornado missiles.

## 2. design loads (from general analysts)

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

Refer to FSAR, Table 3.8-4F. (Pg. 340)

## 4. detailed design of rebar placement at key sections

See Attachment A. (Pg. 325)

## 5. general comments and preliminary audit findings



## B. Interior Shear Walls

## 1. design requirements

The interior walls are designed to satisfy structural function as bearing walls and shear walls.

## 2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

Refer to FSAR, Table 3.8-4F. (Pg. 340)

## 4. detailed design of rebar placement at key sections

See Attachment A. (Pg. 325)

## 5. general comments and preliminary audit findings



## C. Main Floors and Roofs

## 1. design requirements

Main floors and roofs are primarily designed for dead, live and seismic loads, ~~as defined in the Project Design Criteria.~~ Roofs are also designed to satisfy minimum thickness to preclude perforation by tornado generated missiles.

## 2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

Refer to FSAR, Table 3.8-4F. (Pg. 340)

## 4. detailed design of rebar placement at key sections

See Attachment A. (Pg. 325)



5. general comments and preliminary audit findings





## D. Steel Structural Bracing Systems (if any)

## 1. design requirements

The Fuel Building floors at elevation 120'-0", 140'-0", and roof are supported on structural steel beams, girders and columns. Beams in general are designed for construction loads. Girders and columns are designed for dead, live and seismic loads.

## 2. design loads

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

Refer to FSAR, Table 3.8-4G. (Pg. 341)

## 6. general comments and preliminary audit findings



## E. Foundation Mat

## 1. design requirements

Refer to FSAR, Sections 3.8.5.4.2 and 3.8.5.5.

## 2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

Refer to FSAR, Table 3.8-4F. (Pg. 340)

## 4. detailed design of rebar placement at key sections

See Attachment A. (Pg. 325)

## 5. general comments and preliminary audit findings



F. Main Frame Concrete Column Design (Key Columns)

Not applicable. There are no concrete columns in this building.

1. design requirements
2. design loads (from general analysis)
3. forces and moments at key sections
4. detailed design of rebar placement at key sections
5. general comments and preliminary audit findings



G.. Secondary Floors

Not applicable.

1. design requirements
2. design loads (from general analysis)
3. forces and moments at key sections
4. detailed design of rebar placement at key sections
5. general comments and preliminary audit findings





**H. Detailing at Floor-Wall Joints****1. design requirements**

As per ACI 318-71 Code, Chapters 6 and 17.

**2. design loads (from general analysis)**

Refer to FSAR, Section 3.8.3.3.

**3. forces and moments at key sections**

Refer to FSAR, Table 3.8-4F. (Pg. 340)

**4. detailed design of rebar placement at key sections**

See Attachment A. (Pg. 325)

**5. general comments and preliminary audit findings**



**I. Dynamic Effects Applied to Floors and Walls by Machinery**

Dynamic effects from machinery are negligible. Major pumps are located on the basemat. HVAC units are mounted with isolation pads.

1. design requirements
2. design loads (from general analysis)
3. forces and moments at key sections
4. detailed design
5. general comments and preliminary audit findings



## J. Crane &amp; Support

## 1. design of bents (columns and roof trusses)

The crane support system consists of corbels and pilasters.

## a. design requirements

Corbels and pilasters, located along the north and south walls, support the crane, rail and crane support girders. They are designed for dead, live, impact and seismic loads, ~~per the Project Design Criteria.~~

## b. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

## c. forces and moments at key sections

Maximum forces in the pilasters at El. 167'-0" subjected to crane lateral seismic loads are:

$$M_u = 4442 \text{ K-Ft}$$

$$P_u = 171.6 \text{ K}$$

## d. detailed design

See Attachment A. (Pg. 325)



e. general comments and preliminary audit findings





## 2. design of girders supporting crane rails

## a. design requirements

1) 150 T Crane

2) 10 T Crane

## b. design loads (from general analysis)

The crane support girders are designed for dead, live, impact, and seismic loads, per the Project Design Criteria.

## b. design loads (from general analysis)

~~Refer to Project Design Criteria Part II, Section 3.5.4 and Part III, Section 1.4.1.3.~~

Dead load includes girder and all the associated equipment.

Live load is the load lifted by crane. Capacities of cranes are 150 T & 10 T.

## c. forces and moments at key sections

<sup>Support</sup>  
150 T Crane Girder: Moment = 3646 K-Ft  
Shear = 600 K

<sup>Support</sup>  
10 T Crane Girder: Moment = 486 K-Ft  
Shear = 133 K

## d. detailed design

See Attachment B. (Pg. 326)



e. general comments and preliminary audit findings



3. design of spent fuel bridge

The spent fuel bridge is designed and furnished by Combustion Engineering.

- a. design requirements
- b. design loads (from general analysis)
- c. forces and moments at key sections
- d. detailed design
- e. general comments and preliminary audit findings



**K. Fuel Pool Liner Design****1. stresses and strain controls**

The liner is not designed as a load carrying member. It acts as a water tight membrane for the pool.

**2. conformance to code requirements**

Design is in accordance with AISC requirements.

**3. analysis procedure and results**

See Item 1.

**4. consideration of accidental drop of crane loads**

The west wall of the spent fuel pool was designed to withstand the impact of a fuel cask drop.

Refer to FSAR, amended Section 3.8.4.1.2. (See Attachment C.)

**5. corrosion effects (e.g., pitting) on liner integrity**


Stainless steel liner plate has been used.

**6. preliminary findings of audit results**







ATTACHMENT "A"





FUEL BUILDING  
TYP. WALL SECTION



FUEL BUILDING



TYP. CRANE GIRDER DETAILS



TYP. WALL SECTIONS

ATTACHMENT "B"



## PVNGS FSAR

DESIGN OF  
CATEGORY I STRUCTURES

## 3.6.4.1.2 Fuel Building

The fuel building is 88 x 124 feet in plan and is a reinforced concrete structure whose roof is 94 feet above grade. It is physically separated from adjoining structures and has an independent foundation. The building contains the new fuel storage area and spent fuel pool. The walls and the floor of the spent fuel pool are lined with stainless steel plates for leak-tightness.

The new and spent fuel storage is described in section 9.1.

The fuel building has an overhead crane capable of handling such heavy loads as the fuel cask. Travel of this crane over the spent fuel pool is prevented by design. Interlocks are provided to prevent the crane from moving over the new fuel area during cask handling operations. A new fuel handling crane, running on rails mounted over the operating floor, is provided to handle the new fuel assemblies.

A spent fuel handling machine, running on rails mounted on the operating floor, is provided to handle spent fuel assemblies.

An aluminium honeycomb energy absorption pad mounted on the wall in cask decontamination pit, is provided to prevent any damage to west wall of the spent fuel pool from the fuel cask drop.

Building plans and elevations are shown in figures 1.2-4 through 1.2-13.



Table 2.5-15  
 STATIC BEARING CAPACITY OF CATEGORY I STRUCTURES

Structure	Average Static Design Load $q_s$ (k/ft <sup>2</sup> )	Ultimate Bearing Capacity $q_o$ (k/ft <sup>2</sup> )	Factor of Safety ( $q_o/q_s$ )
Containment Building	7.9	35.7	4.5
Auxiliary Building (deep section)	6.2	34.9	5.6
Main Steam Support Structure	7.1	64.8	9.1
Control Building	3.3	45.3	13.7
Fuel Building	5.3	54.9	10.4
Diesel Generator Building	3.1	79.5	25.6
Refueling Water Tank	4.4	90.4	20.5
Condensate Storage Tank	3.5	112.4	32.1

PVNGS FSAR

GEOLOGY AND SEISMOLOGY

224





Table 2.5-16

DYNAMIC BEARING CAPACITY OF CATEGORY I STRUCTURES <sup>(a)</sup>

Structure	Equivalent Uniform Vertical Stress $q_d$ (k/ft <sup>2</sup> )	Ultimate Bearing Capacity $q_o$ (k/ft <sup>2</sup> )	Factor of Safety ( $q_o/q_d$ )
Containment Building	16.1	32.2	2.0
Auxiliary Building (deep section)	10.3	25.8	2.5
Main Steam Support Structure	25.3	60.6	2.4
Control Building	9.8	39.8	4.1
Fuel Building	19.1	50.3	2.6
Diesel Generator Building	5.6	75.5	13.5
Refueling Water Tank	13.2	58.7	4.4
Condensate Storage Tank <sup>(b)</sup>	13.2	30.2	2.3

a. Based upon maximum dynamic loads derived from analyses described in section 3.7.

b. Condensate storage tank loads were conservatively chosen to be equal to the dynamic design load for the refueling water tank. Actual loads will be less.

PVNGS FSAR

GEOLOGY AND SEISMOLOGY



Table 3.5-8

## TORNADO-GENERATED MISSILES CONSIDERED IN DESIGN OF SAFE SHUTDOWN STRUCTURES

Description	Weight (lbs)	Impact Area (ft <sup>2</sup> )	Maximum Velocity (ft/s)	Kinetic Energy (ft-lbs)
(A) A 12-foot wood plank, 4 x 12 inches in cross-section, traveling end on at a speed of 240 mi/h.	200	0.333	352	$3.85 \times 10^5$
(B) A steel pipe, Schedule 40, 3 inches in diameter by 10 feet long, traveling end on at 120 mi/h.	78	0.063	176	$3.75 \times 10^4$
(C) A steel rod, 1 inch in diameter, 3 feet long, traveling end on at 180 mi/h.	8	0.005	264	$8.66 \times 10^3$
(D) A steel pipe, Schedule 40, 6 inches in diameter by 15 feet long, traveling end on at 120 mi/h.	285	0.24	176	$1.37 \times 10^5$
(E) A steel pipe, Schedule 40, 12 inches in diameter by 15 feet long, traveling end on at 120 mi/h.	743	0.886	176	$3.57 \times 10^5$
(F) A utility pole, 13-1/2 inches in diameter, 35 feet long, traveling end on at 120 mi/h.	1490	0.994	176	$7.17 \times 10^5$
(G) An automobile of 4,000 pounds weight, striking the structure at 60 mi/h.	4000	20.0	88	$4.81 \times 10^5$

PVNGS FSAR

MISSILE PROTECTION



Table 3.7-6  
 FUEL BUILDING  
 NATURAL FREQUENCIES (b)

4


		Mode	Frequency (Hz)
Horizontal (N-S)	OBE	1	0.26 (a)
		2	2.77
		3	4.81
		4	5.42
		5	5.77
		6	6.34
		7	17.26
		8	29.92
		9	34.03
	SSE	1	0.26 (a)
		2	2.52
		3	4.36
		4	5.38
		5	5.51
		6	5.99
		7	16.95
		8	29.83
		9	33.91
Horizontal (E-W)	OBE	1	0.26 (a)
		2	2.73
		3	3.46
		4	5.47
		5	5.60
		6	6.13
		7	7.81
		8	14.66
		9	20.84
	SSE	1	0.26 (a)
		2	2.59
		3	3.36
		4	4.97
		5	5.40
		6	5.76
		7	7.77
		8	14.66
		9	20.63
Vertical	OBE	1	4.61
		2	36.77
	SSE	1	3.87
		2	36.73


a. Fluid oscillation mode

b. See figure 3.7-23 for mode shapes and participation factors.

4






 Palo Verde Nuclear Generating Station  
FSAR


HORIZONTAL DESIGN SPECTRA  
FOR SSE 0.25 g

Figure 3.7-1










**Palo Verde Nuclear Generating Station**  
**FSAR**

---

VERTICAL DESIGN SPECTRA  
 FOR SSE 0.25 g  
 Figure 3.7-2








**Palo Verde Nuclear Generating Station  
FSAR**

HORIZONTAL DESIGN SPECTRA  
 FOR OBE 0.13 g  
 Figure 3.7-3

334






 Palo Verde Nuclear Generating Station  
FSAR

VERTICAL DESIGN SPECTRA  
FOR OBE 0.13 g  
Figure 3.7-4



DEPTH (FT.)	LAYER DEPTH (FT.)	DESCRIPTION	LAYER THICKNESS	UNIT WEIGHT (PCF)	POISSON'S RATIO	IN SITU SHEAR WAVE VELOCITY (FT/SEC)	LOW STRAIN SHEAR MODULUS (KSF)	LOW STRAIN P-WAVE VELOCITY (FT/SEC)
AVERAGE PERCHED WATER LEVEL 44'	47'	SAND (2)	47'	123	.27	938 1118 1173	3790 4760 5760	1990 2090
	76'	CLAY (1)	23'	121	.44	1194	5450	3150
	77'	SAND (2)	1'	121	.48	1209	9500	4445
	100'	CLAY (1)	82'	123	.47	1253	6700	9200
	1291					6270	8300	
	1401					7500	9402	
	163'	SAND (2)	18'	125	.465	1389		5454
	189'	CLAY (1)	27'	127	.48	1300	6300	8544
	206'	SAND (2)	12'	127	.48			
	228'	CLAY (1)	28'	128	.45	1776	12300	9997
	230'	SAND (2)	18'	127	.44	1944	15630	8060
	254'	CLAY (1)	73'	128	.44	2040	10000	6700
	2270					20050	6340	
	2701					19270	8726	
311'	SAND (2)	23'	130	.44	2176	19130	8890	
334'	BEDROCK							

- NOTES 1. LOW STRAIN SHEAR MODULI AT VARIOUS DEPTHS ARE AVERAGE VALUES.  
 2. SHEAR WAVE VELOCITY CALCULATED FROM  $V_s = (G/\rho)^{1/2}$   
 3. P WAVE VELOCITY CALCULATED FROM  $V_p = V_s (1 + 2/\mu)^{1/2}$





002

CHANGE









 Palo Verde Nuclear Generating Station  
FSAR

SHEAR MODULUS VS. STRAIN - CLAY  
FIGURE 3.7-8

337.






 Palo Verde Nuclear Generating Station  
FSAR


SHEAR MODULUS VS. STRAIN - SAND

FIGURE 3.7-9





CHANGE

	<b>Palo Verde Nuclear Generating Station</b> <b>FSAR</b>
	<b>FUEL BUILDING</b> <b>LUMPED MASS MODEL</b> <b>FIGURE 3.7-13</b>



December 1980

3.8-95F

Amendment 3

13

329 A

Table 3.8-4F

FUEL BUILDING SUMMARY OF GOVERNING LOAD INTERACTIONS FOR PRINCIPAL  
REINFORCED CONCRETE MEMBERS (Sheet 1 of 2)

Description of Principal Member	Location of Principal Member	Governing Load Combination Number (a)	Calculated Axial Load ( $P_u$ ) and Flexural Load ( $M_u$ )		Maximum Flexural Interaction Capacity ( $M_u$ ), Given Axial Load ( $P_u$ ) (b) (c)	Calculated Shear Load ( $V_u$ ) (b)	Maximum Shear Capacity ( $V_u$ ) (b)
			$P_u$ (b)	$M_u$ (c)			
Basemat surrounding sump	West side of base mat El. 100'-0"	2	39	-252	-603	-(d)	-(d)
Grade beam 4'-6" thick	N-W extremity of basemat	2	125	-216	-1073	-	-
10'-6" thick area of basemat	North peripheral external strip	2	65	-46	-621	-	-
6'-2" thick area of basemat slab	Decontamination pit floor	2	66	55	132	-	-
7'-0" thick area of basemat slab	Cask loading pit floor	2	54	-3	-11	-	-
12'-0" thick area of basemat slab	Equipment area (E) floor)	2	44	52	86	-	-
1'-0" thick slab	El. 120'-0"	2	11	-2	-11	-	-
1'-0" thick slab	El. 140'-0"	2	25	3	14	-	-
1'-0" thick slab	El. 140'-0"	2	19	-3	-7	-	-
5'-0" thick wall	Exterior east wall at El. 123'-0"	2	35	89	1222	-	-

- a. Refer to section 3.8.3.3.2.A(2) for description of load combination number.  
b.  $P_u$  and  $V_u$  are in kips; Sign convention for  $P_u$ : Compression (-), Tension (+).  
c.  $M_u$  is in ft-k/ft.  
d. Negligible.

PVNGS FSAR

3

CATEGORY I STRUCTURES

DESIGN OF

339 A  
319a





Table 3.8-4F

FUEL BUILDING SUMMARY OF GOVERNING LOAD INTERACTIONS FOR PRINCIPAL  
REINFORCED CONCRETE MEMBERS (Sheet 2 of 2)

Description of Principal Member	Location of Principal Member	Governing Load Combination Number (a)	Calculated Axial Load ( $P_u$ ) and Flexural Load ( $M_u$ )		Maximum Flexural Interaction Capacity ( $M_u$ ), Given Axial Load ( $P_u$ ) (b) (c)	Calculated Shear Load ( $V_u$ ) (b)	Maximum Shear Capacity ( $V_u$ ) (b)
			$P_u$ (b)	$M_u$ (c)			
1'-9" thick wall	Exterior south wall at El. 145'-0"	2	18	3	27	-	-
8'-0" thick wall	Exterior north wall at El. 129'-6"	2	27	318	1957	-	-
5'-0" thick wall	West wall of spent fuel pool at El. 104'-6"	2	151	3	818	-	-
5'-0" thick wall	South wall of transfer tube canal at El. 129'-6"	2a	38	76	818	-	-
2'-0" thick wall	Wall above equipment area between El. 120' and 140'-0"	2a	0.2	0.5	44	-	-

PVNGS FSAR

3  
DESIGN OF  
CATEGORY I STRUCTURES



Table 3.8-4G

FUEL BUILDING SUMMARY OF GOVERNING COMBINED STRESS  
RATIOS FROM THE BEAM/COLUMN INTERACTION EQUATION FOR  
PRINCIPAL STRUCTURAL STEEL MEMBERS

Description of Principal Members	Location of Principal Members	Governing Load Combination Number (a)	Combined Stress Ratio ( $\leq 1.0$ )
W 14 X 202	Column @ FD - F2.4	2	0.97
W 18 X 35	Floor Beam @ El. 120'-0"	2	0.89
W 30 X 108	Main Girder @ El. 120'-0"	2	0.90
W 30 X 190	Floor Beam @ El. 140'-0"	2	0.89
W 36 X 300	Main Girder @ El. 140'-0"	2	0.97
W 14 X 342	Top Chord Roof Truss	2	0.94
W 14 X 311	Bottom Chord Roof Truss	2	1.00
W 12 X 136	Compression Member Roof Truss	2	0.86
W 12 X 136	Tension Member Roof Truss	2	0.91

a. Refer to section 3.8.3.3.3.A(1) for description of load combination number.




3.8.5.5 Structural Acceptance Criteria

The foundations of Seismic Category I buildings are designed to meet the same structural acceptance criteria as the buildings themselves. These criteria are discussed in sections 3.8.1.5, 3.8.3.5, and 3.8.4.5. The limiting conditions for the foundation medium, together with a comparison of actual capacity and estimated structure loads, are found in sections 2.5.4.10 and 2.5.4.11. Computed factors of safety against overturning, sliding, and flotation for Category I structures are given in table 3.8-5.

Table 3.8-5  
COMPUTED FACTORS OF SAFETY

Structure	Overturning		Sliding		Flotation
	OBE	SSE	OBE	SSE	
Auxiliary	3200	830	2.2	1.3	4.7
Containment	3400	1200	1.7	1.2	4.5
Control	1500	420	1.6	1.2	4.8
Diesel Generator	1200	400	2.2	1.1	NA <sup>(a)</sup>
Fuel	1600	400	1.9	1.1	NA
Main Steam Support	340	91	1.6	1.1	NA
Condensate Storage and Refueling Water Tanks	500	150	1.7	1.4	NA
a. Not applicable					






Palo Verde Nuclear Generating Station  
FSAR


FUEL BUILDING SSE VERTICAL  
ACCELERATION RESPONSE SPECTRA

Figure 3D-31










 Palo Verde Nuclear Generating Station  
 FSAR  
 FUEL BUILDING SSE HORIZONTAL  
 ACCELERATION RESPONSE SPECTRA  
 EL 105'-0", FUEL TRANSFER TUBE  
 Figure 3D-32






**Palo Verde Nuclear Generating Station**  
**FSAR**  
 FUEL BUILDING SSE HORIZONTAL  
 (N-S) ACCELERATION RESPONSE SPECTRA  
 EL 193.67 FT  
 Figure 3D-33

345



PALO VERDE NUCLEAR STATION UNITS 1, 2, 3  
DESIGN ADEQUACY AUDIT

STRUCTURAL AUDIT OF CONTROL BUILDING  
Part I - General Analysis

I. BASIC DESIGN CRITERIA

A. 'g' value - free field

	Seismic level based on construction permit license	Seismic level used in design of structures and equipment
SSE	0.20g	0.25g
OBE	0.10g	0.13g

Reference: FSAR, Section 3.7

B. Spectra (attach figs. for all damping values, ductilities)

1. zero period acceleration

SSE	0.25g
OBE	0.13g

*(pages 389, 390, 391, 392)*

Reference: FSAR, Figures 3.7-1 - 3.7-4, and Section 3.7.1.1  
*This is consistent with Reg. Guide 1.60*

Frequency (or period) interval

Refer to BC-TOP-4A, Section 2.5.1 (c)

C. Damping

Refer to FSAR, Section 3.7.1.3

*This is consistent with Reg. Guide 1.61*

*Refer to FSAR figures 3.7-5 and 3.7-6 (pages 92A, 92B)*

D. Artificial time history and corresponding spectra (attach figures)

1. original time history and its composition, i.e., rising time, strong motion and tail end.

Refer to FSAR, Section 3.7.1.2 and BC-TOP-4A, Section 2.5



2. base line correction, check the integrated velocity and displacement time histories

The velocity and displacement time histories were checked and found to be satisfactory. In addition, only the acceleration time history was used as input in analysis.

3. time interval - compatible with the highest frequency considered in the spectral calculation

0.005 seconds

E. Motion duration

24 seconds

Refer to FSAR, Section 3.7.1.2

F. components of motion including their relative motion amplitudes

Analysis was performed for the three principle directions with equal amplitudes.

G. Dead and live loads for various operating floors and base slab

~~Refer to Project Design Criteria Part II, Section 3.0 and Part III, Section 4.0~~

Dead load - includes all structures, major equipment load and 50 psf equivalent for small equipment.

Live load - see action item 3.





H. Ground water level

The groundwater design level is at plant El 70'-0". The actual water level is at approximately plant El. 60'-0".

Reference: FSAR, Sections 2.4.13.2.4 and 2.4.13.5.

I. Backfill earth pressure, wind, overpressure due to postulated external explosions (as applicable)

~~Refer to Project Design Criteria Part II, Sections 3.4.5.3 and 3.5.5 for lateral earth pressure, wind and tornado loads.~~

For lateral earth pressure see pages 208 A & 208 B, 208C, 208D  
Wind does not govern.

J. Other considerations

All penetrations in roof and exterior walls that expose safety related equipment have tornado missile protection. Concrete covers or steel plate shields to prevent missile perforation are provided.



## II. ANALYSIS METHOD

## A. Seismic Analysis

## 1. Mathematical model-general description with sketch.

Two planar lumped parameter models were used.  
Refer to FSAR Section 3.7.2.3.3 and Figure 3.7-12

## a. (1) concrete modulus

$$E_c = 3.64 \times 10^6 \text{ psi for } f'_c = 4000 \text{ psi}$$

$$E_c = 4.07 \times 10^6 \text{ psi for } f'_c = 5000 \text{ psi}$$

Reference: ACI 318-71

## (2) rebar modulus and yield strength

$$E = 29 \times 10^3 \text{ ksi}$$

$$F_y = 60 \text{ ksi}$$

## (3) Poisson's ratio

$$\nu = 0.17 \text{ for concrete}$$

Reference: "Theory of Plates and Shells" second edition by Timoshenko, Woinowsky-Kreiger page 97.

## (4) damping

Refer to FSAR Section 3.7.1.3 and ~~response to NRC Question 220.2 (Q3A-4)~~.

*this is consistent with Reg. Guide 1.6)*



## (5) properties of foundation materials

- shear modulus

Refer to FSAR, Figures 3.7-7, -8, -9.

- subgrade reactions

~~Refer to Project Design Criteria Part II,  
Section 3.4.5.4 for coefficient of subgrade  
reaction.~~

coefficient of subgrade reaction = 40-60 kips/ft<sup>2</sup>/ft

- bearing capabilities

Refer to Tables 2.5-15 and 2.5-16 of the FSAR.

## (6) other parameters

## b. stiffness calculations

## (1) exterior walls and interior walls

Stiffness calculations were performed manually using standard engineering methods.

## (2) interior walls

Same as exterior walls except for concrete masonry walls (fire barrier walls) and plaster walls which were neglected.



## 2. method of Analysis

- a. method of analysis used (time history, response spectrum methods, etc.) and consideration of torsional and translational response

Time history analyses were performed to generate in-structure response spectra using SAP 1.9. Modal response spectrum analyses were performed to obtain the seismic loads for design of structural elements using SAP 1.9.

## (1) general description

The Control Building analysis used two planar lumped parameter models. For a horizontal earthquake the model consisted of one vertical cantilever beam, having 6 nodes, representing each floor level. For a vertical earthquake the model consisted of two vertical branches on a common rigid mat. The first branch, representing the exterior walls at each floor level, has 6 nodes. The second branch, representing the interior structural steel columns between each level, also has 6 nodes. Attached to each of these 6 nodes was a single degree of freedom subsystem, which represents the floor structural steel framing system at each level.

Reference: FSAR, Figure 3.7-12 (Pg. 396)  
*The soil structure interaction analysis method was used and compared against current NRC review position and this meets the intent of NRC soil structure interaction position*

## (2) findings and comments

- b. selection of number of masses and degrees of freedom

## (1) general description

For horizontal direction earthquake, the model consists of 6 nodes with 12 degrees of freedom.

For vertical direction earthquake, the model consists of 22 nodes with 16 degrees of freedom.





## (2) findings and comments

## c. number of modes considered

		<u>SSE</u>	<u>OBE</u>
Horizontal	E-W	3 modes f = 23.1 cps	3 modes f = 23.6 cps
Horizontal	N-S	3 modes f = 20.6 cps	3 modes f = 21.1 cps
Vertical		3 modes f = 11.8 cps	3 modes f = 11.7 cps

Frequencies shown above are for highest mode considered.

## (1) general description

Refer to FSAR, Table 3.7-5 for modal frequencies and participation factors. (Pg. 388)

## (2) findings and comments



d. combining modal responses

(1) actual procedures used

Refer to FSAR, Section 3.7.2.7

(2) general findings

e. consideration of three components of motion

(1) actual procedures used

Refer to FSAR, Section 3.7.2.6.

*this is consistent with Reg-Guide 1.92*

(2) general findings







(3) general findings and comments

h. modeling of hydrodynamic effects in spent fuel pool

Not applicable. The spent fuel pool is in Fuel Handling Building.

i. modeling of spent fuel pool wells and interior floor slabs and equipment thereof

Not applicable.





## 3. development of in-structure response spectra

Refer to FSAR, Section 3.7.2.5

## a. general procedures

The "SPECTRA" program was used to compute the response spectra. Refer to FSAR, Appendix 3B for a description and applications of this program.

## (1) smoothing (describe specific smoothing method used)

The smoothed response spectra represent an envelope of the maximum peaks.

## (2) peak widening

$\pm 15\%$

Reference: FSAR, Section 3.7.2.9.

## b. typical results (attach figures)

Refer to FSAR, Figures 3D-4, -5, -6. (Pages 402,3,4)



**B. Stress Analysis****1. shear walls and floors****a. mathematical model - general description w/sketch**

Shear wall and floor stresses were computed by performing standard manual calculations. Vertical loads were distributed in the structure by conventional methods. Lateral loads were calculated by multiplying lumped mass and seismic acceleration obtained from floor spectra at each level. These lateral loads were then distributed among the shear walls according to their relative stiffness and location.

**b. method of analysis--incorporation of torsion**

The center of mass and center of rigidity of the Control Building coincided. Therefore, torsion was not considered.

**c. load combinations**

Refer to FSAR, Section 3.8.3.3



## 1. foundation mat

## · Finite element model (SAP 1.9)

## a. mathematical model - description of boundary conditions

A three-dimensional finite element model was used in the basemat analysis. Equivalent soil springs were attached to each node.

## b. method of analysis

Dead and live loads on the exterior walls and columns were calculated based on tributary floor areas. Seismic loads were obtained from the response spectrum analysis. (Three-dimensional earthquake was considered by using the component factor method). These loads were then applied as nodal point loads to obtain the moment and shear forces in the foundation mat.

## c. load combinations

Refer to FSAR Section 3.8.3.3.

*this is in compliance with the SRP*

## d. key results (figures, etc.)

Refer to FSAR Table 3.8-4H. (Pg. 399)



3. Material to protect against structure - structure interaction

Below grade (EL 100'-0") Rodof foam II (WR Grace and Co.) or EVERLASTIC Micro II (Williams Products, Inc.) may be left in place in seismic joints between structures. Above grade gaps between walls were left open, typically 6" between Category I structures.

- a. mechanical properties
- b. additional pressure on walls
- c. findings and comments





#### 4. vertical dynamic analysis

##### a. mathematical model - general description with sketch

The planar lumped parameter model consisted of two vertical branches founded on a common rigid mat. The first of the two branches represents the exterior walls. The second branch represents the steel columns. A single degree of freedom subsystem was attached at each of the column node points. It represents the local effects created by vibrating floor beams framing into the steel columns.

Refer to FSAR, Figure 3.7-12.

##### b. development of stiffnesses, including floor stiffness, as applicable

Stiffnesses were calculated manually for walls, columns and floors.

##### c. method of analysis

The model described above was used for acceleration time-history and modal response spectrum analyses. The above analyses were performed by using the SAP 1.9 computer program.



## C. Computer Programs Used in Analysis

SAP 1.9, SPECTRA,  
Refer to FSAR, Appendix 3B.

## 1. assumptions and limitations

Refer to FSAR, Appendix 3B.

## 2. applicability

Refer to FSAR, Appendix 3B.

## 3. verification

- sensitivity study in case of numerical solutions (e.g., finite element analysis)

Refer to FSAR, Appendix 3B.

## 4. load input (include all cases)

<u>Program</u>	<u>Input</u>
SAP 1.9	Finite element model (nodes and elements) loading (pressure, nodal loads), response spectra, time history.
SPECTRA	In-Structure Time histories, frequency or periods and damping value.



5. output (include all cases)

Refer to FSAR, Appendix 3B.

6. other discussions



**D. Overall Stability**

1. forces and moments from seismic analysis

Refer to FSAR, Figure 3.7-17, -18. (Pages 397, 8)

2. various cases considered

Seismic event loading combinations considered SSE or OBE applied in the North-South, East-West, and vertical directions simultaneously.





3. bearing pressure versus bearing capability and safety factor against bearing failure

Refer to FSAR, Section 2.5.4.10 and Tables 2.5-15, -16. (pages 385, 6)

4. factors of safety

Refer to FSAR, Section 3.8.5.5 and Table 3.8-5. (pg. 401)

- a. sliding

Factor of Safety = 1.2 (SSE)

- b. overturning

Factor of Safety = 420 (SSE)



E. Interaction of Non-category I Structures with the Structure Considered

1. identification of pertinent non-Category I structures

The Corridor Building and Radwaste Building are adjacent to the Control Building.

2. consideration given to potential failure of non-Category I systems on Category I systems

The ~~Corridor and~~ Radwaste Buildings <sup>was</sup> ~~were~~ designed to preclude structural failure of building or parts thereof that could damage the Control Building and its Category I systems. Within the Control Building non-Category I systems which potentially could affect Category I systems were designed for structural integrity under SSE loads.

Reference: FSAR, Section 3.8.4.4.

3. general findings and comments

During a walk-down those items whose failure will not affect any safety related equipment are left as they are. If they are judged that they might affect Category I systems, they are designed to maintain their structural integrity under an SSE.



**F. Design Consideration for Tornado Missiles****1. design requirements**

Refer to FSAR, Table 3.5-8. (Pg. 387)

**2. models for****a. local damage**

Refer to FSAR, Section 3.5.3.

**b. overall response**

Refer to FSAR, Section 3.5.3.

**3. load combinations**

Refer to FSAR, Section 3.8.3.3.

**4. forces**

The governing structural members are of sufficient thickness to preclude perforation by postulated missiles and maintain structural integrity.



6. general comments and preliminary audit findings





III. CONFORMANCE TO ACCEPTABLE CRITERIA

A. Identification of deviations, if any

None

B. Justification of deviations and disposition of the deviations

D. general comments



Part II Audit of Key Designs

## A. Exterior Shear Walls

## 1. design requirements

The exterior walls were designed to satisfy structural function as bearing walls, shear walls, and protection against tornado missiles.

## 2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

Refer to FSAR, Table 3.8-4H. (Pg. 399)

## 4. detailed design of rebar placement at key sections

See Attachment A. (Pg. 384)

## 5. general comments and preliminary audit findings



## B. Interior Shear Walls

Not Applicable

## 1. design requirements

~~The interior walls were designed to satisfy structural function as bearing walls and shear walls.~~

## 2. design loads (from general analysis)

~~Same as exterior walls except that plaster and concrete masonry walls (fire barrier walls) were neglected for the strength of the building but were designed to resist the loads due to their own weight (Dead Load plus Seismic) in order to preclude damage to safety related equipment.~~

## 3. forces and moments at key sections

~~Refer to FSAR, Table 3-8-4B.~~

## 4. detailed design of rebar placement at key sections

~~See Attachment A.~~

## 5. general comments and preliminary audit findings



## C. Main Floors and Roofs

## 1. design requirements

Main floors and roofs were primarily designed for vertical dead, live and seismic loads, ~~as defined in the Project Design Criteria.~~ Roofs were also designed to satisfy minimum thickness to preclude perforation by tornado generated missiles.

## 2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

Refer to FSAR, Table 3.8-4H. (Pg. 399)

## 4. detailed design of rebar placement at key sections

See Attachment A. (Pg. 384)





5. general comments and preliminary audit findings



## D. Steel Structural Bracing Systems (if any)

## 1. design requirements

The Control Building floors and roof slab are supported on structural steel beams, girders, and columns which primarily are designed for dead, live, and seismic loads, ~~per the Project Design Criteria.~~

## 2. design loads

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

Refer to FSAR, Table 3.8-4I. (Pg. 400)

## 6. general comments and preliminary audit findings



## E. Foundation Mat

## 1. design requirements

Refer to FSAR, Sections 3.8.5.4.2 and 3.8.5.5.

## 2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

Refer to FSAR, Table 3.8-4H (Pg. 399)

## 4. detailed design of rebar placement at key sections

See Attachment A. (Pg. 384)

## 5. general comments and preliminary audit findings



## F. Main Frame Concrete Column Design (Key Columns)

## 1. design requirements

Not applicable. There are no concrete columns in this building.

## 2. design loads (from general analysis)

## 3. forces and moments at key sections

## 4. detailed design of rebar placement at key sections

## 5. general comments and preliminary audit findings





## G. Secondary Floors

1. design requirements

Not applicable.

2. design loads (from general analysis)

3. forces and moments at key sections

4. detailed design of rebar placement at key sections

5. general comments and preliminary audit findings



## H. Detailing at Floor-Wall Joints

### 1. design requirements

As per ACI 318-71 Code, Chapter 6 and 17.

### 2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

### 3. forces and moments at key sections

Refer to FSAR, Table 3.8-4H. (Pg. 399)

### 4. detailed design of rebar placement at key sections

See Attachment A. (Pg. 384)

### 5. general comments and preliminary audit findings



### I. Dynamic Effects Applied to Floors and Walls by Machinery

Dynamic effects from machinery are negligible. Major pumps are located on the basemat. HVAC units are mounted with isolation pads.

1. design requirements
2. design loads (from general analysis)
3. forces and moments at key sections
4. detailed design
5. general comments and preliminary audit findings



## J. Crane &amp; Support

Not applicable. There are no cranes located in this building.

1. design of bents (columns and roof trusses)
  - a. design requirements
  - b. design loads (from general analysis)
  - c. forces and moments at key sections
  - d. detailed design





e. general comments and preliminary audit findings



2. design of girders supporting crane rails

Not applicable.

a. design requirements

.. b. design loads (from general analysis)

c. forces and moments at key sections

d. detailed design



e. general comments and preliminary audit findings



3. design of spent fuel bridge

Not applicable.

a. design requirements

b. design loads (from general analysis)

c. forces and moments at key sections

d. detailed design

e. general comments and preliminary audit findings






## K. Fuel Pool Liner Design

Not applicable. The spent fuel liner is located in the Fuel Handling Building.

1. stresses and strain controls
2. conformance to code requirements
3. analysis procedure and results
4. consideration of accidental drop of crane loads
5. corrosion effects (e.g., pitting) on liner integrity
6. preliminary findings of audit results





SLAB PARALLEL TO EXT. WALL

4 #11 TO MATCH DOWELS

CONST. JOINT



#10

#11

#6 TIES

4-#11  
EA. LAYER  
(2-LAYERS)

#11



ATTACHMENT "A"

CONTROL BUILDING  
TYP. WALL SECTIONS AND DETAILS

(NO SCALE)

2011



Amendment 1

2.5-162

March 2000

205

Table 2.5-15

## STATIC BEARING CAPACITY OF CATEGORY I STRUCTURES

Structure	Average Static Design Load $q_s$ (k/ft <sup>2</sup> )	Ultimate Bearing Capacity $q_o$ (k/ft <sup>2</sup> )	Factor of Safety ( $q_o/q_s$ )
Containment Building	7.9	35.7	4.5
Auxiliary Building (deep section)	6.2	34.9	5.6
Main Steam Support Structure	7.1	64.8	9.1
Control Building	3.3	45.3	13.7
Fuel Building	5.3	54.9	10.4
Diesel Generator Building	3.1	79.5	25.6
Refueling Water Tank	4.4	90.4	20.5
Condensate Storage Tank	3.5	112.4	32.1

PUNGS FSAR

GEOLOGY AND SEISMOLOGY



Table 2.5-16

## DYNAMIC BEARING CAPACITY OF CATEGORY I STRUCTURES (a)

Structure	Equivalent Uniform Vertical Stress $q_d$ (k/ft <sup>2</sup> )	Ultimate Bearing Capacity $q_o$ (k/ft <sup>2</sup> )	Factor of Safety ( $q_o/q_d$ )
Containment Building	16.1	32.2	2.0
Auxiliary Building (deep section)	10.3	25.8	2.5
Main Steam Support Structure	25.3	60.6	2.4
Control Building	9.8	39.8	4.1
Fuel Building	19.1	50.3	2.6
Diesel Generator Building	5.6	75.5	13.5
Refueling Water Tank	13.2	58.7	4.4
Condensate Storage Tank (b)	13.2	30.2	2.3

a. Based upon maximum dynamic loads derived from analyses described in section 3.7.

b. Condensate storage tank loads were conservatively chosen to be equal to the dynamic design load for the refueling water tank. Actual loads will be less.





Table 3.5-8

## TORNADO-GENERATED MISSILES CONSIDERED IN DESIGN OF SAFE SHUTDOWN STRUCTURES

Description	Weight (lbs)	Impact Area (ft <sup>2</sup> )	Maximum Velocity (ft/s)	Kinetic Energy (ft-lbs)
(A) A 12-foot wood plank, 4 x 12 inches in cross-section, traveling end on at a speed of 240 mi/h.	200	0.333	352	$3.85 \times 10^5$
(B) A steel pipe, Schedule 40, 3 inches in diameter by 10 feet long, traveling end on at 120 mi/h.	78	0.063	176	$3.75 \times 10^4$
(C) A steel rod, 1 inch in diameter, 3 feet long, traveling end on at 180 mi/h.	8	0.005	264	$8.66 \times 10^3$
(D) A steel pipe, Schedule 40, 6 inches in diameter by 15 feet long, traveling end on at 120 mi/h.	285	0.24	176	$1.37 \times 10^5$
(E) A steel pipe, Schedule 40, 12 inches in diameter by 15 feet long, traveling end on at 120 mi/h.	743	0.886	176	$3.57 \times 10^5$
(F) A utility pole, 13-1/2 inches in diameter, 35 feet long, traveling end on at 120 mi/h.	1490	0.994	176	$7.17 \times 10^5$
(G) An automobile of 4,000 pounds weight, striking the structure at 60 mi/h.	4000	20.0	88	$4.81 \times 10^5$

3.5-34

PVNGS FSAR

MISSILE PROTECTION





Table 3.7-5  
CONTROL BUILDING NATURAL FREQUENCIES (a)

		Mode	Frequency (Hz)
Horizontal (N-S)	OBE	1	4.0
		2	11.6
		3	21.1
	SSE	1	3.7
		2	10.4
		3	20.6
Horizontal (E-W)	OBE	1	4.4
		2	12.2
		3	23.6
	SSE	1	4.0
		2	10.9
		3	23.1
Vertical	OBE	1	7.1
		2	10.3
		3	11.7
	SSE	1	6.5
		2	10.0
		3	11.8

4 | a. See figure 3.7-22 for mode shapes and participation factors.








**Palo Verde Nuclear Generating Station  
FSAR**

**HORIZONTAL DESIGN SPECTRA  
FOR SSE 0.25 g**

**Figure 3.7-1**







**Palo Verde Nuclear Generating Station**  
**FSAR**


---

**VERTICAL DESIGN SPECTRA**  
 FOR SSE 0.25 g  
 Figure 3.7-2










**Palo Verde Nuclear Generating Station**  
**FSAR**

---

**HORIZONTAL DESIGN SPECTRA**  
**FOR OBE 0.13 g**  
**Figure 3.7-3.**







**Palo Verde Nuclear Generating Station**  
**FSAR**

VERTICAL DESIGN SPECTRA  
 FOR OBE 0.13 g  
 Figure 3.7-4



DEPTH (FT)	LAYER DEPTH (FT)	DESCRIPTION	LAYER THICKNESS	UNIT WEIGHT (PCF)	POISSON'S RATIO	IN SITU SHEAR WAVE VELOCITY (FT/SEC)	LOW STRAIN SHEAR MODULUS (KSF)	LOW STRAIN P WAVE VELOCITY (FT/SEC)
AVERAGE PERCHED WATER LEVEL 41'						996	3740	1790
	41'	SAND (2)	47'	123	27	1116	4740	2070
50						1173	5450	3650
	70'	CLAY (1)	23'	121	44	1194	5500	4415
	77'	SAND (2)	7'	121	46	1209	6200	5260
100						1253	6770	5385
		CLAY (1)	82'	123	47	1281	7500	5502
150						1401	8180	5454
159'		SAND (2)	10'	125	46	1389	8980	5544
169'		CLAY (1)	21'	127	46	1308	12350	5997
196'		SAND (2)	12'	127	46	1776	15570	6060
206'		CLAY (1)	20'	126	45	1981	16880	6293
228'		SAND (2)	10'	127	46	2010	20650	6744
238'		CLAY (1)	23'	128	44	2270	19770	6774
250						2770	19100	6850
311'		SAND (2)	21'	130	41	2776		
334'		BEDROCK						


NOTES: 1. LOW STRAIN SHEAR MODULUS AT VARIOUS DEPTHS ARE AVERAGE VALUES  
 2. SHEAR WAVE VELOCITY CALCULATED FROM  $V_s = 102.8 \sqrt{G/\rho}$   
 3. P WAVE VELOCITY CALCULATED FROM  $V_p = 1.75 \sqrt{G/\rho}$



**Palo Verde Nuclear Generating Station**  
 CSAR  
 2011-10-01-111  
 11:00:00

393

CHANGE







**Palo Verde Nuclear Generating Station**  
**FSAR**


---

**SHEAR MODULUS VS. STRAIN - CLAY**  
**FIGURE 3.7-8**










**Palo Verde Nuclear Generating Station**  
**FSAR**

---

**SHEAR MODULUS VS. STRAIN - SAND**  
**FIGURE 3.7-9**







**Palo Verde Nuclear Generating Station**  
**FSAR**


---

**CONTROL BUILDING**  
**LUMPED MASS MODEL**  
**FIGURE 3.7-12**






HORIZONTAL E-W



HORIZONTAL N-S



**Palo Verde Nuclear Generating Station  
FSAR**

---

CONTROL BUILDING  
DESIGN RESPONSE (OBE)


FIGURE 3.7-17.

CHANGE


September 1980

Amendment 2






HORIZONTAL E-W



HORIZONTAL N-S

	<b>Palo Verde Nuclear Generating Station FSAR</b>
	<b>CONTROL BUILDING DESIGN RESPONSE (SSE)</b>
	<b>FIGURE 3.7-18</b>

CHANGE

September 1980

Amendment 2

398





Table 3.8-4II

**CONTROL BUILDING SUMMARY OF GOVERNING LOAD INTERACTIONS FOR PRINCIPAL  
REINFORCED CONCRETE MEMBERS**

Description of Principal Member	Location of Principal Member	Governing Load Combination Number (a)	Calculated Axial Load ( $P_u$ ) and Flexural Load ( $M_u$ )		Maximum Flexural Interaction Capacity ( $M_u$ ), Given Axial Load ( $P_u$ ) (b) (c)	Calculated Shear Load ( $V_u$ ) (b)	Maximum Shear Capacity ( $V_u$ ) (b)
			$P_u$ (b)	$M_u$ (c)			
2'-0" thick wall - vertical reinforcement	Exterior west wall @ El. 74'-0"	2	-73	415	437	(d)	(d)
1'-0" thick wall - vertical reinforcement	Interior wall @ El. 74'-0"	2	+118.5	37	45.4	-	-
1'-9" thick wall - vertical reinforcement	Exterior west wall @ El. 100'-0"	2	+71.2	233	284	-	-
1'-9" thick wall - vertical reinforcement	Exterior south wall @ El. 120'-0"	2	+53	61	118	-	-
1'-0" thick slab - E-W reinforcement	El. 100'-0"	2	(d)	74	90	-	-
8" thick slab - E-W reinforcement	El. 120'-0"	2	-	9	11	-	-
4'-0" thick basemat	El. 74'-0"	2	-	1,189	1,395	-	-
4'-0" thick basemat	El. 74'-0"	2	-	899	1,132	-	-

- a. Refer to Section 3.8.3.3.2.A.(2) for description of load combination number.  
 b.  $P_u$  and  $V_u$  are in kips; Sign convention for  $P_u$ : Compression (-), Tension (+).  
 c.  $M_u$  is in ft-k/ft..  
 d. Negligible.

Amendment 3

3.8-95I

December 1980

PVNGS FSAR

3

CATEGORY I STRUCTURES

DESIGN OF

399



Table 3.8-4I

CONTROL BUILDING SUMMARY OF GOVERNING COMBINED STRESS  
RATIOS FROM THE BEAM/COLUMN INTERACTION EQUATION FOR  
PRINCIPAL STRUCTURAL STEEL MEMBERS

Description of Principal Members	Location of Principal Members	Governing Load Combination Number (a)	Combined Stress Ratio ( $\leq 1.0$ )
W 27 X 84	Floor Beam @ El. 100'-0"	2	0.85
W 36 X 300	Main Girder @ El. 100'-0"	2	0.52
W 24 X 55	Floor Beam @ El. 100'-0"	2	0.62
W 14 X 550	Column @ El. 74'-0"	2	0.55
W 27 X 84	Floor Beam @ El. 120'-0"	2	0.91
W 36 X 300	Main Girder @ El. 120'-0"	2	0.59
W 14 X 314	Column @ El. 140'-0"	2	0.34
W 12 X 35	Staircase Beam	2	0.76

a. Refer to section 3.8.3.3.3.A(1) for description of load combination number.




3.8.5.5 Structural Acceptance Criteria


The foundations of Seismic Category I buildings are designed to meet the same structural acceptance criteria as the buildings themselves. These criteria are discussed in sections 3.8.1.5, 3.8.3.5, and 3.8.4.5. The limiting conditions for the foundation medium, together with a comparison of actual capacity and estimated structure loads, are found in sections 2.5.4.10 and 2.5.4.11. Computed factors of safety against overturning, sliding, and flotation for Category I structures are given in table 3.8-5.

Table 3.8-5  
COMPUTED FACTORS OF SAFETY

Structure	Overturning		Sliding		Flotation
	OBE	SSE	OBE	SSE	
Auxiliary	3200	830	2.2	1.3	4.7
Containment	3400	1200	1.7	1.2	4.5
Control	1500	420	1.6	1.2	4.3
Diesel Generator	1200	400	2.2	1.1	NA <sup>a</sup>
Fuel	1600	400	1.9	1.1	NA
Main Steam Support	340	91	1.6	1.1	NA
Condensate Storage and Refueling Water Tanks	500	150	1.7	1.4	NA
a. Not applicable					








**Palo Verde Nuclear Generating Station  
FSAR**  
 CONTROL BUILDING SSE VERTICAL  
 ACCELERATION RESPONSE SPECTRA  
 EL 140'-0"  
 Figure 3D-4










**Palo Verde Nuclear Generating Station**  
**FSAR**  
 CONTROL BUILDING SSE HORIZONTAL  
 ACCELERATION RESPONSE SPECTRA  
 EL 74'-0", BASE MAT  
 Figure 3D-5



ACCELERATION (G'S)



 Palo Verde Nuclear Generating Station  
FSAR  
CONTROL BUILDING SSE HORIZONTAL  
ACCELERATION RESPONSE SPECTRA  
EL 180'-0", ROOF  
Figure 3D-6



PALO VERDE NUCLEAR STATION UNITS 1, 2, 3  
DESIGN ADEQUACY AUDIT

STRUCTURAL AUDIT OF DIESEL GENERATOR BUILDING  
Part I - General Analysis

I. BASIC DESIGN CRITERIA

A. 'g' value - free field

	Seismic level based on construction permit license	Seismic level used in design of structures and equipment
SSE	0.20g	0.25g
OBE	0.10g	0.13g

Reference: FSAR, Section 3.7

B. Spectra (attach figs. for all damping values, ductilities)

1. zero period acceleration

SSE	0.25g
OBE	0.13g

*(Pages 45, 2, 3, 4)*

Reference: FSAR, Figures 3.7-1 - 3.7-4 and Section 3.7.1.1  
*This is consistent with Reg Guide 1.60*

Frequency (or period) interval

Refer to BC-TOP-4A, Section 2.5.1 (c)

C. Damping

Refer to FSAR, Section 3.7.1.3

*This is consistent with Reg. Guide 1.61*

*Refer to FSAR figures 3.7-5 and 3.7-6 (Pages 92A, 92B)*

D. Artificial time history and corresponding spectra (attach figures)

1. original time history and its composition, i.e., rising time, strong motion and tail end.

Refer to FSAR, Section 3.7.1.2 and BC-TOP-4A, Section 2.5



2. base-line correction, check the integrated velocity and displacement time histories

The velocity and displacement time histories were checked and found to be satisfactory. In addition, only the acceleration time history was used as input in analysis.

3. time interval - compatible with the highest frequency considered in the spectral calculation

0.005 seconds

- E. Motion duration

24 seconds

Refer to FSAR, Section 3.7.1.2

- F. components of motion including their relative motion amplitudes

Analysis was performed for the three principle directions with equal amplitudes.

- G. Dead and live loads for various operating floors and base slab

~~Refer to the Project Design Criteria Part II, Sections 3.5.1 and 3.5.2, and Part III Sections 1.4.1.1 and 1.4.1.2.~~

Dead load - includes all structures, major equipment load and 50 psf equivalent for small equipment.

Live load - see action item 3.





H. Ground water level

The groundwater design level is at plant El 70'-0". The actual water level is at approximately plant EL 60'-0".

Reference: FSAR, Sections 2.4.13.2.4 and 2.4.13.5.

I. Backfill earth pressure, wind, overpressure due to postulated external explosions (as applicable)

~~Refer to Project Design Criteria Part II Sections 2.4.5.2 and 2.4.5.3 lateral earth pressure, wind, and tornado loads.~~  
For lateral earth pressure see pages 208 A & 208 B, 208 C, 208 D.  
Wind does not govern.

J. Other considerations

All the penetrations in the roof and the exterior walls have tornado missile protection. Concrete slabs, hatches, and panels are provided to prevent missile penetration.



## II. ANALYSIS METHOD

## A. Seismic Analysis

## 1. Mathematical model-general description with sketch.

Two planar lumped parameter models were used.

See Attachment A.

## a. (1) concrete modulus

$$E = 3.64 \times 10^6 \text{ psi for } f'c = 4000 \text{ psi}$$

$$E = 4.07 \times 10^6 \text{ psi for } f'c = 5000 \text{ psi}$$

Reference: ACI 318-71

## (2) rebar modulus and yield strength

$$E = 29 \times 10^3 \text{ KSI}$$

$$F_y = 60 \text{ KSI}$$

## (3) Poisson's ratio

$$\nu = 0.24$$

~~Reference: Project Design Criteria, Part II,  
Section 3.5.7.~~

## (4) damping

Refer to FSAR, Section 3.7.1.3 and ~~response to NRC  
Question 220.2 (Q3A 4).~~

*This is consistent with Reg Guide 1.61*



(5) properties of foundation materials

- shear modulus

Refer to FSAR, Figures 3.7-7, -8, -9

- subgrade reactions

~~Refer to Project Design Criteria Part II,  
Section 3.4.5.4 for coefficient of Subgrade~~

~~reaction~~  
coefficient of subgrade reaction = 40-60 kips/ft<sup>2</sup>/ft

- bearing capabilities

Refer to Tables 2.5-15 and 2.5-16 of the FSAR. (Pages 448,9)

(6) other parameters

b. stiffness calculations

(1) exterior walls

Stiffness calculations were performed manually using standard engineering methods.

(2) interior walls

Same as exterior walls.



2. method of Analysis

- a. method of analysis used (time history, response spectrum methods, etc.) and consideration of torsional and translational response

Time history analyses were performed to generate the in-structure response spectra using Folin. Modal response spectrum analyses were performed to obtain the seismic loads for design of structural elements using SAP 1.9.

- (1) general description

The Diesel Generator Building analysis used two planar lumped parameter models. Soil structure interaction was incorporated into the model by adding to the fixed base system discrete soil springs based on elastic half-space theory.

~~The SSI analysis method was~~  
Based on the results of 4 category I structures by the comparison of lumped model & finite element model, the NRC SSI intent is met.

- (2) findings and comments

- b. selection of number of masses and degrees of freedom

- (1) general description

For horizontal direction earthquake, the model consisted of 3 nodes with 3 degrees of freedom.

For vertical direction earthquake, the model consisted of 3 nodes with 3 degrees of freedom.





(2) findings and comments

c. number of modes considered

	SSE	OBE
Horizontal (E-W)	3 modes f = 43.7 cps	3 modes f = 43.3 cps
Horizontal (N-S)	3 modes f = 47.7 cps	2 modes f = 47.8 cps
Vertical	3 modes f = 126 cps	3 modes f = 127 cps

f = Frequency of highest mode considered.

(1) general description

See Attachment B for modal frequencies and participation factors. (Pg. 445)

(2) findings and comments



d. combining modal responses

(1) actual procedures used

Refer to FSAR, Section 3.7.2.7.

(2) general findings

e. consideration of three components of motion

(1) actual procedures used

Refer to FSAR, Section 3.7.2.5.

*this is consistent with Reg. Guide 1.92*

(2) general findings



f. consideration of soil-structure interaction

	Soil Springs		
	East-West	$K_x = 1.38 \times 10^6 \text{ K/ft}$	$K_{xx} = 2.67 \times 10^9 \text{ K-ft/rad}$
OB E	Vertical	$K_y = 1.90 \times 10^6 \text{ K/ft}$	
	North-South	$K_z = 1.52 \times 10^6 \text{ K/ft}$	$K_{zz} = 1.76 \times 10^9 \text{ K-ft/rad}$
	East-West	$K_x = 1.06 \times 10^6 \text{ K/ft}$	$K_{xx} = 1.91 \times 10^9 \text{ K-ft/rad}$
S SE	Vertical	$K_y = 1.46 \times 10^6 \text{ K/ft}$	
	North-South	$K_z = 1.06 \times 10^6 \text{ K/ft}$	$K_{zz} = 1.35 \times 10^9 \text{ K-ft/rad}$

(1) general description

Refer to FSAR, Section 3.7.2.4.

(2) findings and comments

g. decoupling criteria for subsystems

(1) general procedure

Refer to BC-TOP-4A, Section 3.2

(2) key examples

(3) The other criteria pertaining to frequency ratio as defined in S.R.P 3.3.3. II.3.b are also met.



(3) general findings and comments

h. modeling of hydrodynamic effects in spent fuel pool

Not applicable.

i. modeling of spent fuel pool wells and interior floor  
slabs and equipment thereof

Not applicable.





3. development of in-structure response spectra

Refer to FSAR, Section 3.7.2.5

a. general procedures

The "SPECTRA" program was used to compute the response spectra. Refer to FSAR, Appendix 3B for a description and applications of this program.

(1) smoothing (describe specific smoothing method used,

The smoothed floor response spectra represent an envelope of the maximum peaks.

(2) peak widening

± 15%

Reference: FSAR, Section 3.7.2.9

b. typical results (attach figures)

Refer to FSAR, Figures 3D-34, -35, -36 (Pages 461, 461A, 462)



B. Stress Analysis

1. shear walls and floors

a. mathematical model - general description w/sketch

Shear wall and floor stresses were computed by performing standard manual calculations. Vertical loads were distributed in the structure by conventional methods. Lateral loads were calculated by multiplying lumped mass and seismic accelerations obtained from floor spectra at each floor level. These lateral loads were then distributed among the shear walls according to their relative stiffness and location.

b. method of analysis--incorporation of torsion

The torsional moment was determined by resolving the couple due to eccentricity between the center of mass and the center of rigidity at each floor. Shear derived from this torsional moment is added directly to the forces considered for the individual shear walls.

c. load combinations

Refer to FSAR, Section 3.8.3.3.



1. foundation mat

a. mathematical model - description of boundary conditions

Basemat calculations were performed manually.

b. method of analysis

Loading on the basemat was obtained from an equivalent static analysis considering total dead and live load and its eccentricity, and three directional earthquake forces. Soil pressures were calculated directly from these forces using manual procedures.

c. load combinations

Refer to FSAR, Section 3.8.3.3.

*This is in compliance with the SRP*

d. key results (figures, etc.)

Refer to FSAR, Table 3.8-4J. (Pg. 458)



3. Material to protect against structure - structure interaction

Below grade (EL 100'-0") Rodofam II (WR Grace and Co.) or EVERLASTIC Micro II (Williams Products, Inc.) may be left in place in seismic joints between structures. Above grade gaps between walls were left open, typically 6" between Category I structures.

- a. mechanical properties
- b. additional pressure on walls
- c. findings and comments





4. vertical dynamic analysis

a. mathematical model - general description with sketch

The planar lumped parameter model consisted of one vertical beam on a rigid mat. Three nodes, representing the floor slabs at each elevation in the building, were used for the modal response spectrum model. The addition of a fourth node was used in the time history model to obtain the in-structure seismic response of the crane girder located 17.7 feet above the building's foundation.

See Attachment A. (Pg. 444)

b. development of stiffnesses, including floor stiffness, as applicable

Stiffness calculations were performed manually using standard engineering methods.

c. method of analysis

The models described above were used for time history and modal response spectrum analysis. The time-history analysis was performed using FOSIN. The Modal response spectrum analysis was performed using BSAP.



C. Computer Programs Used in Analysis

BSAP - SMIS - LUCON - FOSIN - SPECTRA

1. assumptions and limitations

See FSAR, Appendix 3B.

2. applicability

See FSAR, Appendix 3B.

3. verification

- sensitivity study in case of numerical solutions (e.g., finite element analysis)

See FSAR, Appendix 3B.

4. load input (include all cases)

PROGRAM	INPUT
BSAP	Finite element model (modes and elements), scaled response spectra, soil stiffness.
SMIS	Mass matrix, stiffness matrix, damping values.
SPECTRA	In-structure time history, frequency or period, and damping values.
FOSIN	Free-field time history, damping values, frequency.
LUCON	Shear modulus, damping values



5. output (include all cases)

See FSAR Appendix 3B.

6. other discussions



D. Overall Stability

1. forces and moments from seismic analysis

Seismic responses at the basemat, center of resistance:

SSE

$$\begin{array}{l}
 P_x = 0.555 \times 10^4 \text{ K} \\
 P_y = 0.488 \times 10^4 \text{ K} \\
 P_z = 0.555 \times 10^4 \text{ K} \\
 M_x = 1.08 \times 10^5 \text{ Ft-K} \\
 M_z = 1.08 \times 10^5 \text{ Ft-K}
 \end{array}$$

EAST-WEST

$$\begin{array}{l}
 P = 0.555 \times 10^4 \text{ K} \\
 M = 1.08 \times 10^5 \text{ Ft-K}
 \end{array}$$

NORTH-SOUTH

$$\begin{array}{l}
 P = 0.555 \times 10^4 \text{ K} \\
 M = 1.08 \times 10^5 \text{ Ft-K}
 \end{array}$$

VERTICAL

$$P = 0.488 \times 10^4 \text{ K}$$

~~x = East-West~~  
~~y = Vertical~~  
~~z = North-South~~

2. various cases considered

Seismic event loading combinations considered SSE or OBE applied in the North-South, East-West, and vertical directions simultaneously.





3. bearing pressure versus bearing capability and safety factor against bearing failure

Refer to FSAR Section 2.5.4.10 and Table 2.5-15, -16 (Pages 448, 9)

4. factors of safety

Refer to FSAR, Section 3.8.5.5 and Table 3.8-5. (Pg. 460)

- a. sliding

Factor of Safety = 1.1 (SSE)

- b. overturning

Factor of Safety = 400 (SSE)



E. Interaction of Non-category I Structures with the Structure Considered

1. identification of pertinent non-Category I structures

None. There are no non-Category I structures adjacent to the Diesel Generator Building.

2. consideration given to potential failure of non-Category I systems on Category I systems

Non-Category I systems which could affect Category I systems were designed for structural integrity under SSE loads.

Reference: FSAR, Section 3.8.4.4.

3. general findings and comments

During a walk-down those items whose failure will not affect any safety-related equipment are left as they are. If they are judged that they might affect Category I systems, they are designed to maintain their structural integrity under an SSE.



F. Design Consideration for Tornado Missiles

1. design requirements

Refer to FSAR, Table 3.5-8. (Pg. 450)

2. models for

a. local damage

Refer to FSAR, Section 3.5.3.

b. overall response

Refer to FSAR, Section 3.5.3.

3. load combinations

Refer to FSAR Section 3.8.3.3.

4. forces

The governing structural members are of sufficient thickness to preclude perforation by postulated missiles and to maintain structural integrity.



6. general comments and preliminary audit findings





III. CONFORMANCE TO ACCEPTABLE CRITERIA

A. Identification of deviations, if any

None.

B. Justification of deviations and disposition of the deviations

D. general comments



Part II Audit of Key Designs

A. Exterior Shear Walls

1. design requirements

The exterior walls were designed to satisfy structural function as bearing walls, shear walls, and protection against tornado missiles.

2. design loads (from general analysts)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Refer to FSAR, Table 3.8-4J. (Pg. 458)

4. detailed design of rebar placement at key sections

See Attachment C (Pg. 446)

5. general comments and preliminary audit findings



B. Interior Shear Walls

1. design requirements

The requirements for the interior shear walls are the same as those for the exterior shear walls with the additional requirement that the wall separating the two diesel generators must withstand the effects of an internally-generated missile resulting from a crank case explosion.

Refer to FSAR, Section 9A - NRC Question 430.7.

2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Refer to FSAR, Table 3.8-4J. (Pg. 458)

4. detailed design of rebar placement at key sections

See Attachment C. (Pg. 446)

5. general comments and preliminary audit findings



C. Main Floors and Roofs

1. design requirements

Main floors and roofs are primarily designed for vertical dead, live, and seismic loads, ~~as defined in the Project Design Criteria~~. Roofs are also designed to satisfy minimum thickness to prevent perforation by tornado generated missiles.

2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Refer to FSAR, Table 3.8-4J. (Pg. 458)

4. detailed design of rebar placement at key sections

See Attachment C. (Pg. 446)





5. general comments and preliminary audit findings



D. Steel Structural Bracing Systems (if any).

1. design requirements

The Diesel Generator Building floors and roof slabs are supported by steel beams spanning between concrete walls. The beams in general are designed for construction loads. Girders are designed for dead, live and seismic loads.

2. design loads

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Refer to FSAR, Table 3.8-4K (Pg. 459)

6. general comments and preliminary audit findings



E. Foundation Mat

1. design requirements

Refer to FSAR, Sections 3.8.5.4.2 and 3.8.5.5.

2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Refer to FSAR, Table 3.8-4J. (Pg. 458)

4. detailed design of rebar placement at key sections

See Attachment C. (Pg. 446)

5. general comments and preliminary audit findings



F. Main Frame Concrete Column Design (Key Columns)

Not applicable. There are no concrete columns in this building.

1. design requirements
2. design loads (from general analysis)
3. forces and moments at key sections
4. detailed design of rebar placement at key sections
5. general comments and preliminary audit findings





G. Secondary Floors

1. design requirements

Secondary floors were designed in the same manner as main floors and roofs.

2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Refer to FSAR, Table 3.8-4J. (Pg. 459)

4. detailed design of rebar placement at key sections

See Attachment C. (Pg. 446)

5. general comments and preliminary audit findings



H. Detailing at Floor-Wall Joints

1. design requirements

As per ACI 318-17 Code, Chapters 6 and 17.

2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Refer to FSAR, Table 3.8-4J. (Pg. 459)

4. detailed design of rebar placement at key sections

See Attachment C. (Pg. 446)

5. general comments and preliminary audit findings



I. Dynamic Effects Applied to Floors and Walls by Machinery

Due to the nature of the equipment foundations, the dynamic motion of the diesel generators will have no effect on the floors and the walls of the structure. A two inch gap filled with an expansion material completely isolates the diesel generator pads from the foundation of the building. These equipment pads are designed to satisfy all of the manufacturer's requirements and will transmit all dynamic vibrations from the diesel generators directly into the soil.

1. design requirements
2. design loads (from general analysis)
3. forces and moments at key sections
4. detailed design
5. general comments and preliminary audit findings



J. Crane & Support

1. design of bents (columns and roof trusses)

Not applicable.

a. design requirements

b. design loads (from general analysis)

c. forces and moments at key sections

d. detailed design





- e. general comments and preliminary audit findings



2. design of girders supporting crane rails

a. design requirements

The crane rails are supported by a built-up steel member. This built-up member is in turn supported by a cantilevered wide flange bracket connected to an insert plate located in the shear walls.

b. design loads (from general analysis)

~~Refer to Project Design Criteria Part II, Section 3.5.2~~

Dead load ~~and live load~~, includes girder and all the associated equipment.

Live load is the load lifted by crane. (Capacity - 5T)

c. forces and moments at key sections

	DESIGN MOMENT		DESIGN SHEAR
	$M_x$	$M_y$	
Built-up crane rail support girder	41.4 ft-K	31.3 ft-K	60 K
Cantilevered Bracket		60 ft-K	60 K

d. detailed design

See Attachment D. (Pg. 447)



e.. general comments and preliminary audit findings



3. design of spent fuel bridge

Not applicable.

a. design requirements

b. design loads (from general analysis)

c. forces and moments at key sections

d. detailed design

e. general comments and preliminary audit findings






K. Fuel Pool Liner Design

Not applicable.

1. stresses and strain controls
2. conformance to code requirements
3. analysis procedure and results
4. consideration of accidental drop of crane loads
5. corrosion effects (e.g., pitting) on liner integrity
6. preliminary findings of audit results



DIESEL GENERATOR BLDG.



LUMPED MASS MODEL  
MODAL RESPONSE SPECTRUM  
ANALYSIS


LUMPED MASS MODEL  
TIME HISTORY ANALYSIS



DIESEL GENERATOR BUILDING NATURAL FREQUENCIES

		Mode	Frequency (Hz)	Participation Factor
Horizontal (N-S)	OBE	1	7.98	17.1
		2	21.9	6.36
		3	47.8	0.41
	SSE	1	6.98	17.4
		2	19.3	5.00
		3	47.7	0.27
Horizontal (E-W)	OBE	1	6.72	16.5
		2	19.1	7.79
		3	43.8	0.44
	SSE	1	6.17	16.7
		2	17.3	7.33
		3	43.7	0.32
Vertical	OBE	1	11.6	15.3
		2	62.8	0.66
		3	126.8	0.022
	SSE	1	10.3	18.2
		2	62.7	0.66
		3	126.8	0.025






DIESEL GENERATOR BLDG.  
TYPICAL WALL SECTIONS

ATTACHMENT "C"







DIESEL GENERATOR BLDG.



ELEVATION



SECTION 

ATTACHMENT "D"



Table 2.5-15

## STATIC BEARING CAPACITY OF CATEGORY I STRUCTURES

Structure	Average Static Design Load $q_s$ (k/ft <sup>2</sup> )	Ultimate Bearing Capacity $q_o$ (k/ft <sup>2</sup> )	Factor of Safety ( $q_o/q_s$ )
Containment Building	7.9	35.7	4.5
Auxiliary Building (deep section)	6.2	34.9	5.6
Main Steam Support Structure	7.1	64.8	9.1
Control Building	3.3	45.3	13.7
Fuel Building	5.3	54.9	10.4
Diesel Generator Building	3.1	79.5	25.6
Refueling Water Tank	4.4	90.4	20.5
Condensate Storage Tank	3.5	112.4	32.1

PVNGS FSAR

GEOLOGY AND SEISMOLOGY



Table 2.5-16  
DYNAMIC BEARING CAPACITY OF CATEGORY I STRUCTURES (a)

Structure	Equivalent Uniform Vertical Stress $q_d$ (k/ft <sup>2</sup> )	Ultimate Bearing Capacity $q_o$ (k/ft <sup>2</sup> )	Factor of Safety ( $q_o/q_d$ )
Containment Building	16.1	32.2	2.0
Auxiliary Building (deep section)	10.3	25.8	2.5
Main Steam Support Structure	25.3	60.6	2.4
Control Building	9.8	39.8	4.1
Fuel Building	19.1	50.3	2.6
Diesel Generator Building	5.6	75.5	13.5
Refueling Water Tank	13.2	58.7	4.4
Condensate Storage Tank (b)	13.2	30.2	2.3

a. Based upon maximum dynamic loads derived from analyses described in section 3.7.

b. Condensate storage tank loads were conservatively chosen to be equal to the dynamic design load for the refueling water tank. Actual loads will be less.



Table 3.5-8

## TORNADO-GENERATED MISSILES CONSIDERED IN DESIGN OF SAFE SHUTDOWN STRUCTURES

Description	Weight (lbs)	Impact Area (ft <sup>2</sup> )	Maximum Velocity (ft/s)	Kinetic Energy (ft-lbs)
(A) A 12-foot wood plank, 4 x 12 inches in cross-section, traveling end on at a speed of 240 mi/h.	200	0.333	352	$3.85 \times 10^5$
(B) A steel pipe, Schedule 40, 3 inches in diameter by 10 feet long, traveling end on at 120 mi/h.	78	0.063	176	$3.75 \times 10^4$
(C) A steel rod, 1 inch in diameter, 3 feet long, traveling end on at 180 mi/h.	8	0.005	264	$8.66 \times 10^3$
(D) A steel pipe, Schedule 40, 6 inches in diameter by 15 feet long, traveling end on at 120 mi/h.	285	0.24	176	$1.37 \times 10^5$
(E) A steel pipe, Schedule 40, 12 inches in diameter by 15 feet long, traveling end on at 120 mi/h.	743	0.886	176	$3.57 \times 10^5$
(F) A utility pole, 13-1/2 inches in diameter, 35 feet long, traveling end on at 120 mi/h.	1490	0.994	176	$7.17 \times 10^5$
(G) An automobile of 4,000 pounds weight, striking the structure at 60 mi/h.	4000	20.0	88	$4.81 \times 10^5$

3.5-34

EVNGS P.5AR


MISSILE PROTECTION


17

450









 Palo Verde Nuclear Generating Station  
FSAR

HORIZONTAL DESIGN SPECTRA  
FOR SSE 0.25 g


Figure 3.7-1






	<b>Palo Verde Nuclear Generating Station</b> <b>FSAR</b>
<b>VERTICAL DESIGN SPECTRA</b> <b>FOR SSE 0.25 g</b> <b>Figure 3.7-2</b>	








**Palo Verde Nuclear Generating Station**  
**FSAR**

---

HORIZONTAL DESIGN SPECTRA  
 FOR OBE 0.13 g  
 Figure 3.7-3






 Palo Verde Nuclear Generating Station  
FSAR

VERTICAL DESIGN SPECTRA  
FOR OBE 0.13 g  
Figure 3.7-4








- NOTES: 1 LOW STRAIN SHEAR MODULUS AT VARIOUS DEPTHS ARE AVERAGE VALUES  
 2 SHEAR WAVE VELOCITY CALCULATED FROM  $V_s = (G/\rho)^{1/2}$   
 3 P WAVE VELOCITY CALCULATED FROM  $V_p = V_s / (2/3)^{1/2}$

00  
2



Palo Verde Nuclear Generating Station  
ES&H

SOIL PROFILE  
FIGURE 1.7.7


CHANGE


Engineering Division

Amended

455







 Palo Verde Nuclear Generating Station  
FSAR

SHEAR MODULUS VS. STRAIN - CLAY  
FIGURE 3.7-8





 Palo Verde Nuclear Generating Station  
FSAR

SHEAR MODULUS VS. STRAIN - SAND

FIGURE 3.7-9



Table 3.8-4J

DIESEL GENERATOR BUILDING SUMMARY OF GOVERNING LOAD INTERACTIONS FOR PRINCIPAL  
REINFORCED CONCRETE MEMBERS

Description of Principal Member	Location of Principal Member	Governing Load Combination Number (a)	Calculated Axial Load ( $P_u$ ) and Flexural Load ( $M_u$ )		Maximum Flexural Interaction Capacity ( $M_u$ ), Given Axial Load ( $P_u$ ) (b) (c)	Calculated Shear Load ( $V_u$ ) (b)	Maximum Shear Capacity ( $V_u$ ) (b)
			$P_u$ (b)	$M_u$ (c)			
1'-9" x 60'-0" wall - vertical and horizontal reinforcement	Exterior wall @ El. 100'-0"	2	-1,042	53,671	153,503	1,548	4,986
1'-9" x 19'-6" wall - vertical and horizontal reinforcement	Interior wall @ El. 100'-0"	2	-497	8,323	16,869	166	1,619
1'-9" x 60'-0" wall - vertical and horizontal reinforcement	Interior wall @ El. 131'-0"	2	-556	5,772	146,549	385	4,986
1'-4" thick slab - E-W reinforcement	El. 115'-0"	2	(d)	13	34	(d)	4,986
1'-4" thick slab - N-S reinforcement	El. 131'-0"	2	-	16	34	-	-
4'-0" thick basemat - E-W reinforcement	El. 100'-0"	2	-	247	249	-	-
4'-0" thick basemat - E-W or N-S reinforcement	El. 100'-0"	2	-	210	240	-	-

- a. Refer to Section 3.8.3.3.2.A(2) for description of load combination number.  
b.  $P_u$  and  $V_u$  are in kips; sign convention for  $P_u$ : Compression (-), Tension (+).  
c.  $M_u$  is in  $ft-k/ft$  for slabs and  $ft-k$  for walls.  
d. Not applicable.





Table 3.8-4K

## DIESEL GENERATOR BUILDING SUMMARY OF GOVERNING COMBINED STRESS RATIOS FROM THE BEAM/COLUMN INTERACTION EQUATION FOR PRINCIPAL STRUCTURAL STEEL MEMBERS

Description of Principal Members	Location of Principal Members	Governing Load Combination Number (a)	Combined Stress Ratio ( $\leq 1.0$ )
W 24 X 84	Floor Beam @ El. 115'-0"	2	0.47
W 12 X 45	Floor Beam @ El. 115'-0"	2	0.71
W 24 X 130	Main Girder @ El. 131'-0"	2	0.87
W 36 X 160	Main Girder @ El. 131'-0"	2	0.85
W 24 X 100	Floor Beam @ El. 146'-0"	2	0.58
S 24 X 120	Monorail Beam @ El. 126'-5"	1	0.98

- a. Refer to section 3.8.3.3.3.A(1) for description of load combination number.

3



DESIGN OF  
CATEGORY I STRUCTURES

3.8.5.5 Structural Acceptance Criteria


The foundations of Seismic Category I buildings are designed to meet the same structural acceptance criteria as the buildings themselves. These criteria are discussed in sections 3.8.1.5, 3.8.3.5, and 3.8.4.5. The limiting conditions for the foundation medium, together with a comparison of actual capacity and estimated structure loads, are found in sections 2.5.4.10 and 2.5.4.11. Computed factors of safety against overturning, sliding, and flotation for Category I structures are given in table 3.8-5.


Table 3.8-5  
COMPUTED FACTORS OF SAFETY

Structure	Overturning		Sliding		Flotation
	OBE	SSE	OBE	SSE	
Auxiliary	3200	830	2.2	1.3	4.7
Containment	3400	1200	1.7	1.2	4.5
Control	1500	420	1.6	1.2	4.5
Diesel Generator	1200	400	2.2	1.1	NA <sup>(a)</sup>
Fuel	1600	400	1.9	1.1	NA
Main Steam Support	340	91	1.6	1.1	NA
Condensate Storage and Refueling Water Tanks	500	150	1.7	1.4	NA


a. Not applicable







**Palo Verde Nuclear Generating Station**  
**FSAR**  
 DIESEL GENERATOR BUILDING  
 SSE VERTICAL  
 ACCELERATION RESPONSE SPECTRA  
 Figure 3D-34







**Palo Verde Nuclear Generating Station**  
**FSAR**


---

DIESEL GENERATOR BUILDING  
 SSE HORIZONTAL ACCELERATION  
 RESPONSE SPECTRA, EL 100'-0",  
 BASE MAT  
 Figure 3D-35








**Palo Verde Nuclear Generating Station**  
**FSAR**

---

DIESEL GENERATOR BUILDING  
 SSE HORIZONTAL ACCELERATION  
 RESPONSE SPECTRA, EL 146'-0", ROOF  
 Figure 3D-36



PALO VERDE NUCLEAR STATION UNITS 1, 2, 3  
DESIGN ADEQUACY AUDIT

STRUCTURAL AUDIT OF CATEGORY I TANKS

Part I - General Analysis

I. BASIC DESIGN CRITERIA

(1) 'g' value - free field

	Seismic level based on construction permit license	Seismic level used in design of structures and equipment
SSE	.20g	.25g
OBE	.10g	.13g

Reference: FSAR Section 3.7

(2) Spectra (attached fig. for all damping values, ductilities)

A. Zero period acceleration

SSE .25g

OBE .13g

Reference: FSAR, Figures 3.7-1 - 3.7-4 and Section 3.7.1.1

*(Pages 490, 1, 2, 3)*  
This is consistent with Reg Guide 1.60

B. Frequency (or period) interval

Refer to BC-TOP-4A, Section 2.5.1(c)

C. Damping

Refer to FSAR, Section 3.7.1.3.

*This is consistent with Reg Guide 1.61*

*Refer to FSAR figures 3.7-5 and 3.7-6 (Pages 92A & 92B)*

D. Artificial time history and corresponding spectra (attach figures)

1. original time history and its composition i.e., rising time, strong motion and tail end.

A time history analysis was not used.



2. base line correction, check the integrated velocity and displacement time histories.
3. time interval - compatible with the highest frequency considered in the spectral calculation.

E. Motion duration

F. Components of motion including their relative motion amplitudes. Analysis was performed for the three principle directions with equal amplitudes. Due to symmetry, only one horizontal analysis was performed.

G. Dead and live loads

~~Refer to Project Design Criteria Part II, Sections 3.5.1 and 3.5.2 and Part III, Section 1.4.1.~~  
*dead load includes all the structures and equipment.  
 there is no live load*

H. Internal Pressure

In addition to the normal hydrostatic pressure, the following pressures were considered:

TYPE OF PRESSURE	CAUSE OF PRESSURE	REFUELING WATER TANK (psig)	HOLD-UP TANK (psig)	CONDENSATE STORAGE TANK (psig)
Normal Operating Pressure, Po	(a) Due to Suction or Discharge of Water,	± 0.5	± 0.5	± 0.5
	or (b) Due to Temp. Change	± 0.1	± 0.1	± 0.1
Accident Pressure, Pa	Due to Suction in LOCA	- 1.5	- 1.5	± 0.5



I. Ground water level

The groundwater design level is at plant El. 70'-0". The actual water level is at approximately plant El. 60'-0".

Reference: FSAR, Section 2.4.13.2.4 and 2.4.13.5.

J. Back fill earth pressure, wind, overpressure due to postulated external explosions (as applicable).

~~Refer to Project Design Criteria Part II, Sections 3.4.5.3 and 3.5.5 for lateral earth pressure, wind and tornado loads.~~

For lateral earth pressure see pages 208A & 208B.  
Wind does not govern.

K. Other considerations





## II. METHOD OF ANALYSIS

- (a) Method of analysis used (Time history, response spectrum methods, etc.) and consideration of torsional and translation response.

A modal response spectrum analysis was performed to determine seismic loads for the design of structural elements.

(i) general description

The Category I tank analysis used a planar lumped parameter model with 9 nodes. Soil springs and hydrodynamic effects (modeled per US AEC TID 7024, Nuclear Reactor and Earthquakes) were incorporated. Only the most critical tank was modeled for the seismic analysis. The results were applied to all three tanks.

See Attachment A for a sketch of the mathematical model. (Pg. 481)

(ii) findings and comments

(b) Selection of number of masses and degrees of freedom

(i) general description

Total number of nodes considered = 9

Total number of degrees of freedom = 22



(ii) findings and comments

(c) number of modes considered

Six modes

Frequency of 6th mode = 39.92 cps (SSE)  
= 40.24 cps (OBE)

(i) general description

See Attachment B for modal frequencies and participation factors. (Pg. 482)

(ii) findings and comments



(d) combining modal responses

(i) actual procedures used

Refer to FSAR, Section 3.7.2.7.

(ii) general findings

(e) consideration of three components of motion

(i) actual procedures used

Refer to FSAR, Section 3.7.2.6

*This is consistent with Reg Guide 1.92*

(ii) general findings



STRESS ANALYSIS

1. Computer programs used in analysis

BSAP, OPTCON

A. Assumptions and limitations

Refer to FSAR, Appendix 3B.

B. Applicability

Refer to FSAR, Appendix 3B.

C. Verification

- Sensitivity study in case of numerical solutions (e.g., finite element analysis)

Refer to FSAR, Appendix 3B.

D. Load input (include all cases)

PROGRAM

INPUT

BSAP            Finite element model (nodes and elements), response spectra, damping

OPTCON        Actual wall reinforcement, temperatures, section properties, element loadings.





E. Output (include all cases)  
Refer to FSAR, Appendix 3B.

F. Other discussions



## (2) Overall Stability

## A. forces and moments from seismic analysis (computer output)

	SSE	OBE
Horizontal Force (K)	3,302	1,770
Vertical Force (K)	4,883	2,501
Over-turning Moment (FT-K)	142,557	75,514

## B. Applicable loads other than those in item A above

None.

## C. Various cases considered

Seismic event loading combinations considered OBE or SSE applied in N-S, E-W and vertical directions simultaneously.



- D. bearing pressure versus bearing capacity and safety factor against bearing failure

Refer to FSAR, Section 2.5.4.10 and Tables 2.5-15, -16. (Pages 488, 9)

- E. factors of safety

Refer to FSAR, Section 3.8.5.5 and Table 3.8-5. (Pg. 494)

- a. sliding

Factor of Safety = 1.40 (SSE)

- b. overturning

Factor of Safety = 150 (SSE)



(3) interaction of non-category I structures or pipings with the storage tanks

(a) identification of pertinent non-category I structures or pipings

None. There are no non-Category I structures adjacent to the tanks.

(b) consideration given to potential failure of non-category I pipings on Category I tank elements

(c) general findings and comments





III. Conformance to current NRC Criteria

(1) Identification of deviations, if any

• None.

(2) Justification of deviations and disposition of the deviations

(3) Comparison of reevaluation results with the original design and discussions.

(4) general comments



(5) Tank wall-base plate or mat junction design

A. design requirements and model (as applicable)

Refer to FSAR, Sections 3.8.4.2 and 3.8.4.4.

B. Design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

C. forces and moments at key sections

TANK WALL MOMENTS AT BASE

Mu = 61.4 K-Ft/Ft (Tension inside Face)  
Mu = 49.3 K-Ft/Ft (Tension outside Face)

TANK WALL RING TENSION

Tmax = 164.3 K/Ft

TANK WALL RADIAL SHEAR

Vu = 20.9 K/Ft



PART II - AUDIT OF KEY DESIGNS

For each key design area audited, the design calculations should be reviewed together with applicable drawings, sketches, etc. Also, key details and/or sections, as appropriate, in this audit report should be included.

1. Storage Tank Liner Design

(1) conformance with

AISC Code.

(2) specific check of key liner locations

A. cylinder-base mat junction

(a) sketch

See Attachment C. (Pg. 483)

(b) forces and displacements obtained from computer analysis

The liner is not designed as a load carrying member.  
It acts only as the water-tight membrane for the tank.



F. Key penetration design

Refer to Attachments D and G. (Pages 484,5)

G. preliminary audit findings





(6) Tank roof or dome-to-cylinder junction design

See Attachment E. (Pg. 485)

A. design requirements and model

Refer to FSAR, Sections 3.8.4.2, 3.8.4.4, 3.8.4.1.7,  
and 3.8.4.1.8

B. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

C. forces and moments at key sections

Maximum Load in Radial Beams

Axial:  $279^K$  (tension) Moment: 158.8 Ft-K



- D. detailed design of rebar placement or steel connections at key sections

See Attachments E and F. (Pg. 485, 6)

- E. Conformance to applicable codes and standards

Refer to FSAR, Section 3.8.4.2.

- F. general comments and preliminary audit findings



(7) Piping penetrating design

See Attachment G. (Pg. 487)

A. design requirements and model

Refer to FSAR, Sections 3.8.4.2 and 3.8.4.4.

B. design loads (from general analysis)

Refer to FSAR Section 3.8.3.3.

C. forces and moments at key sections

Applied load on shell manhole cover = 25.25 K

D. Detailed design of the penetration

~~Refer to Project Design Criteria Part II, Section 3.3 and Part III, Section 4.0.~~


E. conformance to applicable codes and standards

Refer to FSAR, Section 3.8.4.2.

F. general comments and preliminary audit findings



ATTACHMENT A



CATEGORY I TANK MATH MODEL






CAT. I TANKS BUILDING NATURAL FREQUENCIES & PARTICIPATION FACTORS

		Mode	Frequency (Hz)		PARTICIPATION FACTOR
OBE 2-D MODEL	1	0.27	SLOSHING	4.975	
	2	3.70	ROCKING	-14.824	
	3	7.34	VERTICAL	-17.600	
	4	10.90	HORIZ.	-9.437	
	5	35.90	HORIZ.	0.754	
	6	40.74	HORIZ.	-0.174	
SSE 2-D MODEL	1	0.27	SLOSHING	4.979	
	2	3.38	ROCKING	-14.817	
	3	6.63	VERTICAL	17.600	
	4	9.92	HORIZ.	-9.409	
	5	35.68	HORIZ.	0.600	
	6	39.92	HORIZ.	-0.155	






ATTACHMENT C



CYLINDER - BASE MAT JUNCTION



FAB NOTE PROVIDE STD GASKET OR RINGS FOR ALL MANHOLE COVERS



SHELL MANHOLE

V T S



KEY PENETRATION DETAIL

ATTACHMENT D

7/27



# ATTACHMENT E




SECTION C  
 1/2" = 1'-0"






# ATTACHMENT F






ATTACHMENT G



REINF. AROUND SLEEVES IN WALLS & SLAB  
 WHEN "D" IS LARGER THAN MAIN REINF. SPACING



REINF AROUND SLEEVE IN WALLS OR SLABS  
 WHEN "D" IS LESS THAN MAIN REINF. SPACING

PIPING PENETRATION DESIGN



Table 2.5-15  
 STATIC BEARING CAPACITY OF CATEGORY I STRUCTURES

Structure	Average Static Design Load $q_s$ (k/ft <sup>2</sup> )	Ultimate Bearing Capacity $q_o$ (k/ft <sup>2</sup> )	Factor of Safety ( $q_o/q_s$ )
Containment Building	7.9	35.7	4.5
Auxiliary Building (deep section)	6.2	34.9	5.6
Main Steam Support Structure	7.1	64.8	9.1
Control Building	3.3	45.3	13.7
Fuel Building	5.3	54.9	10.4
Diesel Generator Building	3.1	79.5	25.6
Refueling Water Tank	4.4	90.4	20.5
Condensate Storage Tank	3.5	112.4	32.1

PVNGS FSAR

GEOLOGY AND SEISMOLOGY



March 1980

2.5-163

Amendment 1

Table 2.5-16

DYNAMIC BEARING CAPACITY OF CATEGORY I STRUCTURES (a)

Structure	Equivalent Uniform Vertical Stress $q_d$ (k/ft <sup>2</sup> )	Ultimate Bearing Capacity $q_o$ (k/ft <sup>2</sup> )	Factor of Safety ( $q_o/q_d$ )
Containment Building	16.1	32.2	2.0
Auxiliary Building (deep section)	10.3	25.8	2.5
Main Steam Support Structure	25.3	60.6	2.4
Control Building	9.8	39.8	4.1
Fuel Building	19.1	50.3	2.6
Diesel Generator Building	5.6	75.5	13.5
Refueling Water Tank	13.2	58.7	4.4
Condensate Storage Tank (b)	13.2	30.2	2.3

a. Based upon maximum dynamic loads derived from analyses described in section 3.7.


b. Condensate storage tank loads were conservatively chosen to be equal to the dynamic design load for the refueling water tank. Actual loads will be less.


GEOLOGY AND SEISMOLOGY

489









 Palo Verde Nuclear Generating Station  
FSAR

HORIZONTAL DESIGN SPECTRA  
FOR SSE 0.25 g

Figure 3.7-1








**Palo Verde Nuclear Generating Station**  
**FSAR**

---


**VERTICAL DESIGN SPECTRA**  
**FOR SSE 0.25 g**  
**Figure 3.7-2**






	<p><b>Palo Verde Nuclear Generating Station</b></p> <p><b>FSAR</b></p>
<p>HORIZONTAL DESIGN SPECTRA FOR OBE 0.13 g</p> <p>Figure 3.7-3</p>	





 Palo Verde Nuclear Generating Station  
FSAR

VERTICAL DESIGN SPECTRA  
FOR OBE 0.13 g

Figure 3.7-4





DESIGN OF  
CATEGORY I STRUCTURES

3.8.5.5 Structural Acceptance Criteria

The foundations of Seismic Category I buildings are designed to meet the same structural acceptance criteria as the buildings themselves. These criteria are discussed in sections 3.8.1.5, 3.8.3.5, and 3.8.4.5. The limiting conditions for the foundation medium, together with a comparison of actual capacity and estimated structure loads, are found in sections 2.5.4.10 and 2.5.4.11. Computed factors of safety against overturning, sliding, and flotation for Category I structures are given in table 3.8-5.

Table 3.8-5  
COMPUTED FACTORS OF SAFETY

Structure	Overturning		Sliding		Flotation
	OBE	SSE	OBE	SSE	
Auxiliary	3200	830	2.2	1.3	4.7
Containment	3400	1200	1.7	1.2	4.5
Control	1500	420	1.6	1.2	4.8
Diesel Generator	1200	400	2.2	1.1	NA <sup>(a)</sup>
Fuel	1600	400	1.9	1.1	NA
Main Steam Support	340	91	1.6	1.1	NA
Condensate Storage and Refueling Water Tanks	500	150	1.7	1.4	NA
a. Not applicable					



PALO VERDE NUCLEAR STATION UNITS 1, 2, 3  
DESIGN ADEQUACY AUDIT

STRUCTURAL AUDIT OF SPRAY PONDS  
Part I - General Analysis

I. BASIC DESIGN CRITERIA

A. 'g' value - free field

	Seismic level based on construction permit license	Seismic level used in design of structures and equipment
SSE	0.20g	0.25g
OBE	0.10g	0.13g

Reference: FSAR, Section 3.7

B. Spectra (attach figs. for all damping values, ductilities)

1. zero period acceleration

SSE	0.25g
OBE	0.13g

*Pages 539-542*

Reference: FSAR, Figures 3.7-1 - 3.7-4 and Section 3.7.1.1

*This is consistent with REG. GUIDE 1.60*

Frequency (or period) interval

Refer to BC-TOP-4A, Section 2.5.1 (c)

C. Damping

Refer to FSAR, Section 3.7.1.3

*This is consistent with Reg. Guide 1.61*

*Refer to FSAR Figures 3.7-5 and 3.7-6 (Pages 216 A & 216B)*

D. Artificial time history and corresponding spectra (attach figures)

1. original time history and its composition, i.e., rising time, strong motion and tail end.

A time history was not used in the design of the Spray Ponds and Spray Pond Pump House.



2. base line correction, check the integrated velocity and displacement time histories
3. time interval - compatible with the highest frequency considered in the spectral calculation

E. Motion duration

F. components of motion including their relative motion amplitudes

Analysis was performed for the three principle directions with equal amplitudes.

G. Dead and live loads for various operating floors and base slab

~~Refer to Project Design Criteria Part II, Section 3.0 and Part III, Section 1.4.~~

*Dead Load: includes all structures, major equipment load and 50 psf equivalent for small equipment.*

*Live Load: see action item 3*



H. Ground water level

The groundwater design level is at plant El 70'-0". The actual water level is at approximately plant El. 60'-0".

Reference: FSAR, Sections 2.4.13.2.4 and 2.4.13.5.

I. Backfill earth pressure, wind, overpressure due to postulated external explosions (as applicable)

~~Refer to Project Design Criteria Part II, Sections 3.4.5.3 and 3.5.5 for lateral earth pressure, wind and tornado loads.~~

*For lateral earth pressure see pages 208 A & 208 D  
Wind does not govern.*

J. Other considerations

The concrete walls and roof slab of the Spray Pond Pump house were designed for missile protection.





II. ANALYSIS METHOD

A. Seismic Analysis

1. Mathematical model-general description with sketch.

See Attachment A. (Pages 534 & 535)

a. parameters used

(1) concrete modulus

$$E_c = 3605 \text{ Ksi} \quad f'_c = 4000$$

(2) rebar modulus and yield strength

$$E_s = 29000 \text{ Ksi} \quad f_y = 60 \text{ Ksi}$$

(3) Poisson's ratio

$$\nu = .24$$

~~Reference: Project Design Criteria~~

(4) damping

Refer to FSAR, Section 3.7.1.3.

*This is consistent with Reg. Guide 1.61*



(5) properties of foundation materials.

- shear modulus

Refer to FSAR, Figures 3.7-7, -8, -9 (Pages 543-545)

- subgrade reactions

Coefficient of Subgrade Reaction:  $30 \text{ K/Ft}^3$

- bearing capabilities

Static Capacity: 8 KSF

Dynamic Capacity: 17.2 KSF

(6) other parameters

b. stiffness calculations

(1) exterior walls

Stiffness calculations were performed manually using standard engineering methods.

(2) interior walls

Same as exterior walls.



2. method of Analysis

- a. method of analysis used (time history, response spectrum methods, etc.) and consideration of torsional and translational response

(1) general description

A response spectrum analysis was performed for each of the two principle horizontal directions of the Spray Pond Pump House. Due to the rigidity of the pump house in the vertical direction, the ZPA from the free-field was used. The calculations were performed manually.

(2) findings and comments

- b. selection of number of masses and degrees of freedom

(1) general description

Each of the two planar models consisted of two masses with two degrees of freedom.



(2) findings and comments

c. number of modes considered

(1) general description

N-S 2 modes<sup>2</sup>

E-W 2 modes

(2) findings and comments





d. combining modal responses

(1) actual procedures used

Refer to FSAR, Section 3.7.2.7.

(2) general findings

e. consideration of three components of motion

Refer to FSAR, Section 3.7.2.6.

(1) actual procedures used

The component factor method was used to combine the three components of motion.

*It is consistent with Reg Guide 1.92*

(2) general findings



f. consideration of soil-structure interaction

Soil - structure interaction was not considered.

(1) general description

(2) findings and comments

g. decoupling criteria for subsystems

(1) general procedure

Refer to BC-TOP-4A, Section 3.2.

(2) key examples

(3) The other criteria pertaining to frequency ratio as defined in SRP 3.7.3.II.3.6 are also met



~~(A)~~ general findings and comments

h. modeling of hydrodynamic effects in spent fuel pool

The Spray Pond Pump House and Spray Ponds were analyzed to withstand hydrodynamic effects in accordance with U.S. AEC TID 7024, Nuclear Reactors and Earthquakes.

i. modeling of spent fuel pool wells and interior floor slabs and equipment thereof

Not applicable.



3. development of in-structure response spectra

In-structure Response Spectra was not developed for the Spray Ponds and Pump House. *The Pump vendor was given generic In-structure response spectra for the design of the pump. See Page 545-A*

a. general procedures

(1) smoothing (describe specific smoothing method used)

(2) peak widening

b. typical results (attach figures)





**B. Stress Analysis****1. shear walls and floors****a. mathematical model - general description w/sketch**

Shear wall and floor stresses are computed by performing standard manual calculations. Vertical loads are distributed in the structure by conventional methods. Lateral loads were obtained from the response spectrum analysis. These lateral loads are then distributed among the shear walls according to their relative stiffness and location.

**b. method of analysis--incorporation of torsion**

The torsional moment is determined by resolving the couple due to eccentricity between the center of mass and center of rigidity at each floor. Shear derived from this torsional moment is added directly to the forces considered for the individual shear walls.

**c. load combinations**

Refer to FSAR, Section 3.8.3.3.



1. foundation mat

a. mathematical model - description of boundary conditions

b. method of analysis

Manual calculations using "Beam on Elastic Foundation" theory were performed to determine the design moments and forces.

c. load combinations

Refer to FSAR, Section 3.8.3.3.

d. key results (figures, etc.)

Spray Pond Pump House Basemat:

$$M_u = 128 \text{ Ft-K/Ft}$$

$$V_u = 54 \text{ K/Ft}$$

Basemat of Pond Perimeter Wall

$$M_u = 83 \text{ Ft-K/Ft}$$

$$V_u = 12 \text{ K/Ft}$$



3. Material to protect against structure - structure interaction

Not applicable. The Spray Ponds and Pump House do not have any other structures adjacent to them.

- a. mechanical properties
- b. additional pressure on walls
- c. findings and comments



4. vertical dynamic analysis

The structure was analyzed for the free field vertical accelerations due to its rigidity.

b. development of stiffnesses, including floor stiffness, as applicable

c. method of analysis

Manual calculations were used in the analysis.





C. Computer Programs Used in Analysis

None.

1. assumptions and limitations

2. applicability

3. verification

• sensitivity study in case of numerical solutions (e.g., finite element analysis)

4. load input (include all cases)



5. output (include all cases)

6. other discussions



D. Overall Stability

1. forces and moments from seismic analysis

Forces and Moments acting at top of Pump House basemat:

	<u>OBE</u>	<u>SSE</u>
Shear	273 K	519 K
Overturning Moment	7977 Ft-K	15156 Ft-K

2. various cases considered

Seismic event loading combinations considered SSE or OBE applied in the North-South, East-West, and vertical directions simultaneously.



3. bearing pressure versus bearing capability and safety factor against bearing failure'

For Pump House Foundation:

	<u>Actual</u>	<u>Capacity</u>
Static	3.6 KSF	8 KSF
Dynamic	6.9 KSF	17.2 KSF

4. factors of safety

- a. sliding

The Pump House Foundation is integral with the Spray Pond basemat. Due to the size of the Spray Pond basemat, sliding was not considered to be a problem.

- b. overturning

Factor of Safety = 3.8 (SSE)





E. Interaction of Non-category I Structures with the Structure Considered

1. identification of pertinent non-Category I structures

None. There are no non-Category I structures close to the Spray Ponds or Pump House.

2. consideration given to potential failure of non-Category I systems on Category I systems

3. general findings and comments



F. Design Consideration for Tornado Missiles

1. design requirements

Refer to FSAR, Table 3.5-8. (Page 538)

2. models for

a. local damage

Refer to FSAR, Section 3.5.3

b. overall response

Refer to FSAR, Section 3.5.3.

3. load combinations

Refer to FSAR, Section 3.8.3.3.

4. forces

The governing structural members are of sufficient thickness to preclude perforation by postulated missiles and maintain structural integrity.



6. general comments and preliminary audit findings



III. CONFORMANCE TO ACCEPTABLE CRITERIA

A. Identification of deviations, if any

None.

B. Justification of deviations and disposition of the deviations

D. general comments





Part II Audit of Key Designs

A. Exterior Shear Walls

1. design requirements

The exterior walls of the Pump House are designed to satisfy structural requirements as bearing walls, shear walls and protection against tornado missiles.

2. design loads (from general analysts)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

$$M = 1195 \text{ Ft-K}$$

$$P = 357 \text{ K}$$

4. detailed design of rebar placement at key sections

See Attachment B. (page 536)

5. general comments and preliminary audit findings



B. Interior Shear Walls

1. design requirements

Same as exterior walls.

2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

The forces and moment in the interior walls are less than those of the exterior walls. The reinforcement is the same for both walls.

4. detailed design of rebar placement at key sections

See Attachment B. *(page 536)*

5. general comments and preliminary audit findings



C. Main Floors and Roofs

1. design requirements

Main floors and roofs were primarily designed for dead, live, and seismic loads, ~~as defined in the Project Design Criteria~~. Roofs are also designed to satisfy minimum thickness to preclude perforation by tornado generated missiles.

2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

For elevated slab:

$$M_u = 34 \text{ Ft-K/Ft}$$

$$V_u = 13 \text{ K/Ft}$$

4. detailed design of rebar placement at key sections

See Attachment B. (page 536)



5. general comments and preliminary audit findings





D. Steel Structural Bracing Systems (if any)

1. design requirements

The Spray Pond Pump House floor and roof slabs are supported by structural steel beams which are primarily designed for construction loads.

2. design loads

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

	<u>Moment</u>	<u>Shear</u>
El. 120' - 7-1/2"	35 Ft -K	8.6 K
El. 105' - 7-1/2"	22 Ft -K	8.5 K

6. general comments and preliminary audit findings



E. Foundation Mat

1. design requirements

Refer to FSAR, Sections 3.8.5.4.2 and 3.8.5.5.

2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

3. forces and moments at key sections

Basemat of perimeter wall:  $M_u = 83 \text{ Ft-K/Ft}$        $V = 12 \text{ K/Ft}$

Basemat of Pump House:       $M_u = 128 \text{ Ft-K/Ft}$        $V = 54 \text{ K/Ft}$

4. detailed design of rebar placement at key sections

See Attachments B and C. *(pages 536 & 537)*

5. general comments and preliminary audit findings



F. Main Frame Concrete Column Design (Key Columns)

Not applicable. There are no concrete columns in this structure.

1. design requirements
2. design loads (from general analysis)
3. forces and moments at key sections
4. detailed design of rebar placement at key sections
5. general comments and preliminary audit findings



G. Secondary Floors

Not applicable.

1. design requirements
2. design loads (from general analysis)
3. forces and moments at key sections
4. detailed design of rebar placement at key sections
5. general comments and preliminary audit findings





## H. Detailing at Floor-Wall Joints

## 1. design requirements

As per ACI 318-71 Code, Chapter 6 and 17.

## 2. design loads (from general analysis)

Refer to FSAR, Section 3.8.3.3.

## 3. forces and moments at key sections

$$M_u = 34 \text{ Ft-K/Ft}$$

$$V_u = 12 \text{ Ft-K/Ft}$$

## 4. detailed design of rebar placement at key sections

See Attachments B and C. (pages 536 & 537)

## 5. general comments and preliminary audit findings



I. Dynamic Effects Applied to Floors and Walls by Machinery

1. design requirements

The natural frequency of the floor/structure support is about twice that of the operating frequency of the pump/motor units. Since resonance is not a problem, dynamic effects have been neglected.

2. design loads (from general analysis)

3. forces and moments at key sections

4. detailed design

5. general comments and preliminary audit findings



## J. Crane &amp; Support

## 1. design of bents (columns and roof trusses)

Not applicable. There are no cranes in this structure.

## a. design requirements

## b. design loads (from general analysis)

## c. forces and moments at key sections

## d. detailed design



e. general comments and preliminary audit findings





2. design of girders supporting crane rails

Not applicable.

a. design requirements

b. design loads (from general analysis)

c. forces and moments at key sections

d. detailed design



e. general comments and preliminary audit findings



3. design of spent fuel bridge

Not applicable.

a. design requirements

b. design loads (from general analysis)

c. forces and moments at key sections

d. detailed design

e. general comments and preliminary audit findings



K. Fuel Pool Liner Design

Not applicable.

1. stresses and strain controls
2. conformance to code requirements
3. analysis procedure and results
4. consideration of accidental drop of crane loads
5. corrosion effects (e.g., pitting) on liner integrity
6. preliminary findings of audit results





ATTACHMENT A

ESSENTIAL SPRAY POND CONCRETE WALLS


The reinforced concrete walls and their connections to the base slab were designed manually as free standing cantilevered walls. Two load cases were considered (see Sheet 2 for sketch):

- 1) Hydrostatic Pressure - included hydrodynamic effects under an OBE or SSE. In this analyses, the presence of the soil embankment outside the wall was conservatively neglected.
- 2) Loading from the active soil pressure included effects from an OBE or SSE. The pond was assumed to be empty for this load case. The dynamic lateral forces were determined in accordance with the Project Design Criteria Part II, Section 3.4.5.3.

ESSENTIAL SPARY POND PUMP HOUSE

Two lumped parameter planar models were used for a response spectrum dynamic analysis. See Sheet 2 for a sketch of the model.







CONCRETE WALL MODELS



PUMP HOUSE LUMPED  
PARAMETER MODEL




# ATTACHMENT B DETAILS OF SPRAY POND PUMP HOUSE





# ATTACHMENT C



## DETAILS OF SPRAY PONDS





Table 3.5-8


## TORNADO-GENERATED MISSILES CONSIDERED IN DESIGN OF SAFE SHUTDOWN STRUCTURES


Description	Weight (lbs)	Impact Area (ft <sup>2</sup> )	Maximum Velocity (ft/s)	Kinetic Energy (ft-lbs)
(A) A 12-foot wood plank, 4 x 12 inches in cross-section, traveling end on at a speed of 240 mi/h.	200	0.333	352	$3.85 \times 10^5$
(B) A steel pipe, Schedule 40, 3 inches in diameter by 10 feet long, traveling end on at 120 mi/h.	78	0.063	176	$3.75 \times 10^4$
(C) A steel rod, 1 inch in diameter, 3 feet long, traveling end on at 180 mi/h.	8	0.005	264	$8.66 \times 10^3$
(D) A steel pipe, Schedule 40, 6 inches in diameter by 15 feet long, traveling end on at 120 mi/h.	285	0.24	176	$1.37 \times 10^5$
(E) A steel pipe, Schedule 40, 12 inches in diameter by 15 feet long, traveling end on at 120 mi/h.	743	0.886	176	$3.57 \times 10^5$
(F) A utility pole, 13-1/2 inches in diameter, 35 feet long, traveling end on at 120 mi/h.	1490	0.994	176	$7.17 \times 10^5$
(G) An automobile of 4,000 pounds weight, striking the structure at 60 mi/h.	4000	20.0	88	$4.81 \times 10^5$

3.5-34

MISSILE PROTECTION:







 Palo Verde Nuclear Generating Station  
FSAR

HORIZONTAL DESIGN SPECTRA  
FOR SSE 0.25 g  
Figure 3.7-1








**Palo Verde Nuclear Generating Station**  
**FSAR**

---

VERTICAL DESIGN SPECTRA  
 FOR SSE 0.25 g  
 Figure 3.7-2








**Palo Verde Nuclear Generating Station  
FSAR**  
 HORIZONTAL DESIGN SPECTRA  
 FOR OBE 0.13 g  
 Figure 3.7-3









**Palo Verde Nuclear Generating Station**  
**FSAR**  
 VERTICAL DESIGN SPECTRA  
 FOR OBE 0.13 g  
 Figure 3.7-4



DEPTH (FT.)	LAYER DEPTH (FT.)	DESCRIPTION	LAYER THICKNESS	UNIT WEIGHT (pcf)	POISSON'S RATIO	IN SITU SHEAR WAVE VELOCITY (FT/SEC)	LOW STRAIN SHEAR MODULUS (KSF)	LOW STRAIN P WAVE VELOCITY (FT/SEC)
AVERAGE PERCHED WATER LEVEL 44'		SAND (2)	47'	123	.27	996	3740	1990
	50	CLAY (1)	23'	121	.44	1116	4160	7090
	70	SAND (2)	7'	121	.46	1177	5760	4445
	100	CLAY (1)	82'	123	.47	1194	5450	5280
	150					1269	6000	5388
	159	SAND (2)	10'	125	.465	1253	6270	5502
	169	CLAY (1)	27'	127	.46	1401	7500	5454
	196	SAND (2)	12'	127	.46	1749	8980	6544
	206	CLAY (1)	20'	126	.45	1708	12350	5992
	228	SAND (2)	10'	127	.44	1776	15570	6060
	238	CLAY (1)	73'	124	.44	1941	18890	6793
	300					2040	20650	6948
	311	SAND (2)	23'	110	.44	2770	19770	6776
	334	BEDROCK				2701	19170	6850

- NOTES: 1. LOW STRAIN SHEAR MODULI AT VARIOUS DEPTHS ARE AVERAGE VALUES  
 2. SHEAR WAVE VELOCITY CALCULATED FROM  $V_s = (G/\rho)^{1/2}$   
 3. P WAVE VELOCITY CALCULATED FROM  $V_p = V_s \sqrt{1 + 2\mu}$





543

CHANGE

00  
2







 Palo Verde Nuclear Generating Station  
FSAR

SHEAR MODULUS VS. STRAIN - CLAY  
FIGURE 3.7-8





 Palo Verde Nuclear Generating Station  
FSAR

SHEAR MODULUS VS. STRAIN - SAND

FIGURE 3.7-9








FIGURE 4E-1  
 REQUIRED RESPONSE SPECTRUM (RRS) FOR THE MAJORITY OF NUCLEAR  
 POWER PLANT LOCATIONS IN THE CONTINENTAL UNITED STATES.

