

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8110090198 DOC. DATE: 81/10/01 NOTARIZED: YES DOCKET #  
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publ 05000528  
 STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Publ 05000529  
 STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publ 05000530

AUTH. NAME: AUTHOR AFFILIATION  
 VAN BRUNT, E. E. Arizona Public Service Co.  
 RECIP. NAME: RECIPIENT AFFILIATION  
 TEDESCO, R. L. Assistant Director for Licensing

SUBJECT: Forwards revised response to NRC Question 251.5 re  
 qualifications of personnel performing fracture toughness  
 tests. Response will be incorporated into future FSAR amend.

DISTRIBUTION CODE: B0015 COPIES RECEIVED: LTR    / ENCL:    SIZE:   3    
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: Standardized Plant, 1 cy: C Grimes 05000528  
 Standardized Plant, 1 cy: C Grimes 05000529  
 Standardized Plant, 1 cy: C Grimes 05000530


ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTTR	ENCL	ID CODE/NAME	LTTR	ENCL
ACTION:	A/D LICENSNG	1	0	LIC BR #3 BC	1	0
	LIC BR #3 LA	1	0	KERRIGAN, J. 04	1	1
INTERNAL:	ACCID EVAL BR26	1	1	AUX SYS BR 27	1	1
	CHEM ENG BR 11	1	1	CONT SYS BR 09	1	1
	CORE PERF BR 10	1	1	EFF TR SYS BR12	1	1
	ELD	1	0	EQUIP QUAL BR13	3	3
	GEOSCIENCES 28	2	2	HUM FACT ENG 40	1	1
	HYD/GEO BR 30	2	2	I&C SYS BR 16	1	1
	I&E 06	3	3	IE/EPDB 35	1	1
	IE/EPLB 36	3	3	LIC GUID BR 33	1	1
	LIC QUAL BR 32	1	1	MATL ENG BR 17	1	1
	MECH ENG BR 18	1	1	MPA	1	0
	OP LIC BR 34	1	1	POWER SYS BR 19	1	1
	PROC/TST REV 20	1	1	QA BR 21	1	1
	RAD ASSESS BR22	1	1	REAC SYS BR 23	1	1
	<u>REG FILE</u> 01	1	1	SIT ANAL BR 24	1	1
STRUCT ENG BR25	1	1				
EXTERNAL:	ACRS 41	16	16	FEMA-REP DIV 39	1	1
	LPDR 03	1	1	NRC PDR 02	1	1
	NSIC 05	1	1	NTIS	1	1

001 2/11

A4

*[Handwritten signature]*

TOTAL NUMBER OF COPIES REQUIRED: LTTR   63   ENCL   58    
  62     57



ARIZONA




PUBLIC SERVICE COMPANY

STA. \_\_\_\_\_

P.O. BOX 21666 - PHOENIX, ARIZONA 85036

October 1, 1981  
ANPP-19053-JMA/TFQ



Mr. R. L. Tedesco  
Assistant Director for Licensing  
Division of Licensing  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: Palo Verde Nuclear Generating Station  
(PVNGS) Units 1, 2 and 3  
Docket Nos. STN-50-528/529/530  
File: 81-056-026; G.1.10

Reference: (A) Letter from R. L. Tedesco, NRC, to E.E. Van Brunt, Jr.,  
dated August 13, 1981; Subject: Request for Addi-  
tional Information and Draft SER Inputs (Materials  
Engineering Branch) (MTEB).  
(B) Letter from E. E. Van Brunt, Jr., to R. L. Tedesco,  
dated September 16, 1981; ANPP-18929.

Dear Mr. Tedesco:

Attached is the revised response to NRC Question 251.5 for your use.  
Our original response was transmitted to you through Reference (B).  
This revision will be incorporated into the FSAR in a future amend-  
ment.

Please contact me if you have any further questions on this matter.

Very truly yours,

E. E. Van Brunt, Jr.  
APS Vice President,  
Nuclear Projects  
ANPP Project Director

BOO/  
s  
/ /

EEVBJr/TFQ/ma

Attachment/


cc: J. Kerrigan (w/a)  
P. L. Hourihan (w/a)  
A. C. Gehr (w/a)

8110090198 811001  
PDR ADDCK 05000528  
A PDR




STATE OF ARIZONA )  
 ) ss.  
COUNTY OF MARICOPA)

I, Edwin E. Van Brunt, Jr., represent that I am Vice President Nuclear Projects of Arizona Public Service Company, that the foregoing document has been signed by me on behalf of Arizona Public Service Company with full authority so to do, that I have read such document and know its contents, and that to the best of my knowledge and belief, the statements made therein are true.

  
Edwin E. Van Brunt, Jr.

Sworn to before me this 2<sup>ND</sup> day of October, 1981.

  
Notary Public

My Commission expires:

June 24, 1983

1950  
JULY 10 1950  
U.S. DEPARTMENT OF AGRICULTURE  
WASHINGTON, D. C.

NRC Question 251.5:

"Provide data on the qualifications of the personnel performing the fracture toughness tests to demonstrate compliance with Paragraph III.B.4 of Appendix G, 10 CFR Part 50."

Response:

The personnel performing the preservice Charpy and drop weight impact testing were qualified by schooling, training, and many years of experience. Their qualification to perform work was certified by qualified supervisory personnel. Records of the certification of personnel are maintained and available for review at C-E's Chattanooga facility.

Individuals performing inservice fracture toughness test shall be qualified by training and experience and shall have demonstrated competency to perform the tests in accordance with written procedures and ASME Code, Section III, Subarticle NB-2300, Fracture Toughness Requirements for Materials. The recommendations for qualification of nuclear power plant inspection, examination, and testing personnel that are included in ANSI N45.2.6 -1973 are generally acceptable and provide an adequate basis for complying with Paragraph III.B.4 of Appendix G, 10 CFR Part 50.