

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION# NBR: 8110230247 DOC. DATE: 81/10/20 NOTARIZED: YES DOCKET #
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Public 05000528
 STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Public 05000529
 STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Public 05000530

AUTH. NAME: AUTHOR AFFILIATION
 VAN BRUNT, E. E. Arizona Public Service Co.
 RECIP. NAME: RECIPIENT AFFILIATION
 TEDESCO, R. L. Assistant Director for Licensing

SUBJECT: Forwards: matl test repts reviewed by NRC during 810723-24
 site visit. Suomits results of review of containment pressure
 boundary matls w/low metal svc temp in compliance w/GDC 51.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 53
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: Standardized Plant: 1 cy: C: Grimes 05000528
 Standardized Plant: 1 cy: C: Grimes 05000529
 Standardized Plant: 1 cy: C: Grimes 05000530

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL	ID CODE/NAME	LTR	ENCL
ACTION:	A/D LICENSNG	1	0	LIC BR #3 BC	1	0
	LIC BR #3 LA	1	0	KERRIGAN, J. 01	1	1
INTERNAL:	ACCID. EMAL BR26	1	1	AUX SYS BR 27	1	1
	CHEM ENG. BR 11	1	1	CONTI SYS BR 09	1	1
	CORE. PERF. BR 10	1	1	EFF TR SYS BR12	1	1
	ELDI	1	0	EQUIP QUAL BR13	3	3
	GEOSCIENCES 28	2	2	HUM FACT. ENG 40	1	1
	HYD/GEO BR 30	2	2	I&C SYS BR 16	1	1
	I&E 06	3	3	IE/EPDB 35	1	1
	IEVEPL 36	3	3	LIC GUID BR 33	1	1
	LIC. QUAL BR 32	1	1	MATL ENG BR 17	1	1
	MECH ENG BR 18	1	1	MPA	1	0
	OP LIC BR 34	1	1	POWER SYS BR 19	1	1
	PROC/TST REV 20	1	1	QA BR 21	1	1
	RADI ASSESS BR22	1	1	REAC SYS BR 23	1	1
	REG. FILE 04	1	1	SIT ANALI BR 24	1	1
STRUCT. ENG BR25	1	1				
EXTERNAL:	ACRS 41	16	16	BNL (AMDTS ONLY)	1	1
	FEMA-REP DIV 39	1	1	LPDR 03	1	1
	NRCI PDRI 02	1	1	NSIC 05	1	1
	NTIS	1	1			

OCT 28 1981

MA4

64

59

TOTAL NUMBER OF COPIES REQUIRED: LTR 64 ENCL 59

THE UNITED STATES OF AMERICA
DEPARTMENT OF THE INTERIOR
BUREAU OF LAND MANAGEMENT

WATER RESOURCES DIVISION
SALT WATER IRRIGATION
SALT WATER IRRIGATION
SALT WATER IRRIGATION

WATER RESOURCES DIVISION
SALT WATER IRRIGATION
SALT WATER IRRIGATION
SALT WATER IRRIGATION

WATER RESOURCES DIVISION
SALT WATER IRRIGATION
SALT WATER IRRIGATION
SALT WATER IRRIGATION

WATER RESOURCES DIVISION
SALT WATER IRRIGATION
SALT WATER IRRIGATION
SALT WATER IRRIGATION

WATER RESOURCES DIVISION
SALT WATER IRRIGATION
SALT WATER IRRIGATION
SALT WATER IRRIGATION

WATER RESOURCES DIVISION
SALT WATER IRRIGATION
SALT WATER IRRIGATION
SALT WATER IRRIGATION

WATER RESOURCES DIVISION
SALT WATER IRRIGATION
SALT WATER IRRIGATION
SALT WATER IRRIGATION

WATER RESOURCES DIVISION
SALT WATER IRRIGATION
SALT WATER IRRIGATION
SALT WATER IRRIGATION

WATER RESOURCES DIVISION
SALT WATER IRRIGATION
SALT WATER IRRIGATION
SALT WATER IRRIGATION

WATER RESOURCES DIVISION
SALT WATER IRRIGATION
SALT WATER IRRIGATION
SALT WATER IRRIGATION

WATER RESOURCES DIVISION
SALT WATER IRRIGATION
SALT WATER IRRIGATION
SALT WATER IRRIGATION

ARIZONA



PUBLIC SERVICE COMPANY

STA. _____

P.O. BOX 21666 - PHOENIX, ARIZONA 85036

October 20, 1981
ANPP-19195 - JMA/WFQ

Mr. R. L. Tedesco
Assistant Director for Licensing
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555



Subject: Palo Verde Generating Station
(PVNGS) Units 1, 2 and 3
Docket Nos. STN-50-528/529/530
File: 81-056-026; G.1.10

Reference: Letter from R. L. Tedesco, NRC, to E. E. Van Brunt, Jr.
dated July 14, 1981--Subject: GDC 51 Compliance

Dear Mr. Tedesco:

One copy of the material test reports reviewed by NRC at the PVNGS site visit on July 23-24, 1981 (GDC 51) is provided as Attachment 1. In addition, the following information is submitted in response to our compliance with GDC 51 as discussed at the July 23-24, 1981 meeting.

As a result of NRC's review of PVNGS containment pressure boundary materials, the following list of lowest metal service temperatures (LMST) was generated:

Personnel Air Lock	+50° F
Penetrations	+30° F
Flued Head (Main Steam and Main Feed)	+53° F
Main Steam Piping	+40° F
Main Feed Piping	+30° F
Main Steam Isolation Valve	+73° F
Main Feed Isolation Valve	+70° F

For PVNGS the environment inside the containment for materials which are subjected to the fracture toughness requirements of ASME B & PV Code, Section III, Sub-section NE-2331 will not be lower than 50° F.

This is based on the following conservative assumptions:

- a) The plant is at the end of a refueling outage.
- b) The reactor coolant pumps are not in operation.
- c) The containment purge system is in operation.

8110230247 811020
PDR ADDCK 05000528
A PDR

*Bool
S.11*



SECRET

SECRET

Mr. R. L. Tedesco
ANPP-19195 - JMA/WFO
October 20, 1981
Page 2

- d) The minimum outdoor ambient temperature is 28° F.
- e) The outdoor wind velocity is 15 mph.
- f) The containment normal heating coils are available for use to ensure that the minimum ambient temperature is 50° F inside the containment.

Similarly, the minimum ambient temperature inside the Auxiliary Building is maintained at 50° F with the use of duct heaters in the HVAC system.

The following will address the items which have been identified by NRC in the proceeding list:

1. The Personnel Air Lock is located inside the Auxiliary Building at EL. 143'-10", therefore the minimum temperature of 50° F can be met.
2. Even though NRC has stipulated a minimum temperature of 30° F for Penetrations, we believe that the minimum outside temperature of 28° F for a short duration should not affect the penetration materials since the inside temperature is at least 50° F and we therefore believe a short term deviation of less than 2° F should be acceptable. Additional information is listed in the attached table.
3. The Flued Heads for Main Steam and Main Feedwater Piping are inside the containment. We believe the minimum temperature of 50° F inside the containment should be acceptable since the remaining portion of each flue head is partly embedded in concrete, partly sheltered in a recessed area, and therefore is not fully exposed to the outside environmental temperature. Additional information is listed in the attached table.
4. For Main Steam Piping, Main Feedwater Piping, Main Steam Isolation Valves, and Main Feedwater Isolation Valves which have minimum stipulated temperatures of 40° F, 30° F, 73° F, and 70° F respectively, we do not foresee any difficulty in meeting these temperatures if the pipe and valve insulations are left intact and undisturbed during plant shutdown. Should any section of the insulation be removed for component inspection or repair when the pressure-retaining capability is required, then portable space heaters in conjunction with temporary shelters will be used to maintain the required environmental

CONFIDENTIAL - SECURITY INFORMATION

CONFIDENTIAL - SECURITY INFORMATION


Mr. R. L. Tedesco

ANPP-19195 - JMA/WFO

October 20, 1981

Page 3

temperatures stipulated by Mr. Halapatz. For Main Steam and Main Feedwater Isolation Valves, additional information is listed on the attached table.



E. E. Van Brunt, Jr.
APS Vice President,
Nuclear Projects
ANPP Project Director

EEVBJr/WFQ/sam
Attachments

cc: J. Kerrigan (NRC) w/a
J. Halapatz (NRC MTEB) w/a
P. Hourihan w/a
A. Gehr w/a

OF THE ...

...

STATE OF ARIZONA)
) ss.
COUNTY OF MARICOPA)

I, Edwin E. Van Brunt, Jr., represent that I am Vice President Nuclear Projects of Arizona Public Service Company, that the foregoing document has been signed by me on behalf of Arizona Public Service Company with full authority so to do, that I have read such document and know its contents, and that to the best of my knowledge and belief, the statements made therein are true.

Edwin E. Van Brunt, Jr.
Edwin E. Van Brunt, Jr.


Sworn to before me this 20th day of October, 1981

Connie Lou Armstrong
Notary Public

My Commission expires:

June 24, 1983

ATTACHMENT 1



EQUIPMENT ACCESS HATCH COVER

LUKENS STEEL COMPANY
COALDSVILLE, PA. 15320

DATE: 1/25/77

FILE NO. A205-02-01

TEST CERTIFICATE

MILL ORDER NO.

CUSTOMER P.O.

73135 1

25131302

12277 JW

CONSIGNEE:

KAISER STEEL CORP.
PLANT #1
13032 SLOVER AVE.
KAISER, CA

KAISER STEEL CORP.

FABR. DIV.

PUR. AGENT

PO. BOX 95

FONTANA, CALIF. 92335

MATERIAL HAS BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATION(S)

SA-516 GR. 70 ASME CODE SECTION II & III SUB NE 1974 EDITION THRU SUMMER 1974 ADDENDA

N-1160 8/4/78

BEND TEST

0-K HOMOGENEITY TEST

CHEMICAL ANALYSIS

MILT NO.	C	MN	P	S	Cu	SI	NI	CR	MO	V	TI	AL	B	GRAIN SIZE
03849	.26	1.05	.012	.023		.23								7-8

* 24/25/78

MURDOCK INC.

LOT # A23593-N

JOB # UOL 3-1662-01

DATE 5-24-77 (2/2/8)

FC 3351-03-09

PHYSICAL PROPERTIES 2PCS 4 1/2 X 9 3/4 X 137 1/4 R X 194 1/8

MILT NO	SLAB NO	YIELD PSI X100	TENSILE PSI X100	% ELONG. IN 2"	% R.A.	IMPACTS			FRACTURE APPEARANCE	DESCRIPTION
						BHN XXX LOC	V	O F		
03849	2	515	803	30		T	40	38	40	40-40-40 1- 4-1/2 X 44 X 240
		498	784	29		L	96	94	90	
LATERAL EXPANSION IN INCHES										
						T	.038	.035	.035	
						L	.084	.089	.091	

NUCLEAR

PLATE AND TESTS HEATED TO 1625 F. / 1675 F., HELD 1 1/2 HR. PER INCH MIN., AND WATER QUENCHED, THEN TEMPERED 1220 F., HELD 1 1/2 HR. PER INCH MIN., AND WATER QUENCHED.

STRESS RELIEVED BY HEATING WITHIN A RATE OF 100 F. PER HR. TO 100 F. / 200 F., HELD 30 HRS. AND FURNACE COOLED WITHIN A RATE OF 100 F. PER HR. TO 800 F.

M.T.R. REVIEWED AND ACCEPTED


APPROVE
3-4-77
2/23/78

13

We hereby certify the above information is correct.

Reviewed by
Paul Abner

SUPERVISOR



EQUIPMENT ACCESS HATCH COVER

LUKENS STEEL COMPANY

COATESVILLE, PA. 19320

TEST CERTIFICATE

DATE: 2/03/77 FILE NO. 4205-02-01
 CONSIGNEE: KAISER STEEL CORP.
 PLANT #1
 13032 SLOVER AVE.
 KAISER, CALIF.

BUYER: KAISER STEEL CORP.
 FABR. DIV.
 PUR. AGENT
 P.O. BOX 95
 FONTANA, CALIF. 92335

MILL ORDER NO. 73135 1
 CUSTOMER P.O. 25131302
 2277 DD

MATERIAL HAS BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATION(S).

SA-516 GR. 70 ASME CODE SECT. II & III SUB NE 1974 EDITION THRU SUMMER 1974 ADDENDA
 N-1160 8/4/78

BEND TEST D.K. HOMOGENEITY TEST

CHEMICAL ANALYSIS

MELT NO.	C	MN	P	S	CU	SI	NI	CR	MO	V	TI	AL	B	GRAIN SIZE
03950	.25	.98	.007	.023		.25								Y-8

MURDOCK INC.
 LOT # A23593-3
 JOB # 11013-1663-251
 DATE 5-29-77

SA OF U
 2/2/77

PHYSICAL PROPERTIES *FL 355-071PC 4 1/2 x 9 1/2 x 137 1/2*

MELT NO.	SLAB NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG. IN 2"	% R.A.	BHN	IMPACTS			FRACTURE APPEARANCE	DESCRIPTION	
							U	O	F			
03950	2B	518 530	804 810	30 30			T	26	28	28	30-30-30 60-60-60	1- 4-1/2 X 44 X 240
							L	66	64	58		
							LATERAL EXPANSION IN INCHES					
							T	.022	.020	.024		
							L	.052	.061	.062		

SPC & QAE

NUCLEAR

RECEIVED
 2/4/78
 3/23/78


M.T.R. REVIEWED AND ACCEPTED

19 FEB 07 1977

PLATE AND TESTS HEATED TO 1625 F./1675 F., HELD 1/2 HR. PER INCH MIN. AND WATER QUENCHED, THEN TEMPERED 1220 F., HELD 1/2 HR. PER INCH MIN. AND WATER QUENCHED.
 Tests stress relieved by heating within a rate of 100°F. per hr. to 1100°F./1200°F., held 30 hrs. and furnace cooled within a rate of 100°F. per hr. to 800°F.

We hereby cert. the above information is correct.

[Signature]



BODY RING HATCH COVER

LUKENS STEEL COMPANY
COATESVILLE, PA. 19320

DATE: 2/15/77 FILE NO. 15-02-01

KAISER STEEL CORP.
FABR. DIV.
PUR. AGENT
P.O. BOX 95
FONTANA, CALIF. 92335

TEST CERTIFICATE

MILL ORDER NO. 73135 3
CUSTOMER P.O. 251.31302
21477 JW

CONSIGNEE:
KAISER STEEL CORP.
KAISER, CA

THIS MATERIAL HAS BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATION(S):

SA-516 GR. 70 ASME CODE SECTION II & III SUB NE 1974 EDITION THRU SUMMER 1974 ADDENDA
N-1160 8/4/78

BEND TEST O.K. HOMOGENEITY TEST

CHEMICAL ANALYSIS

MELT NO.	C	Mn	P	S	Cu	Si	Ni	Cr	Mo	V	Ti	Al	B	GRAIN SIZE
C7606	.25	1.06	.006	.016		.21								7-8

MURDOCK INC.

LOT # A22876-1

JOB # WOL J-1663-01

DATE 4-13-77

4-14-77
★
MURDOCK

PHYSICAL PROPERTIES

IPC EC340-04 L213

MELT NO.	SLAB NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG. IN 2"	% R.A.	IMPACTS U O F	FRACTURE APPEARANCE	DESCRIPTION
C7606	A PC10	490	750	29		LOC. T 28 26 30 L 38 42 40	% SHEAR 30-30-30 40-40-40	1- 3-1/2 X 70 X 238
						LATERAL EXPANSION IN INCHES T .027 .022 .025 L .036 .039 .034		

M.T.R. REVIEWED AND ACCEPTED

29 FEB 22 1977

NUCLEAR

BECHTEL 844 3/23/78

IT VCS. 27189

R 335


PLATE AND TESTS NORM. 1625 F./1675 F., HELD 1/2 HR. PER INCH MIN. AND AIR COOLED.

TESTS STRESS RELIEVED BY HEATING WITHIN A RATE OF 100 F. PER HR. TO 1100 F./1200 F., HELD 30 HRS. AND FURNACE COOLED WITHIN A RATE OF 100 F. PER HR. TO 800 F.

KSC JOB: 13131
ITEM: EC340-04

We hereby certify the above information is correct.

SUPERVISOR-TESTING J. P. Dine



5
PURCHASER:

BODY RING HATCH COVER

LUKENS STEEL COMPANY

COATESVILLE, PA. 19320

TEST CERTIFICATE

DATE: 1/13/77

FILE NO. 4205-02-01

KAISER STEEL CORP.
FABR. DIV.
PUR. AGENT
P.O. BOX 95
FONTANA, CALIF. 92335

MILL ORDER NO.

CUSTOMER P.O.

73135 3

25131302

11277 WM

CONSIGNEE:

KAISER STEEL CORP.
PLANT #1
13032 SLOVER AVENUE
KAISER, CALIF.

THIS MATERIAL HAS BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATION(S)

SA-516 GR. 70 ASME CODE SECT II & III SUB NE 1974 EDITION THRU SUMMER 1974 ADDENDA
N-1160 8/4/78

BEND TEST
O.K. HOMOGENEITY TEST

CHEMICAL ANALYSIS

MELT NO.	C	MN	P	S	CU	SI	NI	CR	MO	V	TI	AL	B	GRAIN SIZE
D3968	.23	1.04	.011	.004										7-8

MURDOCK INC.

LOT. # A22976-1

JOB # WOL 3-1663-01

DATE 4-13-77

4-14-77

PHYSICAL PROPERTIES IPC EC390-05

MELT NO.	SLAB. NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG. IN 2"	% R.A.	BHN	IMPACTS			FRACTURE APPEARANCE	DESCRIPTION
							V	O	F		
D3968	3 R L	458	740	32			T 56	58	58	50-50-50	2- 3-1/2 X 70 X 238
							L 72	66	68	70-70-70	
							LATERAL EXPANSION IN INCHES				
							.050	.052	.053		
							.062	.060	.068		

M.T.R. REVIEWED AND ACCEPTED

5 JAN 22 1977

NUCLEAR

R BECHTEL 344 4/23/77

LT VRS. 27189


XXXX PLATES AND TESTS NORM. 1625 F./1675 F., HELD 1/2 HR. PER INCH MN. AND AIR COOLED.
TESTS STRESS RELIEVED BY HEATING WITHIN A RATE OF 100 F. PER HR. TO 1100 F./1200 F., HELD 30 HRS. AND FURNACE COOLED WITHIN A RATE OF 100 F. PER HR. TO 800 F.

KSC JOB: 1313
ITEM: EC390-05

We hereby certify the above information is correct.

A. H. Gline
SUPERVISOR

27189
1978 NO.



BODY RING HATCH COVER

PURCHASER:

KAISER STEEL CORP.
FABR. DIV.
PUR. AGENT
P.O. BOX 95
FONTANA, CALIF. 92335

LUKENS STEEL COMPANY
COATESVILLE, PA. 19320
TEST CERTIFICATE

DATE: 1/25/77

FILE NO. 4205-02-01

CONSIGNEE:

KAISER STEEL CORP.
KAISER, CA

MILL ORDER NO.

CUSTOMER P.O.

73135 3

25131302

12277 JW

MATERIAL HAS BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATION(S):

SA-516 GR. 70 ASME CODE SECTION II & III SUB NE 1974 EDITION THRU SUMMER 1974 ADDENDA
N-1160 8/4/78

BEND TEST

D.K. HOMOGENEITY TEST

CHEMICAL ANALYSIS

MELT NO.	C	Mn	P	S	Cu	Si	Ni	Cr	Mo	V	Ti	Al	B	GRAIN SIZE
C7606	.25	1.06	.006	.016		.21								7-8

MURDOCK INC.

LOT # A22976-1

JOB # WOL3-1663-01

DATE 4-13-77

☆
4-14-77

PHYSICAL PROPERTIES

104 EC340 - 01

1313

MELT NO.	SLAB NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG. IN 2"	% R.A.	BHN XXX	IMPACTS			FRACTURE APPEARANCE	DESCRIPTION						
							V	O	F								
C7606	5	477	743	24		LOC.	T	22	20	22	20-20-20	2- 3-1/2 X 70 X 238					
							L	28	30	30	30-30-30						
							LATERAL EXPANSION IN INCHES						T	.017	.019	.018	
							L	.026	.025	.027							
C7606	3	505	780	30		LOC.	T	30	30	28	30-30-30	1- "					
							L	42	50	46	40-40-40						
							LATERAL EXPANSION IN INCHES						T	.022	.026	.025	
							L	.042	.045	.038							

NUCLEAR

M.T.R. REVIEWED AND ACCEPTED

14 FEB 01 1977

PLATES AND TESTS NORM., 1625 F./1675 F., HELD 1/2 HR. PER INCH MIN., AND AIR COOLED.

TESTS STRESS RELIEVED BY HEATING WITHIN A RATE OF 100 F. PER HR. TO 1100 F./1200 F., HELD 30 HRS. AND FURNACE COOLED WITHIN A RATE OF 100 F. PER HR. TO 800 F.

We hereby certify the above information is correct.

KSC JOB: 1313

SUPERVISOR-TESTING

F. J. Line

IT INS.
74889
R3351



PURCHASED:

PERSONNEL AIR LOCKS

LUKENS STEEL COMPANY

COATESVILLE, PA. 19320

DATE: 2/15/77

FILE NO: 7-02-01

KAISER STEEL CORP.

FABR. DIV.

PUR. AGENT

P.O. BOX 95

FONTANA, CALIF. 92335

TEST CERTIFICATE

MILL ORDER NO.

CUSTOMER P.O.

73135 2

25131302

21477 JW

CONSIGNEE:

KAISER STEEL CORP.
KAISER, CA

RECEIVED
5-14
7/10/78

MATERIAL HAS BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATION(S).

SA-516 GR. 70 ASME CODE SECTION II & III SUB NE 1974 EDITION THRU SUMMER 1974 ADDENDA

N-1160 8/4/70

BEND TEST

A.K. HOMOGENEITY TEST

CHEMICAL ANALYSIS

MELT NO.	C	MN	P	S	CU	SI	NI	CR	MO	V	TI	AL	B	GRAIN SIZE
A5599	.25	1.03	.007	.022		.25								

JUL 20 1978
M/JW 02

MURDOCK INC.
 LOT # A 27-344-1
 JOB # WOL 3-1665-01
 DATE 4-8-7
 2 PCS FROM 23
 LOT REMOVED

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG IN 2"	% R.A.	LUC	IMPACTS			FRACTURE APPEARANCE	DESCRIPTION
							V	D	F		
A5599	1	533	922	28			22	20	22	20-20-20	2- 4 X 56 X 330
							32	32	30	20-20-20	
						LATERAL EXPANSION IN INCHES					
						T	.017	.015	.018		
						L	.025	.027	.027		

NUCLEAR

PLATES AND TESTS NORM. 1625 F./1675 F., HELD 1/2 HR. PER INCH MIN., AND AIR COOLED.

TESTS STRESS RELIEVED BY HEATING WITHIN A RATE OF 100 F. PER HR. TO 1100 F./1200 F., HELD 30 MINS. AND FURNACE COOLED WITHIN A RATE OF 100 F. PER HR. TO 600 F.


LL-017
NOV 1977
METS 11716
WINTER 1977/4/24

We hereby certify the above information is correct.

A.I. REVIEW

[Signature]
4-6-78

SUPERVISOR-TESTING



PERSONNEL AIR LOCKS

LUKENS STEEL COMPANY
COATESVILLE, PA. 19320

DATE: 2/15/77 FILE NO: 5-02-01

TEST CERTIFICATE

Kaiser Steel Corp.
FABR. DIV.
PUR. AGENT
P.O. BOX 95
FONTANA, CALIF. 92335

MILL ORDER NO. 73135 2
CUSTOMER P.O. 25131.302
21477 JU

CONSIGNEE: KAISER STEEL CORP.
KAISER, CA

RECEIVED
S.A.A.
7/10/77

MATERIAL HAS BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATION(S):

SA-516 GR. 70 ASME CODE SECTION II & III SUB NE 1974 EDITION THRU SUMMER 1974 ADDENDA
N-1160. 8/4/78

SEND TEST D.K. HOMOGENEITY TEST

MEETS 1974 Ed. WINTEC 1974 Add.

CHEMICAL ANALYSIS

MELT NO.	C	MN	P	S	CU	SI	NI	CR	MO	V	TI	AL	B	GRAIN SIZE
85599	.25	1.03	.007	.022		.25								

MURDOCK INC. 7-8
LOT # A228-12
JOB # WOL 3-1665-01
DATE 4-8-7 (M) 8

16 Pcs ITEM 23

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG. IN 2"	% R.A.	IMPACTS V O F	FRACTURE APPEARANCE	DESCRIPTION
85599	1	533	822	28		LOC T 22 20 22 L 32 32 30	20-20-20 20-20-20	2- 4 X 56 X 330
						LATERAL EXPANSION IN INCHES		
						T .017 .015 .018		
						L .025 .027 .027		

M.T.R. REVIEWED AND ACCEPTED (Signature)
28 FEB 22 1977

NUCLEAR

PLATES AND TESTS NORM. 1625 F./1675 F. HELD 1/2 HR. PER INCH MIN., AND AIR COOLED.

TESTS STRESS RELIEVED BY HEATING WITHIN A RATE OF 100 F. PER HR. TO 1200 F./1200 F., HELD 30 HRS. AND FURNACE COOLED WITHIN A RATE OF 100 F. PER HR. TO 800 F.

We hereby certify the above information is correct.

A.I. REVIEW (Signature)
11-6-78

SUPERVISOR-TESTING


(Signature)

JUL 2 1977
MURDOCK

K.F. 5

TIME 4:12 PM 2/23/77

36541



United States Steel Corporation

01.000.0172

PENETRATION #10

Test Report

AP-414



CONTRACT NO.		P. O. DATE	PURCHASE ORDER NO.	
			NA-336-NUCLEAR 12/11/76	
SHIPPER'S NO.		MILL ORDER NO.	INVOICE NO.	
GARY WORKS GARY, INDIANA 45402		421139 3/31/77	AME1175 154-26721	
VEHICLE IDENTITY		UPC 0258		
SOUTHERN BOILER & TANK WKS INC P O BOX 7274 MEMPHIS TENN 38107		SOUTHERN BOILER & TANK WKS INC 1199 THOMAS MEMPHIS TENN		S H I P T O
WE HEREBY CERTIFY THAT THE CHEMICAL ANALYSES AND/OR TEST RESULTS SHOWN IN THIS REPORT ARE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.				BY: <i>[Signature]</i> SIGNATURE
				MGR QUALITY ASSURANCE
				DATE 4-20-77

PLATE CARBON ASME SA515-74A WINTER 74 ADDENDA GRADE
TO PRESSURE VESSEL QUALITY NORMALIZE PLATE STRESS
RELIEVE TEST SPECIMENS ONLY AT 1100/1200 DEG F FOR
1 HOUR PER INCH IN ACCORDANCE WITH NE-4620 QUALITY
USED TO INSP & EXPECTING BY SS/T AND/OR BATCHEL CORP CERT TO NE-2
130 T/PS TO SLD TO ATTN PURCH MGR AND GARY WORKS MUST CERTIFY MATL
PRODUCED IN ACCORDANCE WITH NA-3700

[Handwritten initials]
4/17/77

THICKNESS OR SECTION	MATERIAL DESCRIPTION		QUAN-TITY	WEIGHT	HEAT NO.	TEST OR PIECE IDENTITY	YIELD PT. P.S.	TENSILE STR. P.S.	ELONGATION %		% RED. OF AREA	BI...
	WIDTH, DIA. OR FL. WD.	LENGTH							IN 8"	IN 2"		
1 1/4	100.0	308	3	10919	Y52333	1 W3	#54700	75600		33.0		OK
<p>FULL SIZE CHARPY IMPACTS: FT LBS 50-47-47 % SHEAR 20-25-25 LATERAL EXPANSION MILS 39-45-41</p> <p>LATERAL EXPANSION AND PERCENT SHEAR FOR INFORMATION ONLY.</p>												
<p>*ASSURANCE CERT REQ CHARPY V-NOTCH LONGITUDINAL IMPACT TESTS EACH PLATE AS HEAT TREATED 20/15 FT LBS AT 0 DEG F MATERIAL IN ACCORDANCE WITH ASME SECTION 3 SURFER 75 ADDENDA CLASS MC SUB SECTION NE TO SUB ARTICLES NE-2100 NE-2200 C-2300 NE-2400 NE-2500 NE-2500 NE-2700 TO THOSE PARAGRAPHS APPLICABLE TO PLATE PRODUCTS</p>												

BATCHEL P. O. / SPEC. NO.
16407-13-CM-52
DOCUMENT CATEGORY NO. *4/17/77*

NO	TYPE	C	MN	P	S.	SI	CU	NI	CR	MO	SN	AL	N	V	B	TI	CB	*SUL-0.5%
333	HEAT	24	109	009	019	25												68

AV GR SIZ 08
BECITEL
313

RETENTION TIME 27 YRS

R1810

Test Report

SS) PENETRATION # 1 & 2

AP-414

SHIP, CONTRACT NO.	P. O. DATE	PURCHASE ORDER NO.	
GARY WORKS GARY, INDIANA 46402	12/26/77	NA-376-NUCLEAR	12/12/77
SOUTHERN BOILER & TANK WORKS INC P O BOX 7274 MEMPHIS TENN 38107	SHIP TO	MILL ORDER NO.	INVOICE NO.
	381-1289	2451175	124467579
SOUTHERN BOILER & TANK WORKS INC 1109 THOMAS MEMPHIS TENN			

WE HEREBY CERTIFY THAT THE CHEMICAL ANALYSES AND/OR TEST RESULTS SHOWN IN THIS REPORT ARE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.

BY: *[Signature]*
SIGNATURE

DATE 5-13-77

HGR QUALITY ASSURANCE

NUCLEAR

PLATE CARBON ASME SA516-74A WINTER 74 ADDENDA GRADE 70 PRESSURE VESSEL QUALITY NORMALIZE PLATE STRESS RELIEVE TEST SPECIMENS ONLY AT 1100/1200 DEG F FOR 1 HOUR PER INCH IN ACCORDANCE WITH NE-4620 QUALITY +SEE BELOW


EXPEDITING BY SB/T AND/OR BECHTEL CORP CERT TO NE-2 100 T/SS TO SLD TO ATTN PURCH MGR AND GARY WORKS MUST CERTIFY MATL PRODUCED IN ACCORDANCE WITH NA-3760

ITEM NO.	MATERIAL DESCRIPTION			QUANTITY	WEIGHT	HEAT NO.	TEST OR PIECE IDENTITY	YIELD ST. PSI	TENSILE STR. PSI	ELONGATION %		% RED. OF AREA
	THICKNESS OR SECTION	WIDTH DIA. OR FT. WT.	LENGTH							IN 8"	IN 2"	
5	5/8	109.0	346	1	17320	Y52333 ✓	3 W1	*52900	78900		30.0	
FULL SIZE CHARPY IMPACTS FT LBS - 42-45-42 % SHEAR 15-20-15 LATERAL EXPANSION MILS 41-39-40 LATERAL EXPANSION AND PERCENT SHEAR FOR INFORMATION ONLY. ASSURANCE CERT REQ CHARPY V-NOTCH LONGITUDINAL IMPACT TESTS EACH PLATE AS HEAT TREATED 20/15 FT LBS AT 0 DEG F - CLASS MC SUB SECTION NE TO SUB ARTICLES NE-2100 - NE-2200 - NE-2300 - NE-2400 - NE-2500 - NE-2600 - NE-2700 TO THOSE PARAGRAPHS APPLICABLE TO PLATE PRODUCTS												
											*YSEUL 0.5%	

BECHTEL P. O. SPEC. NO.
10407 13-CM-157
DOCUMENT CATEGORY NO. 6/17.1

HEAT NO.	TYPE	C	MN	P	S	SI	CU	NI	CR	MO	SN	AL	N	V	B	TI	CB	CO
Y52333	HEAT	24	108	005	019	25												

AVG GR SIZ 08
BECHTEL
31



FLUED HEAD PENETRATION #1

STEEL

RETENTION TIME 1/2 YRS.

FORGE DIVISION

8531 E. MARGINAL WAY SOUTH • PHONE 752-1100 (AREA 235)

MAILING ADDRESS: P. O. BOX 24026

SEATTLE, WASHINGTON 98124

R485⁰

CERTIFIED TEST REPORT

CUSTOMER

AMETEK/STRAZA
P O BOX 668
EL CAJON, CA 92021

Date 12-23-76
Customer's Order No. N92757-4
Our Invoice No. 7385 FS
Contract No.

ATT: C B HENDRIKSEN

HEAT NO.	MATERIAL	DESCRIPTION	SPECS.
17296/ 20091	1027	1 PENETRATION FORGING ROUGH TURNED PER DWG #7-050054-2 REV B 7-050054-2 FORGING SN F-3 7-050054-1 PEN #1 SITE 1 SN 223	ASME SA 350 LF 2 - ASME SECT III NC 2300 - ASME B & PV CODE SECT III, 1974 ED.

CHEMICAL ANALYSIS INCL ADDENDA THRU SUMMER 1975 FOR CLASS 2

HEAT NO.	MATERIAL	C	MN	P	S	SI	NI	CR	MO	V	CU	SN	OTHER
17296/ 20091	1027	.28	1.33	.011	.025	.20							

HARDENABILITY - ROCKWELL "C" IN 1/16" OF AN INCH

HEAT NO.	MATERIAL	1	2	3	4	5	6	8	10	12	14	16	20	24	28	32	HARDNESS EQUIVALENT

MECHANICAL PROPERTIES

TEST NO.	HEAT NO.	MATERIAL	YIELD (LBS./SQ. IN.)	TENSILE (LBS./SQ. IN.)	ELONG. (IN./2 IN.)	RED. OF AREA (%)	CHARPY V 1/2" (FT-LBS)	BEND	MACRO	IMPACT
LMW 0°	17296/ 20091	1027	56,500	76,500	34.0	70.1	CUP			45-48-52 [#] 35-35-40 41-46-50
LMW 180°	17296/ 20091	1027								80-94-75 [#] 50-60-50 72-73-72

REMARKS:	NORMALIZE 1600 DEG F 31 HRS ✓ TEMPER 1200 30 ✓	INSPECTOR DPC & OAE 368 5/5/77
----------	---	---

WE CERTIFY THAT THE MATERIAL COVERED BY THIS REPORT HAS BEEN INSPECTED & TESTED IN ACCORDANCE WITH THE APPLICABLE REQUIREMENTS DESCRIBED HEREIN AND TEST REPORTS ARE ON FILE SUBJECT TO EXAMINATION

SUBSCRIBED AND SWORN TO BEFORE ME THIS _____ DAY OF _____ 19____

EARLE M. JORGENSEN CO.



PENETRATION #21

STANDARD SWORN TEST REPORT
TUBULAR PRODUCTS

RETENTION TIME 2 YRS

1-27-76 DATE

MATERIAL Seamless Pressure Pipe

GRADE 6 ASME SA333

TREATMENT Normalized 1600°F for 91 min. (Aircooled)

6 ASTM A333

CUSTOMER NAME Capitol Pipe and Steel Products, Inc.

CUSTOMER'S ORDER NO. 75908-00

CUSTOMER ADDRESS

U.S. STEEL ORDER NO. KC 10365

CUSTOMER STATE

INVOICE NO. 356-00231

Longitudinal tensile tests

SIZE O.D.	WALL THICKNESS	HEAT NUMBER	HYDRO. TEST PRESSURE MIN. P.S.I.	MECHANICAL PROPERTIES			CHEMICAL ANALYSIS (%)					
				YIELD STRENGTH P.S.I.	TENSILE STRENGTH P.S.I.	ELONG. IN 2" <u>1 1/2</u>	C	Mn	P	S	Si	Mo
4669 24"	.688	A04102	1200	47870	68450	52.5	.15	1.19	.011	.018	.16	check
		A04102	1200	51370	70000	49.0	.15	1.19	.011	.018	.16	check
							.17	1.15	.012	.019	.16	ladle
Flattening tests satisfactory												
Full size longitudinal C.V.N. impacts at minus - 50°F												
		A04102										
					Ft. Lbs.	% Shear	Lat. Exp.					
					54	48	.048					
					60	51	.055					
					61	51	.055					

D. M. ...
8-31-74

PK
8/27/74

BECHTEL 313

BPC & QAE

Southern Boiler & Tank
P.O.# NA-014
S.O.# AN-6232-A
Ch# H-80290
Item# 12

BECHTEL-P: O./SPEC. NO. 10407-1 - CM - 152
DOCUMENT CATEGORY NO. 8/1/74


PUBLISHED BY
NOTAR PUBLIC
January 19 76

BEING DULY SWORN ACCORDING TO
LAW, DEPOSES AND SAYS THAT THE FIGURES SET FORTH ABOVE ARE COR-
RECT AS CONTAINED IN THE RECORDS OF THE COMPANY

Geo. J. ...

A. Belkin

Chief Metallurgist



FLUED HEAD PENETRATION #46

EARLE M. JORGENSEN CO.

LOS ANGELES DELIVERY RECEIPT

528

TEST REPORT

MARR. NO. 36194

GENERAL FORGE DIVISION

10650 SO. ALAMEDA STREET - PHONE 567-1122 (Area Code 213) MAILING ADDRESS, P.O. Box 34633 LOS ANGELES, CALIFORNIA 90054

(b) - P

INVOICE NO.

SHIPPED 10-11-78

TESTED BY DEV

7429 FL

CUSTOMER ORDER-REQ NO H-92766-4	DATE ENTERED 1/13/78	ENT D. BY PATE	ORDERED BY HENRIKSEN
------------------------------------	-------------------------	-------------------	-------------------------

AMETEK/STRAZA
P O BOX 666
EL CAJON CA
35-104664-1

RETENTION TIME
LT YES SN F-5
92021

SHIP TO
790 GREENFIELD DRIVE
MAKES 7-050063-1
CODE SN # 365 PEN # 46 SITE 3

OUR TRUCK	WILL CALL	CARRIER	F O B	DEST. FREIGHT PPD.	OUR PLANT FREIGHT COLL.	O/P PREPAID CHANGE FNL.	O/P COLLECT ALLOW FNL.
XX		EMJ WHSE		XX			

QUANTITY AND DESCRIPTION

ASME SA-182 F22 AND ASME BSPV CODE SECTION 3, 1974 EDITION AND ADDENDA THRU SUMMER 1975 FOR CLASS 2 COMPONENTS. FORGED OVERSIZE TO ALLOW FOR FINISH NORMALIZED, WATER QUENCHED AND TEMPERED ROUGH MACHINED COMPLETE TO DWG#7-050063-2 REV "C" TOLERANCE SHOWN, INCLUDING ID; 250 RMS OR BETTER ULTRASONIC INSPECTED PER NB-2542 GRAY WITH GREEN STRIPE 212201

2 PCS P/N-7-050063-2 REV "C" BHN 179 .2090#

PENT# 46 AND 47

MECHANICAL TESTING REQD AND INCL IN PRICE.

NUCLEAR

81-20984

368

MECHANICAL TESTING REQD AND INCL IN PRICE.

ACTUAL PHYSICAL CERTS ATTACHED

C	MHC	P	S	REL	HI	CR	MU	V	3	MILL	HEAT NO	1	4	5	8	10	16	20
.13	.47	.017	.014	.32		2.48	.91			EMJ-SEA	20984							

CERTIFIED TEST REPORT

We certify that the material covered by this report has been inspected and tested in accordance with the applicable requirements described herein and test results are on file subject to examination.

10-11-78

By *Alvince R...*

ASME QUALITY SYSTEM
CERTIFICATE NUMBER N-1707
EXPIRES APRIL 15, 1980


SUBSCRIBED AND SWORN TO BEFORE ME THIS 11 DAY OF OCTOBER 1978

NOTARY PUBLIC

R. HAROLD ELSTON
ROTARY PUBLIC - CALIFORNIA
LOS ANGELES COUNTY
My Commission Expires May 6, 1979

HEAT NO	YIELD	TENSILE	IN INCHES	OF A

ALL OTHER TESTING CERTS ATTACHED



CERTIFICATE OF TEST ON PIPE MATERIAL

ST. YRS. R1351

1-SG-205-S001

PULLMAN POWER PRODUCTS
 P. O. BOX 909
 PARAMOUNT, CA 90723

P. O. BOX 1212
 HOUSTON, TEXAS 77001

Date: 26 September 1977

Customer Order No. 205-19-17.131	C.I.W. Sales Order No. F-9125	Specification ASME SA106 Gr. C ASME SECTION III, Class 2 Components 1974 Edition Thru Summer 1975 Addenda as modified by Customer P.O. with impacts at +40°F
Material O.D. 24"	Material I.D.	Material WALL THICKNESS 1.00"

C.I.W. Part No. 86-9125-240-210 ASME QUALITY SYSTEM CERTIFICATE (MATERIALS)
 NO. N-125 EXPIRES 10-27-78

Test No.	Location of Serial No.	C	MN	P	S	SI	CR	NI	MO
----------	------------------------	---	----	---	---	----	----	----	----

387 23 79 011 019 24

Heat No.	Test Loc.	Tensile PSI	2% Offset Yield PSI	% Elong. In.	% Red. Area	MECHANICAL PROPERTIES			
						Test Loc. of Flat	Charpy	Impact +40°F	
2 J 6387	Trans.	70,200	46,700	30.8	52.9	310	OK	90.0	80HLS
								71.0	60
								105.0	80

Org. Ser. # Test Lot# Tensile specimen Size: 510
 29507Y 310
 29507Z 310

Pullman Power Products
 Division of Pullman Incorporated
QVR IDENTIFICATION
 205-19-17.131
 3:172 @ARIC-3

APPROVED BY G.A.
 DATE 11-10-77
 M.S.


SEP 13 1977

Hydrostatic Test: Each length of pipe hydrostatically tested at 2500 psi for 5 sec. and found acceptable.

Pipe has been heat treated in accordance with C.I.W. Approved Procedure PH-8, Rev. 'C'.
 1600°F., held 1 hr. at temp. Air cooled.

and Sworn to before me this 5th Day of September 1977

I certify these tests to be correct as contained in the records of the company.
 Metallurgical Representative



1-SG-205-S001
 UNITED STATES STEEL CORP.
 CHRISTY PARK WORKS.
 HICKESPORT, PA.

QUALITY CONTROL SYSTEM
 RECORD OF TESTS

DATE 11-6-78

ORDER NUMBER ED-20210

CUSTOMER Guyon Alloys Inc.

CONTRACT NUMBER A-22955

GRADE "C" ASTM A106 - ASME SA106

O.D. 24"

WALL 1.531"

HEAT TREATMENT Normalizing
1550°F - 2.5 hrs. at Temp.

HEAT NUMBER 70C547 HEAT CODE B13

TEST IDENTITY 4901

FURNACE CHARGE NUMBER C3610

TEST NO.	DIMENSIONS	AREA	YIELD STRENGTH		TENSILE STRENGTH		ELONGATION		REDUC. DIMENSIONS	REDUC. AREA	REDUC. IN AREA, %	TEST TEMP °F	RESULTS
			BEAM POUNDS	POUNDS PER SQ. IN.	BEAM POUNDS	POUNDS PER SQ. IN.	IN 2 INS.	%					
4901	5.05	2003	10050	50175	15350	76635	64	22.0	301	0712	64.4	+40°F	1.38.0 2.42.0 3.46.0 } FT
	Hydro tested to 2800 PSI												
				40000		70000		20%					
												12.3"	OK TO 11"

Material was manufactured in accordance with the quality system audited and approved by

CHEMICAL ANALYSIS

Guyon Alloys Inc. as conforming with the requirements of ASME Sect III Subarticle NCA-3800

APPROVES PIPE NUMBERS

	C.	Mn.	P.	S.	SI	V.				
TABLE	.25	.87	.006	.025	.25	-				
Check	.27	.87	.007	.026	.26	.09				
Check	.24	.82	.007	.024	.24	.09				

4901A 4922A 4931A
 12/1/78

Pullman Power Products
 Paramount, Calif.
 Q.A. APPROVAL
 By [Signature]
 Date 3/6/79

Test results which were not witnessed have been reviewed and meet order requirements.

Third Party Inspector

(D 12)

Q. A. APPROVED
 BY: [Signature] DATE: 1-10-79
 GUYON ALLOYS, INC.

We hereby certify that the above figures are correct, as contained in records maintained at the above address.

Chief Metallurgist

[Signature]
 17550-339

CP-CC 4529
 UNITED STATES STEEL CORP.
 CHRISTY PARK WORKS
 McKEESPORT, PA.

QUALITY CONTROL SYSTEM
 RECORD OF CHARPY IMPACT TESTS

7-3 TURN
 DATE: 11-7-78

Agency Number _____ Customer _____ Contract Number _____
 Mill Order _____ O.D. .74" Wall 1.531" ^{ASPM A106} Grade "C" ^{ASME SA106} Heat Treatment NORMALIZE
 Heat Number 70C543 Heat Code B13 Test Number 4901

Remarks: _____

LONGITUDINAL IMPACTS


1/2" Below OD Surface

Specimen No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
Code <u>A106</u>																					
Temp.	<u>44.0</u>	<u>44.0</u>	<u>44.0</u>																		
Ft. lbs.	<u>38.0</u>	<u>42.0</u>	<u>46.0</u>																		
% Shear	<u>40.0</u>	<u>40.0</u>	<u>40.0</u>																		
Lat. Exp.	<u>45.0</u>	<u>43.0</u>	<u>46.5</u>																		
"RC"	<u>82.0</u>	<u>79.0</u>	<u>79.0</u>																		
Code																					
Temp.																					
Ft. lbs.																					
% Shear																					
Lat. Exp.																					
"RC"																					
Code																					
Temp.																					
Ft. lbs.																					
% Shear																					
Lat. Exp.																					
"RC"																					

Q. A. APPROVED
 BY [Signature] DATE 10-29-78
 GUY IN A LOG, INC.

RECEIVED
 Pullman Power Products
 Paramount, Cal.
 Q.A. APPROVAL
 By [Signature]
 Date 11/16/78







Bonney Forge Division
 Energy Products Group
 GULF-WESTERN MANUFACTURING COMPANY
 ALLENTOWN, PENNSYLVANIA 18105

CORRECTED CERTIFICATIONS 12/19/78

CUSTOMER: PULLMAN POWER PROD
CUSTOMER'S Order No.: 2805-71
SHIPPED TO: PULLMAN POWER PROD
 PO BOX 912
 14507 S PARAMOUNT BLVD
 PARAMOUNT CA 90723

RECEIVED
 JAN 2 1979
 MARK
 PULLMAN POWER PRODUCTS

NOVEMBER 13, 1978
 Bonney Order No. 67034
 2805-71
 RETENTION TIME YRS

R 6704A

Item No.	Quantity	Bonney Lot No.	Grade or Specification No. Chemical Analysis, Physical Properties, Remarks
681	4	P557	<p><u>SA420-WPL6</u></p> <p>28 (1.750mw) x 12 (.343) Sweepolet C.22 Mn 1.28 P.018 S.022 Si.28 T/S 84,600 Y/S 54,000 El 31 Ra 69 <u>Charpy +40°F.:</u> 58.6 - 67.0 - 81.4 ave. 69.0 (ft lbs) <u>L.E. (mils):</u> 58 - 65 - 78 <u>Shear (%):</u> 90 - 90 - 90 <u>Charpy -50°F.:</u> 13.9 - 15.6 - 35.3 ave. 21.6 (ft lbs) <u>L.E. (mils):</u> 17 - 19 - 34 <u>Shear (%):</u> 10 - 20 - 30</p>

This is to certify that:

- The fittings supplied were normalized by heating to within 1625°F. and 1675°F. for 3/4 hr. per inch of thickness (1 HR. MIN.) followed by cooling in still air.
- The fittings supplied are in complete accordance with the ASME Boiler and Pressure Vessel Code, Section III, Class 2, 1974 Ed. Thru Winter 1975 Addenda, SA420-WPL6 and the Purchase Order.
- The Charpy V-Notch Impact Test was performed at +40°F. in accordance with ASME E370 & SA420-WPL6 & ASME NC-2331-1.
- The Charpy V-Notch Impact Test was performed at -50°F. in accordance with ASME E370 & SA420-WPL6.




THE BUYER ACCEPTS THE RISK OF THE QUALITY OF THE ITEM ORDERED FROM THE SUPPLIER OR MANUFACTURER AS BY THE PRODUCTION UNIT OR IS OTHERWISE BY THE BUYER'S INSPECTION DEPARTMENT.

Bonney Forge Division
 Energy Products Group
 ALLENTOWN, PENNSYLVANIA 18105

L. M. Landerslager
 QUALITY ASSURANCE MANAGER

APPROVED
 BY Q. A.
 Date 1/3/79
 By MS

EECHTEL
 149



AREA CODE 218
TELEPHONE 435 9611
TWX 510-661-3752
TELEX 847453

SONNEY
FORGE

2805-71

IT: 08/2 OE 2

Log No. 629-8
660-3

Page 2

CORRECTED CERTIFICATIONS 12/19/78

CUSTOMER: PULLMAN POWER PROD

Date DECEMBER 19, 1978

CUSTOMER'S Order No.: 2805-71

Sonney Order No. 67034

Item No.	Quantity No.	Sonney Lot No.	Grade or Specification No. Chemical Analysis, Physical Properties, Remarks: RETENTION TIME
			<p>5. The Charpy V-Notch test specimen was taken from a separate test forging that was approximately 2 3/4 square by 13" long. The test specimens are removed along the 13" longitudinal axis which is parallel to the direction of working.</p> <p style="text-align: right;">R6704</p>

APPROVED
BY Q. A.
Date 1/3/79
By MS


BECHTEL
149



The data on this sheet is a copy taken from our records of material furnished us by the production mill or as obtained by additional laboratory tests.

ENERGY PRODUCTS GROUP
Cedar and Meadow Streets, P. O. Box 359
Allentown, Pennsylvania 18105

by [Signature]
QUALITY ASSURANCE MANAGER



1-SG-206-S001

WEST JERSEY MANUFACTURING CO.
Williamstown, N.J.

DATE January 17 19 78

RETENTION TIME

OUR ORDER NUMBER 6029-A

CUSTOMER'S ORDER NUMBER 2805-32

TEST RECORD OF SA105 Sec. III Class 2 STEEL

FURNISHED Pullman Power Products

HEAT NO.	CHEMICAL ANALYSIS									TENSILE STRENGTH, p.s.i.	YIELD POINT p.s.i.	ELONGATION % 2"	% REDUCTION OF AREA	TESTOR CODE NO.	REPRESENTS
	C	Mn	P	S	Si	Cr	NI	Mo	ITEM						
6010782	.24	.80	.006	.032	.19	.04	.09	.01	235	79,800	53,600	38.2	57.6	6010782	20-6" 1500# Large Female Long WN flange per Sk.# 2805-6. Heated to 1650° F, and held 1/2 hr. per inch of max. s removed from furnace and cooled in still air. We certify that these flanges conform to the general conditions and restrictions of ASME SA1 Note: No non-destructive testing required.

APPROVED
BY Q. A.
Date 2/1/78
By K.T.

BECHTEL
250



WEST JERSEY MANUFACTURING CO.

Joseph Walker
JOSEPH WALKER

RETENTION TIME 17 YRS. 244918

MILL TEST CERTIFICATE

SOLD TO Pullman Power Products

PULLMAN POWER CORPORATION
WELDING PRODUCTS DIVISION
MUNCKTON, KY.

ORDER NO. 77-2

SHIP TO _____

DATE Jun. 29, 1979
REVISED 11-9-79
REVISED 7-25-79

CUSTOMER'S ORDER NO. _____

DESCRIPTION OF FITTING	PHYSICAL PROPERTIES FITTING MATERIAL				CHEMICAL ANALYSIS							HEAT CODE OR HEAT NO.	SPECIFICATION FITTING MATERIAL	
	HEAT TREATMENT	YIELD POINT P. S. I.	TENSILE STRENGTH P. S. I.	ELONG. IN 1" %	C	MN	P	S	SI					
ASME SA-155 Class 1 KCF-70														A-516 GR. 1
28" O.D. x 1.750" W/D x 8' 2-5/8" Length Pipe	A	47100	71700	#27.0	(Ladle)	.20	1.06	.010	.009	.25			RDWH	Item # 64A
		46500	73500	#29.7	(Check)	.21	1.05	.010	.010	.21				
REF 7039A REF 7038A REF 7038B REF 7039B					Full Size Charpy V-Notch @ Plus 40° Longitudinal Body & Orientation and location per Foot Lbs. - 98, 105, 82; Average = 95								NB-222 and Para. 1	
					% Shear - 90, 100, 90; Average = 93									
					Lateral Expansion = .07, .073, .070; Average = .071									
					Full Size Charpy V-Notch @ Minus 50° Longitudinal Body & Orientation and location per Foot Lbs. - 47, 49, 46; Average = 47.3								NB-222 and Para. 1	
					% Shear - 20, 20, 20; Average = 20									
					Lateral Expansion = .035, .035, .030; Average = .033									
Weld repair preheat treated to 300°F. REF 7038A, REF 7039A.														
Weld repair to be stress relieved upon installation. See Page 2 of 2 for location of weld repair.														REF 7038A, REF 7039A
The above pipe was manufactured and tested in strict compliance with ASME Section III, 1974 Edition, Class 2 through the 1975 Summer Addenda.														
Rept. Test: OK														
The above pipe was hydro tested at 2800 lbs. PSI and found acceptable.														
The above pipe was normalized for 2 hrs. at 1650 ± 50 in accordance with Procedure #350-5.														
The above pipe was radiographically examined in accordance with ASME Section I, PW-51 and found acceptable. Approved Procedure I-S-181-10 and I-S-158 or I-TE-1.														
*Standard round test specimen used for tensile properties.														

Pullman Power Products
Paramount, Calif.
Q.A. APPROVAL
By *[Signature]*
Date 2/7/80

HEAT TREATMENT - LEGEND - A = NORMALIZED B = NORMALIZED AND TEMPERED C = NORMALIZED, QUENCHED, & TEMPERED D = STRESS RELIEVED


E = HEAT TREATED PER SPECIFICATION ON ORDER F = HOT FORMED BETWEEN 1150 AND 1200°F AND COOLED IN STILL

SUBSCRIBED AND SWORN TO BEFORE ME

I HEREBY CERTIFY THIS TO BE A TRUE AND CORRECT REPORT ACCORDING TO RECORDS IN THE POSSESSION OF THIS CORPORATION.

THIS _____ DAY OF _____ 19 _____

[Signature]



MAIN STEAM ISOLATION VALVE UNIT 1

A/D PO #
P-1841

(3)

METALLURGICAL INSPECTION REPORT
 NEWPORT NEWS SHIPBUILDING AND DRY DOCK COMPANY
 NEWPORT NEWS, VIRGINIA
 FORM 120-C
 MATERIAL

CAST STEEL														INSPECTION:			DATE:		
.505" Dia. Tensile														Yard			May 9, 1979		
HEAT NO.	Lab. NO.	NO. PCS.	ITEM	DWG.	CARBON	CHROME	MANG.	NICKEL	MOLY	COPPER	SILICON	PHOS.	SUL.	SPECIFICATION	Y.P. LBS./SQ.IN.	T.S. LBS./SQ.IN.	ELONG. %	R.A. %	COLL. TEND.
216C2	2553-S	1	1	288901	.22	.19	1.23	.42	.11	.12	.37	.012	.006	ASME SA-216 Gr. WCC, Cl. 2	54000	78200	28.0	63.5	
					Impact (Casting Condition)														
					Sample No.	Temp. °F	Ft. /Lbs.		Mils	Lat.	Exp. %	% Shear.							
					1	+40	117		74	18.8	50								
					2	+40	122		74	18.8	50								
					3	+40	132		81	20.6	65								
					Additional Post Weld Heat Treatment														
					1	+40	130		73	18.5	50		52500	77350	32.0	68.8			
					2	+40	115		75	19.0	50								
					3	+40	115		69	17.5	75								

REMARKS: Newport News Industrial Corporation J. O. 1326-N (NN J. O. 5058-A), Anchor-Darling Valve Company
 Customer Order No. P-1841, Anchor-Darling Pattern No. F-5089

	<u>Date Cast</u>	<u>X-Ray No.</u>	<u>MT No.</u>
1-Valve Body	3-14-79	NN28895	302

BP
17
of
24

A. E. Nace
 A. E. Nace
 MRC Supervisor, Laboratory Services

J. H. Arthur, Jr.
 J. H. Arthur, Jr.
 Section Manager, Laboratory Services

A. W. J. Roedel

6-11-79

MAIN STEAM ISOLATION VALVE UNIT 1

Newport News Shipbuilding
 2161 WASHINGTON AVE.
 NEWPORT NEWS, VIRGINIA 23607

MATERIAL TEST REPORT

FOR Anchor Darling Valve Company DATE May 9, 1979 **P. B. B. 10**
 CUSTOMER P.O. NO. P-1841
 NNS JOB ORDER NO. 5058-A NNI JOB ORDER NO. 1326-N
 DESCRIPTION 28 x 24 x 28, 900 MSIV Body Casting
 SERVICE DESIGNATION ASME Code, Sect. III, Class 2
 DRAWING NO. 288901 REV. None PC NO. 1
 HEAT NO. (5246C-2) SERIAL NO. (if required) NA

EFFECTIVE ASME BOILER AND PRESSURE VESSEL CODE SECTION III YR. 1977 ADDENDA Summer 1977
 MATERIAL SPECIFICATION SA216 REV. 1977 w/Summer 1977 Addenda
 MATERIAL GRADE WCC
 Mfg. under QA program meeting ASME Code, Sect. III, ART. NCA 3800

FURNACE PROCESS Electric Furnace
 HEAT TREATMENT CONDITION Normalized, Quenched, & Tempered* See* TIME See*
 HYDROSTATIC TEST PRESSURE NA

CHEMICAL ANALYSIS (values in maximum % or specific range)

ELEMENT	C	Mn	P	S	Si	Residual Elements-See
SPECIFICATION	0.25	1.28	0.04	0.045	0.60	Attached Metallurgical
ACTUAL	0.22	1.23	0.012	0.006	0.37	Inspection Report

MECHANICAL TESTS (all values minimum)

	TENSILE KSI	YIELD POINT KSI	ELONGATION IN 2 INCHES	REDUCTION IN AREA	Charpy Impact - See
SPECIFICATION	70 to 95	40	22.0	35.0	Attached Metallurgical
ACTUAL	78.2	54.0	28.0	63.5	Inspection Report

WELD REPAIRS (see attached sketch) Procedure NNI-19.2, Rev. A
 WELDING MATERIAL IDENTIFICATION 5/32" and 3/16" E7018 Electrode
 LOT IDENTIFICATION NO. for 5/32" is 77NNI607 IDENTIFICATION OF WELD REPAIR See T.R. Report
 LOT IDENTIFICATION NO. for 3/16" is 90128Y001 IDENTIFICATION OF WELD REPAIR See T.R. Report
 LOT IDENTIFICATION NO. _____ IDENTIFICATION OF WELD REPAIR _____
 POST WELD REPAIR HEAT TREATMENT NNI-19.901, Rev. A TEMP. 1175°F ±25° TIME 3 hours

NDT PERFORMED RT Proc. N-540, Rev. A4, RSSS Proposed #84, Rev. A, MT Proc. N-320/420, Rev. C6
 UT MT PT RT NN 28895
 VISUAL INSPECTION STANDARD (if applicable) MSS-SP-55 MT No. 302

* Designates analyses, tests, examinations or heat treatments which were not performed but were required by the material specification.
 Explanation: NA

* Designates conflicts between material specifications and code requirements.
 Explanation: In addition to material specification requirements of normalizing and tempering operations, a quenching operation was performed, see attached material test report supplement.

REMARKS:
 Newport News Shipbuilding certifies that all requirements of the material specification are satisfactorily met, except as so noted, and that the data contained herein is correct and reliable and was obtained by appropriate inspection techniques in accordance with the company's procedures.
 RECEIVED
 SECURE
 A.J.G.
 REVIEWER [Signature] DATE 5-9-79
 USER OF QUALITY ASSURANCE

R-12750

MATERIAL TEST REPORT SUPPLEMENT

Heat Treatment Requirement - J.O. 5058-A (1326-N)

Drawing No. 288901, Rev. None, Body Casting, Heat #5246C-2

Normalizing

Temperature 1700 ± 25°F
Time (Soak) 6 hours

Water Quench

Temperature 1700 ± 25°F
Time (Soak) 7 hours

Temper

Temperature 1225 ± 25°F
Time (Soak) 8 hours

The above heat treatments were performed in accordance with Procedure NNI-19.901, Rev. A.

R.T. Clark, Jr.


R. T. Clark, Jr. 5-9-79
Manager of Quality Assurance

A.W.G.
BECHTEL

EPC
17
QAE

A/D PD #
P-1841

(2)



7044 MAIN STEAM ISOLATION VALVE UNIT 1

CUSTOMER Anchor/Darling Valve Co. 701 First Street Williamsport, Pa. 17701		SHIP TO Same		K1809	
PREPAID		COLLECT XX	VIA TRUCK	TERMS Net 30 days	
CUSTOMER Anchor/Darling Valve Co. - Pa.		SHIP DATE		D.P. ORDER NO. 2-06077 1-3	
QUANTITY 8	PATTERN NO. F-5091 (28"x24"x28" Bonnet)	CUSTOMER ORDER NO. P-1840			
STL. NO.	MOLDS	S/P NO. F-5091	UNIT WGT. 4140	TOTAL WGT. 33120	OPER. 25
ORD. DATED 9/27/78	CUSTOMER SPECIFICATION SA216-WCC, VT-MSS-SP55, No weld		METAL Spec.	M.T. CODE C10	ROUFING CODE 128
SALESMAN 04	INSTRUCTIONS (2) 3 copies T.R. & Docu., Subm. 4 t/b heat (8) Melt & Lab use melt procedure MP 1.20, use 120 for gates, Charpy @ 40°F + 40 M.L.E., Arc air visual defects as per Dodge's no weld specification. No weld - Nucl., H.I. 2NET, H.T. Chart req., PWHI 15 hrs. @1150°F, Subm. sample and obtain RT results before production				TEST BARS 5 K.B.
CUSTOMER DEL. Sample ASAP 2-10/30/78 Bal. 1 per month					


CERTIFICATE OF CHEMICAL & PHYSICAL TESTS - HEAT TREATMENT - N.D.E. TESTS

HEAT NO. 4495	SERIAL NO. (AH-2665)	QUANTITY IN HEAT 1	DATE FOUNDED 1/15/79								
CHEMICAL ANALYSIS - MAT. SPEC. SA216 WCC											
C	MN	SI	P	S	CR	NI	MO	AL	CU		
.16	.83	.49	.021	.015	.33	.27	.16	.037	.09		
WELD METAL CHEMICAL ANALYSIS					WELDING PROCEDURE NUMBER						
Filler Metal SMC	Lot Number	C	MN	SI	CR	NI	MO	Welder's I.D.			
TENSILE PROPERTIES OF CASTING					HEAT TREATMENT						
T.S. P.S.I.	Y.P. P.S.I.	Y.S. P.S.I.	EL. %	R.A. %	BHN RANGE	TYPE	TEMP. FO	TOT HRS	LOADNO	CHART ATT.	
71,900	55,600		26.7	27.0	163	HOMOGENIZE					
TENSILE PROPERTIES OF WELDING ELECTRODE						NORMALIZE					
T.S. P.S.I.	Y.P. P.S.I.	Y.S. P.S.I.	EL. %	R.A. %	BHN RANGE	NORMALIZE	11650°F	7	3273	✓	
						TEMPER	1250°F	7 1/4	3275	✓	
IMPACT TEST			BEND TEST			WATER QUENCH					
TEMP 40FO	1	2	3	AVG.	Specification	OIL QUENCH					
(FT. LBS.)	74	86	83	81		Heat treat Procedure 48.05					
(M.L.E.)	65	82	74	74	TYPE	dated 4/21/77 and 48.04					
SHEAR. %	80	90	80	82	RESULTS	Rev. 1 - 6/15/78					
CORROSION TEST			Ferrite Content %			PWHT 781150°F 15					
SPEC.	TYPE	Measured by			REPORTS ATTACHED						
TEMP.	RESULTS				HEAT TREATMENT CHART						
N.D.E. SPECIFICATIONS			SER. No.	APP'D	DATE	RT FILM & READER & SHOOTING SKETCH					
VT PER	MSS-SP55			2665	OK	1/79	WELD REPAIR MAP RECHIL				
FAT-LPT PER							SNT-TC-1A CERTIFICATE 364				
RT PER							WELDING PROCEDURE - QUALIFICATION TEST				
						WELDER'S QUALIFICATION TEST					

REMARKS:
Casting were manufactured in accordance with A/DV SPI PUR-2, Rev. B, ASME Section III, 1977 Edition including 1977 Summer Addenda
24562, 24563-45
SEE ATTACHED REPORT / 4 ROUGH TEST BARS

We hereby certify that the above material has been tested in accordance with the listed specifications and conforms to all applicable requirements thereof.
William M. Keesel 2/1/79
Quality Assurance Date
DODGE FOUNDRY & MACHINE CO.
6701 STATE ROAD, PHIL A., PA. 17 35





21230

Ramball Testlab

6501 STATE ROAD - PHILADELPHIA, PA. 19135
(215) 332-4011

LABORATORY REPORT

Date: January 26, 1979
P.O.# M-2129

Anchor/Darling Valve Co.
701 First Street
Williamsport, PA 17701

Heat # 4495, PO# P-1840
Material: ASME-SA-216, WCC

TENSILE TEST	
Lab #	24582
YIELD STRENGTH	55,600 psi
TENSILE STRENGTH	71,900 psi
ELONGATION	36 %
REDUCTION OF AREA	67 %

CHARPY IMPACT TEST			
LAB #	FOOT POUNDS	MILS LATERAL EXPANSION	% SHEAR
24583	74	65	80
24584	86	82	90
24585	83	74	80
Average	81	74	83

0.505" diameter tensile specimen, 2" gauge length.

1.0 cm x 1.0 cm Charpy Specimen.


The above test specimens were heat treated similar to production castings. The test bars only were given an additional stress relief heat treatment at 1150 degrees F for 15 hours. The Charpy V-Notch Impact Test was performed at +40 degrees F.


J. Ramball

Metallurgist

BECHTEL
364

BPC
17
CAE






63114
R1275

MAIN STEAM ISOLATION VALVE UNIT 1

10-23-78

10/23/78 Heat Treat Proc 1007; Rev. 1 (11/9/77)
Anchor/Darling Valve Co
P-1980 S.O.#P-9023-1-7
16" 241900 Disc Forgings for Drawings C-16399
Forgings serialized 1 thru 16,000
Heat #218121



BECHTEL
284

BPC
17
QAE

Form T-14

CANN & SAUL STEEL CO.

ROYERSFORD, PA. 19468

Report of Physical Tests and/or Chemical Compositions

Date 11/20/78

Customer ANCHOR/DARLING VALVE CO. Customer's Order No. P-1938
 701 FIRST ST. S.O.#E-9023-1
 Address WILLIAMSPORT, PA. 17701

Cann & Saul Order No. 49771

R12730

Attention PURCHASING DEPT.

CHEMICAL COMPOSITIONS											
HEAT NO.	C	MN	P	S	SI	CR	NI	MO	CB		
218191	.23	.91	.009	.017	.21						

PHYSICAL TESTS											
CUT FROM	TEST NUMBER	GAUGE	YIELD PT. LBS.	YIELD PER Square In Lbs.	BROKE AT LBS.	ULTIMATE TENSILE LBS.	ELONG %	REDUCED AREA	Reduction %	B.H.N.	
Forging	49771 1	.505	YS 11,600	YS .2% 58,000	18,000	90,000	29.0	.076	62.0		
Charpy Impacts - V Notch		42 46	44 Mils	Lat. Exp. @ +40° F							
		59 59	58 Ft. Lbs.								
		20 10	10 percent shear								

OTHER TESTS

BRINELL 157/174

We certify that the material meets the ASME Code, Section III, 1977 Edition thru 1977 summer Addenda.

Customer's Specifications: ASME SA105
 CHARPY "V" IMPACT 40 MILS LAT. EXP. @ + 40° F
 26/35 CARBON B.H.N. 187 MAX.

XX 36,000 YS .2%
 T. 70,000
 E. 22%
 R. 30%

THE ABOVE TESTS COVER THE FOLLOWING MATERIAL:

16 - 24" 900 DISC FORGINGS FOR DRAWING C-16399
 Forgings serialized #1 thru 16

BECHTEL
 ARIZONA, PUBLIC SERVICE & A/DV
 Inspection

Inspector


11-22-78


CANN & SAUL STEEL CO.

Exp/ of Tests

BECHTEL
 284

BPC
 17
 OAF





NUTS Incorporated

R1293

PHILADELPHIA
Routes 724 & 23
Phoenixville, Pennsylvania 19460
Phone: (215) 935-2330

CLEVELAND
24272 Detroit Road
Cleveland, Ohio 44145
Phone: (216) 835-0660

CERTIFICATE OF ANALYSIS AND TESTS 12/20/78

TO: Anchor/Darling Valve Company
701 First Street
Williamsport, Pa. 17701

DATE: Heavy Hex Nuts; ASME-SA-194, Grade 7, B & P.V. Code Section III 1977 Edition thru Winter 1977
Addenda with Impact Tests At -150°F.: Traceability
TYPE: Stamping "N2A"
P/N W-3199

YOUR ORDER # P-2225

DESCRIPTION OF MATERIAL AND SPECIFICATIONS 2 1/2"-8 (240 pcs.)

Heat No. 51262

7608

CHEMICAL ANALYSIS

Carbon (C)	.40
Manganese (Mn)	.90
Phosphorus (P)	.010
Sulfur (S)	.022
Silicon (Si)	.29
Chromium (Cr)	.99
Nickel (Ni)	

Molybdenum (Mo)	.18
Columbium (Cb)	
Copper (Cu)	
Cobalt (Co)	
Tin (Sn)	
Iron (Fe)	
Tungsten (W)	

Impact Test Data attached

PHYSICAL ANALYSIS

Hardness: Rb
Rc 31/32
Brinell
Hardness after 24 hours @ 1100°F.: BHN 235

BECHTEL
284

SPECIAL TESTS

Subscribed and sworn to before me this
day of 12.20. 1978

Min. Tempering Temp.: 1100°F

QA
91


1-2-79

***** We Certify that the material used in the manufacture of this order is in accordance with the above specifications. *****

George W. Reed, Jr., Notary Public
East Pikeland Township, Chester County
My Commission Expires June 23, 1990
Member, Pennsylvania Association of Notaries

BY: John Wallace
V. P. Q. C.
DATE: 12/20/78

BPC
17
QAE





CERTIFICATE OF ANALYSIS AND TESTS

RESERVATION TIME MR. NO.

MAIN STEAM ISOLATION VALVE UNIT 1

To:

Anchor Darling Valve Company
701 First Street
Williamsport, PA 17701
Attn: G. Brubaker

DATE 17 YRS. 61
Nov. 27, 1978
CUST. ORDER NO. R12730
P 2223
OUR ORDER NO. 2387

DESCRIPTION OF MATERIAL AND SPECIFICATIONS.

1. Studs - ASME SA 193, Gr. B7:
Item 1: 2-1/4" - 8 x 13-3/4". W-4342. Trace AD.

2.
3. Material per ASME SECT. III, CLASS 2, 1977 Edition
thru Winter 1977 Addendum.

4. "We hereby certify that the materials supplied fully conforms
to the specifications as outlined in your order and drawings
indicated."

CHEMICAL ANALYSIS

Manufacturer	Heat Number	Carbon	Mang.	Phos.	Sulphur	Silicon	Nickel	Chromium	Moly.	ITEM:
Republic 2-1/4"	8085668	.460	.92	.007	.026	.23		.96	.21	(1)

MECHANICAL PROPERTIES

Yield Lbs./Sq. In.	Tensile Strength Lbs./Sq. In.	Elongation % in	Reduction of Area %	Hardness	Bend Test ITEM.	TEMPERING TEMP.
116,700	142,600	17.5	58.4	BHN 302/311	(1)	1100 F.

CHARPY IMPACT TEST

SPECIAL TESTS

Test. Temp. Plus 40 F.

SPECIMEN:	#1	#2	#3	REO:
Lateral Expan.	38	39	40	25 min.

Sworn and Subscribed to before me
this _____ day of _____ 1978

QA 91 1-3-79

We hereby certify that the foregoing data is a true copy of the data furnished us by the producing mill or laboratory.

R. E. C. CORPORATION


Lois A. Grieco
Lois A. Grieco

DECTEL 284

BPC 17 QAE

R. E. C. CORPORATION

47 CEDAR ST., NEW ROCHELLE, N. Y.




MAIN STEAM ISOLATION VALVE UNIT 1

MIN. DIMENSIONAL RECORD
MQCS-44

E9023-1-4 AD
RETENTION TIME MRR NO.
LT. YRS. 6 1414

R12930



Record A & B after machining these areas.
Record C & D at Receiving.

Record E at Receiving Inspection.
Record F at completion of final machining.

Thoroughly scan the zones required and record only one dim. per zone.

The one recorded dim. shall be the min. thickness reading observed in that zone.

FOR USE ON DISCS ONLY:

Shop Order/Item

E-9023 - 1

Heat/Serial No.

HT-218191 SN-14

Min. Dimension "F" Zone


3.840

Date & Stamp.

QAE6 low 2-20-79

BECHTEL
284






MIN. DIMENSIONAL RECORD
MQCS-44

RETENTION TIME MRR NO.

LT YRS. 6 1 4 1 4

R 12730



Record A & B after machining these areas...
Record C & D at Receiving.

Record E at Receiving Inspection.
Record F at completion of final machining.

Thoroughly scan the zones required and record
only one dim. per zone.

The one recorded dim. shall be the min. thickness
reading observed in that zone.

FOR USE ON BONNETS ONLY:

Shop Order/Item

E9023-1-4

Heat/Serial No.

HT-4495 S/N-K1809

Min. Dimension "E" Zone

2.906

Date & Stamp

QA 85 5-3-79
LEVEL 11

BECHTEL
284





The page contains extremely faint and illegible text, likely bleed-through from the reverse side of the document. The text is scattered across the page and is not readable.


MAIN STEAM ISOLATION VALVE UNIT 1

RETENTION TIME MDR AB.

MIN. DIMENSIONAL RECORD
MQCS-44

LT YRS. 61414

R12730



Record A & B after machining these areas.
Record C & D at Receiving.

Record E at Receiving Inspection.
Record F at completion of final machining.

Thoroughly scan the zones required and record only one dim. per zone.

The one recorded dim. shall be the min. thickness reading observed in that zone.

FOR USE ON BODIES ONLY: 28" x 24" x 28"

Shop Order/Item

E9023-1

Heat/Serial No.

HT5246C2 S/N NN28895

Min. Dimension "A" Zone

3.300

Min. Dimension "B" Zone

3.300

Date & Stamp

6-14-79

QA 14
LEVEL II

Min. Dimension "C" Zone

3.000

Min. Dimension "D" Zone

2 13/16"

Date & Stamp

6-14-79


QA 14
LEVEL II

MQCS-44-1

Fig. 1

BECHTEL
284

BECHTEL
QA



MAIN FEEDWATER ISOLATION VALVE UNIT 1

CUSTOMER'S REQUEST	Anchor/Darling Valve Co. 701 First Street Williamsport, Pa. 17701		SHIP TO	Same	K1814	TK 1014
	CUST. CODE	050	MARK FOR P.O.			
PREPAID	COLLECT XX	VIA Truck	TERMS	Net 30 days		
CUSTOMER			SHIP DATE	D.P. ORDER NO.		
Anchor/Darling Valve Co. - Pa.				1-06077 2-3		
QUANTITY	C.D.	PATTERN NO.	CUSTOMER ORDER NO.			
8		F-5078 (24x22x2 1/4 900# FWIV Body)	P-1840			
PACK PER	MOLDS	B/P NO.	UNIT WGT.	TOTAL WGT.	OPER.	
1	8	F-5078, Rev. A att.	6700	53600	25	
ORD. ENTERED	CUSTOMER SPECIFICATION		METAL	H.T. CODE	ROUTING CODE	
9/8/78	VT-MSS-SP55, No weld - Nucl. SA216 WCC		Spec,	C10	128	
SALESMAN					TEST BARS	
04					5 K.B.	
BUYER	INSTRUCTIONS					
Louden.	(2) 3 copies T.R. & Docu., Subm. 4 rgh TB/heat (8) Melt & Lab use Melt Procedure MP 1.20, use 120 for gates, Charpy @ 40°F +40 M.L.E. Arc air visual defects as per Dodge's no weld spec. No weld - Nuc H.T. 2N&T, H.T. Chart req. PWHT 15 hrs. @1150°F, Subm. sample and obtain RT results before prod.					
CUST. REQ. DEL						
1 Samp ASAP						
2-10/30/78						
Bal. 1 per month						

CERTIFICATION OF CHEMICAL & PHYSICAL TESTS - HEAT TREATMENT - N.D.E. TESTS


HEAT NO.	4218	SERIAL NO'S.	KK-2253		QUANTITY IN HEAT	1	DATE POURED	11/22/78	
CHEMICAL ANALYSIS - MAT. SPEC. SA216 WCC									
C	MN	SI	P	S	CR	NI	MO	AL	CU
.18	.80	.43	.015	.016	.25	.26	.14	.062	.08
WELD METAL CHEMICAL ANALYSIS					WELDING PROCEDURE NUMBER				
Filler Metal Spec.	Lot Number		C	MN	SI	CR	NI	MO	Welder's I.D.
TENSILE PROPERTIES OF CASTING					HEAT TREATMENT				
T.S. P.S.I.	Y.P. P.S.I.	Y.S. P.S.I.	EL. %	R.A. %	BHN RANGE	TYPE	TEMP. °F	TOT HRS	LOADING
76,400	54,100		32%	59.0	163	HOMOGENIZE			
TENSILE PROPERTIES OF WELDING ELECTRODE					NORMALIZE				
T.S. P.S.I.	Y.F. P.S.I.	Y.S. P.S.I.	EL. %	R.A. %	BHN RANGE	NORMALIZE	1650°F	8	3097
						NORMALIZE	1600°F	8 1/4	3099
						TEMPER	1250°F	8	2966
IMPACT TEST			BEND TEST			WATER QUENCH:			
TEMP. °F	1	2	3	AVG.	Specification	OIL QUENCH			
(FT. LBS.)	34	53	39	43		Heat Treat Procedure 48.05			
(M.L.E.)	10	19	41	13	TYPE	DEG.	AGE	No.	
SHEAR. %	40	40	50	43	RESULTS	dated 4/21/77 and 48.04, Rev. 1 dated 6/15/78			
CORROSION TEST			Ferrite Content			PWHT TB 1150°F 15			
SPEC.	TYPE		Measured by			REPORTS ATTACHED			
TEMP.	RESULTS					HEAT TREATMENT CHART			
N.D.E. SPECIFICATIONS			SER. No.	APP'D	DATE	RT FILM & READER & SHOOTING SKETCH			
VT PER	MSS-SP55		2253	OK	11/78	WELD REPAIR MAP			
MT-LPT PER						SNT-TC-1A CERTIFICATE			
RT PER						WELDING PROCEDURE - QUALIFICATION TEST			
						WELDER'S QUALIFICATION TEST			

REMARKS:
Castings were manufactured in accordance with A/DV SPI PUR-2, Rev. 8, ASME Section III, 1977 Edition including 1977 Summer Addenda 23612, 23678-80
SEE ATTACHED REPORT
RAMBALL TEST LAB
4 ROUGH TEST BARS

We hereby certify that the above material has been tested in accordance with the listed specifications and conforms to all applicable requirements thereof.

Don P. ... 12/5/78
Quality Properties Date
DODGE LUNDRY & MACHINE CO.
6501 STATE ROAD., PHILA., PA. 19135

TECHTEL
454



Faint vertical text along the left margin, possibly a table of contents or index.

R12780

Ramball Testlab

6501 STATE ROAD - PHILADELPHIA, PA. 19135
(215) 332-4011

LABORATORY REPORT

Date: December 5, 1978
P.O.# M-2129

Anchor/Darling Valve Co.
701 First Street
Williamsport, PA 17701

Heat # 4218, PO# P-1840
Material: ASME-SA-216, WCB

TENSILE TEST

Lab #	23612
YIELD STRENGTH	54,100 psi
TENSILE STRENGTH	76,400 psi
ELONGATION	32 %
REDUCTION OF AREA	59 %

CHARPY IMPACT TEST

LAB #	FOOT MILS LATERAL		% SHEAR
	POUNDS	EXPANSION	
23678	34	40	40
23679	55	49	40
23680	39	41	50
Average	43	43	43

0.505" diameter tensile specimen, 2" gauge length.


1.0 cm x 1.0 cm Charpy Specimen.

The above test specimens were heat treated similar to production castings. The test bars only were given an additional stress relief heat treatment at 1150 degrees F for 15 hours. The Charpy V-Notch Impact Test was performed at +40 degrees F.



Metallurgist

BECHTEL
454



CASTING FEEDWATER ISOLATION VALVE UNIT 1

Anchor/Darling Valve Co. 701 First Street Williamsport, Pa. 17701		Same	U.S.	TK
PREPAID	COLLECT XX	VIA Truck	TERMS Net 30 days	
Anchor/Darling Valve Co. - Pa.		SHIP DATE See Below	D.P. ORDER NO. 1-06077 3-3	
QUANTITY 8	PATTERN NO. F-5080 (24x22x24 900# FWIV Bonnet)	CUSTOMER ORDER NO. P-184U		
PART. PER 1	MOLDS 8	S/P NO. F-5080 Rev. A att.	UNIT WGT. 405U	TOTAL WGT. 32499
ORD. ENTERED 9/8/78	CUSTOMER SPECIFICATION VT-MSS-SP55, No weld - Nucl. SA216-WCC	METAL Spec.	H.T. COUL C10	ROUTING CODE 128
SALESMAN 04	BUYER Louden.			TEST BARS 5 K.B.
CUST. REQ. DEL. 1 samp. ASA 2-10/30/78 Bal. 1 per month	INSTRUCTIONS (2) 3 copies T.R. & Docu., Subm. 4 rgh TB/heat (8) Melt & Lab use Melt Procedure MP 1.20, use 12U for gates, Charpy @40°F 40 M.L.E., Arc air visual defects as per Dodge's no weld spec. No weld - Nucl H.T. 2NET; H.T.-Chart req. PWHT 15 hrs. @1150°F, Subm. sample and obtain RT results before prod.			

CERTIFICATION OF CHEMICAL & PHYSICAL TESTS - HEAT TREATMENT - N.D.E. TESTS

HEAT NO. 4192	SERIAL NO. KD-2246	QUANTITY IN HEAT 1	DATE FORW'D 11/16/78							
CHEMICAL ANALYSIS - MAT. SPEC. SA216-WCC										
C	MN	SI	P	S	CU	NI	MO	AL	CU	
.16	1.00	.48	.019	.015	.37	.28	.12	.050	.09	
WELD METAL CHEMICAL ANALYSIS					WELDING PROCEDURE NUMBER					
Filler Metal Spec.	Lot Number	C	MN	SI	CR	NI	MO	Welder's I.D.		
TENSILE PROPERTIES OF CASTING					HEAT TREATMENT					
T.S. P.S.I.	Y.P. P.S.I.	Y.S. P.S.I.	EL. %	R.A. %	BHN RANGE	TYPE	TEMP. °F	TOT. HRS.	LOADING	CHAR. ATT.
82,400	55,400		36%	64.0	170	HOMOGENIZE				
TENSILE PROPERTIES OF WELDING ELECTRODE					HEAT TREATMENT					
T.S. P.S.I.	Y.P. P.S.I.	Y.S. P.S.I.	EL. %	R.A. %	BHN RANGE	NORMALIZE	1650°F	5	3085	✓
						NORMALIZE	1600°F	5	3087	✓
						TEMPER	1250°F	5 3/4	2960	✓
IMPACT TEST					BEND TEST					
TEMP. 40°F	1	2	3	AVG.	Specification	WATER QUENCH				
(FT. LBS.)	66	61	62	63		OIL QUENCH				
(M.L.E.)	56	56	54	55	TYPE	Heat Treat Procedure 48.05				
SHEAR. %	80	80	80	80	DEF. AGE No.	dated 4/21/77 and 48.04				
CORROSION TEST					RESULTS					
SPEC.	TYPE	Ferrite Content %			PWHT TB 1150°F 15					
TEMP.	RESULTS	Measured by			REPORTS ATTACHED					
N.D.E. SPECIFICATIONS					HEAT TREATMENT CHART					
VT PER MSS-SP55	SER. NO. 2246	APP'D OK	DATE 11/78	RT FILM & REPAIR & SHOOTING SKETCH						
MT-LPT PER					WELD REPAIR MAP					
RT PER					SNT-TC 1A CERTIFICATE					
					WELDING PROCEDURE - QUALIFICATION TEST					
					WELDER'S QUALIFICATION TEST					


REMARKS:
Castings were manufactured in accordance with ASME Section III, including NCA-2800 1977 Edition including 1977 Summer Addenda 23543, 23544, 40
SEE ATTACHED REPORT
RAMBALL TEST LAB
4 ROUGH TEST BARS

BECHTEL
454

We hereby certify that the above material has been tested in accordance with the listed specifications and conform to all applicable requirements thereof.
[Signature]
DODGE FOUNDRY & MACHINE CO.
6501 STATE ROAD, PHILA., PA. 19135

14
K1823

BPC
17
QAE



R2220

Ramball Testlab

6501 STATE ROAD - PHILADELPHIA, PA. 19135
(215) 332-4011

LABORATORY REPORT

Date: November 29, 1978
P.O.# M-2129

Anchor/Darling Valve Co.
701 First Street
Williamsport, PA 17701

Heat # 4192, PO# P-1840
Material: ASME-SA-216, WCC

TENSILE TEST

Lab #	23543
YIELD STRENGTH	55,400 psi
TENSILE STRENGTH	82,400 psi
ELONGATION	36 %
REDUCTION OF AREA	64 %

CHARPY IMPACT TEST

LAB #	FOOT	MILS LATERAL	%
	POUNDS	EXPANSION	
23544	66	56	80
23545	61	56	80
23546	62	54	80
Average	63	55	80

0.505" diameter tensile specimen, 2" gauge length.


1.0 cm x 1.0 cm Charpy Specimen.

The above test specimens were heat treated similar to production castings. The test bars only were given an additional stress relief heat treatment at 1150 degrees F for 15 hours. The Charpy V-Notch Impact Test was performed at +40 degrees F.

BECHTEL
454

Metallurgist

BPC
QAE



MAIN FEEDWATER ISOLATION VALVE UNIT 1

K1280

Heat Treat. Proc. #1007 (11/9/77)

RETENTION TIME MRR NO.

Anchors/Darling Valve Co.

TK

P-1980 S.O. #E-9023-2


1773

61414

7 - 22" 900 Disc Forgings for Dwg. C-16363


Forgings serialized #1 thru 7


Heat No. 218343



BECHTEL
284

BPC
17
QAE





NUTS Incorporated

TR
R.D. 12

PHILADELPHIA
Routes 724 & 23
Phoenixville, Pennsylvania 19460
Phone: (215) 935-2330

CLEVELAND
24272 Detroit Road
Cleveland, Ohio 44145
Phone: (216) 835-0660

MAIN FEEDWATER ISOLATION VALVE UNIT 1

CERTIFICATE OF ANALYSIS AND TESTS 12/21/78

TO: Anchor/Darling Valve Company
701 First Street
Williamsport, Pa. 17701

Heavy Hex Nuts; ASME-SA-194, Grade 7 B &
DATE: P.V.. Code Section III
1977 Edition thru Winter 1977
Addenda with Impact Tests
@ -150°F. Traceability
TYPE: stamping "NIA"
P/N (W-3288)

YOUR ORDER # P-2225

DESCRIPTION OF MATERIAL AND SPECIFICATIONS 2 1/2-8 (162 pcs.)

Heat No. 87254

7608

CHEMICAL ANALYSIS

Carbon (C)	.41
Manganese (Mn)	.85
Phosphorus (P)	.011
Sulfur (S)	.019
Silicon (Si)	.28
Chromium (Cr)	.93
Nickel (Ni)	

Molybdenum (Mo)	.17
Columbium (Cb)	
Copper (Cu)	
Cobalt (Co)	
Tin (Sn)	
Iron (Fe)	
Tungsten (W)	

Impact Test Data attached

PHYSICAL ANALYSIS

BECHTEL
284

Hardness: Rb
Rc 27/28
Brinell
Hardness after 24 hours
@ 1100°F.: BHN 255

SPECIAL TESTS

Subscribed and sworn to before me this

Min. Tempering Temp.: 1100°F.

21st day of Dec. 1978

91

12-74

***** We Certify that the material used in the manufacture of this order is in accordance with above specifications. *****

George W. Reed, Jr., Notary Public
East Pikeland Township, Chester County
My Commission Expires June 23, 1980
Member, Pennsylvania Association of Notaries

BY: John Wallace
V. P. Q. C.
DATE: 12/21/78



CERTIFICATE OF ANALYSIS AND TESTS

MAIN FEEDWATER ISOLATION VALVE UNIT 1

TK
RETENTION TIME
DATE [] YRS. 6 1 4 14
Nov. 27, 1978
CUST. ORDER NO.
2223
OUR ORDER NO. 2387

To:
Anchor Darling Valve Company
701 First Street
Williamsport, PA 17701
Attn: G. Brubaker

DESCRIPTION OF MATERIAL AND SPECIFICATIONS

1. Studs - ASME SA 193, Gr. B7:
Item 2 : 2-1/2" - 8 x 13-3/4" . (W-3320) Trace (All)
- 2.
3. Material per ASME SECT. III, CLASS 2, 1977 Edition thru Winter 1977 Addendum.
4. "We hereby certify that the materials supplied fully conforms to the specifications as outlined in your order and drawings indicated."

CHEMICAL ANALYSIS

Manufacturer	Heat Number	Carbon	Mang.	Phos.	Sulphur	Silicon	Nictel	Chromium	Maly.	ITEM
1. Copperweld 2-1/2"	2. 64931	3. .40	4. .97	.011	.019	.27		.99	.20	(2)

MECHANICAL PROPERTIES

Yield Lbs./Sq. In.	Tensile Strength Lbs./Sq. In.	Elongation % in	Reduction of Area %	Hardness	Bend Test ITEM	TEMPERING TEMP.
1. 124,000	2. 138,500	3. 20.0	4. 61.1	BHN 302	(2)	1100 F.

CHARPY IMPACT TEST

SPECIAL TESTS

Test. Temp. Plus 40 F.

SPECIMEN:	#1	#2	#3	REQ:		
1. Lateral Expan.	2. 41	3. 43	4. 41	25 min.		


BECHTEL
284

Sworn and Subscribed to before me this _____ day of _____ 1978

We hereby certify that the foregoing data is a true copy of the data furnished us by the producing mill or testing laboratory.

QA 91 1-3-79

R. E. C. CORPORATION
Lois A. Grieco
Lois A. Grieco



R. E. C. CORPORATION

47 CEDAR ST., NEW ROCHELLE, N. Y.



Faint vertical text along the left edge of the page, possibly bleed-through from the reverse side.

MAIN FEEDWATER ISOLATION VALVE UNIT 1

MIN. DIMENSIONAL RECORD
MQCS-44


E9023-2-2
TK

RETENTION TIME MRR NO.

LT YRS. 6 14 14

R13730

min. wall thickness



Record A & B after machining these areas.
Record C & D at Receiving.

Record E at Receiving Inspection.
Record F at completion of final machining.

Thoroughly scan the zones required and record only one dim. per zone.

The one recorded dim. shall be the min. thickness reading observed in that zone.

FOR USE ON BODIES ONLY:

Shop Order/Item E9023 -2- 2

Heat/Serial No. HT-4218 S/N-K1814

Min. Dimension "A" Zone 3.050

Min. Dimension "B" Zone 3.040

Min. Dimension "C" Zone 2.670

Min. Dimension "D" Zone 2.750

QA 83 APR 28 1979
Date & Stamp

BECHTEL
284
Date & Stamp

MQCS-44-1

Fig. 1



QA 85
Level III
5-1-79

MAIN FEEDWATER ISOLATION VALVE UNIT 1

E9023-2-2


MIN. DIMENSIONAL RECORD

MQCS-44

RETENTION TIME ^{TK} MRR NO.

LT YRS. 61414

R-12730



Record A & B after machining these areas.
Record C & D at Receiving.

Record E at Receiving Inspection.
Record F at completion of final machining.

Thoroughly scan the zones required and record only one dim. per zone.

The one recorded dim. shall be the min. thickness reading observed in that zone.

FOR USE ON BONNETS ONLY:

Shop Order/Item

E9023 -2-2

Heat/Serial No.

HT-4192...S/N-K1823.

Min. Dimension "E" Zone

2.390.

Date & Stamp

QA 85
LEVEL 11 3-7-79

BECHTEL
284

BPC
17
QAE

MQCS-44-2

Fig. 2.




MAIN FEEDWATER ISOLATION VALVE UNIT 1

MIN. DIMENSIONAL RECORD
MQCS-44

E9023-2-2

TK
RETENTION TIME MRR NO.

61414
R1273(0)



Record A & B after machining these areas.
Record C & D at Receiving.

Record E at Receiving Inspection.
Record F at completion of final machining.

Thoroughly scan the zones required and record
only one dim. per zone.

The one recorded dim. shall be the min. thickness
reading observed in that zone.

FOR USE ON DISCS ONLY:

Shop Order/Item

E-9023 - 2-2

Heat/Serial No.

HT-218343 S/N-5

Min. Dimension "F" Zone


3.830

Date & Stamp

DA86
levII 3-7-79

BEGTEL
284





ATTACHMENT 2

ITEM	PENETRATION CAPS			MAIN STEAM & MAIN FEEDWATER FLUED HEAD PENETRATION			MAIN STEAM ISOLATION VALVE MAIN FEEDWATER ISOLATION VALVES	
	Pene.	Thickness	LSMT	Pene.	Thickness	LSMT	Pipe Size	
1. NRC Proposed LSMT.	1	1.5"	53°F	1	5.5"	53°F	28"	6 Valves: Various parts at various thickness. UV-170 UV-180 UV-171 UV-181 UV-132 UV-137
	2	1.5"		2	5.5"		28"	
	3	1.5"		3	5.5"		28"	
	4	1.5"		4	5.5"		28"	
	8	1.5"	53°F	8	5.5"	53°F	24"	
	10	1.5"		10	5.5"		24"	
2. Normal Operation	(See Item No. 5 below)			Flued heads for both main steam and main feedwater penetrations are at normal operating system fluid temperatures which are well above the proposed LSMT's.			(See Item No. 5 below)	
3. Maintenance and testing	(See Item No. 5 below)			<u>Main Steam</u> A. Hot Standby - For these conditions the flued head will be at system fluid temperatures which are greater than LSMT's.		<u>Main Feedwater</u> A. Hot Standby - The motor-driven startup auxiliary feedwater pump will be used for hot standby conditions. The warm feedwater will keep the flued head well above the LSMT.		(See Item No. 5 below)
				B. Cold Shutdown - (See Item No. 5 below)		B. Cold Shutdown - (See Item No. 5 below)		

ITEM	PENETRATION CAPS	MAIN STEAM & MAIN FEEDWATER FLUED HEAD PENETRATION	MAIN STEAM ISOLATION VALVE MAIN FEEDWATER ISOLATION VALVES
4. Postulated Accidents	(See Item No. 5 below)	A. For DBAs normal operating temperatures and pressures are assumed as initial conditions (see 2 above). B. For potential accident at other initial conditions (see 3 above)	A. For DBAs (see 4A for main steam) B. For other conditions (see 4B for main steam) (See Item No. 5 below)
5. Remarks	A. The design of the penetration caps listed above has been reviewed and the current design shows that they are properly sized to fulfill their function; i.e., design thickness is more than sufficient to maintain containment function. B. However, it has been noted that to fulfill the same function the minimum required wall thickness is less than 1.5 inches. Under code requirements, material of this thickness need not be impact tested. Therefore, caps with a minimum required wall	A. For the Cold Shutdown condition, pipe break loads would not be induced on the main steam flued head. Therefore an analysis can be performed to determine the minimum required wall thickness. The thickness would be less than 5.5 inches. B. Pipebreak loads are the largest loads on the flued heads and are the controlling factors in establishing the flued head dimension. C. The limiting temperature condition on the flued head occurs during the hydrostatic	A. (See Item No. 5A for Main Steam) B. (See Item No. 5B for Main Steam) A. MSIV's and MFIV's are similar to flued heads (see Item Nos. 5A and 5B under main steam and main under feedwater flued heads).

ITEM	PENETRATION CAPS	MAIN STEAM & MAIN FEEDWATER FLUED HEAD PENETRATION	MAIN STEAM ISOLATION VALVE MAIN FEEDWATER ISOLATION VALVES
5. <u>Cont'd</u>	thickness of approxi- mately 1.5" will main- tain containment function for all temperatures.	test of the steam gen- erators. For this test, temperatures should be maintained above 60°F. This is a limiting con- dition under which the material of interest is called upon to provide a pressure boundary during the performance of the containment function.	

10005