

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8210190717 DOC. DATE: 82/10/14 NOTARIZED: NO DOCKET #
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528
 STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Publi 05000529
 STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publi 05000530

AUTH. NAME AUTHOR AFFILIATION
 VAN BRUNT, E.E. Arizona Public Service Co.
 RECIP. NAME RECIPIENT AFFILIATION
 NOVAK, T.M. Assistant Director for Licensing

SUBJECT: Requests NRC review results of PWR design analyses to
 approve removal of pipe whip restraints. Meeting w/NRC to
 discuss request & facilitate exchange of info & questions
 suggested.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: Standardized plant. 05000528
 Standardized plant. 05000529
 Standardized plant. 05000530

RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
NRR/DL/ADL	1 0	NRR LB3 BC	1 0
NRR LB3 LA	1 0	LICITRA, E. 01	1 1

INTERNAL: ELD/HDS3	1 0	IE FILE	1 1
IE/DEP EPDS 35	1 1	IE/DEP/EPLB 36	3 3
NRR/DE/AEAB	1 0	NRR/DE/CEB 11	1 1
NRR/DE/EQB 13	3 3	NRR/DE/GB 28	2 2
NRR/DE/HGEB 30	2 2	NRR/DE/MEB 18	1 1
NRR/DE/MTEB 17	1 1	NRR/DE/QAB 21	1 1
NRR/DE/SAB 24	1 1	NRR/DE/SEB 25	1 1
NRR/DHFS/HFEB 40	1 1	NRR/DHFS/LQB 32	1 1
NRR/DHFS/OLB 34	1 1	NRR/DHFS/PTRB20	1 1
NRR/DSI/AEB 26	1 1	NRR/DSI/ASB 27	1 1
NRR/DSI/CPB 10	1 1	NRR/DSI/CSB 09	1 1
NRR/DSI/ETSB 12	1 1	NRR/DSI/ICSB 16	1 1
NRR/DSI/PSB 19	1 1	NRR/DSI/RAB 22	1 1
NRR/DSI/RSE 23	1 1	NRR/DST/LGB 33	1 1
<u>REG FILE</u> 04	1 1	RGNS	2 2
RM/DDAMI/MIB	1 0		

EXTERNAL: ACRS 41	6 6	BNL (AMDTs ONLY)	1 1
DMB/DSS (AMDTs)	1 1	FEMA-REP DIV 39	1 1
LPDR 03	1 1	NRC PDR 02	1 1
NSIC 05	1 1	NTIS	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTR 55 ENCL 49

ARIZONA



PUBLIC SERVICE COMPANY

P. O. BOX 21666 • PHOENIX, ARIZONA 85036

October 14, 1982
ANPP-22020 - WFQ/TFQ

Mr. Thomas Novak
Assistant Director for Licensing
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Subject: Palo Verde Nuclear Generating Station
(PVNGS) Units 1, 2 and 3
Docket Nos. STN-50-528/529/530
File: 82-056-026; G.1.01.10

Reference: NUREG/CR-2189, "Probability of Pipe Fracture in the primary coolant loop of a PWR plant", dated September, 1981.

Dear Mr. Novak:

The design basis for PVNGS Units 1, 2 and 3 includes the postulation of guillotine pipe breaks in the Reactor Coolant System (RCS) main loop piping. Recent analyses, the referenced report, of Westinghouse PWR's have shown that:

1. The probability of guillotine failures are extremely small (10^{-12})
2. A through-the-wall crack of detectable size will remain stable when subjected to an SSE.

A probabilistic analysis of the PVNGS RCS is being conducted by Lawrence Livermore Laboratories (LLL) to define the probability of a guillotine rupture. We have furnished LLL with information related to the design and expected loads on the RCS and our seismic consultant, ERTEC, is developing a site specific seismic hazard curve. This seismic hazard curve is expected to be complete and transmitted to LLL by October 31, 1982. It is expected that LLL will complete their analyses on PVNGS by December, 1982. Favorable results from this analysis is expected, similar to the results of the referenced report. This may justify the elimination of the double-ended guillotine break of RCS piping from the PVNGS design basis, which would dismiss the need for RCS pipe whip restraints. These restraints require substantial maintenance, surveillance and adjustment efforts during the in-service inspection program, which creates a substantial radiation exposure hazard to personnel performing these tasks. These restraints are also extensive and expensive to manufacture and install. If justified by the LLL analysis, we would very much consider removing them from the PVNGS design.

8210190717 821014
PDR ADCK 05000528
A PDR



13001

511

Mr. T. Novak
October 14, 1982
ANPP-22020 - WFQ/TFQ
Page 2

The construction status of the restraints is shown below:


UNITS

STATUS

1	Installed, Unadjusted
2	Machining of saddles to start November, 1982
3	Machining of saddles to start January, 1985.

We feel, from results of previous analyses on other PWR designs, the LLL analysis for PVNGS will justify elimination of these restraints from the design basis. We request that the NRC review the results of LLL analyses as soon as they are available, so that you can approve the removal of the restraints from the PVNGS design. We request a meeting with the appropriate members of the NRC staff, as discussed with R. Bosnak, Chief, Mechanical Engineering Branch, on October 20, 1982, to discuss this request and to facilitate an exchange of information, and any additional questions the NRC staff may have on this matter.

Very truly yours,



E. E. Van Brunt, Jr.
APS Vice President,
Nuclear Projects
ANPP Project Director

EEVBJr/TFQ/sp

cc: E. Licitra
R. Bosnak
L. Bernabei
P. L. Hourihan
A. C. Gehr

57

THE UNITED STATES OF AMERICA

1957