

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8210220394 DOC. DATE: 82/10/06 NOTARIZED: NO DOCKET #
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Public 05000528
 AUTH. NAME AUTHOR AFFILIATION
 VAN BRUNT, E.E. Arizona Public Service Co.
 RECIP. NAME RECIPIENT AFFILIATION
 NOVAK, T. Assistant Director for Licensing

SUBJECT: Corrected copy of commitment to perform guide tube wear surveillance insp described in NUREG-0852 Section 4.2.3.1, per NUREG-0857 Section 4.2.5 requirement. Commitment will be incorporated into next PSAR amend.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: Standardized plant.

05000528

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	NRR/DL/ADL	1 0	NRR LB3 BC	1 0
	NRR LB3 LA	1 0	LICITRA, E. 01	1 1
INTERNAL:	ELD/HDS3	1 0	IE FILE	1 1
	IE/DEP EPDS 35	1 1	IE/DEP/EPLB 36	3 3
	NRR/DE/AEAB	1 0	NRR/DE/CEB 11	1 1
	NRR/DE/EQB 13	3 3	NRR/DE/GB 28	2 2
	NRR/DE/HGEB 30	2 2	NRR/DE/MEB 18	1 1
	NRR/DE/MTEB 17	1 1	NRR/DE/QAB 21	1 1
	NRR/DE/SAB 24	1 1	NRR/DE/SEB 25	1 1
	NRR/DHFS/HFEB40	1 1	NRR/DHFS/LGB 32	1 1
	NRR/DHFS/OLB 34	1 1	NRR/DHFS/PTRB20	1 1
	NRR/DSI/AEB 26	1 1	NRR/DSI/ASB 27	1 1
	NRR/DSI/CPB 10	1 1	NRR/DSI/CSB 09	1 1
	NRR/DSI/ETSB 12	1 1	NRR/DSI/ICSB 16	1 1
	NRR/DSI/PSB 19	1 1	NRR/DSI/RAB 22	1 1
	NRR/DSI/RSB 23	1 1	NRR/DST/LGB 33	1 1
	REG FILE 04	1 1	RGN5	2 2
	RM/DDAMI/MIB	1 0		
EXTERNAL:	ACRS 41	6 6	BNL (AMDTS ONLY)	1 1
	DMB/DSS (AMDTS)	1 1	FEMA-REP DIV 39	1 1
	LPDR 03	1 1	NRC PDR 02	1 1
	NSIC 05	1 1	NTIS	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 55 ENCL 49

ARIZONA



PUBLIC SERVICE COMPANY

P. O. BOX 21666 • PHOENIX, ARIZONA 85036

October 6 1982

ANPP-21957 - WFQ/TFQ

Mr. Thomas Novak
Assistant Director for Licensing
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

CORRECTED COPY

Subject: Palo Verde Nuclear Generating Station
(PVNGS) Units 1, 2 and 3
Docket Nos. STN-50-528/529/530
File: 82-056-026; G.1.01.10

- References: (A) NUREG-0857, "Safety Evaluation Report related to the operation of the Palo Verde Nuclear Generating Station Units, 1, 2 and 3," dated November, 1981.
(B) NUREG-0852, "Safety Evaluation Report related to the Final Design Approval of the Combustion Engineering Standard Nuclear Steam Supply System", dated November, 1981

Dear Mr. Novak:

Section 4.2.5 of Reference (A), requires the first CESSAR System 80 applicant, PVNGS Unit 1, commit to performing the Guide Tube Surveillance Program described in Reference (B), Section 4.2.3.1.

Our commitment to this item will be as follows:

We will perform the Guide Tube Wear Surveillance inspection on representative bundles of the first reload of Unit 1. If, following this inspection, no significant Guide Tube wear is observed, no subsequent inspections for Guide Tube wear will be conducted. If, on the other hand, significant Guide Tube wear is observed, we will perform the inspection at the next reload and evaluate action to be taken to eliminate the problem, as well as future inspection programs.

This commitment will be incorporated into the PVNGS FSAR in an upcoming amendment.

Please contact me if you have any questions on this matter.

Very truly yours,

E. E. Van Brunt, Jr.

E. E. Van Brunt, Jr.

APS Vice President,

Nuclear Projects

ANPP Project Director

8210220394 821006
PDR ADOCK 05000528
PDR

EEVBJr/TFQ/sp

BOO1

DISTRIBUTION

E. Licitra
L. Bernabei
P. L. Hourihan
R. Meyer
A. C. Gehr

bcc:

G. C. Andognini
J. E. Kirby
J. M. Allen
A. C. Rogers
J. Vorees
W. F. Quinn
R. W. Kramer
S. R. Frost
M. D. Holohan
C. Ferguson
W. G. Binham
G. F. Kopchinski