

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8402270340. DOC. DATE: 84/02/23 NOTARIZED: YES DOCKET #  
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Public 05000528  
 STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Public 05000529  
 STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Public 05000530  
 AUTH. NAME AUTHOR AFFILIATION  
 VAN BRUNT, E. E. Arizona Public Service Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 KNIGHTON, G. Licensing Branch 3

SUBJECT: Forwards response to NRC 831220 request for addl info re:  
 TMI Item II.F.2, "Instrumentation for Detection of Inadequate  
 Core Cooling."

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 40 <sup>ON S/P/F</sup> SIZE: 17  
 TITLE: OR Submittal: Inadequate Core Cooling (Item II.F.2) GL 82-28

NOTES: Standardized plant. 05000528  
 Standardized plant. 05000529  
 Standardized plant. 05000530

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	NRR LB3 BC	1 1	NRR LB3 LA	1 1
	LICITRA, E.	1 1		
INTERNAL:	NRR SHEA, J 01	1 1	NRR/DHFS/HFEB15	1 1
	NRR/DHFS/PSRB16	1 1	NRR/DL/ORAB 08	1 1
	NRR/DL/ORB5	1 1	NRR/DSI DIR 09	1 1
	NRR/DSI/CPB 10	3 3	NRR/DSI/ICSB 14	1 1
	NRR/DSI/R5B 13	1 1	<u>REG FILES</u> 04	1 1
	RGNS 07	1 1		
EXTERNAL:	ACRS 17	10 10	LPDR 03	1 1
	NRC PDR 02	1 1	NSIC 06	1 1
	NTIS 05	1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 30 ENCL 30



# Arizona Public Service Company

P.O. BOX 21666 • PHOENIX, ARIZONA 85036

February 23, 1984  
ANPP 28929-WFQ/MAJ

Director of Nuclear Reactor Regulation  
Attention: Mr. George Knighton, Chief  
Licensing Branch No. 3  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: Palo Verde Nuclear Generating Station (PVNGS)  
Units 1, 2 and 3  
Docket Nos. STN-50-528/529/530  
File: 84-056-026; G.1.01.10

Reference: 1. Letter from G. W. Knighton, NRC, to E. E. Van Brunt, Jr.,  
APS, dated December 20, 1983. Request for Additional  
Information on TMI Item II.F.2.  
2. Letter to G. W. Knighton, NRC, from E. E. Van Brunt, Jr.,  
APS, dated July 29, 1983. Revised APS response to TMI  
Item II.F.2.

Dear Mr. Knighton:

Reference (1) requested Arizona Public Service Company (APS) to submit  
additional information to the NRC concerning TMI Item II.F.2,  
"Instrumentation for Detection of Inadequate Core Cooling." Attachment A  
is the APS response to the NRC request in Reference (1).

If you have any further questions, please contact me.

Very truly yours,

*E. E. Van Brunt*

E. E. Van Brunt, Jr.  
APS Vice President, Nuclear  
ANPP Project Director

EEVB/MAJ/sp  
Attachment

cc: E. A. Licitra (w/a)  
A. C. Gehr "  
T. Huang "  
G. Mazetis "

8402270340 840223  
PDR ADCK 05000528  
A PDR

*Adopt  
1/40*



STATE OF ARIZONA    )  
                              ) ss.  
COUNTY OF MARICOPA)

I, A. Carter Rogers, represent that I am Nuclear Engineering Manager of Arizona Public Service Company, that the foregoing document has been signed by me for Edwin E. Van Brunt, Jr., Vice President, Nuclear, on behalf of Arizona Public Service Company with full authority so to do, that I have read such document and know its contents, and that to the best of my knowledge and belief, the statements made therein are true.

A. Carter Rogers  
A. Carter Rogers

Sworn to before me this 23rd day of February, 1984.

Nora E. Meador  
Notary Public

My Commission Expires:

My Commission Expires April 6, 1987



APS RESPONSE TO THE NRC  
REQUEST FOR ADDITIONAL INFORMATION ON TMI-2  
TASK ACTION PLAN II.F.2 FOR PALO VERDE  
NUCLEAR GENERATING STATION  
UNITS 1, 2, AND 3

QUESTION: 1. Provide a functional and design description of the Emergency Response Facility Data Acquisition and Display System (ERFDADS) relative to the function and design of the Critical Function Monitoring System (CFMS) described in the CESSAR-80 submittal.

RESPONSE: The CFMS is described in the CESSAR-80 submittal as the "Heart of the Integrated Accident Monitoring System (AMS)." It is designed to meet the criteria set forth in NUREG-0696; "Functional Criteria for Emergency Response Facilities." The CFMS is a dedicated, computer based, Non-Class IE plant information and display system. Specifically, the CFMS:

1. Provides primary Safety Parameter Display System/Inadequate Core Cooling (SPDS/ICC) display in Control Room, Technical Support Center (TSC), and the Emergency Operation Facility (EOF).
2. Includes the Historical Data Storage and Retrieval (HDSR) System.
3. Provides the hardware capability for transmitting data to the NRC Operation Center via the Nuclear Data Link (NDL).
4. Provides the capability to display Regulatory Guide 1.23 and 1.97 input parameters in the Control Room, TSC and EOF.

ERFDADS is a Non-Class IE System, very similar to CFMS, that provides all the above mentioned information. Figure (1) shows the block diagram of the ERFDADS System.

The ERFDADS man/machine interface includes one color-graphic CRT per unit in the Control Room, three color-graphic CRT's per unit and two line printers, one for demand and one dedicated for alarms, in the TSC and two color-graphic CRT's per unit and a line printer in the EOF. A simplified configuration diagram for ERFDADS and the QSPDS is shown in Figure (2).

The following is a design description of the CFMS:

- A. The CFMS shall provide the capability to display the status of the following critical functions:





1. Core Reactivity Control
  2. Core Heat Removal Control
  3. Reactor Coolant System Inventory Control
  4. Reactor Coolant System Pressure Control
  5. Reactor Coolant System Heat Removal Control
  6. Containment Pressure/Temperature Control
  7. Containment Isolation Control
  8. Radiation Emission Control
- B. The CFMS shall alarm deviations of the critical functions.
- C. The CFMS shall provide the User with concise, understandable, integrated information to assist in accessing plant status during all modes of plant operation.
- D. The CFMS shall be capable of measuring the value of plant process input signals.
- E. The CFMS shall be capable of storing the values of plant process signals for a minimum of 16 hours. The values shall be time tagged.
- F. The CFMS shall be capable of determining the alarm status of each process parameter.
- G. The CFMS shall be capable of displaying information to the operator by means of a color cathode ray tube (CRT). The CFMS shall be capable of utilizing alphanumeric data formats, shapes, symbols, color coding, and blinking for information display in accordance with established human engineering guidelines.
- H. The CFMS shall be capable of utilizing greater than 20 fixed format displays (pages) for information presentation. Page selection shall be under control of the operator. Each display station (CRT and keyboard) shall be capable of independently calling up any fixed format display page in the repertoire.

The ERFDADS has all the design capabilities as the CFMS. The ERFDADS presents plant data to personnel in the Control Room and in other areas. This presentation is primarily via a set of color monitor displays. To help personnel focus on detailed information the displays are organized in a hierarchial arrangement. The highest level in the display hierarchy is deviation bar charts, which are designated safety parameter displays (SPD). The SPDS indicates deviation from normal key safety parameters per operational mode such that an operator can rapidly access system parameters.

Below the SPD hierarchy are piping and instrumentation diagrams, displays (P&ID's) and various plots. The P&ID's present plant data using simplified diagrams of plant systems identifying key process parameters. Thus, the operator can focus on a particular plant function. The plots available include time-history plots and pressure versus temperature plots. The time-history plots show parameter value versus time curves. The pressure versus temperature plots allow the operator to quickly access the state of the primary and secondary systems. Other displays, such as demand and summary displays, are also available.

While ERFDADS employs a three-level hierarchy of displays, menus also allow the operator to quickly determine the position of a display in the hierarchy. Additionally, menus are also hierarchial in nature and can easily be selected from the local keyboard. The top-level menu, from which all other menus can be displayed, includes the following:

1. SPD Menu
2. P&ID Menu
3. Demand Display Menu
4. Summary Display Menu, and
5. System Interface Menu.

Table (1) provides a comparison of the CFMS and ERFDADS in relation to the NRC regulatory requirements.



QUESTION 2. Provide a figure to show the Accident Monitoring System (AMS) including all of the components of the final Inadequate Core Cooling Instrumentation (ICCI) System which will clearly identify the primary and backup display system for Core Exit Thermocouples (CETs) and the location of the ICCI display system in the control room. Describe any deviation from the standard CESSAR-80 system design.

RESPONSE: The Accident Monitoring System (AMS) consists of two major subsystems:

1. Critical Function Monitoring System (CFMS).
2. Qualified Safety Parameter Display System (QSPDS). (Including processing and display for Inadequate Core Cooling).

The Emergency Response Facility (ERF) computer system is similar to the AMS and consists of three major subsystems:

1. ERFDADS (Emergency Response Facility Data Acquisition and Display System) which is identical to the CFMS as explained in Item No. 1.
2. QSPDS (Qualified Safety Parameter Display System) including processing and display for Inadequate Core Cooling. This item is provided by C-E and is identical to the System 80 QSPDS.
3. Chemical and Radiological Analysis Computer System (CRACS). Provides post-accident sampling and dose projection.

These major systems communicate with each other, and provide information collection, processing, and a display capability to the emergency operation crew. Figure (1) shows the block diagram of the ERFDADS System.

The QSPDS (Qualified Safety Parameter Display System) provides a two-channel, seismically qualified Class IE display of safety parameters including the Inadequate Core Cooling processing information.

The QSPDS utilizes a microprocessor based design for the signal processing equipment in conjunction with an alphanumeric display and associated keyboard for each of the two channels. Each channel will accept and process QSPDS/ICCI input parameter signals such as core exit thermocouples and transmit its output to the alphanumeric display. In addition, each channel will transmit its output to the ERFDADS.



2

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62

63

64

65

66

67

68

69

70

71

72

73

74

75

Figure (3) shows the block diagram of the QSPDS. It also identifies the primary and backup display systems.

Figure (4) shows the location of the QSPDS in the Control Room.

Figure (5) provides the sensor locations for the Inadequate Core Cooling instrumentation.

QUESTION 3. Describe locations of the Heated Junction Thermocouple (HJTC) sensors in the reactor vessel and identify any deviation from the standard CESSAR-80 system design.

RESPONSE: The HJTC design incorporates two separate probe assemblies which enter the reactor vessel through the two Reactor Vessel Level Monitoring System (RVLMS) nozzles located on the top of the reactor vessel head as shown in Figure (6).

There are a total of 8 HJTC sensors on each of the two probe assemblies. Their respective locations are shown on Figure (7) relative to the fuel alignment plate.

The Palo Verde Nuclear Generating Station (PVNGS) RVLMS design is identical with the Standard System 80 design. There are no plant specific deviations. Therefore, the discussion in CESSAR Appendix B, Section II.F.2 is applicable to the PVNGS System.

QUESTION 4. In the CESSAR SER it is required that the CE Owners Group (CEOG) should provide a modification to the generic CEOG Emergency Procedure Guidelines (EPG), CEN-152, Revision 1, for use of the RVLMS. Discuss the status of the CEOG effort with respect to this requirement including the completion schedule and provide the completion schedule for Arizona Public Service Company (APS) to incorporate this CEOG EPG into the PVNGS ICC procedures.

RESPONSE: In a letter to D. G. Eisenhut, USNRC, from R. W. Wells, CEOG, dated October 28, 1983, the NRC was informed that the CEOG authorized the incorporation of the RVLMS information into the EPGs as Revision 2 to CEN-152. The CEOG is to submit this revision to the EPGs to the NRC by April 1984. Once Revision 2 to CEN-152 is issued, APS will review the EPG modifications for the RVLMS information and determine what revisions to the PVNGS Procedure Generation Package (PGP) are required, or what deviations are necessary.

Any revisions made to the PVNGS PGP will be made in accordance with the description and schedule (shown in Figure 8) identified in the letter to G. W. Knighton, NRC, from E. E. Van Brunt, Jr., APS, (ANPP-23213) dated June 30, 1983. Even though the above



referenced letter pertains to the TMI Action Plan Item II.K.3.5, the plan and schedule for the plant specific activities of factoring the CEOG program results into the PVNGS EOPs and operator training applies to the subject of incorporation of the RVLMS information. Therefore, the evaluation and inclusion of the CEN-152, Revision 2 changes into the PVNGS PGP will be completed within 6 months of receipt of the NRC approval of the Revision 2 changes.

QUESTION 5. Clarify the implementation schedule for declaring that the final ICCI system is fully operational.

RESPONSE: The final ICCI installation and verification will be four (4) weeks after the completion of the fuel load on PVNGS Unit 1.





A  
B  
C  
D  
E  
F  
G  
H  
I  
J  
K  
L  
M  
N  
O  
P  
Q  
R  
S  
T  
U  
V  
W  
X  
Y  
Z

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100


101 102 103 104 105 106 107 108 109 110 111 112 113 114 115 116 117 118 119 120 121 122 123 124 125 126 127 128 129 130 131 132 133 134 135 136 137 138 139 140 141 142 143 144 145 146 147 148 149 150 151 152 153 154 155 156 157 158 159 160 161 162 163 164 165 166 167 168 169 170 171 172 173 174 175 176 177 178 179 180 181 182 183 184 185 186 187 188 189 190 191 192 193 194 195 196 197 198 199 200

201 202 203 204 205 206 207 208 209 210 211 212 213 214 215 216 217 218 219 220 221 222 223 224 225 226 227 228 229 230 231 232 233 234 235 236 237 238 239 240 241 242 243 244 245 246 247 248 249 250 251 252 253 254 255 256 257 258 259 260 261 262 263 264 265 266 267 268 269 270 271 272 273 274 275 276 277 278 279 280 281 282 283 284 285 286 287 288 289 290 291 292 293 294 295 296 297 298 299 300

301 302 303 304 305 306 307 308 309 310 311 312 313 314 315 316 317 318 319 320 321 322 323 324 325 326 327 328 329 330 331 332 333 334 335 336 337 338 339 340 341 342 343 344 345 346 347 348 349 350 351 352 353 354 355 356 357 358 359 360 361 362 363 364 365 366 367 368 369 370 371 372 373 374 375 376 377 378 379 380 381 382 383 384 385 386 387 388 389 390 391 392 393 394 395 396 397 398 399 400

401 402 403 404 405 406 407 408 409 410 411 412 413 414 415 416 417 418 419 420 421 422 423 424 425 426 427 428 429 430 431 432 433 434 435 436 437 438 439 440 441 442 443 444 445 446 447 448 449 450 451 452 453 454 455 456 457 458 459 460 461 462 463 464 465 466 467 468 469 470 471 472 473 474 475 476 477 478 479 480 481 482 483 484 485 486 487 488 489 490 491 492 493 494 495 496 497 498 499 500

DATE 11/03/83	ARIZONA NUCLEAR POWER PROJECT JOB 10407	SYSTEM DESCRIPTIONS	
REVISION 0		TITLE EMERGENCY RESPONSE FACILITIES DATA ACQUISITION AND DISPLAY SYSTEM	DESIGNATION SD



\* POSSIBLE IMPLEMENTATION IN FUTURE  
DATA ACQUISITION AND DISPLAY SYSTEM  
BLOCK DIAGRAM  
Figure SD-1




TABLE 1

COMPARISON BETWEEN CFMS AND ERFDADS

<u>Regulation</u>	<u>Regulation Requirement</u>	
	<u>CFMS</u> Non-Class IE	<u>ERFDADS</u> Non-Class IE
NUREG 0696 Emergency Response Facility Criteria	o Human Engineered Safety Parameter Display System	o Human Engineered Safety Parameter Display System
	o Nuclear Data Link (Hardware Portion)	o Nuclear Data Link (Hardware Portion)
	o Technical Support Center Data System	o Technical Support Center Data System
	o Emergency Operation Facility Data System	o Emergency Operation Facility Data System
NUREG 0737	o Human Engineered Primary Display	o Human Engineered Primary Display
Regulatory Guide 1.97 Accident Monitoring Instrument and Display	o Categories 2 and 3 Signal processing and display (Category 1 signal processing met by Class IE QSPDS data link to CFMS)	o Categories 2 and 3 Signal processing and display (Category 1 signal processing met by Class IE QSPDS data link to ERFDADS. Additionally, Category 1 signals are available for display on ERFDADS.)
Regulatory Guide 1.23 Meteorological Data Acquisition, Recording and Retention	o Category 3 Signal processing and display	o Category 3 Signal processing and display




ERFDADS / OSPDS CONFIGURATION



LEGEND

SPD	SAFETY PARAMETER DISPLAY
CFM	CRITICAL FUNCTION MONITORING
HDSR	HISTORIC DATA STORAGE & RETRIEVAL
DL	DATA LINK
VDU	VISUAL DISPLAY UNIT
KB	KEYBOARD
PL	PHONE LINE
SCM	SUBCOOLED MARGIN MONITOR
RVLMS	REACTOR VESSEL LEVEL MONITORING SYSTEM
CET	CORE EXIT THERMOCOUPLES
I	ISOLATOR
ODU	QUALIFIED DISPLAY UNIT






QUALIFIED SAFETY PARAMETER DISPLAY SYSTEM DIAGRAM






FIGURE - 4



"AT THE CONTROLS"  
AREA  
(REFER TO SECTION 13.5)


 Palo Verde Nuclear Generating Station  
FSAR

MAIN CONTROL ROOM AND  
COMPUTER ROOM ARRANGEMENT  
(Sheet 1 of 2)  
Figure 7.5-1



FIGURE - 5.


SENSOR LOCATIONS FOR INADEQUATE CORE COOLING INSTRUMENTATION



- 31 CET SENSORS FOR CHANNEL A
- 30 CET SENSORS FOR CHANNEL B
- \*\* ALTHOUGH TOP MOUNTED IN CORE INSTRUMENTATION IS SHOWN, SENSOR LOCATIONS FOR BOTTOM MOUNTED INSTRUMENTATION ARE IN SAME GENERAL VICINITY



FIGURE - 6  
RVLMS Locations



PLAN VIEW  
SCALE: NONE  
CEDM LOCATIONS  
92 & 96



FIGURE 7.

HJTC Sensor Locations








FIGURE 8

TASK	TIME/MONTH	1	2	3	4	5	6
REVIEW							
REVISE PSTG							
REVISE EP & RO's							
VERIFY PROCEDURES							
VALIDATE PROCEDURES							
INC. INTO STATION MANUAL							
INC INTO TRAINING PROGRAM							

6 - 10 months for results from CE  
 6 months for incorporation into PVNGS  
 12 - 16 months from start to completion

