

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RID'S)

ACCESSION NBR: 8411060398 DOC. DATE: 84/11/01 NOTARIZED: YES DOCKET #
 FACIL: STN-50-528 Palo Verde Nuclear Station, Unit 1, Arizona Publi 05000528
 STN-50-529 Palo Verde Nuclear Station, Unit 2, Arizona Publi 05000529
 STN-50-530 Palo Verde Nuclear Station, Unit 3, Arizona Publi 05000530


AUTH.NAME	AUTHOR AFFILIATION
VAN BRUNT, E,E.	Arizona Public Service Co.
RECIP.NAME	RECIPIENT AFFILIATION
KNIGHTON, G.	Licensing Branch 3

SUBJECT: Forwards info supporting ESF actuation sys design compliance ~~SECRET~~
 w/GDC 21, Reg Guides 1.22 & 1.118 & IEEE Std 338, per 840702
 request.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 49
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: Standardized plant. 05000528
 Standardized plant. 05000529
 Standardized plant. 05000530

	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL
INTERNAL:	NRR/DL/ADL	1	0	NRR LB3 BC	1	0
	NRR LB3 LA	1	0	LICITRA, E	01	1
	ADM/LFMB	1	0	ELD/HDS3	1	0
	IE FILE	1	1	IE/DEPER/EPB 36	1	1
	IE/DEPER/IRB 35	1	1	IE/DQASIP/QAB21	1	1
	NRR ROE, M,L	1	1	NRR/DE/AEAB	1	0
	NRR/DE/CEB 11	1	1	NRR/DE/EHEB	1	1
	NRR/DE/EQB 13	2	2	NRR/DE/GB 28	2	2
	NRR/DE/MEB 18	1	1	NRR/DE/MTEB 17	1	1
	NRR/DE/SAB 24	1	1	NRR/DE/SGEB 25	1	1
	NRR/DHFS/HFEB40	1	1	NRR/DHFS/LQB 32	1	1
	NRR/DHFS/PSRB	1	1	NRR/DL/SSPB	1	0
	NRR/DSI/AEB 26	1	1	NRR/DSI/ASB	1	1
	NRR/DSI/CPB 10	1	1	NRR/DSI/CSB 09	1	1
	NRR/DSI/ICSB 16	1	1	NRR/DSI/METB 12	1	1
	NRR/DSI/PSB 19	1	1	NRR/DSI/RAB 22	1	1
	NRR/DSI/RSB 23	1	1	REG FILE 04	1	1
	RGNS	3	3	RM/DDAMI/MIB	1	0
EXTERNAL:	ACRS	41	6	BNL (AMDTS ONLY)	1	1
	DMB/DSS (AMDTS)	1	1	FEMA-REP DIV 39	1	1
	LPDR	03	1	NRC PDR 02	1	1
	NSIC	05	1	NTIS	1	1





Arizona Nuclear Power Project

P.O. BOX 52034 • PHOENIX, ARIZONA 85072-2034

Director of Nuclear Reactor Regulation
Attention: Mr. George Knighton, Chief
Licensing Branch No. 3
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

November 1, 1984
ANPP-31035 SRF/JRP

Subject: Palo Verde Nuclear Generating Station (PVNGS)
Units 1, 2 and 3
Docket Nos. STN-50-528/529/530
Engineered Safety Features Actuation System (ESFAS)
File: 84-056-026; G.1.01.10

Reference: Letter dated July 2, 1984, from G.W. Knighton, (NRC)
to E.E. Van Brunt, Jr., (APS)

Dear Mr. Knighton:


In your referenced letter, you requested that we provide information in support of the PVNGS design as it relates to compliance with General Design Criterion 21 as supplemented by the provisions of Regulatory Guides 1.22 and 1.118, and IEEE Standard 338.

Specifically, it is requested in part that we provide a list of ESFAS actuation devices and actuated equipment associated with each that should not be tested during plant operations and justification for why each actuation device identified cannot be tested at power should it be determined that various actuation devices cannot be tested in accordance with the design criteria.

The PPS/ESFAS at Palo Verde complies with General Design Criterion 21 in that the protection system as defined by IEEE Standard 279-1971 and Regulatory Guide 1.22 is designed to permit complete testing up to the input of the actuation devices with the reactor in operation. However, following our meeting on October 10 and 11, 1984, with Messrs. Jack Donohew, Bob Stevens and Jose Calvo of the NRC, it has been determined that of a total of 104 ESFAS cycling/subgroup relays (actuation devices per Regulatory Guide 1.22), 20 of these cannot be tested without adverse consequences for plant safety and/or operability, and therefore do not fully comply with the provisions of Regulatory Guide 1.22 and IEEE Standard 338. In accordance with Sections 7.1.2.7 and 7.1.2.15 of the Palo Verde CESSAR, which reference conformance to IEEE 338 and Regulatory Guide 1.22 respectively, those ESFAS actuated devices which could affect operations are not tested while the reactor is operating, but during reactor shutdown.

841106039B 841101
PDR ADDCK 05000528
A PDR

500
11



George Knighton
Engineered Safety Features Actuation System (ESFAS)
ANPP- 31035
Page 2

Enclosed please find three attachments:

- (1) Attachment 1: Palo Verde response to ICSB request for information.
- (2) Attachment 2: List of ESFAS actuation devices and associated actuated equipment.
- (3) Attachment 3: Characteristics of the Potter Brumfield relay types MDR-7033 and MDR-7034.

We request that the actuation devices listed in the table presented in Attachment (1), APS Response to NRC Question 1, be exempted from testing at power as required by Regulatory Guide 1.22.


Should you have any questions or comments, please feel free to call.

Very truly yours,

E.E. Van Brunt Jr.
E.E. Van Brunt, Jr.
APS Vice President
Nuclear Production
ANPP Project Director

EEVBJr/JRP/no
Attachment

cc: E.A. Licitra w/a
R.P. Zimmerman w/a
A.C. Gehr w/a



November 1, 1984
ANPP-31035

STATE OF ARIZONA)
) ss.
COUNTY OF MARICOPA)

I, Donald B. Karner, represent that I am Assistant Vice President, Nuclear Production of Arizona Public Service Company, that the foregoing document has been signed by me on behalf of Arizona Public Service Company with full authority to do so, that I have read such document and know its contents, and that to the best of my knowledge and belief, the statements made therein are true.

Donald B. Karner
Donald B. Karner

Sworn to before me this 1nd day of November, 1984.

Dora E. Meador
Notary Public

My Commission Expires:

My Commission Expires April 6, 1987



LIBRARY OF THE UNIVERSITY OF TORONTO

Attachment 1 - Palo Verde Response to ICSB Request for Information

NRC Question 1: A list of ESFAS actuation devices and actuated equipment associated with each that should not be tested during plant operation.


APS Response: Attachment 2 lists all ESFAS actuation devices (subgroup relays) and associated actuated equipment for Train A and Train B. For each train, the actuation devices and associated equipment are sequentially listed according to the ESF initiation function (SIAS, CIAS, etc.). The ACTUATION DEVICE column indicates whether the actuation device can or cannot be tested at power, based on whether the associated equipment can be tested as indicated in the ASSOCIATED EQUIPMENT column.

From Attachment 2, the actuation devices that cannot be tested at power may be summarized as follows:

ACTUATION DEVICES THAT CANNOT BE TESTED AT POWER			
TRAIN A		TRAIN B	
ESF FUNCTION	ACTUATION DEVICE	ESF FUNCTION	ACTUATION DEVICE
SIAS A	K108	SIAS B	K108
SIAS A	K409	SIAS B	K409
CIAS A	K202	CIAS B	K204
CIAS A	K204	CIAS B	K205
CIAS A	K205	CSAS B	K304
CSAS A	K304	MSIS B	K305
MSIS A	K305	MSIS B	K404
MSIS A	K404	AFAS 1B	K113
AFAS 1A	K211	AFAS 1B	K211
AFAS 2A	K112	AFAS 2B	K112

Thus a total of 10 actuation devices, and their associated actuated equipment, for each train A and train B (total of 20) cannot be tested at power. Additional information pertaining to each of these relays is contained in Attachment 2, including relay type (and associated actuated equipment).


8411060392



NRC Question 2: Justification for why each actuation device identified in item (1) above cannot be tested at power.

APS Response: For each actuation device identified in (1) above, the COMMENTS column in Attachment 2 provides justification as to why certain actuated equipment cannot be tested at power without having adverse consequences for plant safety and/or operability. This applies to equipment where the MCC cannot be racked out or the equipment start function bypassed, etc. The following list of notes is referenced by Attachment 2 for each relay/associated equipment that cannot be tested at power.


- Note 1. Loss of letdown will effect per level, causing unnecessary perturbation in the letdown subsystems (Boronator, Purification, and Radmonitor).
- Note 2. Equipment is in containment, increasing the start/stop on the equipment could result in increased maintenance on this equipment, which means increased exposure to radiation for maintenance personnel (ALARA).
- Note 3. Testing of this relay results in excessive starting of equipment (large motors on HPSI, LPSI, CS) that is normally in standby to support safety. Also diesel will be tested under each relay resulting in several more starts each 61 days, this large number of starting and stopping, just for testing, could result in decreased reliability of diesel generator. Note is also made of the fact that the ESFAS BOP Load sequencer is to be run in the "Auto-Test" mode on at least a weekly basis. This feature performs a check of the ESFAS BOP processing circuitry, from the inputs up to and including the output relay coil(s) for continuity. An indirect check of Sequencer timing is also made.
- Note 4. SIT Valve will open as soon as handswitch returns to normal after closing due to motor circuit, hence testing of this relay would require lifting of leads to be able to keep valves closed in order to test this relay.
- Note 5. Starting/stopping equipment just to stop/start equipment for ST's can result in increased wear on the equipment and could result in down time for maintenance affecting reliability.



- Note 6. Valves cannot be open due to system design. Resulting in loss of Nuclear Cooling Water to Essential Cooling Water (EW) and lifting relief in the EW surge tank.
- Note 7. Securing Instrument Air to CNTMT will result in:
Normal spray valve fails to close.
Plant will not respond to pressure increases due to pressurizer surges without manual operation of Auxiliary spray valves.
- Note 8. Opening CNTMT refueling purge affects containment integrity. Containment integrity is not protected against single failure. Greater risk to public for off site release.
- Note 9. Loss of RCP seal bleedoff. Lifting of bleedoff relief to RDT increase the risk of damage to the RCP seals.
- Note 10. Remove cooling from CEDM coolers and loss of cooling to RCP's seal coolers which will result in seal damage.
- Note 11. Shifting of MSIV or FW valves at power is not safe operational practices, possible "TRIP" could result.
- Note 12. Could result in possible leakage in containment.

NRC Question 3: Verification that, for each actuation device and associated actuated equipment identified in item 1 above, there are comparable components which will be tested during reactor operation.

APS Response: Actuated equipment, including associated breakers and control circuitry, that is not tested at power by actuation of the subgroup relay is either (1) tested at power by applying a manual start to the control circuit/breaker under other established surveillance testing procedures as provided for by the Palo Verde Technical Specifications (this is to prevent excessive equipment starting), or (2) tested fully during an extended shutdown or refueling.




The COMMENTS column in Attachment 2 indicates which equipment is manually tested at power per other surveillance tests (normally ASME Section XI), and also which equipment, cannot be actuated at power, remains locked in its normal safety position during power operation.

Comparable components which are tested at power are also identified for certain pieces of equipment in the COMMENTS column when the actuation device cannot be tested.

The following table indicates for each of the five actuation relay types utilized in the NSSS ESF system, the number of those that can be tested and those that cannot be tested at power.

ACTUATION RELAY	TRAIN B	TRAIN A	TOTAL	RELAY TESTING AT POWER
POTTER BRUMFIELD MDR-136-1 [AFAS cycling relays]	4	4	8	8 - can be tested 0 - cannot be tested
POTTER BRUMFIELD MDR-7032 [subgroup relays]	1	1	2	2 - can be tested 0 - cannot be tested
POTTER BRUMFIELD MDR-7033 [subgroup relays]	9	9	18	10 - can be tested 8 - cannot be tested
POTTER BRUMFIELD MDR-7034 [subgroup relays]	32	32	64	53 - can be tested 11 - cannot be tested
DEUTSCH 2BP36AF [subgroup relays]	6	6	12	11 - can be tested 1 - cannot be tested



It can be seen that:

- (1) All of the MDR-136-1 and MDR-7032 relays are tested at power.
- (2) Of a total of 18 MDR-7033 relays, 8 cannot be tested at power and 10 can be tested; and of a total of 64 MDR-7034 relays, 11 cannot be tested at power and 53 can be tested.

It is reasonable to treat the MDR-7033 and MDR-7034 relays as a common group since the design and operational characteristics are identical in all respects, (refer to specs included as Attachment 2), with the only difference being the number of contact wafers attached to the rotor shaft, i.e., a 24 pole for MDR-7033 vs. 16 pole for the MDR-7034. Note that an additional number of poles has no appreciable difference in power requirements or operational characteristics of the coil/rotor assembly.


Thus for the MDR-7033/7034 group, a total of 19 relays cannot be tested at power, while 63 can be tested.

It may be concluded with reasonable assurance that the on-line surveillance testing of those MDR-7033/7034 relays that can be operated at power, supplemented by the less frequent (extended cold shutdown or refueling) testing of the remaining relays will be sufficient to reveal any potential common mode failures.

- (3) In the case of the 2BP36AF relays, 1 cannot be tested at power while 11 can be tested. Again, a reasonable assurance is provided as to any potential common mode failure.

NRC Question 4: Justification to show that the actuated equipment assignments to each actuation device were made in a manner to minimize the number of components which cannot be tested with the plant in operation.

APS Response: Attachment 2 presents the actuated equipment assignments to each actuation device. A total of 104 actuation devices (including the 8 cycling relays which function in conjunction with an associated subgroup relay) exists for both trains, of which 84 can be tested at power and 20 cannot be tested.



Of the 20 actuation devices that cannot be tested (ref. table in APS Response to NRC Question 1), 12 have actuated equipment assigned in such a manner that none of this equipment can be actuated. (Note that the BYP TRIPS, ALARM, DISPLAY and BYP-T.O. functions are not included as actuated equipment). The remaining 8 actuation devices which cannot be tested at power are of "mixed assignments", and are listed below:

RELAYS OF "MIXED ASSIGNMENTS"			
TRAIN A		TRAIN B	
ESF FUNCTION	ACTUATION DEVICE	ESF FUNCTION	ACTUATION DEVICE
SIAS A	K108	SIAS B	K108
SIAS A	K409	SIAS B	K409
CIAS A	K202	CIAS B	K204
CIAS A	K204	-	-
AFAS-2A	K112	-	-

In conclusion, actuated equipment has been judiciously assigned to 96 of a total of 104 actuation/cycling relays. (Note that in cases where a certain piece of equipment cannot be actuated, whereas the actuation device will be actuated, it is possible to prevent that piece of equipment from actuating by racking out the associated breaker or pulling the thermal overload,etc.).


NRC Question 5: A list of actuation devices and associated actuated equipment which can be tested at power.

APS Response: Attachment 2 lists all actuation devices and associated equipment that can be tested at power (ref. APS response to NRC Question 1), as indicated in the ACTUATION DEVICE and ASSOCIATED EQUIPMENT columns.

From Attachment 2, the actuation devices that can be tested at power may be summarized as follows:





TRAIN A		TRAIN B	
ESF FUNCTION	ACTUATION DEVICE	ESF FUNCTION	ACTUATION DEVICE
SIAS A	K101	SIAS B	K101
SIAS A	K102	SIAS B	K102
SIAS A	K103	SIAS B	K103
SIAS A	K109	SIAS B	K109
SIAS A	K110	SIAS B	K110
SIAS A	K301	SIAS B	K301*
SIAS A	K302	SIAS B	K302
SIAS A	K308	SIAS B	K308*
SIAS A	K311	SIAS B	K311
SIAS A	K401*	SIAS B	K401
SIAS A	K403	SIAS B	K403
SIAS A	K408	SIAS B	K408
SIAS A	K410*	SIAS B	K410
SIAS A	K412*	SIAS B	K412
CIAS A	K201	CIAS B	K201
CIAS A	K203*	CIAS B	K202
CIAS A	K206	CIAS B	K203*
CIAS A	K208	CIAS B	K206
CIAS A	K209	CIAS B	K208
CIAS A	K210*	CIAS B	K209
CIAS A	K212	CIAS B	K210*
CIAS A	K213	CIAS B	K212
CSAS A	K111	CSAS B	K213
CSAS A	K114	CSAS B	K111
MSIS A	K105	MSIS B	K114
MSIS A	K303	MSIS B	K105
MSIS A	K306	MSIS B	K303
MSIS A	K313	MSIS B	K306
MSIS A	K411	MSIS B	K313
RAS A	K104*	MSIS B	K411
RAS A	K309	RAS B	K104*
RAS A	K312*	RAS B	K309
RAS A	K405*	RAS B	K312*
AFAS-1A	K113*	RAS B	K405*
AFAS-1A	K307	AFAS-1B	K307
AFAS-1A	K402	AFAS-1B	K402
AFAS-2A	K310	AFAS-2B	K310
AFAS-2A	K413	AFAS-2B	K413
(cycling)	K629	(cycling)	K629
(cycling)	K628	(cycling)	K628
(cycling)	K729	(cycling)	K729
(cycling)	K728	(cycling)	K728



Thus a total of 42 actuation devices for each train A and train B (total of 84) can be tested at power. The relay types and associated actuated equipment/functions for each actuation device listed above is contained in Attachment 2.

For each relay listed above all the associated actuated equipment/functions will be tested with the exception of the relays marked(*). In these cases one or more pieces of equipment cannot be actuated, but can be racked out, bypassed, etc., and this will not preclude the relay from being tested. Justification for equipment that cannot be actuated is provided in the COMMENTS column and the referenced notes. (ref. APS response to NRC Question 2).






ATTACHMENT 2

LIST OF ESFAS ACTUATION DEVICES AND ASSOCIATED ACTUATED EQUIPMENT

NOTES:

- (1) Tables are divided into Train A and Train B actuated equipment/devices.
- (2) Actuated equipment/devices are sequentially listed and grouped according to the ESF initiation function (SIAS, CIAS, etc.)
- (3) The relay model number is listed in parenthesis together with each subgroup relay:
 - (a) MDR-7032, -7033, -7034 and -136-1 relays are Potter Brumfield.
 - (b) 2BP36AF relays are Deutsch
- (4) The following abbreviations are used in the "Function" column:
 - (a) BYP-T.O.: Bypass Thermal Overload
 - (b) OR-PRM: Override Permissive
 - (c) BYP TRIPS: Bypass Trips (i.e., bypass certain other inherent equipment protective trips)
- (5) The notes referenced in the COMMENTS column are provided in the APS Response to NRC Question (2) in Attachment 1.




TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 2

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS			TESTING AT POWER				COMMENTS
				ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	YES	NO	YES	NO	COMMENTS
SIAS A-K101..... (MDR-7034)	M-WCN-E01A E-NHN-M19 E-QBN-D91 M-RCE-B01, B09, A14 M-HAA-Z06	Normal Chiller 480V MCC Incoming Feeder Essential Lighting Panel PZR Backup Heaters Elec. Penetration Rm A Ess. ACU	Trip Trip Trip Trip Start	X	X	X	X	Note 5 Test relay but chiller will not be tested.
SIAS A-K102..... (MDR-7033)	M-HCN-A01A M-HCN-A01C M-HCN-A02A M-HCN-A02C J-ESA-C01	Cntmt normal ACU fan Cntmt normal ACU fan CEDM normal ACU fan CEDM normal ACU fan SESS	Interlock* Interlock* Interlock* Interlock* Alarm	X	X	X	X	
SIAS A-K103..... (MDR-7033)	M-HCN-A01A M-HCN-A01C M-HCN-A02A M-HCN-A02C	Cntmt Normal ACU Fan Cntmt Normal ACU Fan CEDM Normal ACU Fan CEDM Normal ACU Fan	Trip Trip Trip Trip	X	X	X	X	

Note:* Interlock to prevent auto-start following SIAS reset.



TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 3

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	ASSOCIATED EQUIP.	ACTUATION DEVICE				
SUBGROUP RELAYS				YES	NO	YES	NO		


SIAS A-K108..... (MDR-7033)	M-DGA-H01 (MODE 1)	Diesel Generator A	Start	X		X			Notes 3 & 5
	E-PEA-G01	ESFAS BOP "A" Load Sequencer	Start		X				Note 3
	E-NHN-M71	Diesel Generator "A" Breaker	Trip		X				Note 3
	M-HJA-Z04	480V MCC Incoming Feeder	Trip	X					
	M-AFN-P01	ESF Eqpt. Rm "A" Ess AHU	Start	X					
	M-SIA-P01	Non-Safety AFW Pump	Trip		X				Note 5
	M-SIA-P02	LPSI pump	OR PRM	X					Sequencer run weekly
	M-DGA-H01	HPSI pump	OR PRM	X					in auto test, and
	J-ESA-C01	Diesel generator A	BYP Trips	X					M-DGA-H01, M-PEA-G01
	M-RCE-B01, B09, A14	SESS	Alarm	X					and M-AFN-P01 tested
	M-HAA-Z01	PZR backup heaters	Interlock*	X					monthly with manual
	M-HAA-Z02	HPSI pump room A ESS ACU	BYP-T.O.	X					actuation to control
	M-HAA-Z05	LPSI pump room A ESS ACU	BYP-T.O.	X					circuits.
	J-SDA-C07	ECW pump room A ESS ACU	BYP-T.O.	X					M-HJA-Z04 does not
	J-SHA-C01	ERFDADS	Display	X					require surveillance
		QSPDS	Display	X					testing in Tech Specs.

E-NHN-71 is same model as E-NHN-M19 and NHN-M20 which are tested in SIAS A-K101 and SIAS B-K101 respectively.

Note:* Interlock to prevent auto-on following SIAS reset.

SIAS A-K109..... (2BP36AF)	M-CTA-P01	Condensate Transfer Pump A	Start	X	
	M-HFA-J01	Fuel & Aux Bldg ESS Exh AFU fan	(Start)*	X	


Note:* Require sequencer permissive too.




TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 4

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS			TESTING AT POWER				COMMENTS
				ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION					
SIAS A-K110..... (2BP36AF)	M-HJA-Z03 M-HJA-J01A M-HJA-J01B	ESF Swgr. Room ESS AHU A Control Bldg Bat Rms ESS Exh Fan Control Bldg Bat Rms ESS Exh Fan	Start Start Start	X X X				X
SIAS A-K301..... (MDR-7034)	J-SIA-UV-709 J-SIA-UV-647 J-SIA-UV-635 M-SIA-P03	HPSI Pump Recirc Line Pass Isol Vlv HPSI-1 Flow Control to Reac Coolant Valve LPSI-1 Flow Control to Reac Coolant Valve Cntmt Spray Pump	Close Open Open	X X X				X
SIAS A-K302..... (MDR-7034)	J-SGA-UV-223 J-SGA-UV-225 J-SGA-UV-227 J-SGA-UV-500S	Blowdn Sample Cntmt ISO Valve SG-2 Blowdn Sample Cntmt ISO Valve SG-2 Blowdn Sample Cntmt ISO Valve SG-2 Blowdn Sample Cntmt ISO Valve SG-2	Close Close Close Close	X X X X				X
SIAS A-K308..... (MDR-7034)	J-SIA-UV-637 J-SIA-UV-645	HPSI-1 Flow Cntrl to Reac Cool Vlv LPSI-1 Flow Cntrl to Reac Cool Vlv	Open Open	X X				X




ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS			TESTING AT POWER				COMMENTS
				ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION					
SIAS A-K311..... (MDR-7033)	M-HJA-M01	CR Norm AHU ISO Damper	Close	X				X
	M-HJA-M52	CR Norm AHU ISO Damper	Close	X				
	M-HJA-M25	Cont Bldg ESS ISO Damper	Close	X				
	M-HJA-M28	Cont Bldg ESS ISO Damper	Close	X				
	M-HJA-M36	Cont Bldg ESS ISO Damper	Close	X				
	M-HJA-M51	Cont Bldg ESS ISO Damper	Close	X				
	M-HJA-M62	Cont Bldg ESS ISO Damper	Close	X				
	M-HJA-M66	Cont Bldg ESS ISO Damper	Close	X				
	M-HJA-M23	ESF Swgr Rm Norm ISO Damper	Close	X				
	M-HJA-M56	Cont Room ESS ISO Damper	Close	X				
	M-HJA-M57	Cont Room ESS ISO Damper	Close	X				
	M-HJA-M15	CR Toilet & Kitchen Exh ISO Damper	Close	X				
	M-HJA-M16	CR Toilet & Kitchen Exh ISO Damper	Close	X				
	M-HJA-M34	ESF RMS A&C ESS Rtn ISO Damper	Open	X				
	M-HJA-M58	Comm Eqpt Rm ESS ISO Damper	Close	X				
	M-HJA-M59	Comm Eqpt Rm ESS ISO Damper	Close	X				
	M-HJA-M53	ESF Swgr Rm Outside Air & Exh ISO Damper	Close	X				
	M-HJA-M54	ESF Swgr Rm Outside Air & Exh ISO Damper	Close	X				
	M-HJA-M55	ESF Swgr Rm Outside Air & Exh ISO Damper	Close	X				
	M-HJA-M02	CR ESS AHU Outside Air Intake Dmpr	Open	X				
	M-HJA-M03	CR ESS AHU Outside Air Intake Dmpr	Open	X				
SIAS-A K401..... (MDR-7034)	J-SIA-UV-627	HPSI-1 Flow Cntrl to Reac Coolnt Vlv	Open	X				
	J-SIA-UV-634	SI TK-3 Iso Valve	Open		X			Note 4 Test Relay only. Do Not Actuate Valve SIA-UV-634 – normally locked open in safety position.



TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT

age 6


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
					ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION						
SIAS A-K403..... (MDR-7034)	J-SGA-UV-211 J-SGA-UV-204 J-SGA-UV-500P J-SGA-UV-220	Blowdn Sample Cntmt ISO Valve SG-1 Blowdn Sample Cntmt ISO Valve SG-1 Blowdn Sample Cntmt ISO Valve SG-1 Blowdn Sample Cntmt ISO Valve SG-1	Close Close Close Close		X X X X			X	
SIAS A-K408..... (MDR-7034)	J-SIC-HV-321 J-SIA-HV-604 J-SIA-HV-657 J-SIA-HV-686 J-SIA-HV-685 J-SIA-HV-688	HPSI pump A long-term clg valve HPSI pump A long-term clg valve SD clg temp cont valve Cntmt spray cross connect valve LPSI pump cross connect valve SD clg exch bypass valve		BYP-T.O. BYP-T.O. BYP-T.O. BYP-T.O. BYP-T.O. BYP-T.O.		X X X X X X		X	
SIAS A-K409..... (MDR-7034)	J-SIA-UV-682 J-CHA-UV-516 J-SIA-HV-698 J-SIA-HV-306 J-SIA-HV-638 J-SIA-HV-691 J-SIA-HV-687 J-SIA-HV-684 J-SIA-HV-678	SI TK RWT Rtn Hdr Cntmt ISO Valve Letdown Line to Regen Heat Exch ISO Valve HPSI pump A discharge LPSI hdr discharge valve LPSI pump A isol valve SD clg loop warmup bypass valve Cntmt spray isol valve SD clg heat exch isol valve SD clg heat exch isol valve	Close Close BYP-T.O. BYP-T.O. BYP-T.O. BYP-T.O. BYP-T.O. BYP-T.O.		X X X X X X X X			X	Note 1 J-SIA-UV-682 is opened and closed quarterly with manual trip to control circuit (per ASME Section XI)



TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 7


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
					ASSOCIATED EQUIP.		ACTUATION DEVICE		
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	YES	NO	YES	NO		
SIAS A-K410..... (MDR-7034)	J-SIA-UV-617	HPSI-1 Flow Cntrl to Reac Coolnt Vlv	Open	X					
	J-SIA-UV-644	SI TK-4 ISO Valve	Open		X				Note 4 Will not actuate valve SIA-UV-644 - normally locked open in safety position.
SIAS A-K412..... (MDR-7034)	M-HAA-M03	Pump RMS Exh ISO Damper	Close	X					
	M-HAA-M01	Pump RMS Sply & Exh ISO Damper	Close	X					
	M-HAA-M02	Pump RMS Sply & Exh ISO Damper	Close	X					
	M-HAA-M04	Pump RMS Sply & Exh ISO Damper	Close	X					
	M-HAA-M05	Pump RMS Sply & Exh ISO Damper	Close	X					
	M-HAA-M06	Pump RMS Sply & Exh ISO Damper	Close	X					
	J-EWA-UV-145	ECW Loop A-NCW Cross Tie Valve	Close		X				Note 6
	J-EWA-UV-65	ECW Loop A-NCW Cross Tie Valve	Close		X				Note 6
									Test relay but valves EWA-UV-145 & 65 will not be stroked. Valves J-EWA-UV-145 and UV-65 are normally locked closed in the safety position.



TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 8


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
					ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION						
CIAS A-K201..... (MDR-7034)	J-SSA-UV-203 J-SSA-UV-204 J-SSA-UV-205 J-SIA-UV-708	Sample Cntmt ISO Valve Sample Cntmt ISO Valve Sample Cntmt ISO Valve Recirc Sump "A" Pass ISO Valve	Close Close Close Close	X X X X					
CIAS A-K202..... (MDR-7034)	J-GAA-UV-001 J-GAA-UV-002 J-IAA-UV-002	Hi Press Nitrogen Cntmt ISO Valve Lo Press Nitrogen Cntmt ISO Valve Instr & Service Air Cntmt ISO Valve	Close Close Close	X X X					X Notes 1 & 7 J-GAA-UV-001 and UV-002 are tested quarterly with manual trip to control circuit (ASME Section XI). All three valves have same Target Rock solenoid actuator (300525-1) as J-HPA-UV-23 and UV-24 which are tested for CIAS A- K213.
CIAS A-K203..... (MDR-7034)	J-CPA-002A J-CPA-004A	Cntmt Purge Refueling Mode ISO Vlv Cntmt Purge Power ACC Mode ISO Vlv	Close Close		X				Note 8 Test relay only don't actuate valve CPA-002A. Valve not tested, and is normally locked closed in the safety position.



TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT

ge 9


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
					ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION						
CIAS A-K204..... (MDR-7033)	J-CHA-UV-560 J-CHA-UV-506 J-CHA-UV-516 J-CHA-UV-580 J-CHA-UV-715	Reac Drain Tk Outlet ISO Valve RCP Controlled Bleedoff to VCT Vlv Letdn Line to Regen Heat Exch Cntmt ISO Valve Makeup to RDT Valve Letdown Line PASS ISO Valve	Close Close Close Close Close	X X X X X					X
									Notes 2 & 9 Note 1 J-CHA-UV-560, UV-580, and UV-715 are tested quarterly with manual trip to control circuit (ASME Section XI).
CIAS A-K205..... (MDR-7034)	J-NCA-UV-402	Nucl Cooling Water Syst Cntmt ISO Vlv	Close	X					X
									Notes 5 & 10. Lose cooling water to RCP. RCP can only operate 10 min. without cooling water. (Close System)
CIAS A-K206..... (MDR-7034)	J-WCA-UV-062	Normal Chilled Water Rtn & Suply Cntmt ISO Valve	Close	X					X
CIAS A-K208..... (MDR-7034)	J-HCA-UV-045 J-HCA-UV-046	Cntmt ATM Rad Monitor Cntmt ISO Vlv Cntmt ATM Rad Monitor Cntmt ISO Vlv	Close Close	X X					X
CIAS A-K209..... (MDR-7034)	J-RDA-UV-023 J-GRA-UV-001	Cntmt Radwst Sumps Internal ISO Vlv Gas Surge Header Cntmt ISO Valve	Close Close	X X					X



TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 10


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS			TESTING AT POWER				COMMENTS
				ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION					
CIAS A-K210..... (MDR-7034)	J-CPA-UV-002B J-CPA-UV-004B	Cntmt Purge Refueling Mode ISO Vlv Cntmt Purge Power ACC Mode ISO Vlv	Close Close		X X			Note 8 (See K203) J-CPA-UV-002B normally locked closed in safety position.
CIAS A-K212..... (MDR-7034)	J-ESA-C01 J-SDA-C07 J-SHA-C01	SESS ERFDADS QSPDS		Alarm Display Display	X X X			
CIAS A-K213..... (MDR-7033)	J-HPA-UV-023 J-HPA-UV-024 J-HPA-UV-001 J-HPA-UV-003 J-HPA-UV-005	Hyd Mon Pass Ret ISO Valve Hyd Mon Pass Sup ISO Valve Hyd Control Cntmt ISO Valve Hyd Control Cntmt ISO Valve Hyd Control Cntmt ISO Valve	Close Close Close Close Close		X X X X X			



TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 11


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS			TESTING AT POWER				COMMENTS
				ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION					
CSAS A-K111..... (2BP36AF)	J-SIA-UV-681 J-SIA-UV-672 J-SHA-C01	Hydrzne Pump to Cntmt Spray Pump Vlv Cntmt Spray Control Valve QSPDS	Open Open Display	X X X				X
CSAS A-K114..... (2BP36AF)	J-SIA-UV-603 M-SIA-P05 J-SDA-C07	Spray Chem Pump Suction Valve Spray Chem Add Pump ERFDADS	Open Start Display		X X X			X
CSAS A-K304..... (MDR-7034)	(MODE 1) M-DGA-H01 J-ESA-C01 M-HAA-Z03	ESFAS BOP "A" Load Sequencer Diesel Generator SESS C.S. pump Rm B ESS ACU	Start Start Alarm BYP-T.O.		X X X X			Note 3 Note 3 & 5 Sequencer run weekly in auto test, and M-DGA-H01 tested monthly with manual start to control circuit.



TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 12


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS			TESTING AT POWER				COMMENTS
				ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	YES	NO	YES	NO	COMMENTS
MSIS A-K105..... (MDR-7034)	J-ESA-C01 J-SDA-C07 J-SHA-C01	SESS ERFDADS QSPDS	Alarm Display Display	X				
MSIS A-K303..... (MDR-7034)	J-SGE-UV-183 J-SGA-UV-1133 J-SGA-UV-1134	SG-2 MSIV Bypass Valve Stm Traps ISO Valve Stm Traps ISO Valve	Close Close Close	X				
MSIS A-K305..... (MDR-7034)	J-SGA-UV-172 J-SGA-UV-175 J-SGE-UV-170 J-SGE-UV-180	SG-1 Downcomer FDW ISO Valve SG-2 Downcomer FDW ISO Valve SG-1 Line-1 MS ISO Valve SG-1 Line-2 MS ISO Valve	Close Close Close Close	X				Note 11 Test per Note 3 of T.S. Pg. 3/4.3.32
MSIS A-K306..... (MDR-7034)	J-SGE-UV-169	SG-1 MSIV Bypass Valve	Close	X				
MSIS A-K313..... (MDR-7034)	J-SGA-UV-223 J-SGA-UV-225 J-SGA-UV-227 J-SGA-UV-500S	Blowdown Sample Cntmt ISO Vlv SG-2 Blowdown Sample Cntmt ISO Vlv SG-2 Blowdown Sample Cntmt ISO Vlv SG-2 Blowdown Sample Cntmt ISO Vlv SG-2	Close Close Close Close	X				



TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 13


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
					ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION						
MSIS A-K404..... (MDR-7034)	J-SGA-UV-174 J-SGA-UV-177 J-SGE-UV-171 J-SGE-UV-181	SG-1 Economizer FWIV SG-2 Economizer FWIV SG-2 Line-1 MS ISO Valve SG-2 Line-2 MS ISO Valve	Close Close Close Close		X X X X				X Note 11 Test per Note 3 of T.S. Pg. 3/4.3.32
MSIS A-K411..... (MDR-7034)	J-SGA-UV-211 J-SGA-UV-204 J-SGA-UV-500P J-SGA-UV-220	Blowdn Sample Cntmt ISO Valve SG-1 Blowdn Sample Cntmt ISO Valve SG-1 Blowdn Sample Cntmt ISO Valve SG-1 Blowdn Sample Cntmt ISO Valve SG-1	Close Close Close Close		X X X X				X



TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 14

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS			TESTING AT POWER				COMMENTS
				ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION					
RAS A-K104..... (MDR-7034)	M-SIA-P01 J-ESA-C01 J-SDA-C07 J-SHA-C01	LPSI Pump SESS ERFDADS QSPDS	Stop Alarm Display Display	X	X			Notes 3 & 5 Test relay but pump will not be tested - it is started and tripped quarterly with manual trip to control circuit.
RAS A-K309..... (MDR-7034)	J-SIA-UV-664	Cntmt Spray Pump to RWT ISO Valve	Close	X				
RAS A-K312..... (2BP36AF)	J-SIA-UV-666 J-SIA-UV-669 J-SIA-UV-673	HPSI Pump to RWT ISO Valve LPSI Pump to RWT ISO Valve Cntmt Sump ISO Valve	Close Close Open	X	X	X		Note 12 This will be tested by interrupting power to valve SIA-UV-673. Valve will not be stroked.



TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT.

Page 15


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS			TESTING AT POWER				COMMENTS
				ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	Close Open	X X	YES	NO	Comments

RAS A-K405.....
(MDR-7034) X

J-SIA-UV-660 HPSI Recirc to RWT Valve
J-SIA-UV-674 Cntmt Sump ISO Valve

Close X
Open X

Note 12
This will be tested
by interrupting power
to valve SIA-UV-674.
Valve will not be
stroked.



ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				
					ASSOCIATED EQUIP.		ACTUATION DEVICE		
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	YES	NO	YES	NO	COMMENTS	


AFAS-1 A-K113..... (2BP36AF)	E-PEA-G01	Diesel Generator Breaker	Trip	X					
	J-SGA-UV-134	SG-1 to AFW Pump Steam Supply Valve	Open	X					
	M-HAA-Z04	Aux FDW Pmp Rm A Ess ACU	Start*	X					
	J-SGA-UV-138	SG-2 to AFW Pump Steam Supply Valve	Close	X					
	M-DGA-H01	Diesel generator A	BYP Trips	X					
	M-HAA-Z05	ECW pump room A ESS ACU	BYP-T.O.	X					
	M-HAA-Z04	Aux FDW pump room A ESS ACU	BYP-T.O.	X					

Note: (1) *M-HAA-Z04 starts when J-SGA-UV-134 opens.

AFAS-1 A-K211..... (MDR-7033)	(MODE 4A)	ESFAS BOP "A" Load Sequencer	Start	X	X				
	M-DGA-H01	Diesel Generator A	Start		X				
	J-ESA-C01	SESS	Alarm	X					
	J-SDA-C07	ERFDADS	Display	X					
	J-SHA-C01	QSPDS	Display	X					

Note 3
Notes 3 & 5
Sequencer run weekly
in auto test, and
M-DGA-H01 tested
monthly with manual
trip to control
circuit.

AFAS-1 A-K307..... (MDR-7033)	J-SGA-UV-225	Blowdown Sample Cntmt ISO Vlv SG-2	Close	X					
	J-SGA-UV-227	Blowdown Sample Cntmt ISO Vlv SG-2	Close	X					
	J-SGA-UV-500S	Blowdown Sample Cntmt ISO Vlv SG-2	Close	X					
	J-SGA-UV-223	Blowdown Sample Cntmt ISO Vlv SG-2	Close	X					
	J-CTA-HV-4	Cnds tk to AFW pump ISO valve	BYP-T.O.	X					
	J-CTA-HV-1	Cnds tk to AFW pump ISO valve	BYP-T.O.	X					



TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT


Page 17

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	ASSOCIATED EQUIP.	ACTUATION DEVICE				
SUBGROUP RELAYS				YES	NO	YES	NO		
AFAS-1 A-K402..... (MDR-7034)	J-SGA-UV-204 J-SGA-UV-500P J-SGA-UV-220 J-SGA-UV-211	Blowdown Sample Cntmt ISO Vlv SG-1 Blowdown Sample Cntmt ISO Vlv SG-1 Blowdown Sample Cntmt ISO Vlv SG-1 Blowdown Sample Cntmt ISO Vlv SG-1	Close Close Close Close	X X X X				X	
K629* & K402** K628* & K402** K729* & K402** K728* & K402**	J-AFC-HV-33 J-AFC-UV-36 J-AFA-UV-37 J-AFA-HV-32	AFAS Chan C Init CKT AFAS Chan C Init CKT Aux Fdw ISO Valve to SG-2 Aux Fdw Reg Valve to SG-1	Open Open Open Open		X X X X				

Note: (1) * K629, K628, K729 and K728 are relay type MDR-136-1

(2) * K629 and K729 are from AFAS-2A circuit

(3) ** K402 only maintains the four valves closed. They can be cycled open individually by deenergizing the associated cycling relay via the PPS Matrix test module



TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 18

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				
	SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	ASSOCIATED EQUIP.	ACTUATION DEVICE			
COMMENTS									

AFAS-2 A-K112..... (MDR-7033)	E-PEA-G01	Diesel Generator Breaker	Trip	X		X			
	J-SGA-UV-138	SG-2 to Aux Fdw Pump A	Open	X					
	M-HAA-Z04 (MODE 4A)	Aux Fdw Pump Rm A ESS ACU	Start*			X			
	M-DGA-H01	ESFAS BOP "A" Load Sequencer	Start			X			
	M-DGA-H01	Diesel Generator A	Start			X			
	M-DGA-H01	Diesel Generator A	BYP trips	X					
	J-ESA-C01	SESS	Alarm	X					
	J-SDA-C07	ERFDADS	Display	X					
	J-SHA-C01	QSPDS	Display	X					
	M-HAA-Z05	ECW pump room A ESS ACU	BYP-T.O.	X					
	M-HAA-Z04	Aux FDW pump room A ESS ACU	BYP-T.O.	X					


Notes 3 & 5

Note 3

Notes 3 & 5
 E-PEA-G01, J-SGA-UV-138, M-HAA-Z04 and
 M-DGA-H01 tested monthly with manual
 actuation to control circuits.
 Sequencer is tested weekly in auto test.

Note: *M-HAA-Z04 starts when J-SGA-UV-138 opens.

AFAS-2 A-K310..... (MDR-7034)	J-SGA-UV-225	Blowdn Sample Cntmt ISO Vlv to SG-2	Close	X		X			
	J-SGA-UV-227	Blowdn Sample Cntmt ISO Vlv to SG-2	Close	X					
	J-SGA-UV-500S	Blowdn Sample Cntmt ISO Vlv to SG-2	Close	X					
	J-SGA-UV-223	Blowdn Sample Cntmt ISO Vlv to SG-2	Close	X					
	J-CTA-HV-4	Cnds tk to AFW pump ISO valve	BYP-T.O.	X					
	J-CTA-HV-1	Cnds tk to AFW pump ISO valve	BYP-T.O.	X					



TRAIN A ESFAS ASSOCIATED ACTUATED EQUIPMENT


Page 19

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS			TESTING AT POWER				COMMENTS
				ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION					
AFAS-2 A-K413..... (MDR-7032)	J-SGA-UV-204 J-SGA-UV-500P J-SGA-UV-220 J-SGA-UV-211	Blowdn Sample Cntmt ISO Vlv to SG-1 Blowdn Sample Cntmt ISO Vlv to SG-1 Blowdn Sample Cntmt ISO Vlv to SG-1 Blowdn Sample Cntmt ISO Vlv to SG-1	Close Close Close Close	X X X X				X
K629* & K413** K628* & K413** K729* & K413** K728* & K413**	J-AFC-UV-33 J-AFA-UV-36 J-AFA-UV-37 J-AFA-UV-32	AFAS Chan C Init CKT AFAS Chan C Init CKT Aux Fdw ISO Valve to SG-2 Aux Fdw Reg Valve to SG-1	Open Open Open Open					X X X X

Note: (1) * K629, K628, K729 and K728 are relay type MDR-136-1

(2) * K628 and 728 are from AFAS-1A circuit


(3) ** K413 only maintains the four valves closed. They can be cycled open individually by deenergizing the associated cycling relay via the PPS matrix test module.



TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

ge 20

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
	SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	ASSOCIATED EQUIP.	ACTUATION DEVICE			
					YES	NO	YES	NO	
SIAS B-K101..... (MDR-7034)									X
	E-NHN-M20	480v MCC incoming feeder		Trip		X			
	E-QBN-D90	Essential lighting panel		Trip		X			
	M-RCE-B18, B10, A05	PZR backup heaters		Trip		X			
	M-HAB-Z06	Elec penetration rm B ESS ACU		Start		X			
SIAS B-K102..... (MDR-7033)									X
	M-HCN-A01B	Cntmt normal ACU fan			Interlock*	X			
	M-HCN-A01D	Cntmt normal ACU fan			Interlock*	X			
	M-HCN-A02B	CEDM normal ACU fan			Interlock*	X			
	M-HCN-A02D	CEDM normal ACU fan			Interlock*	X			
	J-ESB-C01	SESS			Alarm	X			
<u>Note: Interlock to prevent auto-start following SIAS reset.</u>									
SIAS B-K103..... (MDR-7033)									X
	M-HCN-A01B	Cntmt normal ACU fan			Trip	X			
	M-HCN-A01D	Cntmt normal ACU fan			Trip	X			
	M-HCN-A02B	CEDM normal ACU fan			Trip	X			
	M-HCN-A02D	CEDM normal ACU fan			Trip	X			



TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

e 21


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS			TESTING AT POWER				COMMENTS
	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	ASSOCIATED EQUIP.	ACTUATION DEVICE			
SUBGROUP RELAYS				YES	NO	YES	NO	

SIAS B-K108..... (MDR-7033)	M-DGB-H01 (Mode 1)	Diesel generator B	Start	X				Notes 3 & 5
	E-PEB-G02	ESFAS BOP "B" load sequencer	Start	X				Note 3
	E-NHN-M-72	Diesel generator "B" breaker	Trip	X				Note 3
	M-HJB-Z04	480v MCC incoming feeder	Trip	X				Sequencer run weekly
	M-SIB-P01	ESF eqpt rm "B" ESS AHU	Start	X				in auto test, and
	M-SIB-P02	LPSI pump	OR PRM	X				M-DGA-H01, E-PEB-G02
	M-DGB-H01	HPSI pump	OR PRM	X				tested monthly with
	J-ESB-C01	Diesel generator B	BYP Trips	X				manual actuation to
	M-RCE-B18, B10, A05	SESS	Alarm	X				control circuits.
	M-HAB-Z01	PZR backup heaters	Interlock*	X				
	M-HAB-Z02	HPSI pump room ESS ACU	BYP-T.O.	X				M-HJB-Z04 does not
	M-HAB-Z05	LPSI pump room ESS ACU	BYP-T.O.	X				require surveillance
	J-SDB-C08	ECW pump room ESS ACU	BYP-T.O.	X				testing in Tech
	J-SHB-C01	ERFDADS	Display	X				Specs.
		QSPDS	Display	X				
								E-NHN-M-72 is same
								model as E-NHN-M-19
								and E-NHN-M-20 which
								are tested in SIAS A-
								K101 and SIAS B-
								K101 respectively.

Note: Interlock to prevent auto-on following SIAS reset.

SIAS B-K109..... (2BP36AF)	M-CTB-P01	Condensate transfer pump B	Start	X
	M-HFB-J01	Fuel & aux bldg ESS exh AFU fan	(Start)*	X


Note: *Require sequencer start permissive too.



TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 22


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
					ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION						
SIAS B-K110..... (2BP36AF)	M-HJB-Z03 M-HJB-J01A M-HJB-J01B	ESF SWGR rm ESS AHU Cont bldg Batt RMS ESS exh fan Cont Bldg Batt RMS ESS exh fan	Start Start Start		X X X				X
SIAS B-K301..... (MDR-7034)	J-SIB-UV-611 J-SIB-UV-618 J-SIB-UV-710 J-SIB-UB-646 J-SIB-UV-624 M-SIB-P03	SI TK-1 Fill & drain valve SI TK-1 check valve leakage line ISO valve HPSI pump recirc line pass ISO vlv HPSI-2 flow control to reac coolant valve SI TK ISO valve Cntmt Spray Pump	Close Close Close Open Open OR PRM		X X X X X				Note 4 Relay only tested on SIB-UV-624 - normally locked open in safety position.
SIAS B-K302..... (MDR-7034)	J-SGB-UV-222 J-SGB-UV-224 J-SGB-UV-500R J-SGB-UV-226	Blowdown sample cntmt ISO valve SG-2 Blowdown sample cntmt ISO valve SG-2 Blowdown sample cntmt ISO valve SG-2 Blowdown sample cntmt ISO valve SG-2	Close Close Close Close		X X X X				



TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 23


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	ASSOCIATED EQUIP.	ACTUATION DEVICE				
SUBGROUP RELAYS				YES	NO	YES	NO		
SIAS B-K308..... (MDR-7034)	J-SIB-UV-621	SI TK-1 fill & drain valve	Close	X					
	J-SIB-UV-628	SI TK-1 check valve leakage line ISO valve	Close	X					
	J-SIB-UV-636	HPSI-2 flow control to reac coolant valve	Open	X					
	J-SIB-UV-614	SI TK-2 ISO valve	Open		X				Note 4 Relay only tested on SIB-UV-614 - normally locked open in safety position.
SIAS B-K311..... (MDR-7033)	M-HJB-M01	CR AHU ISO damper	Close	X					
	M-HJB-M55	CR AHU ISO damper	Close	X					
	M-HJB-M10	Comm eqpt rm ESS ISO damper	Close	X					
	M-HJB-M13	Comm eqpt rm ESS ISO damper	Close	X					
	M-HJB-M28	ESF SWGR rm sply & exh ISO damper	Close	X					
	M-HJB-M32	ESF SWGR rm sply & exh ISO damper	Open	X					
	M-HJB-M52	ESF SWGR rm sply & exh ISO damper	Close	X					
	M-HJB-M31	Cont bldg ESS ISO damper	Open	X					
	M-HJB-M34	Cont bldg ESS ISO damper	Close	X					
	M-HJB-M38	Cont bldg ESS ISO damper	Close	X					
	M-HJB-M58	Cont bldg ESS ISO damper	Open	X					
	M-HJB-M66	Cont bldg ESS ISO damper	Close	X					
	M-HJB-M56	Cont rm ESS ISO damper	Close	X					
	M-HJB-M57	Cont rm ESS ISO damper	Close	X					
	M-HJB-M23	Cont rm toilet & kitchen exh ISO damper	Close	X					
	M-HJB-M24	Cont rm toilet & kitchen exh ISO damper	Close	X					
	M-HJB-M02	CR ESS AHU outside source intake damper	Open	X					
	M-HJB-M03	CR ESS AHU outside source intake damper	Open	X					



TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 24


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	ASSOCIATED EQUIP.	ACTUATION DEVICE				
SUBGROUP RELAYS				YES	NO	YES	NO		
SIAS B-K401..... (MDR-7034)	J-SIB-UV-641	SI TK-4 fill & drain valve	Close	X					X
	J-SIB-UV-648	SI TK-4 check valve leakage line ISO valve	Close	X					
	J-SIB-UV-626	HPSI-2 flow cont to reac coolant valve	Open	X					
	J-SIB-UV-615	LPSI-2 flow cont to reac coolant valve	Open	X					
SIAS B-K403..... (MDR-7034)	J-SGB-UV-219	Blowdown sample Cntmt ISO vlv SG-1	Close	X					X
	J-SGB-UV-228	Blowdown sample cntmt ISO vlv SG-1	Close	X					
	J-SGB-UV-221	Blowdown sample Cntmt ISO vlv SG-1	Close	X					
	J-SGB-UV-500Q	Blowdown sample cntmt ISO vlv SG-1	Close	X					
SIAS B-K408..... (MDR-7034)	J-SIB-UV-332	Hot leg inj check valve leakage ISO valve	Close	X					X
	J-SID-HV-331	HPSI pump B long-term clg valve	BYP-T.O.	X					
	J-SIB-HV-609	HPSI pump B long-term clg valve	BYP-T.O.	X					
	J-SIB-HV-658	SD clg temp cont valve	BYP-T.O.	X					
	J-SIB-HV-696	Cntmt spray cross connect valve	BYP-T.O.	X					
	J-SIB-HV-694	LPSI pump cross connect valve	BYP-T.O.	X					
	J-SIB-HV-693	SD clg exch bypass valve	BYP-T.O.	X					



TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 25


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				
	SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	ASSOCIATED EQUIP.	ACTUATION DEVICE			
					YES	NO	YES	NO	COMMENTS
SIAS B-K409..... (MDR-7034)	J-SIB-UV-322	Hot leg inj check valve leakage ISO valve		Close	X				X
	J-CHB-UV-515	Letdown line to regen exch valve		Close		X			Note 1 J-SIB-UV-322 is tested quarterly with manual trip to control circuit (ASME Section XI)
	J-SIB-HV-699	HPSI pump B discharge valve		BYP-T.O.	X				
	J-SIB-HV-307	LPSI HDR discharge valve		BYP-T.O.	X				
	J-SIB-HV-692	LPSI pump B ISO valve		BYP-T.O.	X				
	J-SIB-HV-690	SD clg loop warm-up BYP valve		BYP-T.O.	X				
	J-SIB-HV-695	Cntrmt spray ISO valve		BYP-T.O.	X				
	J-SIB-HV-689	SD clg heat exch ISO valve		BYP-T.O.	X				
	J-SIB-HV-679	SD clg heat exch ISO valve		BYP-T.O.	X				
SIAS B-K410..... (MDR-7034)	J-SIB-UV-631	SI TK-3 fill & drain valve		Close	X				X
	J-SIB-UV-638	SI TK-3 check valve leakage ISO valve		Close	X				
	J-SIB-UV-616	HPSI-2 flow control to reac coolant valve		Open	X				
	J-SIB-UV-625	LPSI-2 flow control to reac coolant valve		Open	X				
SIAS B-K412..... (MDR-7034)	M-HAB-M03	Pump rm exh ISO damper		Close	X				X
	M-HAB-M01	Pump rm sply & exh ISO damper		Close	X				
	M-HAB-M02	Pump rm sply & exh ISO damper		Close	X				
	M-HAB-M04	Pump rm sply & exh ISO damper		Close	X				
	M-HAB-M05	Pump rm sply & exh ISO damper		Close	X				
	M-HAB-M06	Pump rm sply & exh ISO damper		Close	X				



TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 26


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS			TESTING AT POWER				COMMENTS
				ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION					
CIAS B-K201..... (MDR-7034)	J-SSB-UV-200 J-SSB-UV-201 J-SSB-UV-202	Sample cntmt ISO valve Sample cntmt ISO valve Sample cntmt ISO valve	Close Close Close	X X X				X
CIAS B-K202..... (MDR-7034)	J-SGB-HV-200 J-SGB-HV-201	Chem INJ ISO valve SG-1 Chem INJ ISO valve SG-2	Close Close	X X				X
CIAS B-K203..... (MDR-7034)	J-CPB-UV-3A J-CPB-UV-5A	Cntmt purge refueling mode ISO vlv Cntmt purge power ACC mode ISO vlv	Close Close		X X			Note 8 J-CPB-UV-3A normally locked closed in safety position.
CIAS B-K204..... (MDR-7033)	J-CHB-UV-561 J-CHB-UV-505 J-CHB-UV-523 J-CHB-UV-924	Reac drain TK outlet ISO valve RCP controlled bleedoff to VCT vlv Regen heat exch to letdown heat ISO valve Letdown line pass ISO valve	Close Close Close Close	X X X X				Notes 2 & 9 Note 1 J-CHB-UV-561 and UV-924 are tested quarterly with manual trip to control circuit (ASME Section XI).
CIAS B-K205..... (MDR-7034)	J-NCB-UV-401 J-NCB-UV-403	Nuclear cooling water system cntmt ISO valve Nuclear cooling water return cntmt ISO valve	Close Close		X X			Notes 5 & 10 Notes 2 & 5 & 10



TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 27

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
					ASSOCIATED EQUIP.	ACTUATION DEVICE			
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	YES	NO	YES	NO		
CIAS B-K206..... (MDR-7034)	J-WCB-UV-61	Normal chilled water return cntmt ISO valve	Close	X					
	J-WCB-UV-63	Normal chilled water return & sply cntmt ISO valve	Close	X					
CIAS B-K208..... (MDR-7034)	J-HCB-UV-44	Cntmt ATM Rad monitor (inside) ISO valve	Close	X					
	J-HCB-UV-47	Cntmt ATM Rad monitor (inside) ISO valve	Close	X					
CIAS B-K209..... (MDR-7034)	J-GRB-UV-2	Gas surge HDR external ISO valve	Close	X					
	J-RDB-UV-24	Cntmt radwaste sumps external ISO valve	Close	X					
	J-RDB-UV-407	Cntmt radwaste sumps pass ISO valve	Close	X					
CIAS B-K210..... (MDR-7034)	J-CPB-UV-3B	Cntmt purge refueling mode ISO vlv	Close		X				Note 8 J-CPB-UV-3B normally locked closed in safety position.
	J-CPB-UV-5B	Cntmt purge power ACC mode ISO vlv	Close	X					
CIAS B-K212..... (MDR-7034)	J-ESB-C01	SESS	Alarm	X					
	J-SDB-C08	ERFDADS	Display	X					
	J-SHB-C01	QSPDS	Display	X					




TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

ge 28

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS			TESTING AT POWER				COMMENTS
				ASSOCIATED EQUIP.	ACTUATION DEVICE			
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	YES	NO	YES	NO	COMMENTS
CIAS B-K213..... (MDR-7033)	J-HPB-UV-2 J-HPB-UV-4 J-HPB-UV-6	Hydrogen control cntmt ISO valve Hydrogen control cntmt ISO valve Hydrogen control cntmt ISO valve	Close Close Close	X X X				X


CIAS B-K213.....
(MDR-7033) J-HPB-UV-2 Hydrogen control cntmt ISO valve Close X
 J-HPB-UV-4 Hydrogen control cntmt ISO valve Close X
 J-HPB-UV-6 Hydrogen control cntmt ISO valve Close X



TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

e 29

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS			TESTING AT POWER				
				ASSOCIATED EQUIP.	ACTUATION DEVICE			
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	YES	NO	YES	NO	COMMENTS
CSAS B-K111..... (2BP36AF)	J-SIB-UV-680 J-SIB-UV-671 J-SHB-C01	Hydrazine pump to cntmt spray pump valve Cntmt spray control valve QSPDS	Open Open Display	X			X	
CSAS B-K114..... (2BP36AF)	J-SIB-UV-602 M-SIB-P05 J-SDB-C08	Spray chem pump suction valve Spray chem add pump ERFDADS	Open Start Display	X	X		X	
CSAS B-K304..... (MDR-7034)	(Mode 1) M-DGB-H01 J-ESB-C01 M-HAB-Z03	ESFAS BOP "B" load sequencer Diesel generator SESS C.S. pump room B ESS ACU	Start Start Alarm BYP T.O.	X	X	X	X	Note 3 Notes 3 & 5 Sequencer tested weekly in auto test, and M-DGB-H01 tested monthly with manual start to control circuit.




TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 30

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
					ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION						
MSIS B-K105..... (MDR-7034)	J-SGB-HV-200 J-SGB-HV-201 J-ESB-C01 J-SDB-C08 J-SHB-C01	Chem INJ ISO valve SG-1 Chem INJ ISO valve SG-2 SESS ERFDADS QSPDS	Close Close Alarm Display Display		X X X X X				X
MSIS B-K303..... (MDR-7034)	J-SGE-UV-183 J-SGB-UV- 1135A J-SGB-UV- 1135B J-SGB-UV- 1136A J-SGB-UV- 1136B	SG-2 MSIV bypass valve Steam traps ISO valve Steam traps ISO valve Steam traps ISO valve Steam traps ISO valve	Close Close Close Close Close		X X X X X				X
MSIS B-K305..... (MDR-7034)	J-SGB-UV-130 J-SGB-UV-135 J-SGE-UV-170 J-SGE-UV-180	SG-1 downcomer FDW ISO valve SG-2 downcomer FDW ISO valve SG-1 line 1 MS ISO valve SG-1 line 2 MS ISO valve	Close Close Close Close		X X X X				X
MSIS B-K306..... (MDR-7034)	J-SGE-UV-169	SG-1 MSIV bypass valve	Close		X				X


Note 11 Test per
Note 3 T.S. Pg. 3/4
3-32



TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

e 31


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				
					ASSOCIATED EQUIP.	ACTUATION DEVICE			
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	YES	NO	YES	NO	COMMENTS	
MSIS B-K313..... (MDR-7034)	J-SGB-UV-222 J-SGB-UV-224 J-SGB-UV-500R J-SGB-UV-226	Blowdown sample cntmt ISO vlv SG-2 Blowdown sample cntmt ISO vlv SG-2 Blowdown sample cntmt ISO vlv SG-2 Blowdown sample cntmt ISO vlv SG-2	Close Close Close Close	X X X X			X		
MSIS B-K404..... (MDR-7034)	J-SGB-UV-132 J-SGB-UV-137 J-SGE-UV-171 J-SGE-UV-181	SG-1 Economizer FWIV SG-2 Economizer FWIV SG-2 Line 1 MSIV SG-2 Line 2 MSIV	Close Close Close Close		X X X X			Note 11 Test valves per T.S. Note 3 Pg 3/4 3-32	
MSIS B-K411..... (MDR-7034)	J-SGB-UV-219 J-SGB-UV-228 J-SGB-UV-221 J-SGB-UV-500Q	Blowdown sample cntmt ISO vlv SG-1 Blowdown sample cntmt ISO vlv SG-1 Blowdown sample cntmt ISO vlv SG-1 Blowdown sample cntmt ISO vlv SG-1	Close Close Close Close	X X X X			X		



TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

e 32


ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
					ASSOCIATED EQUIP.		ACTUATION DEVICE		
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	YES	NO	YES	NO		
RAS B-K104..... (MDR-7034)	M-SIB-P01 J-ESB-C01 J-SDB-C08 J-SHB-C01	LPSI pump SESS ERFDADS QSPDS	Stop Alarm Display Display	X				Notes 3 & 5 Test relay but pump will not be tested - it is started and tripped quarterly with manual trip to control circuit.	
RAS B-K309..... (MDR-7034)	J-SIB-UV-665	Cntmt spray pump to RWT ISO valve	Close	X					
RAS B-K312..... (2BP36AF)	J-SIB-UV-667 J-SIB-UV-668 J-SIB-UV-675	HPSI pump to RWT ISO valve LPSI pump to RWT ISO valve Cntmt sump ISO valve	Close Close Open	X	X	X		Note 2 & 12	
RAS B-K405..... (MDR-7034)	J-SIB-UV-659 J-SIB-UV-676	HPSI recirc to RWT valve Cntmt sump ISO valve	Close Open	X		X		Note 12	



TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 33

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	YES	
SUBGROUP RELAYS									
AFAS-1 B-K113..... (2BP36AF)	E-PEB-G02 M-DGB-H01 M-HAB-Z05 M-HAB-Z04	Diesel generator breaker Diesel generator B ECW pump room B ESS ACU Aux FDW pump room B ESS ACU	Trip BYP Trips BYP-T.O. BYP-T.O.	X				X	Notes 3 & 5 E-PEB-G02 is closed and tripped monthly with manual trip to control circuit.
AFAS-1 B-K211..... (MDR-7033)	(Mode 4A) M-DGB-H01 J-ESB-C01 J-SDB-C08 J-SHB-C01	ESFAS BOP "B" load sequencer Diesel generator B SESS ERFDADS QSPDS	Start Start Alarm Display Display	X		X		X	Note 3 Notes 3 & 5 Sequencer tested weekly in auto test, and M-DGB-H01 tested monthly with manual start to control circuits.
AFAS-1 B-K307..... (MDR-7033)	J-SGB-UV-222 J-SGB-UV-224 J-SGB-UV-500R J-SGB-UV-226	Blowdown sample cntmt ISO vlv SG-2 Blowdown sample cntmt ISO vlv SG-2 Blowdown sample cntmt ISO vlv SG-2 Blowdown sample cntmt ISO vlv SG-2	Close Close Close Close	X		X		X	



TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT


Page 34

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS			TESTING AT POWER				COMMENTS
	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	ASSOCIATED EQUIP.	ACTUATION DEVICE			
SUBGROUP RELAYS				YES	NO	YES	NO	
AFAS-1 B-K402..... (MDR-7034)	J-SGB-UV-219 J-SGB-UV-228 J-SGB-UV-221 J-SGB-UV-500Q	Blowdown sample cntmt ISO vlv SG-1 Blowdown sample cntmt ISO vlv SG-1 Blowdown sample cntmt ISO vlv SG-1 Blowdown sample cntmt ISO vlv SG-1	Close Close Close Close	X X X X				X
K628* & K402** K728* & K402** K629* & K402** K729* & K402**	J-AFB-HV-30 J-AFB-UV-34 J-AFB-HV-31 J-AFB-UV-35	Aux FDW REG valve to SG-1 Aux FDW ISO valve to SG-1 Aux FDW REG valve to SG-2 Aux FDW ISO valve to SG-2	Open Open Open Open					X X X X

Note: (1) * K628, K728, K629 and K729 are relay type MDR-136-1

(2) * K629 and K729 are from AFAS-2B circuit


(3) ** K402 only maintains the four valves closed. They can be cycled open individually by de-energizing the associated cycling relay via the PPS matrix test module.



TRAIN B ESFAS ASSOCIATED ACTUATED EQUIPMENT

Page 35

ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION	ASSOCIATED EQUIP.	ACTUATION DEVICE				
SUBGROUP RELAYS				YES	NO	YES	NO		
AFAS-2 B-K112.....						X			
(MDR-7033)	E-PEB-G02 (Mode 4A)	Diesel generator breaker ESFAS BOP "B" load sequencer	Trip Start	X	X			Notes 3 & 5 Note 3	
	M-DGB-H01	Diesel generator "B"	Start	X				Notes 3 & 5	
	M-DGB-H01	Diesel generator "B"	BYP Trips	X				Sequencer is tested	
	J-ESB-C01	SESS	Alarm	X				weekly in auto test,	
	J-SDB-C08	ERFDADS	Display	X				E-PEB-G02 and	
	J-SHB-C01	QSPDS	Display	X				M-DGB-H01 are tested	
	M-HAB-Z05	ECW pump room B ESS ACU	BYP-T.O.	X				monthly with manual	
	M-HAB-Z04	Aux FDW pump room B ESS ACU	BYP-T.O.	X				actuation to control	
								circuit.	
AFAS-2 B-K310.....						X			
(MDR-7034)	J-SGB-UV-222	Blowdown sample cntmt ISO valve to SG-2	Close	X					
	J-SGB-UV-224	Blowdown sample cntmt ISO valve to SG-2	Close	X					
	J-SGB-UV-500R	Blowdown sample cntmt ISO valve to SG-2	Close	X					
	J-SGB-UV-226	Blowdown sample cntmt ISO valve to SG-2	Close	X					




ACTUATION DEVICES	ASSOCIATED ACTUATED EQUIPMENT/FUNCTIONS				TESTING AT POWER				COMMENTS
					ASSOCIATED EQUIP.	ACTUATION DEVICE	YES	NO	
SUBGROUP RELAYS	TAG ID NO. (MODE NO.)	DESCRIPTION	FUNCTION						
AFAS-2 B-K413..... (MDR-7032)	J-SGB-UV-219 J-SGB-UB-228 J-SGB-UB-221 J-SGB-UB-500Q	Blowdown sample cntmt ISO valve to SG-1 Blowdown sample cntmt ISO valve to SG-1 Blowdown sample cntmt ISO valve to SG-1 Blowdown sample cntmt ISO valve to SG-1	Close Close Close Close		X X X X				X
K628* & K413** K728* & K413** K629* & K413** K729* & K413**	J-AFB-HV-30 J-AFB-UV-34 J-AFB-HV-31 J-AFB-UV-35	Aux FDW REG valve to SG-1 Aux FDW ISO valve to SG-1 Aux FDW REG valve to SG-2 Aux FDW ISO valve to SG-2	Open Open Open Open		X X X X				

Note: (1) * K628, K728, K629 and K729 are relay type MDR-136-1

(2) * K628 and K728 are from AFAS-1B circuit

(3) ** K413 only maintains the four valves closed. They can be cycled open individually by de-energizing the associated cycling relay via the PPS matrix test module.



ATTACHMENT 3: Characteristics of the Potter Brumfield
relay types MDR-7033 and MDR-7034

POTTER & BRUMFIELD DIVISION
2004 LEE ROAD, NEW BRITAIN, CONNECTICUT
1000 E BRONSON, DETROIT, MICHIGAN

CUSTOMER:
ELECTRO-MECHANICS, INC.
NEW BRITAIN, CONN.

RELAY TYPE MDR-7033

Size: Medium

Rated Coil Voltage: 28 VDC

PULL IN Voltage: Less than 18.6 VDC AT
 25°C .

Release Voltage: More than 2.8 VDC AT
 25°C .

TEMPERATURE RANGE: 0°C. TO $\pm 65^{\circ}\text{C}$.

DC Resistance of Coil: 42 ohms $\pm 10\%$
AT 25°C .

Power (steady state): 18.7 watts

Inrush Current: 0.667 ampere

Current (steady state): 0.667 ampere

CONTACT PRESSURE: 60 GRAMS MINIMUM.

* COIL LEADS EXTENDED
18 INCHES OUT OF BASE.

CONTACT RATINGS:

SINGLE CONTACTS

10 AMPS 115 V.AC 50% P.F.
3.0 AMPS 28V.D.C. RESISTIVE

0.8 AMPS 125V.D.C. RESISTIVE

TWO CONTACTS IN SERIES

3.0 AMPS 440 V.AC 50% P.F.

15.0 AMPS 115 V.AC 50% P.F.

1.5 AMPS 125V.D.C. RESISTIVE




NO AUTOMATIC
DISTRIBUTION OF
UFC: MED REVISIONS

DRAWN BY DATE 2-24-74 CHANGED 5-22-74
CHECKED 1-25-74

LEADS WHERE
NOTED
UPATED 1-25-74
TOL. ± 0.10 UNLESS OTHERWISE
SPECIFIED

Scale 3:4 *

1081



POTTER & CRUMFIELD

CUSTOMER:
ELECTRO-MECHANICS, INC.
NEW BRITAIN, CONN.

RELAY TYPE MDR - 7034

Size: Medium

Rated Coil Voltage: 28 VDC

Pull In Voltage: Less than 18.6 VDC AT
25°C.

Release Voltage: More than 2.8 VDC AT 25°C.

TEMPERATURE RANGE: 0°C. TO +65°C.

DC Resistance of Coil: 42 ohms ±10%
AT 25°C.

Power (steady state): 18.7 watts

Inrush Current: 0.667 ampere

Steady State Current: 0.567 amp.

CONTACT PRESSURES: 60 GRAMS MINIMUM

*COIL LEADS EXTENDED
18 INCHES OUT OF BASE.


CONTACT RATINGS:

SINGLE CONTACTS

10 AMPS	115V.AC 50% P.F.
3.0 AMPS	28V.D.C. RESISTIVE
0.8 AMPS	125V.D.C. RESISTIVE

TWO CONTACTS IN SERIES

3.0 AMPS	440V.AC 50% P.F.
15.0 AMPS	115V.AC 50% P.F.
1.5 AMPS	125V.D.C. RESISTIVE



Four Contact
Wires Alike
(16AWG total)

JAN 8/81

NO AUTOMATIC
DISTRIBUTION OF
UPGRADED REVISIONS

DATE 4-24-74 CHANGED LEADS WHERE
SHEET 5-63-11 UPDATED 1-6-81
CHECKED 4-25-74 CHECKED 1-1-81

TOL. ±.010" UNLESS OTHERWISE SPECIFIED. *Potter & Crumfield*

